

ANEX 6

Fleta 6.1 - ACS03 - ATEX Register

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
1	ACS03-950-EHJ-L-0961	E	Kuti Shpërndarese L&P JB 1 C	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1301	ACS03-C1448-820-E-DEB-0002	Zone 2	STAHL	8146/1051	1815738930440035	Ex e	II C	T4	II 2 G	IP 66
2	110-MV-2001 / Zv me tag ACS03-110-MOB-2001	J	Valvula te stacionit me aktuator elektrik	Ena per sherbimin e tubacionit (PIG Trap)	ACS03-110	ACS03-110-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	AUMA	SAEX 14.6-F14	2316MD68166	Ex de	II C	T4	II 2 G	IP 68
3	320-EHJ-R-1584	E	Kuti Shpërndarese (MCC1-Interposing JB Seal Gas Heater)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0109	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8150/1-0176-0236-150-3321	1744046050110000	Ex e	II C	T4	II 2 G	IP 66
4	320-EHJ-R-1892	E	Kuti Shpërndarese (MCC1-Interposing JB Auxiliary Lube Oil Pump)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0107	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8150/1-0176-0236-150-3321	1744046020110000	Ex e	II C	T4	II 2 G	IP 66
5	320-EHJ-R-1898-A	E	Kuti Shpërndarese (MCC1-Interposing JB Lube Oil Tank Heater A)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0107	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8150/1-0176-0236-150-3321	174404603011	Ex e	II C	T4	II 2 G	IP 66
6	320-EHJ-R-1898-B	E	Kuti Shpërndarese (MCC1-Interposing JB Lube Oil Tank Heater B)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0107	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8150/1-0176-0236-150-3321	1744046040110000	Ex e	II C	T4	II 2 G	IP 66
7	320-EHJ-R-1980	E	Kuti Shpërndarese (MCC1-Interposing JB Lube Oil Tank Heater B)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0110	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8150/1-0176-0236-150-3321	1744046060110000	Ex e	II C	T4	II 2 G	IP 66
8	320-EHJ-R-1988	E	Kuti Shpërndarese (Interposing JB Turbine 1 Onskid Power Supply F&G)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0103	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8150/1-0300-0400-150-3321	1744046070110000	Ex e	II C	T4	II 2 G	IP 66
9	320-EHJ-R-2584	E	Kuti Shpërndarese (MCC2-Interposing JB Seal Gas Heater)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0209	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8150/1-0176-0236-150-3321	17440460/120110000	Ex e	II C	T4	II 2 G	IP 66
10	320-EHJ-R-2892	E	Kuti Shpërndarese (MCC2-Interposing JB Auxiliary Lube Oil Pump)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0207	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8150/1-0176-0236-150-3321	17440460/90110000	Ex e	II C	T4	II 2 G	IP 66
11	320-EHJ-R-2898-A	E	Kuti Shpërndarese (MCC1-Interposing JB Lube Oil Tank Heater B)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0207	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8150/1-0176-0236-150-3321	17440460/100110000	Ex e	II C	T4	II 2 G	IP 66
12	320-EHJ-R-2898-B	E	Kuti Shpërndarese (MCC1-Interposing JB Lube Oil Tank Heater B)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0207	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8150/1-0176-0236-150-3321	17440460/110110000	Ex e	II C	T4	II 2 G	IP 66
13	320-EHJ-R-2980	E	Kuti Shpërndarese (MCC2-Interposing JB Lube Oil Tank Heater B)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0210	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8150/1-0176-0236-150-3321	17440460/130110000	Ex e	II C	T4	II 2 G	IP 66
14	320-EHJ-R-2988	E	Kuti Shpërndarese (Interposing JB Turbine 2 Onskid Power Supply F&G)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0203	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8150/1-0300-0400-150-3321	17440460/140110000	Ex e	II C	T4	II 2 G	IP 66
15	320-EHJ-R-3584	E	Kuti Shpërndarese (MCC3-Interposing JB Seal Gas Heater)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0309	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8150/1-0176-0236-150-3321	17440460/190110000	Ex e	II C	T4	II 2 G	IP 66
16	320-EHJ-R-3892	E	Kuti Shpërndarese (MCC3-Interposing JB Auxiliary Lube Oil Pump)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0307	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8150/1-0176-0236-150-3321	17440460/160110000	Ex e	II C	T4	II 2 G	IP 66
17	320-EHJ-R-3898-A	E	Kuti Shpërndarese (MCC3-Interposing JB Lube Oil Tank Heater A)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0307	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8150/1-0176-0236-150-3321	17440460/170110000	Ex e	II C	T4	II 2 G	IP 66
18	ACS03-740-GD-0032	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	CROWCON	IRmax	W274204/01-021	Ex d	II C	T6	II 2 G	IP 66
19	320-EHJ-R-3898-B	E	Kuti Shpërndarese (MCC3-Interposing JB Lube Oil Tank Heater B)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0307	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8150/1-0176-0236-150-3321	17440460/180110000	Ex e	II C	T4	II 2 G	IP 66
20	320-EHJ-R-3980	E	Kuti Shpërndarese (MCC3-Interposing JB Onskid Gas Fuel+Core Trace Heating)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0310	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8150/1-0176-0236-150-3321	17440460/200110000	Ex e	II C	T4	II 2 G	IP 66
21	320-EHJ-R-3988	E	Kuti Shpërndarese (Interposing JB Turbine 3 Onskid Power Supply F&G)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0303	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8150/1-0300-0400-150-3321	17440460/210110001	Ex e	II C	T4	II 2 G	IP 66
22	350-EHJ-Z-1101	E	Kuti Shpërndarese (JB for Transport Gascooler Unit 1 Motor 1 - Measurement)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5071	1815738970440000	Ex de	II C	T4	II 2 G	IP 66
23	350-EHJ-Z-1102	E	Kuti Shpërndarese (JB for Transport Gascooler Unit 1 Motor 2 - Measurement)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5071	1815738970440020	Ex de	II C	T4	II 2 G	IP 66
24	350-EHJ-Z-1103	E	Kuti Shpërndarese (JB for Transport Gascooler Unit 1 Motor 3 - Measurement)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5071	1815738970440020	Ex de	II C	T4	II 2 G	IP 66
25	350-EHJ-Z-1201	E	Kuti Shpërndarese (JB for Transport Gascooler Unit 2 Motor 1 - Measurement)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5071	1815738970440015	Ex de	II C	T4	II 2 G	IP 66
26	350-EHJ-Z-1202	E	Kuti Shpërndarese (JB for Transport Gascooler Unit 2 Motor 2 - Measurement)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5071	1815738970440012	Ex de	II C	T4	II 2 G	IP 66
27	350-EHJ-Z-1203	E	Kuti Shpërndarese (JB for Transport Gascooler Unit 2 Motor 3 - Measurement)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5071	1815738970440002	Ex de	II C	T4	II 2 G	IP 66
28	350-EHJ-Z-1301	E	(Kuti Shpërndarese) (JB for Transport Gascooler Unit 3 Motor 1 - Measurement)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5071	1815738970440018	Ex de / db eb	II C	T4	II 2 G	IP 66
29	350-EHJ-Z-1302	E	(Kuti Shpërndarese) (JB for Transport Gascooler Unit 3 Motor 2 - Measurement)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5071	1815738970440013	Ex de	II C	T4	II 2 G	IP 66
30	350-EHJ-Z-1303	E	Kuti Shpërndarese (JB for Transport Gascooler Unit 3 Motor 3 - Measurement)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5071	1815738970440009	Ex de	II C	T4	II 2 G	IP 66
31	350-EHJ-Z-1401	E	Kuti Shpërndarese (JB for Transport Gascooler Unit 4 Motor 1 - Measurement)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5071	1815738970440004	Ex de	II C	T4	II 2 G	IP 66
32	350-EHJ-Z-1402	E	Kuti Shpërndarese (JB for Transport Gascooler Unit 4 Motor 2 - Measurement)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5071	1815738970440023	Ex de	II C	T4	II 2 G	IP 66
33	350-EHJ-Z-1403	E	Kuti Shpërndarese (JB for Transport Gascooler Unit 4 Motor 3 - Measurement)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5071	1815738970440017	Ex de	II C	T4	II 2 G	IP 66
34	350-EHJ-Z-1501	E	Kuti Shpërndarese (JB for Transport Gascooler Unit 5 Motor 1 - Measurement)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5071	1815738970440010	Ex de	II C	T4	II 2 G	IP 66

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
35	350-EHJ-Z-1502	E	Kuti Shpërndarese (JB for Transport Gascooler Unit 5 Motor 2 - Measurement)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5071	1815738970440007	Ex de	II C	T4	II 2 G	IP 66
36	350-EHJ-Z-1503	E	Kuti Shpërndarese (JB for Transport Gascooler Unit 5 Motor 3 - Measurement)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5071	18157389704400027	Ex de	II C	T4	II 2 G	IP 66
37	350-EHJ-Z-2101	E	Kuti Shpërndarese (JB for Start Up Gascooler Unit 1 Motor 1 - Measurement)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5071	18157389704400025	Ex de	II C	T4	II 2 G	IP 66
38	350-EHJ-Z-2102	E	Kuti Shpërndarese (JB for Start Up Gascooler Unit 1 Motor 2 - Measurement)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5071	18157389704400019	Ex de	II C	T4	II 2 G	IP 66
39	350-EHJ-Z-2103	E	Kuti Shpërndarese (JB for Start Up Gascooler Unit 1 Motor 3 - Measurement)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5071	18157389704400014	Ex de	II C	T4	II 2 G	IP 66
40	350-EHJ-Z-2201	E	Kuti Shpërndarese (JB for Start Up Gascooler Unit 2 Motor 1 - Measurement)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5071	18157389704400011	Ex de	II C	T4	II 2 G	IP 66
41	350-EHJ-Z-2202	E	Kuti Shpërndarese (JB for Start Up Gascooler Unit 2 Motor 2 - Measurement)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5071	18157389704400003	Ex de	II C	T4	II 2 G	IP 66
42	350-EHJ-Z-2203	E	Kuti Shpërndarese (JB for Start Up Gascooler Unit 2 Motor 3 - Measurement)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5071	18157389704400024	Ex de	II C	T4	II 2 G	IP 66
43	350-EHJ-Z-2301	E	Kuti Shpërndarese (JB for Start Up Gascooler Unit 3 Motor 1 - Measurement)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5071	18157389704400022	Ex de	II C	T4	II 2 G	IP 66
44	350-EHJ-Z-2302	E	Kuti Shpërndarese (JB for Start Up Gascooler Unit 3 Motor 2 - Measurement)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5071	18157389704400016	Ex de	II C	T4	II 2 G	IP 66
45	350-EHJ-Z-2303	E	Kuti Shpërndarese (JB for Start Up Gascooler Unit 3 Motor 3 - Measurement)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5071	18157389704400008	Ex de	II C	T4	II 2 G	IP 66
46	350-EHJ-Z-3301	E	Kuti Shpërndarese (JB for Start Up Gascooler Unit 4 Motor 1 - Measurement)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5071	18157389704400006	Ex de	II C	T4	II 2 G	IP 66
47	350-EHJ-Z-3302	E	Kuti Shpërndarese (JB for Start Up Gascooler Unit 4 Motor 2 - Measurement)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5071	18157389704400005	Ex de	II C	T4	II 2 G	IP 66
48	350-EHJ-Z-3303	E	Kuti Shpërndarese (JB for Start Up Gascooler Unit 4 Motor 3 - Measurement)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5071	18157389704400021	Ex de	II C	T4	II 2 G	IP 66
49	534-EHJ-P-0001	E	Kuti Shpërndarese (Kuti Shpërndarese (Junction Box) For Ventilators)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0500		Zone 2	STAHL	8146/1051	18157389504400047	Ex e	II C	T4	II 2 G	IP 66
50	534-EHJ-P-0010	E	Kuti Shpërndarese (Kuti Shpërndarese (Junction Box) For Sockets)	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1100		Zone 2	STAHL	8146/1083	18157397204400001	Ex e	II C	T4	II 2 G	IP 66
51	534-ERJ-Z-001	E	Korrektues volumi Korrektes volumi 1040-3040 JB - Fuel Gas Building	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0500	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/1041	18157389404400063	Ex e	II C	T4	II 2 G	IP 66
52	534-ERJ-Z-002	E	Korrektues volumi Korrektes volumi 2040-4040 JB - Fuel Gas Building	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0500	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/1041	18157389404400062	Ex e	II C	T4	II 2 G	IP 66
53	534-MCV-1020	J	Valvul e motorizuar (Fuel Gas Bldg. - Motorized Control Valve)	Sistemi i Ujit te nxehte (HOT WATER SYSTEM)	ACS03-520	ACS03-520-0100	ACS03-C1448-820-E-DEA-0002 ACS03-C1448.1010-534-P-DPE-0001	Zone 2	AUMA	SAEX 07.2-F10	3417MD68245	Ex de	II C	T4	II 2 G	IP 68
54	534-MCV-2020	J	Valvul e motorizuar (Fuel Gas Bldg. - Motorized Control Valve)	Sistemi i Ujit te nxehte (HOT WATER SYSTEM)	ACS03-520	ACS03-520-0100	ACS03-C1448-820-E-DEA-0002 ACS03-C1448.1010-534-P-DPE-0001	Zone 2	AUMA	SAEX 07.2-F10	3417MD68246	Ex de	II C	T4	II 2 G	IP 68
55	820-EHJ-H-0010	E	Kuti Shpërndarese Condensate Tank Heat Tracing (Gas Heat Tracing) JB	Sistemi i shpërndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS03-820	ACS03-820-0903	ACS03-C1448.3500-820-E-DFB-0001	Zone 1	SPINA	JBPN-252512	18/02735	Ex e	II C	T4	II 2 G	IP 66
56	820-EHJ-H-0010-001	E	Kuti Shpërndarese (Condensate Tank Heat Tracing (Gas Heat Tracing) JB - Subdistribution 001)	Sistemi i shpërndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS03-820	ACS03-820-0903	ACS03-C1448.3500-820-E-DFB-0001	Zone 1	ELTHERM	ELAK-EX-3.7 / 0X80057	2172	Ex e	II C	T6	II 2 G	IP 66
57	820-EHJ-H-0010-002	E	Condensate Tank Heat Tracing (Gas Heat Tracing) JB - Subdistribution 002	Sistemi i shpërndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS03-820	ACS03-820-0903	ACS03-C1448.3500-820-E-DFB-0001	Zone 1	ELTHERM	ELAK-EX-3.7 / 0X80057	2190	Ex e	II C	T6	II 2 G	IP 66
58	820-EHJ-H-0010-003	E	Kuti Shpërndarese Condensate Tank Heat Tracing (Gas Heat Tracing) JB - Subdistribution 003	Sistemi i shpërndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS03-820	ACS03-820-0903	ACS03-C1448.3500-820-E-DFB-0001	Zone 1	ELTHERM	ELAK-EX-3.7 / 0X80057	2182	Ex e	II C	T6	II 2 G	IP 66
59	950-EHJ-L-0508	E	Kuti Shpërndarese Lighting 508 JB	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1301		Zone 2	STAHL	8146/1051	1815738950440185	Ex e	II C	T4	II 2 G	IP 66
60	950-EHJ-L-0509	E	Kuti Shpërndarese Lighting 509 JB	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1301		Zone 2	STAHL	8146/1051	1815738950440083	Ex e	II C	T4	II 2 G	IP 66
61	950-EHJ-L-0526	E	Kuti Shpërndarese Lighting 526 JB	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1301		Zone 2	STAHL	8146/1051	18157389504400035	Ex e	II C	T4	II 2 G	IP 66
62	950-EHJ-L-0527	E	Kuti Shpërndarese Lighting 527 JB	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1301		Zone 2	STAHL	8146/1051	1815738950440151	Ex e	II C	T4	II 2 G	IP 66
63	951-EHJ-L-1030	E	Kuti Shpërndarese JB - Compressor Bldg 1 - Circuit 1.1 JB 1030	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1500	ACS03-C1448-951-E-DEB-0028	Zone 2	STAHL	8146/1051	1815738950440192	Ex e	II C	T4	II 2 G	IP 66
64	ACS03-951-EHJ-L-1031	E	Kuti Shpërndarese Outdoor Lighting - Compressor bldg 1 - Circuit 1.7 L Fixture 1031 JB	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1500	ACS03-C1448-951-E-DEB-0028	Zone 2	STAHL	8146/1051	1815738950440183	Ex e	II C	T4	II 2 G	IP 66
65	951-EHJ-L-1032	E	Kuti Shpërndarese Ndricues (Indoor Lighting - Compressor bldg 1 - Circuit 1.4 JB 1032	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1500	ACS03-C1448-951-E-DEB-0028	Zone 2	STAHL	8146/1051	1815738950440125	Ex e	II C	T4	II 2 G	IP 66
66	ACS03-951-EHJ-L-1033	E	Kuti Shpërndarese Outdoor Lighting - Compressor bldg 1 - Circuit 1.7 L Fixture 1033 JB	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1500	ACS03-C1448-951-E-DEB-0028	Zone 2	STAHL	8146/1051	1815738950440160	Ex e	II C	T4	II 2 G	IP 66
67	951-EHJ-L-1034	E	Kuti Shpërndarese Outdoor Lighting - Compressor Bldg 1 - Circuit 1.7 JB 1034	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1500	ACS03-C1448-951-E-DEB-0028	Zone 2	STAHL	8146/1071	18157396204400005	Ex e	II C	T4	II 2 G	IP 66
68	951-EHJ-L-1041	E	Kuti Shpërndarese Ndricues (Outdoor Lighting - Compressor bldg 1 - Circuit 1.9 JB 1041	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1500	ACS03-C1448-951-E-DEB-0028	Zone 2	STAHL	8146/1051	18157389304400064	Ex e	II C	T4	II 2 G	IP 66
69	951-EHJ-L-2030	E	Kuti Shpërndarese Ndricues (Indoor Lighting - Compressor bldg 2 - Circuit 1.1 JB 2030	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1600	ACS03-C1448-951-E-DEB-0028	Zone 2	STAHL	8146/1051	18157389504400097	Ex e	II C	T4	II 2 G	IP 66
70	951-EHJ-L-2031	E	Kuti Shpërndarese Ndricues (Indoor Lighting - Compressor bldg 2 - Circuit 1.2 JB 2031	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1600	ACS03-C1448-951-E-DEB-0028	Zone 2	STAHL	8146/1051	1815738950440119	Ex e	II C	T4	II 2 G	IP 66
71	951-EHJ-L-2032	E	Kuti Shpërndarese Ndricues (Indoor Lighting - Compressor bldg 2 - Circuit 1.4 JB 2032	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1600	ACS03-C1448-951-E-DEB-0028	Zone 2	STAHL	8146/1051	1815738950440168	Ex e	II C	T4	II 2 G	IP 66

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
72	951-EHJ-L-2033	E	Kuti Shperndarese Ndrices (Indoor Lighting - Compressor bldg 2 - Circuit 1.5 JB 2033	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1600	ACS03-C1448-951-E-DEB-0028	Zone 2	STAHL	8146/1051	1815738950440108	Ex e	II C	T4	II 2 G	IP 66
73	951-EHJ-L-2034	E	Kuti Shperndarese Outdoor Lighting - Compressor Bldg 2 - Circuit 1.7 JB 2034	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1600	ACS03-C1448-951-E-DEB-0028	Zone 2	STAHL	8146/1051	1815738950440140	Ex e	II C	T4	II 2 G	IP 66
74	951-EHJ-L-2041	E	Kuti Shperndarese Outdoor Lighting - Compressor Bldg 2 - Circuit 1.9 JB 2041	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1600	ACS03-C1448-951-E-DEB-0030	Zone 2	STAHL	8146/1051	1815738930440046	Ex e	II C	T4	II 2 G	IP 66
75	951-EHJ-L-3030	E	Kuti Shperndarese Ndrices (Indoor Lighting - Compressor bldg 3 - Circuit 1.1 JB 3030	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700	ACS03-C1448-951-E-DEB-0029	Zone 2	STAHL	8146/1051	1815738950440075	Ex e	II C	T4	II 2 G	IP 66
76	951-EHJ-L-3031	E	Kuti Shperndarese Ndrices (Indoor Lighting - Compressor bldg 3 - Circuit 1.2 JB 3031	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700	ACS03-C1448-951-E-DEB-0029	Zone 2	STAHL	8146/1051	1815738950440178	Ex e	II C	T4	II 2 G	IP 66
77	951-EHJ-L-3032	E	Kuti Shperndarese Ndrices (Indoor Lighting - Compressor bldg 3 - Circuit 1.4 JB 3032	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700	ACS03-C1448-951-E-DEB-0029	Zone 2	STAHL	8146/1051	1815738950440104	Ex e	II C	T4	II 2 G	IP 66
78	951-EHJ-L-3033	E	Kuti Shperndarese Ndrices (Indoor Lighting - Compressor bldg 3 - Circuit 1.5 JB 3033	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700	ACS03-C1448-951-E-DEB-0029	Zone 2	STAHL	8146/1051	1815738950440179	Ex e	II C	T4	II 2 G	IP 66
79	951-EHJ-P-1010	E	Kuti Shperndarese Socket Comb. cabinet 1 - Comp. building 1 - JB - Circuit 3.1 JB 1010	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1500	ACS03-C1448-951-E-DEB-0028	Zone 2	STAHL	8146/1083	1815739740440001	Ex e	II C	T4	II 2 G	IP 66
80	951-EHJ-P-1011	E	Kuti Shperndarese Socket Outlets - Compressor building 1- Circuit 2.1 JB 1011	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1500	ACS03-C1448-951-E-DEB-0028	Zone 2	STAHL	8146/1071	1815739750440010	Ex e	II C	T4	II 2 G	IP 66
81	951-EHJ-P-2010	E	Kuti Shperndarese Socket Comb. cabinet 2 - Comp. building 2 - JB - Circuit 3.1 JB 2010	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1600	ACS03-C1448-951-E-DEB-0028	Zone 2	STAHL	8146/1083	1815739740440003	Ex e	II C	T4	II 2 G	IP 66
82	951-EHJ-P-2011	E	Kuti Shperndarese Socket Outlets - Compressor building 2- Circuit 2.1 JB 2011	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1600	ACS03-C1448-951-E-DEB-0028	Zone 2	STAHL	8146/1071	1815739750440012	Ex e	II C	T4	II 2 G	IP 66
83	ACS03-000-H-1001_JB	E	Kuti Shperndarese (Junction Box)es and Ancillary Electrical Equipment for Crane	STATION MOBILE INSTALLATION & CRANES	ACS03-980	ACS03-980-0300		Zone 2	STAHL	8146/5-V37-305-00-1510	1714870790440000	Ex de	II C	T4	II 2 G	IP 66
84	ACS03-000-H-2001_JB	E	Kuti Shperndarese (Junction Box)es and Ancillary Electrical Equipment for Crane	STATION MOBILE INSTALLATION & CRANES	ACS03-980	ACS03-980-0300		Zone 2	STAHL	8146/5-V37-305-00-1510	1714870790440000	Ex de	II C	T4	II 2 G	IP 66
85	ACS03-000-H-3001_JB	E	Kuti Shperndarese (Junction Box)es and Ancillary Electrical Equipment for Crane	STATION MOBILE INSTALLATION & CRANES	ACS03-980	ACS03-980-0500		Zone 2	STAHL	8146/5-V37-305-00-1510	1714870790440000	Ex de	II C	T4	II 2 G	IP 66
86	ACS03-110-MV-1001	E	Kuti Shperndarese Valvul e motorizuar (Electric Motorized Valve)	Ena per sherbimin e tubacionit (PIG Trap)	ACS03-110	ACS03-110-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	AUMA	ADX0090-2-3.00	2316MM54210	Ex de	II C	T4	II 2 G	IP 68
87	ACS03-110-ZSC/O-1001	J	Celes Fundor (Celes Fundor i mbyllur (Limit Switch Close) & Open)	Ena per sherbimin e tubacionit (PIG Trap)	ACS03-110	ACS03-110-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	EUROTEC	EAE 2103-73-IA-DAE	87433	Ex ia	II C	T6	II 2 G	IP 67
88	ACS03-110-ZSC/O-2001	J	Celes Fundor (Celes Fundor i mbyllur (Limit Switch Close) & Open)	Ena per sherbimin e tubacionit (PIG Trap)	ACS03-110	ACS03-110-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	EUROTEC	EAE 2103-73-IA-DAE	2014-91749	Ex ia	II C	T6	II 2 G	IP 67
89	ACS03-310-FIT-1030	J	Transmetues i prurjes (dP Flow Transmitter)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1JD189120133	Ex d	II C	T3/ T4/T6	II 1/2 G	IP 66
90	ACS03-310-FIT-2030	J	Transmetues i prurjes (dP Flow Transmitter)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DS III 7MF4433-1EA02-2RB7-Z	N1JD189120134	Ex d	II C	T6/ T4	II 1/2 G	IP 66
91	ACS03-310-FIT-3030	J	Transmetues i prurjes (dP Flow Transmitter)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DS III 7MF4433-1EA02-2RB7-Z	N1JD189120135	Ex d	II C	T6/ T4	II 1/2 G	IP 66
92	ACS03-310-HS-1108	J	çeles paneli lokal (Local Panel Hand Switch)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	CORTEM	SA301410/P	17/325338	Ex de	II C	T6	II 2 GD	IP 66
93	ACS03-310-HS-1208	J	çeles paneli lokal (Local Panel Hand Switch)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	CORTEM	SA301410/P	17/325338	Ex de	II C	T6	II 2 GD	IP 66
94	ACS03-310-HS-2108	J	çeles paneli lokal (Local Panel Hand Switch)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-110-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	CORTEM	SA301410/P	17/325338	Ex de	II C	T6	II 2 G	IP 66
95	ACS03-310-HS-2208	J	çeles paneli lokal (Local Panel Hand Switch)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-110-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	CORTEM	SA301410/P	17/325338	Ex de	II C	T6	II 2 G	IP 66
96	ACS03-310-HS-3108	J	çeles paneli lokal (Local Panel Hand Switch)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	CORTEM	SA301410/P	17/325338	Ex de	II C	T6	II 2 GD	IP 66
97	ACS03-310-HS-3208	J	çeles paneli lokal (Local Panel Hand Switch)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	CORTEM	SA301410/P	17/325338	Ex de	II C	T6	II 2 GD	IP 66
98	ACS03-310-JB-0001-A	J	Kuti Shperndarese (Junction Box)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224484	Ex e	II C	T6	II 2 GD	IP 66
99	ACS03-310-JB-0001-B	J	Kuti Shperndarese (Junction Box)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-110-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224483	Ex e	II C	T6	II 2 GD	IP 66
100	ACS03-310-JB-0001-C	J	Kuti Shperndarese (Junction Box)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224482	Ex e	II C	T6	II 2 GD	IP 66
101	ACS03-310-JB-0002-A	J	Kuti Shperndarese (Junction Box)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224522	Ex e	II C	T6	II 2 GD	IP 66
102	ACS03-310-JB-0002-B	J	Kuti Shperndarese (Junction Box)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-110-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224518	Ex e	II C	T6	II 2 GD	IP 66
103	ACS03-310-JB-0002-C	J	Kuti Shperndarese (Junction Box)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224524	Ex e	II C	T6	II 2 GD	IP 66
104	ACS03-310-JB-0100-A	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222202	Ex e	II C	T6	II 2 GD	IP 66
105	ACS03-310-JB-0100-B	J	Kuti Shperndarese (Junction Box)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-110-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222201	Ex e	II C	T6	II 2 GD	IP 66
106	ACS03-310-JB-0100-C	J	Kuti Shperndarese (Junction Box)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222207	Ex e	II C	T6	II 2 GD	IP 66
107	ACS03-310-JB-0200-A	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222195	Ex e	II C	T6	II 2 GD	IP 66
108	ACS03-310-JB-0200-B	J	Kuti Shperndarese (Junction Box)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-110-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222191	Ex e	II C	T6	II 2 GD	IP 66

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
109	ACS03-310-JB-0200-C	J	Kuti Shperndarese (Junction Box)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-273520	I/17/222193	Ex e/ Ex ia	II C	T6	II 2 GD	IP 66
110	ACS03-310-JB-1001-A	J	Kuti Shperndarese (Junction Box)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222160	Ex e	II C	T6	II 2 G	IP 66
111	ACS03-310-JB-1001-B	J	Kuti Shperndarese (Junction Box)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-110-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222154	Ex ia	II C	T6	II 2 GD	IP 66
112	ACS03-310-JB-1001-C	J	Kuti Shperndarese (Junction Box)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222157	Ex ia	II C	T6	II 2 GD	IP 66
113	ACS03-310-JB-1002	J	Kuti Shperndarese (Junction Box)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-352720	I/17/226208	Ex ia	II C	T6	II 2 GD	IP 66
114	ACS03-310-LIT-1102	J	Transmetues i nivelit (Radar Transmetues Nivelit (Level Transmitter))	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	LG270.AEPAX1AXADAM	38485274	Ex db	II C	T6 /T1	II 1/2 G	IP 66/68
115	ACS03-310-LIT-1202	J	Transmetues i nivelit (Radar Transmetues Nivelit (Level Transmitter))	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS LG270	38485275	Ex d / Ex db	II C	T6/T1	II 1/2 G	IP 66/68
116	ACS03-310-LIT-2102	J	Transmetues i nivelit (Radar Transmetues Nivelit (Level Transmitter))	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-110-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS LG270	38485271	Ex d / Ex db	II C	T6/T1	II 1/2 G	IP 66/68
117	ACS03-310-LIT-2202	J	Transmetues i nivelit (Radar Transmetues Nivelit (Level Transmitter))	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-110-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS LG270	38485277	Ex d / Ex db	II C	T6/T1	II 1/2 G	IP 66/68
118	ACS03-310-LIT-3102	J	Transmetues i nivelit (Radar Transmetues Nivelit (Level Transmitter))	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS LG270.AEPAX1AXADAM	38485278	Ex db	II C	T6 /T2	II 1/2 G	IP 66/68
119	ACS03-310-LIT-3202	J	Transmetues i nivelit (Radar Transmetues Nivelit (Level Transmitter))	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS LG270.AEPAX1AXADAM	38485279	Ex db	II C	T6 /T2	II 1/2 G	IP 66/68
120	ACS03-310-LSHH-1104	J	Nivel (Level Switch High High)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	ROSEMOUNT	2120CXXG1E1XH0000Q4Q8QTP1R2477	1239944	Ex db	II C	T6 /T2	II 1/2 GD	IP 66/67
121	ACS03-310-LSHH-1204	J	Nivel (Level Switch High High)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	ROSEMOUNT	2120CXXG1E1XH0000Q4Q8QTP1R2477	1239945	Ex db	II C	T6 /T2	II 1/2 GD	IP 66/67
122	ACS03-310-LSHH-2104	J	Nivel (Level Switch High High)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	ROSEMOUNT	2120CXXG1E1XH0000Q4Q8QTP1R2477	1239946	Ex db	II C	T6 /T2	II 1/2 GD	IP 66/67
123	ACS03-310-LSHH-2204	J	Nivel (Level Switch High High)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	ROSEMOUNT	2120CXXG1E1XH0000Q4Q8QTP1R2477	1239947	Ex db	II C	T6 /T2	II 1/2 GD	IP 66/67
124	ACS03-310-LSHH-3104	J	Nivel (Level Switch High High)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	ROSEMOUNT	2120CXXG1E1XH0000Q4Q8QTP1R2477	1239948	Ex db	II C	T6 /T2	II 1/2 GD	IP 66/67
125	ACS03-310-LSHH-3204	J	Nivel (Level Switch High High)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	ROSEMOUNT	2120CXXG1E1XH0000Q4Q8QTP1R2477	1239949	Ex db	II C	T6 /T2	II 1/2 GD	IP 66/67
126	ACS03-310-LZSLL-1103	J	Nivel (Level Switch Low Low)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	ROSEMOUNT	2130PA2MHXXXM03501E1Q4Q8QTP1R2477	1290970	Ex db	II C	T6 /T2	II 1/2 GD	IP 66/67
127	ACS03-310-LZSLL-1203	J	Nivel (Level Switch Low Low)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	ROSEMOUNT	2130PA2MHXXXM03501E1Q4Q8QTP1R2477	1290834	Ex db	II C	T6 /T2	II 1/2 GD	IP 66/67
128	ACS03-310-LZSLL-2103	J	Nivel (Level Switch Low Low)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	ROSEMOUNT	2130PA2MHXXXM03501E1Q4Q8QTP1R2477	1239952 / S.N:1290836	Ex db	II C	T6 /T2	II 1/2 GD	IP 66/67
129	ACS03-310-LZSLL-2203	J	Nivel (Level Switch Low Low)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	ROSEMOUNT	2130PA2MHXXXM03501E1Q4Q8QTP1R2477	1239953 / S.N: 1290839	Ex db	II C	T6 /T2	II 1/2 GD	IP 66/67
130	ACS03-310-LZSLL-3103	J	Nivel (Level Switch Low Low)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	ROSEMOUNT	2130PA2MHXXXM03501E1Q4Q8QTP1R2477	1290837	Ex db	II C	T6 /T2	II 1/2 GD	IP 66/67
131	ACS03-310-LZSLL-3203	J	Nivel (Level Switch Low Low)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	ROSEMOUNT	2130PA2MHXXXM03501E1Q4Q8QTP1R2477	1239955 / S.N: 1290833	Ex db	II C	T6 /T2	II 1/2 GD	IP 66/67
132	ACS03-310-MV-1010	E	Valvul e motorizuar (Motor Operated Valve)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	AUMA	SAEX 07.6-F10/-a3a1	2217MD48785	Ex de	II C	T3	II 2 G	IP 68
133	ACS03-310-MV-2010	E	Valvul e motorizuar (Motor Operated Valve)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	AUMA	SAEX 07.6-F10/-a3a1	2217MD48785 / S.N: 2217MD48786	Ex de	II C	T3	II 2 G	IP 68
134	ACS03-310-MV-3010	E	Valvul e motorizuar (Motor Operated Valve)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	AUMA	SAEX 07.6-F10/-a3a1	2217MD48787	Ex de	II C	T3	II 2 G	IP 68
135	ACS03-310-PDIT-0001	J	Transmetues i presionit diferencial (Diff.Transmetues presioni(Pressure Transmitter))	Tubacionet (PIPING)	ACS03-360	ACS03-360-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DS III 7MF4433-1FA02-2RB7-Z	N1JN239120082	Ex d	II C	T6 /T4	II 1/2 G	IP 66
136	ACS03-310-PDIT-1010	J	Transmetues i presionit diferencial (Diff.Transmetues presioni(Pressure Transmitter))	Tubacionet (PIPING)	ACS03-360	ACS03-360-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DS III 7MF4433-1GA02-2RB7-Z	N1JN239120083	Ex d	II C	T6 /T4	II 1/2 G	IP 66
137	ACS03-310-PDIT-2010	J	Transmetues i presionit diferencial (Diff.Transmetues presioni(Pressure Transmitter))	Tubacionet (PIPING)	ACS03-360	ACS03-360-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DS III 7MF4433-1GA02-2RB7-Z	N1JN239120084	Ex d	II C	T6 /T4	II 1/2 G	IP 66
138	ACS03-310-PDIT-3010	J	Transmetues i presionit diferencial (Diff.Transmetues presioni(Pressure Transmitter))	Tubacionet (PIPING)	ACS03-360	ACS03-360-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DS III 7MF4433-1GA02-2RB7-Z	N1JN239120085	Ex d	II C	T6 /T4	II 1/2 G	IP 66
139	ACS03-310-PIT-1021	J	Transmetues presioni(Pressure Transmitter)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DS III 7MF4033-1FA00-2RB7-Z	N1JN239000076	Ex d	II C	T6 /T4	II 1/2 G	IP 66
140	ACS03-310-PIT-2021	J	Transmetues presioni(Pressure Transmitter)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DS III 7MF4033-1FA00-2RB7-Z	N1JN239000077	Ex d	II C	T6 /T4	II 1/2 G	IP 66
141	ACS03-310-PIT-3021	J	Transmetues presioni(Pressure Transmitter)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DS III 7MF4033-1FA00-2RB7-Z	N1JN239000078	Ex d	II C	T6 /T4	II 1/2 G	IP 66
142	ACS03-310-YV-1102	J	Valvul Solenoid (Solenoid Valve)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex eb mb	II C	T4	II 2 GD	IP 66/X8
143	ACS03-310-YV-1108	J	Valvul Solenoid (Solenoid Valve)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	THOMPSON VALVES	MAXSEAL	S.N: 62146/3	Ex e m / Ex eb mb	II C	T4	II 2 G	IP 66 / x8
144	ACS03-310-YV-1202	J	Valvul Solenoid (Solenoid Valve)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3 / S.N: 72675/1	Ex eb mb	II C	T4	II 2 GD	IP 66 / x8
145	ACS03-310-YV-1208	J	Valvul Solenoid (Solenoid Valve)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	THOMPSON VALVES	MAXSEAL	S.N: 62146/3	Ex e m	II C	T4	II 2 G	IP 66 / x8

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
146	ACS03-310-YV-2102	J	Valvul Solenoid (Solenoid Valve)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex eb mb	II C	T4	II 2 GD	IP 66 / x8
147	ACS03-310-YV-2108	J	Valvul Solenoid (Solenoid Valve)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex eb mb	II C	T4	II 2 GD	IP 66 / x8
148	ACS03-310-YV-2202	J	Valvul Solenoid (Solenoid Valve)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex eb mb	II C	T4	II 2 GD	IP 66
149	ACS03-310-YV-2208	J	Valvul Solenoid (Solenoid Valve)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	THOMPSON VALVES	MAXSEAL	N/A	Ex e m / Ex eb mb	II C	T4	II 2 G	IP 66 / x8
150	ACS03-310-YV-3102	J	Valvul Solenoid (Solenoid Valve)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex eb mb	II C	T4	II 2 G	IP 66
151	ACS03-310-YV-3108	J	Valvul Solenoid (Solenoid Valve)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex eb mb	II C	T4	II 2 G	IP 66
152	ACS03-310-YV-3202	J	Valvul Solenoid (Solenoid Valve)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex eb mb	II C	T4	II 2 G	IP 66
153	ACS03-310-YV-3208	J	Valvul Solenoid (Solenoid Valve)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex eb mb	II C	T4	II 2 G	IP 66
154	ACS03-310-YZV-1108	J	Valvul Solenoid (Solenoid Valve)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	THOMPSON VALVES	MAXSEAL	62146/3	Ex e m / Ex eb mb	II C	T4	II 2 G	IP 66
155	ACS03-310-YZV-1208	J	Valvul Solenoid (Solenoid Valve)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	THOMPSON VALVES	MAXSEAL	62146/3	Ex e m / Ex eb mb	II C	T4	II 2 G	IP 66
156	ACS03-310-YZV-2108	J	Valvul Solenoid (Solenoid Valve)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex eb mb	II C	T4	II 2 GD	IP 66
157	ACS03-310-YZV-2208	J	Valvul Solenoid (Solenoid Valve)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex eb mb	II C	T4	II 2 GD	IP 66, IP x8
158	ACS03-310-YZV-3108	J	Valvul Solenoid (Solenoid Valve)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex eb mb	II C	T4	II 2 G	IP 66, IP x8
159	ACS03-310-YZV-3208	J	Valvul Solenoid (Solenoid Valve)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex eb mb	II C	T4	II 2 G	IP 66
160	ACS03-310-ZSC/O-1010	J	Celesa fundor (Limit Switches)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	WESTLOCK	ACCUTRAK 3347RBYS00023ECU-AR1	256038-1 010	Ex ia	II C	T6 / T*	II 1 G	IP 66/67, IP 6*
161	ACS03-310-ZSC/O-1102	J	Celesa fundor (Limit Switches)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P5S2	37382	Ex ia	II C	T6	II 2 G	IP 66/67
162	ACS03-310-ZSC/O-1108	J	Celesa fundor (Limit Switches)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P5S2	37382	Ex ia	II C	T6	II 2 G	IP 66/67
163	ACS03-310-ZSC/O-1202	J	Celesa fundor (Limit Switches)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P5S2	37382	Ex ia	II C	T6	II 2 G	IP 66/67
164	ACS03-310-ZSC/O-1208	J	Celesa fundor (Limit Switches)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P5S2	37382	Ex ia	II C	T6	II 2 G	IP 66/67
165	ACS03-310-ZSC/O-2010	J	Celesa fundor (Limit Switches)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	WESTLOCK	ACCUTRAK 3347RBYS00023ECU-AR1	256038-1 019	Ex ia	II C	T6 / T*	II 1 G	IP 66/67, IP 6*
166	ACS03-310-ZSC/O-2102	J	Celesa fundor (Limit Switches)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GI SERIES	N/A / S.N: 37382	Ex ia	II C	T6/T1	II 1/2 G	IP 66/67
167	ACS03-310-ZSC/O-2108	J	Celesa fundor (Limit Switches)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GI SERIES	N/A / S.N: 37382	Ex ia	II C	T6/T1	II 1/2 G	IP 66/67
168	ACS03-310-ZSC/O-2202	J	Celesa fundor (Limit Switches)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GI SERIES	N/A / S.N: 37382	Ex ia	II C	T6/T1	II 1/2 G	IP 66/67
169	ACS03-310-ZSC/O-2208	J	Celesa fundor (Limit Switches)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GI SERIES	N/A / S.N: 37382	Ex ia	II C	T6/T1	II 1/2 G	IP 66/67
170	ACS03-310-ZSC/O-3010	J	Celesa fundor (Limit Switches)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	WESTLOCK	ACCUTRAK 3347RBYS00023ECU-AR1	256038-1 015	Ex ia	II C	T6 / T1/T*	II 1 G	IP 66/67
171	ACS03-310-ZSC/O-3102	J	Celesa fundor (Limit Switches)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P5S2	37382	Ex ia	II C	T6 / T4	II 2 G	IP 66/67
172	ACS03-310-ZSC/O-3108	J	Celesa fundor (Limit Switches)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P5S2	37382	Ex ia	II C	T6 / T4	II 2 G	IP 66/67
173	ACS03-310-ZSC/O-3202	J	Celesa fundor (Limit Switches)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P5S2	37382	Ex ia	II C	T6 / T1	II 2 G	IP 66/67
174	ACS03-310-ZSC/O-3208	J	Celesa fundor (Limit Switches)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P5S2	37382	Ex ia	II C	T6 / T1	II 2 G	IP 66/67
175	ACS03-320-CEMS-01	E	MCC1-CEMS	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0501	ACS03-C1448-820-E-DEA-0002	Zone 2	SIEMENS	G1873-ACX	G1873-1	Ex pz	II A	T2	II 3 G	IP 66
176	ACS03-320-CEMS-01_UC1_JB	E	CEMS-01 UC1 Ex-e Kuti Spherndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0501	ACS03-C1448-820-E-DEA-0002	Zone 2	QUINTEX	CB-V201/17309	03002	Ex de	II C	T4	II 2 G	IP 66
177	ACS03-320-CEMS-02	E	MCC2-CEMS	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0502	ACS03-C1448-820-E-DEA-0002	Zone 2	SIEMENS	8246VA	G1873-2	Ex pz	II A	T2	II 3 G	IP 66
178	ACS03-320-CEMS-02_UC1_JB	E	CEMS-02 UC1 Ex-e Kuti Spherndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0502	ACS03-C1448-820-E-DEA-0002	Zone 2	QUINTEX	CB-V201/17309	03003	Ex de	II C	T4	II 2 G	IP 66
179	ACS03-320-CEMS-03	J	CEMS-03 Analyzer Cabinet	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0503	ACS03-C1448-820-E-DEA-0002	Zone 2	SIEMENS	8246VA	G1873-3	Ex pz	II A	T2	II 3 G	IP 66
180	ACS03-320-CEMS-03_UC1_JB	E	CEMS-03 UC1 Ex-e Kuti Spherndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0503	ACS03-C1448-820-E-DEA-0002	Zone 2	QUINTEX	CB-V201/17309	03001	Ex de	II C	T4	II 2 G	IP 66
181	ACS03-320-E-1584	E	Ngrohes MCC1-Seal Gas Heater	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0109	ACS03-C1448-820-E-DEA-0002	Zone 2	ELMESS	DHK15B03VAD/SE-8-T3	827148/004	Ex db	II C	T3	II 2 G	IP 66
182	ACS03-320-E-1898-A	E	Ngrohes MCC1-Lubrication Oil Tank Heater 1	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0107	ACS03-C1448-820-E-DEA-0002	Zone 2	EXHEAT	RFA-CX-9-59-FS3	163242N	Ex d	II C	T4	II 2 G	IP 66

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
183	ACS03-320-E-1898-B	E	Ngrohes MCC1-Lubrication Oil Tank Heater 2	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0107	ACS03-C1448-820-E-DEA-0002	Zone 2	EXHEAT	RFA-CX-9-59-FS3	163241N	Ex d	II C	T4	II 2 G	IP 66
184	ACS03-320-E-1907-A	E	Ngrohes MCC1-Lube Oil Cooler Header Heater 1	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0107	ACS03-C1448-820-E-DEA-0002	Zone 2	EXHEAT	FP45-CS1-3.5-61-FS2-SO	195651N	Ex d	II C	T4	II 2 G	IP 66
185	ACS03-320-E-1907-B	E	Ngrohes MCC2-Lube Oil Cooler Header Heater 2	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0107	ACS03-C1448-820-E-DEA-0002	Zone 2	EXHEAT	FP45-CS1-3.5-61-FS2-SO	195650N	Ex d	II C	T4	II 2 G	IP 66
186	ACS03-320-E-2584	E	Ngrohes MCC2-Seal Gas Heater	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0209	ACS03-C1448-820-E-DEA-0002	Zone 2	ELMESS	DHK15B03VAD/SE-8-T3	827148/005	Ex d	II C	T3	II 2 G	IP 66
187	ACS03-320-E-2898-A	E	Ngrohes MCC2-Lubrication Oil Tank Heater 1	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0207	ACS03-C1448-820-E-DEA-0002	Zone 2	EXHEAT	RFA-CX-9-59-FS3	163243N	Ex d	II C	T4	II 2 G	IP 66
188	ACS03-320-E-2898-B	E	Ngrohes MCC2-Lubrication Oil Tank Heater 2	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0207	ACS03-C1448-820-E-DEA-0002	Zone 2	EXHEAT	RFA-CX-9-59-FS3	163244N	Ex d	II C	T4	II 2 G	IP 66
189	ACS03-320-E-2907-A	E	Ngrohes MCC2-Lube Oil Cooler Header Heater 1	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0207	ACS03-C1448-820-E-DEA-0002	Zone 2	EXHEAT	FP45-CS1-3.5-61-FS2-SO	165720N	Ex d	II C	T4	II 2 G	IP 66
190	ACS03-320-E-2907-B	E	Ngrohes MCC2-Lube Oil Cooler Header Heater 2	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0207	ACS03-C1448-820-E-DEA-0002	Zone 2	EXHEAT	FP45-CS1-3.5-61-FS2-SO	165712N	Ex d	II C	T4	II 2 G	IP 66
191	ACS03-320-E-3584	E	Ngrohes MCC3-Seal Gas Heater	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0309	ACS03-C1448-820-E-DEA-0002	Zone 2	ELMESS	DHK15B03VAD/SE-8-T3	827148/006	Ex d	II C	T3	II 2 G	IP 66
192	ACS03-320-E-3898-A	E	Ngrohes MCC3-Lubrication Oil Tank Heater 1	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0307	ACS03-C1448-820-E-DEA-0002	Zone 2	EXHEAT	RFA-CX-9-59-FS3	163246N	Ex d	II C	T4	II 2 G	IP 66
193	ACS03-320-E-3898-B	E	Ngrohes MCC3-Lubrication Oil Tank Heater 2	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0307	ACS03-C1448-820-E-DEA-0002	Zone 2	EXHEAT	RFA-CX-9-59-FS3	163245N	Ex d	II C	T4	II 2 G	IP 66
194	ACS03-320-E-3907-A	E	Ngrohes MCC3-Lube Oil Cooler Header Heater 1	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0307	ACS03-C1448-820-E-DEA-0002	Zone 2	EXHEAT	FP45-CS1-3.5-61-FS2-SO	165715N	Ex d	II C	T4	II 2 G	IP 66
195	ACS03-320-E-3907-B	E	Ngrohes MCC3-Lube Oil Cooler Header Heater 2	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0307	ACS03-C1448-820-E-DEA-0002	Zone 2	EXHEAT	FP45-CS1-3.5-61-FS2-SO	165714N	Ex d	II C	T4	II 2 G	IP 66
196	ACS03-320-FIT-1001	J	Transmetues i presionit diferencial (Diff.Transmetues presioni)(Pressure Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0105	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DS III	N1JD189120136	Ex ia/ib	II C	T4/T6	II 1/2 G	IP 66
197	ACS03-320-FIT-2001	J	Transmetues i presionit diferencial (Diff.Transmetues presioni)(Pressure Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0205	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1JD189120137	Ex ia	II C	T4	II 1/2 G	IP 66
198	ACS03-320-FIT-3001	J	Transmetues i presionit diferencial (Diff.Transmetues presioni)(Pressure Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0305	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DS III	N1JD189120138	Ex ia/ib	II C	T4/T6	II 1/2 G	IP 66
199	ACS03-320-FT-1710	J	Mates i prurjes (Gas Fuel Supply Flow)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0108		Zone 2	MICROMOTION TRANSMITTER	2700M15BEFE22X	25894738	Ex d (ib)	II C	T5	II 2 G	IP 66/67
200	ACS03-320-FT-2710	J	Mates i prurjes (Gas Fuel Supply Flow)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0208		Zone 2	MICROMOTION TRANSMITTER	2700M15BEFE22X	25894739	Ex d (ib)	II C	T5	II 2 G	IP 66/67
201	ACS03-320-FT-3710	J	Furnizues me energji I tipit FT-1 FT-1 Power Supply	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0308		Zone 2	MICROMOTION TRANSMITTER	2700M15BEFE22X	25894732	Ex d (ib)	II C	T5	II 2 G	IP 66/67
202	ACS03-320-HS-1010	J	çeles paneli lokal (Local Panel Hand Switch)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	QUINTEX	CB-P6/16353	64736	Ex de	II C	T4	II 2 G	IP 66
203	ACS03-320-HS-1011	J	çeles paneli lokal (Local Panel Hand Switch)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	CORTEM	SA301410/P	17/325338	Ex de	II C	T6	II 2 G	IP 66
204	ACS03-320-HS-1020	J	çeles paneli lokal (Local Panel Hand Switch)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	QUINTEX	CB-P6/16353	64738	Ex de / Ex db eb	II C	T4	II 2 G	IP 66
205	ACS03-320-HS-1021	J	çeles paneli lokal (Local Panel Hand Switch)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	CORTEM	SA301410/P	17/325338	Ex de	II C	T6	II 2 G	IP 66
206	ACS03-320-HS-1310	J	çeles paneli lokal (Local Panel Hand Switch)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	QUINTEX	QP-0220-0120-0904/683455	64724 / S.N: 64726	Ex de	II C	T4	II 2 G	IP 66
207	ACS03-320-HS-1311	J	çeles paneli lokal (Local Panel Hand Switch)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	CORTEM	SA301410/P	17/325338	Ex de	II C	T6	II 2 G	IP 66
208	ACS03-320-HS-1510	J	çeles paneli lokal (Local Panel Hand Switch)	FUEL GAS	ACS03-534	ACS03-534-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	CORTEM	SA301410/P	17/325338	Ex de	II C	T6	II 2 G	IP 66
209	ACS03-320-HS-1610	J	çeles paneli lokal (Local Panel Hand Switch)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0109	ACS03-C1448-856-J-DJA-0001	Zone 2	CORTEM	SA301410/P	17/325338	Ex de	II C	T6	II 2 G	IP 66
210	ACS03-320-HS-1840	E	MCC1-GT Kuti per ndricimin (Enclosure AC Lighting)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0110	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8030/51-033	1613420010440254	Ex de	II C	T6	II 2 G	IP 65
211	ACS03-320-HS-1842	E	MCC1-GT Combustion Air Inlet Filter lighting	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0110	ACS03-C1448-820-E-DEA-0002	Safe Area	CEAG	GHG2732000R0004	1282	Ex de	II C	T6	II 2 G	IP 66
212	ACS03-320-HS-2010	J	çeles paneli lokal (Local Panel Hand Switch)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	QUINTEX	CB-P6/16353	64712	Ex de	II C	T4	II 2 G	IP 66
213	ACS03-320-HS-2011	J	çeles paneli lokal (Local Panel Hand Switch)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	CORTEM	SA301410/P	17/325338	Ex de	II C	T6	II 2 G	IP 66
214	ACS03-320-HS-2020	J	çeles paneli lokal (Local Panel Hand Switch)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	QUINTEX	CB-P6/16353	64717	Ex de	II C	T4	II 2 G	IP 66
215	ACS03-320-HS-2021	J	çeles paneli lokal (Local Panel Hand Switch)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	CORTEM	SA301410/P	17/325338	Ex de	II C	T6	II 2 G	IP 66
216	ACS03-320-HS-2310	J	çeles paneli lokal (Local Panel Hand Switch)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	QUINTEX	CB-P6/16353	64711	Ex de	II C	T4	II 2 G	IP 66
217	ACS03-320-HS-2311	J	çeles paneli lokal (Local Panel Hand Switch)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	CORTEM	SA301410/P	17/325338	Ex de	II C	T6	II 2 G	IP 66
218	ACS03-320-HS-2510	J	çeles paneli lokal (Local Panel Hand Switch)	FUEL GAS	ACS03-534	ACS03-534-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	CORTEM	SA301410/P	17/325338	Ex de	II C	T6	II 2 G	IP 66
219	ACS03-320-HS-2610	J	çeles paneli lokal (Local Panel Hand Switch)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0209	ACS03-C1448-856-J-DJA-0001	Zone 2	CORTEM	SA301410/P	17/325338	Ex de	II C	T6	II 2 G	IP 66

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
220	ACS03-320-HS-3010	J	çeles paneli lokal (Local Panel Hand Switch)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	QUINTEX	CB-P6/16353	64720	Ex de	II C	T4	II 2 G	IP 66
221	ACS03-320-HS-2840	E	MCC2-GT Kuti per ndricimin (Enclosure AC Lighting)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0210	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8030/51-033	1613420010440342	Ex de	II C	T6	II 2 G	IP 65
222	ACS03-320-HS-2842	E	MCC2-GT Combustion Air Inlet Filter lighting	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0210	ACS03-C1448-820-E-DEA-0002	Safe Area	CEAG	GHG2732000R0004	1282	Ex de	II C	T6	II 2 G	IP 66
223	ACS03-320-HS-3011	J	çeles paneli lokal (Local Panel Hand Switch)	Matja e Gazit	ACS03-330	ACS03-320-0209	ACS03-C1448-856-J-DJA-0001	Zone 2	CORTEM	SA301410/P	17/325338	Ex de	II C	T6	II 2 G	IP 66
224	ACS03-320-HS-3020	J	çeles paneli lokal (Local Panel Hand Switch)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	QUINTEX	CB-P6/16353	64745	Ex de	II C	T4	II 2 G	IP 66
225	ACS03-320-HS-3021	J	çeles paneli lokal (Local Panel Hand Switch)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	CORTEM	SA301410/P	17/325338	Ex de	II C	T6	II 2 G	IP 66
226	ACS03-320-HS-3310	J	çeles paneli lokal (Local Panel Hand Switch)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	QUINTEX	CB-P6/16353	64710	Ex de	II C	T4	II 2 G	IP 66
227	ACS03-320-HS-3311	J	çeles paneli lokal (Local Panel Hand Switch)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	CORTEM	SA301410/P	17/325338	Ex de	II C	T6	II 2 G	IP 66
228	ACS03-320-HS-3510	J	çeles paneli lokal (Local Panel Hand Switch)	FUEL GAS	ACS03-534	ACS03-534-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	CORTEM	SA301410/P	17/325338	Ex de	II C	T6	II 2 G	IP 66
229	ACS03-320-HS-3610	J	çeles paneli lokal (Local Panel Hand Switch)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0309	ACS03-C1448-856-J-DJA-0001	Zone 2	QUINTEX	CB-P6/16353	64720 / S.N: 17/325338	Ex de	II C	T4 / T6	II 2 G	IP 66
230	ACS03-320-HS-3840	E	MCC3 - GT Kuti per ndricimin (Enclosure AC Lighting)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0310	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8030/51-033	1513078450440024	Ex e / Ex de	II C	T6	II 2 G	IP 65 / IP 66
231	ACS03-320-HS-3842	E	MCC3 - GT Combustion Air Inlet Filter Lighting	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0310	ACS03-C1448-820-E-DEA-0002	Zone 2	EATON	GHG2732000R0004	N/A	Ex de	II C	T6	II 2 G	IP 65 / IP 66
232	ACS03-320-JB-0001-A	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222197	Ex e	II C	T6	II 2 G	IP 66
233	ACS03-320-JB-0001-B	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222198	Ex e	II C	T6	II 2 G	IP 66
234	ACS03-320-JB-0001-C	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222199	Ex e	II C	T6	II 2 G	IP 66
235	ACS03-320-JB-0200-A	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222192	Ex e	II C	T6	II 2 G	IP 66
236	ACS03-320-JB-0200-B	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222194	Ex e	II C	T6	II 2 G	IP 66
237	ACS03-320-JB-0200-C	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222196	Ex e	II C	T6	II 2 G	IP 66
238	ACS03-320-JB-0201-A	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222187	Ex e	II C	T6	II 2 G	IP 66
239	ACS03-320-JB-0201-B	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222186	Ex e	II C	T6	II 2 G	IP 66
240	ACS03-320-JB-0201-C	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222189	Ex e	II C	T6	II 2 G	IP 66
241	ACS03-320-JB-0202-A	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222183	Ex e	II C	T6	II 2 G	IP 66
242	ACS03-320-JB-0202-B	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222185	Ex e	II C	T6	II 2 G	IP 66
243	ACS03-320-JB-0202-C	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222184	Ex e	II C	T6	II 2 G	IP 66
244	ACS03-320-JB-1001-A	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222166	Ex ia	II C	T6	II 2 G	IP 66
245	ACS03-320-JB-1001-B	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222168	Ex e (ia)	II C	T6	II 2 G	IP 66
246	ACS03-320-JB-1001-C	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222167	Ex e (ia)	II C	T6	II 2 G	IP 66
247	ACS03-320-JB-1002-A	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222172	Ex ia	II C	T6	II 2 G	IP 66
248	ACS03-320-JB-1002-B	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222170	Ex e (ia)	II C	T6	II 2 G	IP 66
249	ACS03-320-JB-1002-C	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222169	Ex e (ia)	II C	T6	II 2 G	IP 66
250	ACS03-320-JB-1101-A	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224543	Ex ia	II C	T6	II 2 G	IP 66
251	ACS03-320-JB-1101-B	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224544	Ex e (ia)	II C	T6	II 2 G	IP 66
252	ACS03-320-JB-1101-C	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224545	Ex ia	II C	T6	II 2 G	IP 66
253	ACS03-320-JB-1102-A	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0105	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224542	Ex e (ia)	II C	T6	II 2 G	IP 66
254	ACS03-320-JB-1102-B	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0205	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224540	Ex e (ia)	II C	T6	II 2 G	IP 66
255	ACS03-320-JB-1102-C	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0305	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224546	Ex ia	II C	T6	II 2 G	IP 66
256	ACS03-320-JB-1103-A	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0105	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222177	Ex ia	II C	T6	II 2 G	IP 66

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
257	ACS03-320-JB-1103-B	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0205	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222178	Ex ia	II C	T6	II 2 G	IP 66
258	ACS03-320-JB-1103-C	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0305	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222182	Ex ia	II C	T6	II 2 G	IP 66
259	ACS03-320-JB-1104-A	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0105	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222181	Ex ia	II C	T6	II 2 G	IP 66
260	ACS03-320-JB-1104-B	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0205	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222175	Ex ia	II C	T6	II 2 G	IP 66
261	ACS03-320-JB-1104-C	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0305	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222179	Ex ia	II C	T6	II 2 G	IP 66
262	ACS03-320-JB-1605	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0105		Zone 2	STAHL	8150/5-0236-0176-091-3311	174382190110010	Ex e ib (ia)	II C	T6	II 2 G	IP 66
263	ACS03-320-JB-1606	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0105		Zone 2	STAHL	8150/5-0236-0176-091-3311	174382190110036	Ex e ib (ia)	II C	T6	II 2 G	IP 66
264	ACS03-320-JB-1607	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0105		Zone 2	STAHL	8150/5-0236-0176-091-3311	174382190110013	Ex e ib (ia)	II C	T6	II 2 G	IP 66
265	ACS03-320-JB-1866	E	Kuti Shperndarese GT Extinguish Cabinet heaters	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0104	ACS03-C1448-820-E-DEA-0002	Zone 2	WEIDMULLER	KLIPPON STB 1.1	XA/GB/ML/0001486	Ex e	II C	T6	II 2 G	IP 66
266	ACS03-320-JB-1975	E	Kuti Shperndarese Gas Turbine Skid JB-1975 Internal Distribution Panel	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0110	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	7145/52	17437708/20110002	Ex de nA nC	II C	T4	II 3 G	IP 66
267	ACS03-320-JB-1980	E	Kuti Shperndarese MCC1-OnskidGas Fuel + Core Trace Heating	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0110	ACS03-C1448-820-E-DEA-0002	Zone 2	WEIDMULLER	KLIPPON STB	XA/GB H016306	Ex e	II C	T4	II 2 G	IP 66
268	ACS03-320-JB-1982	E	Kuti Shperndarese UCS Compressor Unit 1 Lube Oil Emergency pump JB	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0107	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8150/1-0400-0400-150-3321	16437938/10110001	Ex e	II C	T4	II 2 G	IP 66
269	ACS03-320-JB-1988_turb	E	Kuti Shperndarese Gas Turbine Skid 1 JB-1988 UCS Compressor Unit 1 On Skid Control Panel - F&G	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0110	ACS03-C1448-820-E-DEA-0002	Zone 2	SIEMENS	N/A	F2H6013091	Ex nA nC (ia)	II C	T4	II 3 (2) G	IP 66
270	ACS03-320-JB-1993	E	Kuti Shperndarese MCC1-Celes Vibrimi (Vibration Switch)es JB	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0107	ACS03-C1448-820-E-DEA-0002	Zone 2	ABTECH	SX 0.5.140	983508	Ex e	II C	T3	II 2 G	IP 66
271	ACS03-320-JB-1994	E	Kuti Shperndarese MCC1-Offskid Gas Fuel Conditioning Skid Trace Heating	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0108	ACS03-C1448-820-E-DEA-0002	Zone 2	ABTECH	SX 0.5.200	992421	Ex e	II C	T5	II 2 G	IP 66
272	ACS03-320-JB-1997	E	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0107		Zone 2	ABTECH	SX 1.140	983516	Ex e	II C	T3	II 2 G	IP 66
273	ACS03-320-JB-2605	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0205	ACS03-C1448-856-J-DJA-0001	Zone 2	STAHL	8150/5-0236-0176-091-3311	174382190110011	Ex ia	II C	T6	II 2 G	IP 66
274	ACS03-320-JB-2606	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0205	ACS03-C1448-856-J-DJA-0001	Zone 2	STAHL	8150/5-0236-0176-091-3311	174382190110012	Ex ia	II C	T6	II 2 G	IP 66
275	ACS03-320-JB-2607	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0205	ACS03-C1448-856-J-DJA-0001	Zone 2	STAHL	8150/5-0236-0176-091-3311	174382190110014	Ex ia	II C	T6	II 2 G	IP 66
276	ACS03-320-JB-2866	E	Kuti Shperndarese GT Extinguish Cabinet Heaters	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0204	ACS03-C1448-820-E-DEA-0002	Zone 2	WEIDMULLER	KLIPPON STB 1.1	XA/GB/ML/0001487	Ex e	II C	T4	II 2 G	IP 66
277	ACS03-320-JB-2975	E	Kuti Shperndarese Gas Turbine Skid JB-2975 Internal Distribution Panel	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0210	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	7145/52		Ex de nA nC	II C	T4	II 3 G	IP 66
278	ACS03-320-JB-2980	E	Kuti Shperndarese MCC2-OnskidGas Fuel + Core Trace Heating	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0210	ACS03-C1448-820-E-DEA-0002	Zone 2	WEIDMULLER	KLIPPON STB	XA/GB H016321	Ex e	II C	T4	II 2 G	IP 66
279	ACS03-320-JB-2982	E	Kuti Shperndarese UCS Compressor Unit 2 Lube Oil Emergency Pump JB	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0207	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8150/1-0400-0400-150-3321	16437938/10110002	Ex e	II C	T4	II 2 G	IP 67
280	ACS03-320-JB-2988_turb	E	Kuti Shperndarese Gas Turbine Skid 2 JB-2988 On Skid Control Panel - F&G	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0210	ACS03-C1448-820-E-DEA-0002	Zone 2	SIEMENS	N/A	F2H9023022	Ex nA nC (ia)	II C	T4	II 3 (2) G	IP 66
281	ACS03-320-JB-2993	E	Kuti Shperndarese MCC2-Celes Vibrimi (Vibration Switch)es JB	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0207	ACS03-C1448-820-E-DEA-0002	Zone 2	ABTECH	SX 0.5.140	983512	Ex e	II C	T3	II 2 G	IP 66
282	ACS03-320-JB-2994	E	Kuti Shperndarese MCC2-Offskid Gas Fuel Conditioning Skid Trace Heating	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0208	ACS03-C1448-820-E-DEA-0002	Zone 2	ABTECH	SX 0.5.200	992422	Ex e	II C	T5	II 2 G	IP 66
283	ACS03-320-JB-2997	E	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0207		Zone 2	ABTECH	SX 1.140	983517	Ex e	II C	T3	II 2 G	IP 66
284	ACS03-320-JB-3605	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0305	ACS03-C1448-856-J-DJA-0001	Zone 2	STAHL	8150/5-0236-0176-091-3311	174382190110033	Ex e ib (ia)	II C	T6	II 2 G	IP 66
285	ACS03-320-JB-3606	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0305	ACS03-C1448-856-J-DJA-0001	Zone 2	STAHL	8150/5-0236-0176-091-3311	174382190110034	Ex e ib (ia)	II C	T6	II 2 G	IP 66
286	ACS03-320-JB-3607	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0305	ACS03-C1448-856-J-DJA-0001	Zone 2	STAHL	8150/5-0236-0176-091-3311	174382190110015	Ex e ib (ia)	II C	T6	II 2 G	IP 66
287	ACS03-320-JB-3866	E	Kuti Shperndares GT Extinguish Cabinet Heaters	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0304	ACS03-C1448-820-E-DEA-0002	Zone 2	WEIDMULLER	KLIPPON STB	XA/GB/ML/0001485	Ex e	II C	T6	II 2 G	IP 66
288	ACS03-320-JB-3975	E	Kuti Shperndarese Gas Turbine Skid JB-3975 Internal Distribution Panel	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0310	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	7145/52	S.N: 17437708/80110001	Ex de nA nC	II C	T4	II 3 G	IP 66
289	ACS03-320-JB-3980	E	Kuti Shperndarese MCC3-OnskidGas Fuel + Core Trace Heating	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0310	ACS03-C1448-820-E-DEA-0002	Zone 2	WEIDMULLER	KLIPPON STB	XA/GB H018887	Ex e	II C	T4	II 2 G	IP 66
290	ACS03-320-JB-3982	E	Kuti shperndarese UCS Compressor Unit 3 Lube Oil Emergency Pump JB	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0307	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8150/1-0400-0400-150-3321	16437938/10110000	Ex e	II C	T4	II 2 G	IP 67
291	ACS03-320-JB-3988_turb	E	Kuti Shperndarese Gas Turbine Skid 3 JB-3988 On Skid Control Panel - F&G	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0310	ACS03-C1448-820-E-DEA-0002	Zone 2	SIEMENS	N/A	F2HN024523	Ex nA nC (ia)	II C	T4	II 3 (2) G	IP 66
292	ACS03-320-JB-3993	E	Kuti Shperndarese MCC3-Celes Vibrimi (Vibration Switch)es JB	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0307	ACS03-C1448-820-E-DEA-0002	Zone 2	ABTECH	SX 6.5.140	983510	Ex e	II C	T3	II 2 G	IP 66
293	ACS03-320-JB-3994	E	Kuti Shperndarese MCC3-Offskid Gas Fuel Conditioning Skid Trace Heating	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0308	ACS03-C1448-820-E-DEA-0002	Zone 2	ABTECH	SX 0.5.200	992423	Ex e	II C	T5	II 2 G	IP 66

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
294	ACS03-320-JB-3997	E	Kuti Shperndarese Lube Oil Cooler Louver Solenoids	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0307		Zone 2	ABTECH	SX 1.140	983518	Ex e	II C	T3	II 2 G	IP 66
295	ACS03-320-M-1613	E	Motorr elektrik MCC1-Seal Gas Booster	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0109	ACS03-C1448-820-E-DEA-0002	Zone 2	SIEMENS	DNGW-132ST-02M	LDX / 10008890	Ex de	II C	T4	II 2 G	IP 65
296	ACS03-320-M-1761	E	Motorr elektrik MCC1-Electric Motor (Hydraulic Start Space Heater)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0110	ACS03-C1448-820-E-DEA-0002	Zone 2	BROOK	W-EF280MN-D	NF 717169	Ex de	II B	T3	II 2 G	IP 55
297	ACS03-320-M-1845-A-JB	E	Motorr elektrik MCC1-Enclosure Ventilation Fan Motor 1	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0110	ACS03-C1448-820-E-DEA-0002	Zone 2	FEEL	FLAMEPROOF ELECTRICAL ENCLOSURES	003084	Ex e	II C	T5		IP 66
298	ACS03-320-M-1845-B-JB	E	Motorr elektrik MCC1-Enclosure Ventilation Fan Motor 2	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0110	ACS03-C1448-820-E-DEA-0002	Zone 2	FEEL	FLAMEPROOF ELECTRICAL ENCLOSURES	003081	Ex e	II C	T5		IP 66
299	ACS03-320-M-1892	E	Motorr elektrik MCC1-Auxiliary Lubrication Oil Pump	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0107	ACS03-C1448-820-E-DEA-0002	Zone 2	SIEMENS	TYPE 9-10	LDX / 10008687	Ex de	II C	T6	II 2 G	IP 55
300	ACS03-320-M-1908-A	E	Motorr elektrik MCC1-Lube Oil Cooler Fan 1	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0107	ACS03-C1448-820-E-DEA-0002	Zone 2	WEG	W22 X d BE	1032786 503	Ex de	II B	T4	II 2 G	IP 56
301	ACS03-320-M-1908-B	E	Motorr elektrik MCC1-Lube Oil Cooler Fan 2	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0107	ACS03-C1448-820-E-DEA-0002	Zone 2	WEG	W22 X d BE	1032786 507	Ex de	II B	T4	II 2 G	IP 56
302	ACS03-320-M-1908-C	E	Motorr elektrik MCC1-Lube Oil Cooler Fan 3	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0107	ACS03-C1448-820-E-DEA-0002	Zone 2	WEG	W22 X d BE	1032786 495	Ex de	II B	T4	II 2 G	IP 56
303	ACS03-320-M-1922	E	Motorr elektrik MCC1-Lube Oil Tank Breather Coalescer Fan	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0107	ACS03-C1448-820-E-DEA-0002	Zone 2	CEMP	AB30r	1702342002Y17	Ex d	II B	T3	II 2 G	IP 56
304	ACS03-320-M-2613	E	Motorr elektrik MCC2-Seal Gas Booster	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0209	ACS03-C1448-820-E-DEA-0002	Zone 2	SIEMENS	DNGW-132ST-02M	LDX / 10008894	Ex de	II C	T4	II 2 G	IP 65
305	ACS03-320-M-2761	E	Motorr elektrik MCC2-Electric Motor (Hydraulic Start Space Heater)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0210	ACS03-C1448-820-E-DEA-0002	Zone 2	BROOK	W-EF280MN-D	NF 717058	Ex de	II B	T3	II 2 G	IP 55
306	ACS03-320-M-2845-A-JB	E	Motorr elektrik MCC2-Enclosure Ventilation Fan Motor 1-JB	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0210	ACS03-C1448-820-E-DEA-0002	Zone 2	FEEL	FLAMEPROOF ELECTRICAL ENCLOSURES	003087	Ex e	II C	T5		IP 66
307	ACS03-320-M-2845-B-JB	E	Motorr elektrik MCC2-Enclosure Ventilation Fan Motor 2-JB	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0210	ACS03-C1448-820-E-DEA-0002	Zone 2	FEEL	FLAMEPROOF ELECTRICAL ENCLOSURES	003083	Ex e	II C	T5		IP 66
308	ACS03-320-M-2892	E	Motorr elektrik MCC2-Auxiliary Lubrication Oil Pump	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0207	ACS03-C1448-820-E-DEA-0002	Zone 2	SIEMENS	DNGW-160HS-02M	LDX / 30008686	Ex de	II C	T4	II 2 G	IP 55
309	ACS03-320-M-2908-A	E	Motorr elektrik MCC2-Lube Oil Cooler Fan 1	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0207	ACS03-C1448-820-E-DEA-0002	Zone 2	WEG	W22 X d BE	1032786 492	Ex de	II B	T4	II 2 G	IP 56
310	ACS03-320-M-2908-B	E	Motorr elektrik MCC2-Lube Oil Cooler Fan 2	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0207	ACS03-C1448-820-E-DEA-0002	Zone 2	WEG	W22 X d BE	1032786 492	Ex de	II B	T4	II 2 G	IP 56
311	ACS03-320-M-2908-C	E	Motorr elektrik MCC2-Lube Oil Cooler Fan 3	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0207	ACS03-C1448-820-E-DEA-0002	Zone 2	WEG	W22 X d BE	1032786 492	Ex de	II B	T4	II 2 G	IP 56
312	ACS03-320-M-2922	E	Motorr elektrik MCC2-Lube Oil Tank Breather Coalescer Fan	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0207	ACS03-C1448-820-E-DEA-0002	Zone 2	CEMP	AB30r	1702342004Y17	Ex d	II B	T3	II 2 G	IP 56
313	ACS03-320-M-3613	E	Motorr elektrik	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0309	ACS03-C1448-820-E-DEA-0002	Zone 2	SIEMENS	DNGW-132ST-02M	LDX / 10008895	Ex de	II C	T4	II 2 G	IP 65
314	ACS03-320-M-3761	E	Motorr elektrik	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0310	ACS03-C1448-820-E-DEA-0002	Zone 2	SIEMENS	W-EI280MN-D	NF 717167	Ex de	II B	T3	II 2 G	IP 55
315	ACS03-320-M-3845-A-JB	E	Motorr elektrik	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0310	ACS03-C1448-820-E-DEA-0002	Zone 2	FEEL	FLAMEPROOF ELECTRICAL ENCLOSURES	003043	Ex e	II C	T6		IP 66
316	ACS03-320-M-3845-B-JB	E	Motorr elektrik	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0310	ACS03-C1448-820-E-DEA-0002	Zone 2	FEEL	FLAMEPROOF ELECTRICAL ENCLOSURES	003044	Ex e	II C	T6		IP 66
317	ACS03-320-M-3892	E	Motorr elektrik	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0307	ACS03-C1448-820-E-DEA-0002	Zone 2	SIEMENS	TYPE 9-10	LDX / 30008685	Ex de	II C	T6	II 2 G	IP 55
318	ACS03-320-M-3908-A	E	Motorr elektrik	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0307	ACS03-C1448-820-E-DEA-0002	Zone 2	WEG	W22 X d BE	1053559 630	Ex de	II B	T4	II 2 G	IP 56
319	ACS03-320-M-3908-B	E	Motorr elektrik	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0307	ACS03-C1448-820-E-DEA-0002	Zone 2	WEG	W22 X d BE	1032786 498	Ex de	II B	T4	II 2 G	IP 56
320	ACS03-320-M-3908-C	E	Motorr elektrik	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0307	ACS03-C1448-820-E-DEA-0002	Zone 2	WEG	W22 X d BE	1032786 508	Ex de	II B	T4	II 2 G	IP 56
321	ACS03-320-M-3922	E	Motorr elektrik	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0307	ACS03-C1448-820-E-DEA-0002	Zone 2	CEMP	AB30r	1702342006Y17	Ex d	II B	T3	II 2 G	IP 56
322	ACS03-320-MHS-1613-L	E	Celes Komandimi	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0109	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8040/11	1613807580440000	Ex de	II C	T4	II 2 G	IP 66
323	ACS03-320-MHS-1761-L	E	Celes Komandimi	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0110	ACS03-C1448-820-E-DEA-0002	Zone 2	EATON	GHG411	1206	Ex de	II C	T6	II 2 G	IP 66
324	ACS03-320-MHS-1845-AL	E	Celes Komandimi	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0110	ACS03-C1448-820-E-DEA-0002	Zone 2	BARTEC	07-351	437871	Ex ed	II C	T6	II 2 G	IP 66
325	ACS03-320-MHS-1845-BL	E	Celes Komandimi	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0110	ACS03-C1448-820-E-DEA-0002	Zone 2	BARTEC	07-351	437871	Ex ed	II C	T6	II 2 G	IP 66
326	ACS03-320-MHS-1892-L	E	Celes Komandimi	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0107	ACS03-C1448-820-E-DEA-0002	Zone 2	EATON	GHG411	1206	Ex de	II C	T6	II 2 G	IP 66
327	ACS03-320-MHS-1908-AL	E	Celes Komandimi	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0107	ACS03-C1448-820-E-DEA-0002	Zone 2	EATON	GHG4118100R0002	1426	Ex de	II C	T6	II 2 G	IP 66
328	ACS03-320-MHS-1908-BL	E	Celes Komandimi	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0107	ACS03-C1448-820-E-DEA-0002	Zone 2	EATON	GHG4118100R0002	1426	Ex de	II C	T6	II 2 G	IP 66
329	ACS03-320-MHS-1908-CL	E	Celes Komandimi	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0107	ACS03-C1448-820-E-DEA-0002	Zone 2	EATON	GHG4118100R0002	1426	Ex de	II C	T6	II 2 G	IP 66
330	ACS03-320-MHS-1922-L	E	Celes Komandimi	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0107	ACS03-C1448-820-E-DEA-0002	Zone 2	CEFD	N/A	24-15 M	Ex d	II C	T6	II 2 G	IP 65

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
331	ACS03-320-MHS-2613-L	E	Celes Komandimi	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0209	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8040/11	1613807580440000	Ex de	II C	T4	II 2 G	IP 66
332	ACS03-320-MHS-2761-L	E	Celes Komandimi	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0210	ACS03-C1448-820-E-DEA-0002	Zone 2	EATON	GHG411	1206	Ex de	II C	T6	II 2 G	IP 66
333	ACS03-320-MHS-2845-AL	E	Celes Komandimi	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0210	ACS03-C1448-820-E-DEA-0002	Zone 2	BARTEC	07-351	439899	Ex ed	II C	T6	II 2 G	IP 66
334	ACS03-320-MHS-2845-BL	E	Celes Komandimi	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0210	ACS03-C1448-820-E-DEA-0002	Zone 2	BARTEC	07-351	440300	Ex ed	II C	T6	II 2 G	IP 66
335	ACS03-320-MHS-2892-L	E	Celes Komandimi	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0207	ACS03-C1448-820-E-DEA-0002	Zone 2	EATON	GHG411	1206	Ex de	II C	T6	II 2 G	IP 66
336	ACS03-320-MHS-2908-AL	E	Celes Komandimi	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0207	ACS03-C1448-820-E-DEA-0002	Zone 2	EATON	GHG4118100R0002	1426	Ex de	II C	T6	II 2 G	IP 66
337	ACS03-320-MHS-2908-BL	E	Celes Komandimi	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0207	ACS03-C1448-820-E-DEA-0002	Zone 2	EATON	GHG4118100R0002	1426	Ex de	II C	T6	II 2 G	IP 66
338	ACS03-320-MHS-2908-CL	E	Celes Komandimi	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0207	ACS03-C1448-820-E-DEA-0002	Zone 2	EATON	GHG4118100R0002	1426	Ex de	II C	T6	II 2 G	IP 66
339	ACS03-320-MHS-2922-L	E	Celes Komandimi	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0207	ACS03-C1448-820-E-DEA-0002	Zone 2	CEFD	N/A	25-16 M	Ex d	II C	T6	II 2 G	IP 65
340	ACS03-320-MHS-3613-L	E	Celes Komandimi	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0309	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8040/11	1613807580440000	Ex de	II C	T4	II 2 G	IP 66
341	ACS03-320-MHS-3761-L	E	Celes Komandimi	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0310	ACS03-C1448-820-E-DEA-0002	Zone 2	EATON	GHG411	N/A	Ex de	II C	T6	II 2 G	IP 66
342	ACS03-320-MHS-3845-AL	E	Celes Komandimi	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0310	ACS03-C1448-820-E-DEA-0002	Zone 2	BARTEC	07-351	440301	Ex ed	II C	T6	II 2 G	IP 66
343	ACS03-320-MHS-3845-BL	E	Celes Komandimi	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0310	ACS03-C1448-820-E-DEA-0002	Zone 2	BARTEC	07-351	439901	Ex ed	II C	T6	II 2 G	IP 66
344	ACS03-320-MHS-3892-L	E	Celes Komandimi	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0307	ACS03-C1448-820-E-DEA-0002	Zone 2	EATON	GHG411	N/A	Ex de	II C	T6	II 2 G	IP 66
345	ACS03-320-MHS-3908-AL	E	Celes Komandimi	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0307	ACS03-C1448-820-E-DEA-0002	Zone 2	EATON	GHG4118100R0002	N/A	Ex de	II C	T6	II 2 G	IP 66
346	ACS03-320-MHS-3908-BL	E	Celes Komandimi	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0307	ACS03-C1448-820-E-DEA-0002	Zone 2	EATON	GHG4118100R0002	N/A	Ex de	II C	T6	II 2 G	IP 66
347	ACS03-320-MHS-3908-CL	E	Celes Komandimi	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0307	ACS03-C1448-820-E-DEA-0002	Zone 2	EATON	GHG4118100R0002	N/A	Ex de	II C	T6	II 2 G	IP 66
348	ACS03-320-MHS-3922-L	E	Celes Komandimi	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0307	ACS03-C1448-820-E-DEA-0002	Zone 2	SEFD	N/A	46-10 M	Ex d	II C	T6	II 2 G	IP 66
349	ACS03-320-PDIT-1001-A	J	Differential Transmetues presioni(Pressure Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0105	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1JN239120076	Ex ia	II C	T3	II 1/2 G	IP 66
350	ACS03-320-PDIT-1001-B	J	Differential Transmetues presioni(Pressure Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0105	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1JN239120077	Ex ia	II C	T3	II 1/2 G	IP 66
351	ACS03-320-PDIT-1010	J	Differential Transmetues presioni(Pressure Transmitter)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1JN230120 / S.N: N1JN239120086	Ex ia	II C	T3	II 1/2 G	IP 66
352	ACS03-320-PDIT-1020	J	Differential Transmetues presioni(Pressure Transmitter)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1JN239120087	Ex ia	II C	T3	II 1/2 G	IP 66
353	ACS03-320-PDIT-1310	J	Differential Transmetues presioni(Pressure Transmitter)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1JN239120088	Ex ia	II C	T3	II 1/2 G	IP 66
354	ACS03-320-PDIT-2001-A	J	Differential Transmetues presioni(Pressure Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0205	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1JN239120078	Ex ia	II C	T3	II 1/2 G	IP 66
355	ACS03-320-PDIT-2001-B	J	Differential Transmetues presioni(Pressure Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0205	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1JN239120079	Ex ia	II C	T3	II 1/2 G	IP 66
356	ACS03-320-PDIT-2010	J	Differential Transmetues presioni(Pressure Transmitter)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1JN239120089	Ex ia	II C	T3	II 1/2 G	IP 66
357	ACS03-320-PDIT-2020	J	Differential Transmetues presioni(Pressure Transmitter)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1JN239120090	Ex ia	II C	T3	II 1/2 G	IP 66
358	ACS03-320-PDIT-2310	J	Differential Transmetues presioni(Pressure Transmitter)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1JN239120091	Ex ia	II C	T3	II 1/2 G	IP 66
359	ACS03-320-PDIT-3001-A	J	Differential Transmetues presioni(Pressure Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0305	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1JN239120080	Ex ia	II C	T4/T6	II 1/2 G	IP 66
360	ACS03-320-PDIT-3001-B	J	Differential Transmetues presioni(Pressure Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0305	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1JN239120081	Ex ia	II C	T4/T6	II 1/2 G	IP 66
361	ACS03-320-PDIT-3010	J	Differential Transmetues presioni(Pressure Transmitter)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1JN239120092	Ex ia	II C	T3	II 1/2 G	IP 65
362	ACS03-320-PDIT-3020	J	Differential Transmetues presioni(Pressure Transmitter)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1JN239120081	Ex ia	II C	T3	II 1/2 G	IP 65
363	ACS03-320-PDIT-3310	J	Differential Transmetues presioni(Pressure Transmitter)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1JN239120094	Ex ia	II C	T3	II 1/2 G	IP 65
364	ACS03-320-PIT-1003	J	Transmetues presioni(Pressure Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0105	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1H8299000076	Ex ia	II C	T6	II 1/2 G	IP 66
365	ACS03-320-PIT-1086	J	Gauge Transmetues presioni(Pressure Transmitter)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1JN239000079	Ex d	II C	T4/T6	II 1/2 G	IP 66
366	ACS03-320-PIT-1101-A	J	Transmetues presioni(Pressure Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0105	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1H8269000070	Ex ia	II C	T6	II 1/2 G	IP 66
367	ACS03-320-PIT-1101-B	J	Transmetues presioni(Pressure Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0105	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1H8269000071	Ex ia	II C	T6	II 1/2 G	IP 66

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi i Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
368	ACS03-320-PIT-1101-C	J	Transmetues presioni(Pressure Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0105	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1H8269000069	Ex ia	II C	T6	II 1/2 G	IP 66
369	ACS03-320-PIT-1104	J	Transmetues presioni(Pressure Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0105	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1H8299000077	Ex ia	II C	T6	II 1/2 G	IP 66
370	ACS03-320-PIT-2003	J	Transmetues presioni(Pressure Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0205	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1H8299000084	Ex ia	II C	T6	II 1/2 G	IP 66
371	ACS03-320-PIT-2101-A	J	Transmetues presioni(Pressure Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0205	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1H8269000075	Ex ia	II C	T6	II 1/2 G	IP 66
372	ACS03-320-PIT-2101-B	J	Transmetues presioni(Pressure Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0205	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1H8269000079	Ex ia	II C	T6	II 1/2 G	IP 66
373	ACS03-320-PIT-2101-C	J	Transmetues presioni(Pressure Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0205	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1H8269000077	Ex ia	II C	T6	II 1/2 G	IP 66
374	ACS03-320-PIT-2104	J	Transmetues presioni(Pressure Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0205	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1H8299000083	Ex ia	II C	T6	II 1/2 G	IP 66
375	ACS03-320-PIT-3003	J	Transmetues presioni(Pressure Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0305	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1H8299000082	Ex ia	II C	T6	II 1/2 G	IP 66
376	ACS03-320-PIT-3101-A	J	Transmetues presioni(Pressure Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0305	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1H8269000083	Ex ia	II C	T6	II 1/2 G	IP 66
377	ACS03-320-PIT-3101-B	J	Transmetues presioni(Pressure Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0305	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1H8269000081	Ex ia	II C	T6	II 1/2 G	IP 66
378	ACS03-320-PIT-3101-C	J	Transmetues presioni(Pressure Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0305	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DS III	N1H8269000082	Ex ia	II C	T6	II 1/2 G	IP 66
379	ACS03-320-PIT-3104	J	Transmetues presioni(Pressure Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0305	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1H7289000038	Ex ia	II C	T6	II 1/2 G	IP 66
380	ACS03-320-PZIT-0010-A	J	Transmetues presioni(Pressure Transmitter)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1JN239000099	Ex d	II C	T4/T6	II 1/2 G	IP 66
381	ACS03-320-PZIT-0010-B	J	Transmetues presioni(Pressure Transmitter)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1JN239000100	Ex d	II C	T4/T6	II 1/2 G	IP 66
382	ACS03-320-PZIT-0010-C	J	Transmetues presioni(Pressure Transmitter)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1JN239000101	Ex d	II C	T4/T6	II 1/2 G	IP 66
383	ACS03-320-SKT-1822	E	Prize	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0110		Zone 2	STAHL	7571/12-506	174377080110003	Ex nA	II C	T6	II 3 G	IP 66
384	ACS03-320-SKT-2822	E	Prize	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0210		Zone 2	STAHL	7571/12-506	174377080110002	Ex nA	II C	T6	II 3 G	IP 66
385	ACS03-320-SKT-3822	E	Prize	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0310		Zone 2	STAHL	7571/12-506	174377080110001	Ex nA	II C	T6	II 3 G	IP 66
386	ACS03-320-TE-1613	J	Temperature Element	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0109	ACS03-C1612-320-M-DPE-0016	Zone 2	SIEMENS	DNGW-132ST-02M	LDX/10008890	Ex de	II C	T4	II 2 G	IP 65
387	ACS03-320-TE-2613	J	Winding PTC M-2852	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0209		Zone 2	SIEMENS	DNGW-132ST-02M	LDX/10008894	Ex de	II C	T4	II 2 G	IP 65
388	ACS03-320-TE-3613	J	Winding PTC M-3852	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0309		Zone 2	SIEMENS	DNGW-132ST-02M	LDX/10008895	Ex de	II C	T4	II 2 G	IP 65
389	ACS03-320-TIT-0011	J	Transmetues Temperature (Temperature Transmitter)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS TH300	N1JN004463	Ex d	II C	T6	II 1/2 G	IP 65
390	ACS03-320-TIT-1005	J	Transmetues Temperature (Temperature Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0105	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS TS 500	N1J46311	Ex ia	II C	T4	II 1/2 G	IP 67
391	ACS03-320-TIT-1103	J	Transmetues Temperature (Temperature Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0105	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS TS 500	N1J46314	Ex ia	II C	T4	II 1/2 G	IP 67
392	ACS03-320-TIT-1585	J	Transmetues Temperature (Temperature Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0109	ACS03-C1612-320-M-DPE-0016	Zone 2	SIEMENS	SITRANS TS 500 7MC7511-1CA01-9HA6-Z	N1H87473	Ex ia/lb	II C	T4	II 1/2 G	IP 66
393	ACS03-320-TIT-2005	J	Transmetues Temperature (Temperature Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0205	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS TS 500	N1J46312	Ex ia	II C	T4	II 1/2 G	IP 66
394	ACS03-320-TIT-2103	J	Transmetues Temperature (Temperature Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0205	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS TS 500	N1J46315	Ex ia	II C	T4	II 1/2 G	IP 66
395	ACS03-320-TIT-2585	J	Transmetues Temperature (Temperature Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0209		Zone 2	SIEMENS	SITRANS TS 500	INELIGIBLE	Ex ia	II C	T4/T6	II 1/2 G	IP 66
396	ACS03-320-TIT-3005	J	Transmetues Temperature (Temperature Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0305	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS TS 500	N1J46313	Ex ia/lb	II C	T6/T4	II 1/2 G	IP 67
397	ACS03-320-TIT-3103	J	Transmetues Temperature (Temperature Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0305	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS TS 500	N1J46316	Ex ia/lb	II C	T6/T4	II 1/2 G	IP 67
398	ACS03-320-TIT-3585	J	Transmetues Temperature (Temperature Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0309		Zone 2	SIEMENS	SITRANS TS 500	N1H874080	Ex ia	II C	T4/T6	II 1/2 G	IP 66
399	ACS03-320-TT-1102-A	J	Transmetues Temperature (Temperature Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0105	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS TS 500	N1J46317	Ex ia	II C	T4	II 1/2 G	IP 66
400	ACS03-320-TT-1102-B	J	Transmetues Temperature (Temperature Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0105	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS TS 500	N1J46318	Ex ia	II C	T4	II 1/2 G	IP 66
401	ACS03-320-TT-1102-C	J	Transmetues Temperature (Temperature Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0105	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS TS 500	N1J46319	Ex ia	II C	T4	II 1/2 G	IP 66
402	ACS03-320-TT-1584	J	PT-100 Temp. sensor Seal Gas Heater	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0109	ACS03-C1612-320-M-DPE-0016	Zone 2	ELMESS	DHK15B03VAD/SE-8-T3	0827148/004	Ex d	II C	T3	II 2 G	IP 66
403	ACS03-320-TT-2102-A	J	Transmetues Temperature (Temperature Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0205	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS TS 500	N1J46320	Ex ia	II C	T4	II 1/2 G	IP 66
404	ACS03-320-TT-2102-B	J	Transmetues Temperature (Temperature Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0205	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS TS 500	N1J46321	Ex ia	II C	T4	II 1/2 G	IP 66

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi i Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
405	ACS03-320-TT-2102-C	J	Transmetues Temperature (Temperature Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0205	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS TS 500	N1J46322	Ex ia	II C	T4	II 1/2 G	IP 66
406	ACS03-320-TT-2584	J	Sensor temperature PT-100 Temp. sensor Seal Gas Heater	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0209		Zone 2	WIKA	T32.1S.0IS-S	984093	Ex ia	II C	T4/T5/T6	II 1 G	IP 66
407	ACS03-320-TT-3102-A	J	Transmetues Temperature (Temperature Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0305	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS TS 500	N1J46324	Ex ia/ib	II C	T6/T4	II 1/2 G	IP 67
408	ACS03-320-TT-3102-B	J	Transmetues Temperature (Temperature Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0305	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS TS 500	N1J46325	Ex ia/ib	II C	T6/T4	II 1/2 G	IP 67
409	ACS03-320-TT-3102-C	J	Transmetues Temperature (Temperature Transmitter)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0305	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS TS 500	N1J46323	Ex ia/ib	II C	T6/T4	II 1/2 G	IP 67
410	ACS03-320-TT-3584	J	Sensor temperature PT-100 Temp. sensor Seal Gas Heater	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0309		Zone 2	ELMESS	DHK15B03VAD/SE-8-T3	0827148/006	Ex d	II C	T3	II 2 G	IP 66
411	ACS03-320-XZSC-1707	J	Celes fundor Off-Skid Fuel Gas Block Valve limit switch (closed)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0108		Zone 2	K CONTROLS	SBR 76M12/2	127687/018 / S.N: 127687/010	Ex d / Ex db	II C	T6	II 2 G	IP 66/67
412	ACS03-320-XZSC-2707	J	Celes fundor Off-Skid Fuel Gas Block Valve limit switch (closed)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0208		Zone 2	K CONTROLS	SBR 76M12/2	127687/011	Ex d	II C	T6	II 2 G	IP 66 / 67
413	ACS03-320-XZSC-3707	J	Celes fundor Off-Skid Fuel Gas Block Valve limit switch (closed)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0308		Zone 2	K CONTROLS	SBR 76M12/2	127687/002	Ex d	II C	T6	II 2 G	IP 66/67
414	ACS03-320-YV-1010	J	Valvul Solenoid (Solenoid Valve)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	61370/1	Ex e m / Ex eb mb	II C	T4	II 2 G	IP 66
415	ACS03-320-YV-1011	J	Valvul Solenoid (Solenoid Valve)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
416	ACS03-320-YV-1020	J	Valvul Solenoid (Solenoid Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	61370/1	Ex e m	II C	T4	II 2 G	IP 66
417	ACS03-320-YV-1021	J	Valvul Solenoid (Solenoid Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
418	ACS03-320-YV-1310	J	Valvul Solenoid (Solenoid Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	61370/1	Ex e m	II C	T4	II 2 G	IP 66
419	ACS03-320-YV-1311	J	Valvul Solenoid (Solenoid Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
420	ACS03-320-YV-1510	J	Valvul Solenoid (Solenoid Valve)	FUEL GAS	ACS03-534	ACS03-534-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
421	ACS03-320-YV-1610	J	Valvul Solenoid (Solenoid Valve)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0109	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
422	ACS03-320-YV-1706	J	Solenoid Off-Skid Fuel Gas Vent Valve ctrl Solenoid ZV6	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0108		Zone 2	ASCO	EMM-12-II	MO452951	Ex e m	II C	T4	II 2 G	IP 66/67
423	ACS03-320-YV-1707	J	Solenoid Off-Skid Fuel Gas Block Valve ctrl Solenoid ZV6	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0108		Zone 2	ASCO	EMM-12-II	MO452951	Ex e m	II C	T4	II 2 G	IP 66/67
424	ACS03-320-YV-2010	J	Valvul Solenoid (Solenoid Valve)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	61370/1	Ex e m	II C	T4	II 2 G	IP 66
425	ACS03-320-YV-2011	J	Valvul Solenoid (Solenoid Valve)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
426	ACS03-320-YV-2020	J	Valvul Solenoid (Solenoid Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	61370/1	Ex e m	II C	T4	II 2 G	IP 66
427	ACS03-320-YV-2021	J	Valvul Solenoid (Solenoid Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
428	ACS03-320-YV-2310	J	Valvul Solenoid (Solenoid Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	61370/1	Ex e m	II C	T4	II 2 G	IP 66
429	ACS03-320-YV-2311	J	Valvul Solenoid (Solenoid Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
430	ACS03-320-YV-2510	J	Valvul Solenoid (Solenoid Valve)	FUEL GAS	ACS03-534	ACS03-534-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
431	ACS03-320-YV-2610	J	Valvul Solenoid (Solenoid Valve)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0209	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62128/3	Ex e m	II C	T4	II 2 G	IP 66
432	ACS03-320-YV-2706	J	Solenoid Off-Skid Fuel Gas Vent Valve ctrl Solenoid ZV6	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0208		Zone 2	ASCO	EMM-12-II	MO452951	Ex e m	II C	T4	II 2 G	IP 66
433	ACS03-320-YV-2707	J	Solenoid Off-Skid Fuel Gas Block Valve ctrl Solenoid ZV6	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0208		Zone 2	ASCO	EMM-12-II	MO452951	Ex e m	II C	T4	II 2 G	IP 66
434	ACS03-320-YV-3010	J	Valvul Solenoid (Solenoid Valve)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	61370/1	Ex e m	II C	T4	II 2 G	IP 66
435	ACS03-320-YV-3011	J	Valvul Solenoid (Solenoid Valve)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
436	ACS03-320-YV-3020	J	Valvul Solenoid (Solenoid Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	61370/1	Ex e m	II C	T4	II 2 G	IP 66
437	ACS03-320-YV-3021	J	Valvul Solenoid (Solenoid Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
438	ACS03-320-YV-3310	J	Valvul Solenoid (Solenoid Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	61370/1	Ex e m	II C	T4	II 2 G	IP 66
439	ACS03-320-YV-3311	J	Valvul Solenoid (Solenoid Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
440	ACS03-320-YV-3510	J	Valvul Solenoid (Solenoid Valve)	FUEL GAS	ACS03-534	ACS03-534-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
441	ACS03-320-YV-3610	J	Valvul Solenoid (Solenoid Valve)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0309	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62145/8	Ex e m	II C	T4	II 2 G	IP 66

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi i Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
442	ACS03-320-YV-3706	J	Solenoid Off-Skid Fuel Gas Vent Valve ctrl Solenoid ZV6	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0308		Zone 2	ASCO	EMM-12-II	MO452951	Ex e m	II C	T4	II 2 G	IP 66/67
443	ACS03-320-YV-3707	J	Solenoid Off-Skid Fuel Gas Block Valve ctrl Solenoid ZV6	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0308		Zone 2	ASCO	EMM-12-II	MO452951	Ex e m	II C	T4	II 2 G	IP 66/67
444	ACS03-320-YZV-1010	J	Valvul Solenoid (Solenoid Valve)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	61370/1	Ex e m	II C	T4	II 2 G	IP 66
445	ACS03-320-YZV-1011	J	Valvul Solenoid (Solenoid Valve)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
446	ACS03-320-YZV-1020	J	Valvul Solenoid (Solenoid Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	61370/1	Ex e m	II C	T4	II 2 G	IP 66
447	ACS03-320-YZV-1021	J	Valvul Solenoid (Solenoid Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
448	ACS03-320-YZV-1310	J	Valvul Solenoid (Solenoid Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	61370/1	Ex e m	II C	T4	II 2 G	IP 66
449	ACS03-320-YZV-1311	J	Valvul Solenoid (Solenoid Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
450	ACS03-320-YZV-1510	J	Valvul Solenoid (Solenoid Valve)	FUEL GAS	ACS03-534	ACS03-534-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
451	ACS03-320-YZV-1610	J	Valvul Solenoid (Solenoid Valve)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0109	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
452	ACS03-320-YZV-1706	J	Off-Skid Fuel Gas Vent Valve ESD Solenoid ZV6	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0108		Zone 2	ASCO	EMM-12-II	MO452951	Ex e m	II C	T4	II 2 G	IP 66/67
453	ACS03-320-YZV-1707	J	Off-Skid Fuel Gas Block Valve ESD Solenoid ZV6	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0108		Zone 2	ASCO	EMM-12-II	MO452951	Ex e m	II C	T4	II 2 G	IP 66/67
454	ACS03-320-YZV-2010	J	Valvul Solenoid (Solenoid Valve)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	61370/1	Ex e m	II C	T4	II 2 G	IP 66
455	ACS03-320-YZV-2011	J	Valvul Solenoid (Solenoid Valve)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
456	ACS03-320-YZV-2020	J	Valvul Solenoid (Solenoid Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	61370/1	Ex e m	II C	T4	II 2 G	IP 66
457	ACS03-320-YZV-2021	J	Valvul Solenoid (Solenoid Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
458	ACS03-320-YZV-2310	J	Valvul Solenoid (Solenoid Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	61370/1	Ex e m	II C	T4	II 2 G	IP 66
459	ACS03-320-YZV-2311	J	Valvul Solenoid (Solenoid Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
460	ACS03-320-YZV-2510	J	Valvul Solenoid (Solenoid Valve)	FUEL GAS	ACS03-534	ACS03-534-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
461	ACS03-320-YZV-2610	J	Valvul Solenoid (Solenoid Valve)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0209	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62128/3	Ex e m	II C	T4	II 2 G	IP 66
462	ACS03-320-YZV-2706	J	Solenoid Off-Skid Fuel Gas Vent Valve ESD Solenoid ZV6	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0208		Zone 2	ASCO	EMM-12-II	MO452951	Ex e m	II C	T4	II 2 G	IP 66
463	ACS03-320-YZV-2707	J	Solenoid Off-Skid Fuel Gas Block Valve ESD Solenoid ZV6	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0208		Zone 2	ASCO	EMM-12-II	MO452951	Ex e m	II C	T4	II 2 G	IP 66
464	ACS03-320-YZV-3010	J	Valvul Solenoid (Solenoid Valve)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	61370/1	Ex e m	II C	T4	II 2 G	IP 66
465	ACS03-320-YZV-3011	J	Valvul Solenoid (Solenoid Valve)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
466	ACS03-320-YZV-3020	J	Valvul Solenoid (Solenoid Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	61370/1	Ex e m	II C	T4	II 2 G	IP 66
467	ACS03-320-YZV-3021	J	Valvul Solenoid (Solenoid Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
468	ACS03-320-YZV-3310	J	Valvul Solenoid (Solenoid Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	61370/1	Ex e m	II C	T4	II 2 G	IP 66
469	ACS03-320-YZV-3311	J	Valvul Solenoid (Solenoid Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
470	ACS03-320-YZV-3510	J	Valvul Solenoid (Solenoid Valve)	FUEL GAS	ACS03-534	ACS03-534-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
471	ACS03-320-YZV-3610	J	Valvul Solenoid (Solenoid Valve)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0309	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62145/8	Ex e m	II C	T4	II 2 G	IP 66
472	ACS03-320-YZV-3706	J	Solenoid ESD Vent Valve	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0308		Zone 2	ASCO	EMM-12-II	MO452951	Ex e m	II C	T4	II 2 G	IP 66
473	ACS03-320-YZV-3707	J	Solenoid ESD Block Valve	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0308		Zone 2	ASCO	EMM-12-II	MO452951	Ex e m	II C	T4	II 2 G	IP 66
474	ACS03-320-ZIT-1300	J	Valul kontrolli Compressor Anti-Surge Control Valve Pos Feedb CV5	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0105		Zone 2	MOKVELD	M4575-1VO-6	7572046 / S.N: ARR-H001-7572046	Ex ia	II C	T4	II 2 G	N/A
475	ACS03-320-ZIT-2300	J	Valul kontrolli Compressor Anti-Surge Control Valve Pos Feedb CV5	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0205		Zone 2	MOKVELD	M4575-1VO-6	7572046 / S.N: ARR-H001-7572047	Ex ia	II C	T4	II 2 G	N/A
476	ACS03-320-ZIT-3300	J	Valul kontrolli Compressor Anti-Surge Control Valve Pos Feedb CV5	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0305		Zone 2	SIEMENS	SIPART PS2	ARR-H-001-7572048	Ex ia	II C	T4	II 2 G	IP 66
477	ACS03-320-ZSC/O-1010	J	Celesa fundor (Limit Switches)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P552	37382	Ex ia	II C	T6/T1	II 2 G	IP 66/67
478	ACS03-320-ZSC/O-1011	J	Celesa fundor (Limit Switches)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P552	37382	Ex ia	II C	T6/T1	II 2 G	IP 66/67

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi i Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
479	ACS03-320-ZSC/O-1020	J	Celesa fundor (Limit Switches)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GISMORGS2PN2P5S2DW	37198	Ex ia	II C	T6/T1	II 2 G	IP 66/67
480	ACS03-320-ZSC/O-1021	J	Celesa fundor (Limit Switches)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P552	37382	Ex ia	II C	T6/T1	II 2 G	IP 66/67
481	ACS03-320-ZSC/O-1310	J	Celesa fundor (Limit Switches)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GISMORGS2PN2P5S2DW	37198	Ex ia	II C	T6/T1	II 2 G	IP 66/67
482	ACS03-320-ZSC/O-1311	J	Celesa fundor (Limit Switches)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P552	37382	Ex ia	II C	T6/T1	II 2 G	IP 66/67
483	ACS03-320-ZSC/O-1510	J	Celesa fundor (Limit Switches)	FUEL GAS	ACS03-534	ACS03-534-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GI SERIES	N/A / S.N: 37382	Ex ia	II C	T6/T1	II 2 G	IP 66/67
484	ACS03-320-ZSC/O-1610	J	Celesa fundor (Limit Switches)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0109	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GISMORGS2PN2P5S2DW	37382	Ex ia	II C	T6/T1	II 2 G	IP 66/67
485	ACS03-320-ZSC/O-2010	J	Celesa fundor (Limit Switches)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GISMORGS2PN2P5S2DW	37198	Ex ia	II C	T6/T1	II 2 G	IP 66/67
486	ACS03-320-ZSC/O-2011	J	Celesa fundor (Limit Switches)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P552	37382	Ex ia	II C	T6/T1	II 2 G	IP 66/67
487	ACS03-320-ZSC/O-2020	J	Celesa fundor (Limit Switches)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GISMORGS2PN2P5S2DW	37198	Ex ia	II C	T6/T1	II 2 G	IP 66/67
488	ACS03-320-ZSC/O-2021	J	Celesa fundor (Limit Switches)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P552	37382	Ex ia	II C	T6/T1	II 2 G	IP 66/67
489	ACS03-320-ZSC/O-2310	J	Celesa fundor (Limit Switches)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GISMORGS2PN2P5S2DW	37198	Ex ia	II C	T6/T1	II 2 G	IP 66/67
490	ACS03-320-ZSC/O-2311	J	Celesa fundor (Limit Switches)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P552	37382	Ex ia	II C	T6/T1	II 2 G	IP 66/67
491	ACS03-320-ZSC/O-2510	J	Celesa fundor (Limit Switches)	FUEL GAS	ACS03-534	ACS03-534-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GI SERIES	N/A	Ex ia	II C	T6/T1	II 2 G	IP 66/67
492	ACS03-320-ZSC/O-2610	J	Celesa fundor (Limit Switches)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0209	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P552	37382	Ex ia	II C	T6/T1	II 2 G	IP 66/67
493	ACS03-320-ZSC/O-3010	J	Celesa fundor (Limit Switches)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P552	37382	Ex ia	II C	T6/T1	II 2 G	IP 66/67
494	ACS03-320-ZSC/O-3011	J	Celesa fundor (Limit Switches)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P552	37382	Ex ia	II C	T6/T1	II 2 G	IP 66/67
495	ACS03-320-ZSC/O-3020	J	Celesa fundor (Limit Switches)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P552	37382	Ex ia	II C	T6/T1	II 2 G	IP 66/67
496	ACS03-320-ZSC/O-3021	J	Celesa fundor (Limit Switches)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P552	37382	Ex ia	II C	T6/T1	II 2 G	IP 66/67
497	ACS03-320-ZSC/O-3310	J	Celesa fundor (Limit Switches)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P552	37198	Ex ia	II C	T6/T1	II 2 G	IP 66/67
498	ACS03-320-ZSC/O-3311	J	Celesa fundor (Limit Switches)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P552	37382	Ex ia	II C	T6/T1	II 2 G	IP 66/67
499	ACS03-320-ZSC/O-3510	J	Celesa fundor (Limit Switches)	FUEL GAS	ACS03-534	ACS03-534-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GI SERIES	N/A	Ex ia	II C	T6/T1	II 2 G	IP 66/67
500	ACS03-320-ZSC/O-3610	J	Celesa fundor (Limit Switches)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0309	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P552	37382	Ex ia	II C	T6/T1	II 2 G	IP 66/67
501	ACS03-330-AT-0001A	E	Analizues Lageshtire Chromatograph Moisture Analyser	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	ELSTER	ENCAL3000	61301931	Ex d	II B	T4	II 2 G	N/A
502	ACS03-330-AT-0001B	E	Analizues Lageshtire Chromatograph Moisture Analyser	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	ELSTER	ENCAL3000	61301937	Ex d	II B	T4	II 2 G	N/A
503	ACS03-330-AT-0003A	J	Mates I pikes temperaturese se krijimit te kondesimit Dew point transducer	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	VYMPEL	CONG PRIMA-2M	DI8010272	Ex d	II B + H2, IIA	T5	II 2 G	N/A / 54
504	ACS03-330-AT-0003B	J	Mates I pikes temperaturese se krijimit te kondesimit Dew point transducer	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	VYMPEL	CONG PRIMA-2M	DI7060235	Ex d	II B + H2	T5	II 2 G	N/A
505	ACS03-330-DSX01	J	Celes Door switch	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	KROMA MEC	N/A	19-180	Ex d	II C	T6	II 2 G	N/A
506	ACS03-330-FDX01	J	Detektor Flake Detektor Zjarri (Flame Detector)	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	HONEYWELL	FS24X-9	N/A / S.N: 204414	Ex d	II C	T4/T6	II 2 G	N/A
507	ACS03-330-FIT-1001	J	Mates Gazi me ultratinguj Mates i prurjes me ultratinguj (Ultrasonic Flowmeter)	Matja e Gazit	ACS03-330	ACS03-330-0100	ACS03-C1448.4005-330-A-DEB-0001	Zone 2	ELSTER	Q-SONIC-PLUS	69511697	Ex d ia [ia]	II B + H2	T6	II 2 G	IP 66
508	ACS03-330-FIT-1002	J	Mates i prurjes me ultratinguj (Ultrasonic Flowmeter)	Matja e Gazit	ACS03-330	ACS03-330-0100	ACS03-C1448.4005-330-A-DEB-0001	Zone 2	ELSTER	Q-SONIC-PLUS	69511698	Ex d ia [ia]	II B + H2	T6	II 2 G	IP 66
509	ACS03-330-FIT-2001	J	Mates i prurjes me ultratinguj (Ultrasonic Flowmeter)	Matja e Gazit	ACS03-330	ACS03-330-0200	ACS03-C1448.4005-330-A-DEB-0001	Zone 2	ELSTER	Q-SONIC-PLUS	69511699	Ex d ia [ia]	II B + H2	T6	II 2 G	IP 66
510	ACS03-330-FIT-2002	J	Mates i prurjes me ultratinguj (Ultrasonic Flowmeter)	Matja e Gazit	ACS03-330	ACS03-330-0200	ACS03-C1448.4005-330-A-DEB-0001	Zone 2	ELSTER	Q-SONIC-PLUS	69511701	Ex d ia [ia]	II B + H2	T6	II 2 G	IP 66
511	ACS03-330-FIT-3001	J	Mates i prurjes me ultratinguj (Ultrasonic Flowmeter)	Matja e Gazit	ACS03-330	ACS03-330-0300	ACS03-C1448.4005-330-A-DEB-0001	Zone 2	ELSTER	Q-SONIC-PLUS	69511704	Ex d ia [ia]	II B + H2	T6	II 2 G	IP 66
512	ACS03-330-FIT-3002	J	Mates i prurjes me ultratinguj (Ultrasonic Flowmeter)	Matja e Gazit	ACS03-330	ACS03-330-0300	ACS03-C1448.4005-330-A-DEB-0001	Zone 2	ELSTER	Q-SONIC-PLUS	69511705	Ex d ia [ia]	II B + H2	T6	II 2 G	IP 66
513	ACS03-330-GDX01	J	Gas detector	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	HONEYWELL	AMCB 1	18180051 / S.N: 25182115	Ex d / Ex db	II B + H2 / II C	T4/T6	II 2 G	N/A / IP66
514	ACS03-330-GDX02	J	Gas detector	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	HONEYWELL	11-KB4BO-0120X	25182115 / S.N: 25182118	Ex d / Ex db	II B + H2 / II C	T4/T6	II 2 G	N/A / IP66
515	ACS03-330-HNX01	J	Kuti Spherndarese (Junction Box) for Horn and Beacon	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	KROMA MEC	S.26	17/0389	Ex d	II C	T5	II 2 GD	N/A / IP66,67

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
516	ACS03-330-HS-0020	J	çeles paneli lokal (Local Panel Hand Switch)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	QUINTEX	CB-P6/16353	64719	Ex de	II C	T4	II 2 G	IP 66
517	ACS03-330-HS-0021	J	çeles paneli lokal (Local Panel Hand Switch)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	CORTEM	SA301410/P	17/325338	Ex de	II C	T6	II 2 G	IP 66
518	ACS03-330-JB-0001	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224520	Ex e	II C	T6	II 2 GD	IP 66
519	ACS03-330-JB-0100	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224504	Ex e	II C	T6	II 2 GD	IP 66
520	ACS03-330-JB-0101	J	Kuti Shperndarese (Junction Box)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224503	Ex e	II C	T6	II 2 GD	IP 66
521	ACS03-330-JB-0102	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224497	Ex e	II C	T6	II 2 GD	IP 66
522	ACS03-330-JB-0200	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224529	Ex e	II C	T6	II 2 GD	IP 66
523	ACS03-330-JB-1001	J	Instrumentation Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222155	Ex ia	II C	T6	II 2 GD	IP 66
524	ACS03-330-JB-1002	J	Kuti Shperndarese (Junction Box)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222159	Ex ia	II C	T6	II 2 GD	IP 66
525	ACS03-330-JB-1003	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224551	Ex ia	II C	T6	II 2 G	IP 66
526	ACS03-330-JB-1004	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-352720	I/17/226205	Ex ia	II C	T6	II 2 G	IP 66
527	ACS03-330-JB-E-001	E	Kuti Shperndarese (Junction Box) for Thermostat and Heater	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	STAHL	8146/1051	19167842404400008	Ex e	II C	T6	II 2 G	N/A / IP66
528	ACS03-330-JB-E-002	E	Kuti Shperndarese (Junction Box) for Thermostat and Heater	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	STAHL	8146/1051	19167842404400001	Ex e	II C	T6	II 2 G	N/A / IP66
529	ACS03-330-JB-E-003	E	Kuti Shperndarese (Junction Box) for Thermostat and Heater	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	STAHL	8146/1051	19167842404400003	Ex e	II C	T6	II 2 G	N/A / IP66
530	ACS03-330-JB-E-004	E	Kuti Shperndarese (Junction Box)	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	STAHL	8118/111	1411523204400000	Ex e	II C	T6	II 2 G	N/A / IP66
531	ACS03-330-JB-E-005	E	Kuti Shperndarese (Junction Box)	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	STAHL	8118/111	1411523204400000	Ex e	II C	T6	II 2 G	N/A / IP66
532	ACS03-330-JB-E-006	E	Kuti Shperndarese (Junction Box) for Heat Tracing	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	THERMON	ZP-WP	N/A	Ex e	II C	T4/T6	II 2 G	N/A / IP66
533	ACS03-330-JB-E-007	E	Kuti Shperndarese (Junction Box) for Heat Tracing	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	THERMON	ZP-WP	N/A	Ex e	II C	T4/T6	II 2 G	N/A / IP66
534	ACS03-330-JB-E-008	E	Kuti Shperndarese (Junction Box)	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	ABTECH	BPGC01	1011720/2017	Ex e	II C	T6	II 2 G	IP 66
535	ACS03-330-JB-E-009	E	Kuti Shperndarese (Junction Box)	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	ABTECH	BPGC01	264648/2016	Ex e	II C	T6	II 2 G	IP 66
536	ACS03-330-JB-J-001	J	Kuti Shperndarese (Junction Box)	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	WIKA	TR60-A	N/A	Ex ia	II C	T6 / T1	II 1 G	N/A
537	ACS03-330-JB-J-002	J	Kuti Shperndarese (Junction Box)	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	STAHL	8118/211-401	1815331110440039	Ex ia / Ex ib	II C	T6	II 2 G	N/A
538	ACS03-330-JB-J-003 / Zevendesuar me ACS03-330-JB-P-004	J	Kuti Shperndarese (Junction Box)	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	STAHL / Zevendesuar me BARTEC	8118/211-401	1815331110440020 / Zevendesuar me P003075/20	Ex ia / Zevendesuar me Ex ia ib	II C	T6	II 2 G	N/A / Zv IP66
539	ACS03-330-JB-J-005 / Zevendesuar me ACS03-330-JB-OS-001	J	Kuti Shperndarese (Junction Box)	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	STAHL / Zevendesuar me BARTEC	8118/211-401	1815331110440027 / Zevendesuar me P003873/20	Ex ia / Zevendesuar me Ex ia ib	II C	T6	II 2 G	N/A / Zv IP66
540	ACS03-330-JB-J-006	J	Kuti Shperndarese (Junction Box)	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	STAHL	8146/1051	19167842404400002	Ex e / Ex b	II C	T6	II 2 G	IP 66
541	ACS03-330-JB-J-007	J	Kuti Shperndarese (Junction Box)	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	STAHL	8146/1051	19167842404400007	Ex e / Ex b	II C	T6	II 2 G	IP 66
542	ACS03-330-JB-J-008	J	Kuti Shperndarese (Junction Box)	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	WIKA	TR60-A	N/A	Ex ia	II C	T6	II 1 G	N/A
543	ACS03-330-JB-J-009	J	Kuti Shperndarese (Junction Box)	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	STAHL	8118/211-401	1815548760440106	Ex ia / Ex ib	II C	T6	II 2 G	N/A
544	ACS03-330-JB-J-010 / Zevendesuar me ACS03-330-JB-P-005	J	Kuti Shperndarese (Junction Box)	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	STAHL / Zevendesuar me BARTEC	8118/211-401	1815331110440037 / Zevendesuar me P003075/20	Ex ia / Ex ib	II C	T6	II 2 G	IP 66
545	ACS03-330-JB-J-011 / Zevendesuar me ACS03-330-JB-P-003	J	Kuti Shperndarese (Junction Box)	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	STAHL / Zevendesuar me BARTEC	8118/211-401	1815548760440015 / Zevendesuar me P003074/20	Ex ia / Ex ib	II C	T6	II 2 G	IP 66
546	ACS03-330-JB-J-012	J	Kuti Shperndarese (Junction Box)	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	STAHL	8146/1051	19167842404400006	Ex e, Ex eb	II C	T6/ T1	II 2 G	IP 66
547	ACS03-330-JB-J-013	J	Kuti Shperndarese (Junction Box)	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	ABTECH	BPGC02	1011735/2017	Ex e	II C	T6	II 2 G	IP 66
548	ACS03-330-JB-J-014	J	Kuti Shperndarese (Junction Box)	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	ABTECH	BPGC02	891370/2015	Ex e	II C	T6	II 2 G	IP 66
549	ACS03-330-JBX01	J	HVAC Kuti Shperndarese (Junction Box)	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	BARTEC NASP	ESX 2222A	18/0166.1.2	Ex e	II C	T6	II 2 G	IP66
550	ACS03-330-LNX01	E	Ligth Fitting	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	CO.SI.ME	EVFC	18-15073 / 18-15084	Ex d	II C	T6	II 2 G	IP 66
551	ACS03-330-LNX02	E	Ligth Fitting	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	CO.SI.ME	EVFC	18-15075 / 18-15074	Ex d	II C	T6	II 2 G	IP 66
552	ACS03-330-LSX01	E	Ligth switch	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	CO.SI.ME	N/A	18-14384	Ex d	II C	T5	II 2 G	IP66

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
553	ACS03-330-MCV-0070	E	Motor Operated Control Valve	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	AUMA	SAREX 07.6-F10/-a3a1	3617MD72323	Ex de	II C	T3	II 2 G	IP 68
554	ACS03-330-MPX01	J	Break Glass	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	CO.SI.ME	N/A	17-09424	Ex d	II C	T5	II 2 G	IP66
555	ACS03-330-MV-0010	E	Valvul e motorizuar (Motor Operated Valve)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	AUMA	SAEX 10.2-F10/-a3a1	2617MD55058	Ex de	II C	T3	II 2 G	IP 68
556	ACS03-330-MV-1010	E	Valvul e motorizuar (Motor Operated Valve)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0400	ACS03-C1448-856-J-DJA-0001	Zone 2	AUMA	SAEX 07.02-F10/-a3a1	2217MD49443	Ex de	II C	T3	II 2 G	IP 68
557	ACS03-330-MV-2010	E	Valvul e motorizuar (Motor Operated Valve)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0400	ACS03-C1448-856-J-DJA-0001	Zone 2	AUMA	SAEX 07.2-F10/a3a1	2217MD49444	Ex de	II C	T3	II 2 G	IP 68
558	ACS03-330-MV-3010	E	Valvul e motorizuar (Motor Operated Valve)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0400	ACS03-C1448-856-J-DJA-0001	Zone 2	AUMA	SAEX 07.02-F10/-a3a1	2217MD49445	Ex de	II C	T3	II 2 G	IP 68
559	ACS03-330-PDIT-0010	J	Transmetues presioni diferencial (Pressure Transmitter)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DS III	N1JN239120095	Ex d	II C	T4/T6	II 1/2 G	IP 66
560	ACS03-330-PDIT-0020	J	Transmetues presioni diferencial (Pressure Transmitter)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DS III	N1JN239120096	Ex d	II C	T4/T6	II 1/2 G	IP 66
561	ACS03-330-PDIT-1010	J	Transmetues presioni diferencial (Pressure Transmitter)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0400	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DS III 7MF4433-1GA02-2RB7-Z	N1JN239120097	Ex d	II C	T6/ T4	II 1/2 G	IP 66
562	ACS03-330-PDIT-2010	J	Transmetues presioni diferencial (Pressure Transmitter)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0400	ACS03-C1448-330-P-DPE-0001	Zone 2	SIEMENS	SITRANS P DS III 7MF4433-1GA02-2RB7-Z	N1JN239120098	Ex d	II C	T6/ T4	II 1/2 G	IP 66
563	ACS03-330-PDIT-3010	J	Transmetues presioni diferencial (Pressure Transmitter)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0400	ACS03-C1448-330-P-DPE-0001	Zone 2	SIEMENS	SITRANS P DS III 7MF4433-1GA02-2RB7-Z	N1JN239120099	Ex d	II C	T6/ T4	II 1/2 G	IP 66
564	ACS03-330-PIT-1001	J	Transmetues presioni(Pressure Transmitter)	Matja e Gazit	ACS03-330	ACS03-330-0100	ACS03-C1448.4005-330-A-DEB-0001	Zone 2	HONEYWELL	STA87L	17W49 C4000005418305	Ex ia	II C	T4	II 1 G	IP 66/67
565	ACS03-330-PIT-1002	J	Transmetues presioni(Pressure Transmitter)	Matja e Gazit	ACS03-330	ACS03-330-0100	ACS03-C1448.4005-330-A-DEB-0001	Zone 2	HONEYWELL	STA87L	17W49 C4000005418305	Ex ia	II C	T4	II 1 G	IP 66/67
566	ACS03-330-PIT-1011	J	Transmetues presioni(Pressure Transmitter)	Matja e Gazit	ACS03-330	ACS03-330-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DS III 7MF4033-1FA00-2RB7-Z	N1JN239000080	Ex d	II C	T6	II 1/2 G	IP 66
567	ACS03-330-PIT-2001	J	Transmetues presioni(Pressure Transmitter)	Matja e Gazit	ACS03-330	ACS03-330-0200	ACS03-C1448.4005-330-A-DEB-0001	Zone 2	HONEYWELL	STA87L	17W49 C4000005418307	Ex ia	II C	T4/ T6	II 1 G	IP 66/67
568	ACS03-330-PIT-2002	J	Transmetues presioni(Pressure Transmitter)	Matja e Gazit	ACS03-330	ACS03-330-0200	ACS03-C1448.4005-330-A-DEB-0001	Zone 2	HONEYWELL	STA87L	17W49 C4000005418316	Ex ia	II C	T4/ T6	II 1 G	IP 66/67
569	ACS03-330-PIT-2011	J	Transmetues presioni(Pressure Transmitter)	Matja e Gazit	ACS03-330	ACS03-330-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DS III 7MF4033-1FA00-2RB7-Z	N1JN239000081	Ex d	II C	T6/ T4	II 1/2 G	IP 66
570	ACS03-330-PIT-3001	J	Transmetues presioni(Pressure Transmitter)	Matja e Gazit	ACS03-330	ACS03-330-0300	ACS03-C1448.4005-330-A-DEB-0001	Zone 2	HONEYWELL	STA87L	17W49 C4000005418305	Ex ia	II C	T4	II 1 G	IP 66/67
571	ACS03-330-PIT-3002	J	Transmetues presioni(Pressure Transmitter)	Matja e Gazit	ACS03-330	ACS03-330-0300	ACS03-C1448.4005-330-A-DEB-0001	Zone 2	HONEYWELL	STA87L	17W49 C4000005418309	Ex ia	II C	T4/ T6	II 1 G	IP 66/67
572	ACS03-330-PIT-3011	J	Transmetues presioni(Pressure Transmitter)	Matja e Gazit	ACS03-330	ACS03-330-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DS III 7MF4033-1FA00-2RB7-Z	N1JN239000082	Ex d	II C	T6/ T4	II 1/2 G	IP 66
573	ACS03-330-PZIT-0060-A	J	Transmetues presioni(Pressure Transmitter)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DS III	N1JN239000085	Ex d	II C	T4/T6	II 1/2 G	IP 66
574	ACS03-330-PZIT-0060-B	J	Transmetues presioni(Pressure Transmitter)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DS III	N1JN239000086	Ex d	II C	T4/T6	II 1/2 G	IP 66
575	ACS03-330-PZIT-0060-C	J	Transmetues presioni(Pressure Transmitter)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DS III	N1JN239000087	Ex d	II C	T4/T6	II 1/2 G	IP 66
576	ACS03-330-SDX01	J	Detektor Tymi (Smoke Detector)	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	HOCHIKI	SLR-E-IS	N/A	Ex ia	II C	T5	II 1 G	N/A
577	ACS03-330-SDX02	J	Detektor Tymi (Smoke Detector)	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	HOCHIKI	SLR-E-IS	N/A	Ex ia	II C	T5	II 1 G	N/A
578	ACS03-330-SSV-0040-JB2	E	Kuti Shperndarese Slam Shut Valve Heater (Junction Box)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8150/1-0176-0116-091-3311	18440771/10110004	Ex e	II C	T6	II 2 G	IP 66
579	ACS03-330-TIT-1001	J	Transmetues Temperature (Temperature Transmitter)	Matja e Gazit	ACS03-330	ACS03-330-0100	ACS03-C1448.4005-330-A-DEB-0001	Zone 2	HONEYWELL	STT850-T-0-C-CHB-11C-B-11A0-MD,F1-0000	C4000005418341	Ex ia	II C	T4	II 1 G	IP 66/67
580	ACS03-330-TIT-1002	J	Transmetues Temperature (Temperature Transmitter)	Matja e Gazit	ACS03-330	ACS03-330-0100	ACS03-C1448.4005-330-A-DEB-0001	Zone 2	HONEYWELL	STT850-T-0-C-CHB-11C-B-11A0-MD,F1-0000	C4000005418350	Ex ia	II C	T4	II 1 G	IP 66/67
581	ACS03-330-TIT-2001	J	Transmetues Temperature (Temperature Transmitter)	Matja e Gazit	ACS03-330	ACS03-330-0200	ACS03-C1448.4005-330-A-DEB-0001	Zone 2	HONEYWELL	STT850-T-0-C-CHB-11C-B-11A0-MD,F1-0000	C4000005418335	Ex ia	II C	T4	II 1 G	IP 66/67
582	ACS03-330-TIT-2002	J	Transmetues Temperature (Temperature Transmitter)	Matja e Gazit	ACS03-330	ACS03-330-0200	ACS03-C1448.4005-330-A-DEB-0001	Zone 2	HONEYWELL	STT850-T-0-C-CHB-11C-B-11A0-MD,F1-0000	C4000005418345	Ex ia	II C	T4	II 1 G	IP 66/67
583	ACS03-330-TIT-3001	J	Transmetues Temperature (Temperature Transmitter)	Matja e Gazit	ACS03-330	ACS03-330-0300	ACS03-C1448.4005-330-A-DEB-0001	Zone 2	HONEYWELL	STT850-T-0-C-CHB-11C-B-11A0-MD,F1-0000	C4000005418339	Ex ia	II C	T4	II 1 G	IP 66/67
584	ACS03-330-TIT-3002	J	Transmetues Temperature (Temperature Transmitter)	Matja e Gazit	ACS03-330	ACS03-330-0300	ACS03-C1448.4005-330-A-DEB-0001	Zone 2	HONEYWELL	STT850-T-0-C-CHB-11C-B-11A0-MD,F1-0000	C4000005418334	Ex ia	II C	T4	II 1 G	IP 66/67
585	ACS03-330-TTX01	J	Transmetues Temperature (Temperature Transmitter)	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	CORTEM	SL-16.1	17/325417	Ex d	II C	T6	II 2 G	IP66/77
586	ACS03-330-XFX01	E	Ventilator 1 (Fan 1)	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	RAEL	TUBE 56B 4	102585	Ex d	II C	T5	II 2 G	IP 55
587	ACS03-330-XFX02	E	Ventilator 2 (Fan 2)	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	RAEL	TUBE 56B 4	102581	Ex d	II C	T5	II 2 G	IP 55
588	ACS03-330-YV0002	J	Soleniod Valve	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	GSR	K0592430	N/A	Ex e m	II C	T4	II 2 G	N/A
589	ACS03-330-YV0003	J	Soleniod Valve	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	GSR	K0596010	N/A	Ex e m	II C	T4	II 2 G	N/A

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
590	ACS03-330-YV0004	J	Solenoid Valve	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	GSR	K0596010	N/A, S.N: GP1710196	Ex e m	II C	T4	II 2 G	N/A
591	ACS03-330-YV-0020	J	Valvul Solenoid (Solenoid Valve)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	61370/1	Ex e m / Ex eb mb	II C	T4	II 2 G	IP 66
592	ACS03-330-YV-0021	J	Valvul Solenoid (Solenoid Valve)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m / Ex eb mb	II C	T4	II 2 G	IP 66
593	ACS03-330-YZV-0020	J	Valvul Solenoid (Solenoid Valve)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	61370/1	Ex e m	II C	T4	II 2 G	IP 66
594	ACS03-330-YZV-0021	J	Valvul Solenoid (Solenoid Valve)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
595	ACS03-330-ZSC/O-0010	J	Celesa fundor (Limit Switches)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	WESTLOCK	ACCUTRAK	258038-1 029	Ex ia	II C	T6	II 1/2 G	IP 66/67
596	ACS03-330-ZSC/O-0020	J	Celesa fundor (Limit Switches)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GISMORGS2PN2P5S2DW	37198 / S.N: 41504	Ex ia	II C	T6/T1	II 2 G	IP 66/67
597	ACS03-330-ZSC/O-0021	J	Celesa fundor (Limit Switches)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P552	37382	Ex ia	II C	T6/T1	II 2 G	IP 66/67
598	ACS03-330-ZSC/O-0040 / ACS03-330-SSV-040_jb1	J	Celesa fundor (Limit Switches)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-330-P-DPE-0001	Zone 2	STAHL	8150/2-0176-0176-091-3311	17440018/2011000	Ex ia ib	II C	T6	II 2 G	IP 66
599	ACS03-330-ZSC/O-0070	J	Celesa fundor (Limit Switches)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-330-P-DPE-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P552	37382	Ex ia	II C	T6/T1	II 2 G	IP 66/67
600	ACS03-330-ZSC/O-1010	J	Celesa fundor (Limit Switches)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0400	ACS03-C1448-856-J-DJA-0001	Zone 2	WESTLOCK	ACCUTRAK 3347RBYS00023ECU-AR1	308325-1 001	Ex ia	II C	T6	II 1 G	IP 66/67
601	ACS03-330-ZSC/O-1020	J	Celesa fundor (Limit Switches)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	SOLDO	SS3A22E-20B11A6	IT03B0004144	Ex ia	II C	T4 / T6	II 2 G	IP 66/67
602	ACS03-330-ZSC/O-2010	J	Celesa fundor (Limit Switches)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0400	ACS03-C1448-856-J-DJA-0001	Zone 2	WESTLOCK	ACCUTRAK 3347RBYS00023ECU-AR1	258036-1 048	Ex ia	II C	T6 / T4	II 1 G	IP 66/67
603	ACS03-330-ZSC/O-2020	J	Celesa fundor (Limit Switches)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	SOLDO	SS3A22E-20B11A6	IT03B0004144	Ex ia	II C	T4 / T6	II 2 G	IP 66/67
604	ACS03-330-ZSC/O-3010	J	Celesa fundor (Limit Switches)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS03-310	ACS03-310-0400	ACS03-C1448-856-J-DJA-0001	Zone 2	WESTLOCK	ACCUTRAK 3347RBYS00023ECU-AR1	256038-1 026	Ex ia	II C	T6	II 1 G	IP 66/67
605	ACS03-330-ZSC/O-3020	J	Celesa fundor (Limit Switches)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	SOLDO	SS3A22E-20B11A6	IT03B0004144	Ex ia	II C	T4 / T6	II 2 G	IP 66/67
606	ACS03-350-I-1101	J	Celes Vibrimi (Celes Vibrimi (Vibration Switch))	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-1020-350-M-DMA-0001 ACS03-C1448-820-E-DEA-0002	Zone 2	METRIX	5550-931-241-C5M	707602	Ex d	II B + H2	T6	II 2 G	IP 66
607	ACS03-350-I-1102	J	Celes Vibrimi (Vibration Switch)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-1020-350-M-DMA-0001 ACS03-C1448-820-E-DEA-0002	Zone 2	METRIX	5550-931-241-C5M	707594	Ex d	II B + H2	T6	II 2 G	IP 66
608	ACS03-350-I-1103	J	Celes Vibrimi (Vibration Switch)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-1020-350-M-DMA-0001 ACS03-C1448-820-E-DEA-0002	Zone 2	METRIX	5550-931-241-C5M		Ex d	II B + H2	T6	II 2 G	IP 66
609	ACS03-350-I-1201	J	Celes Vibrimi (Vibration Switch)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-1020-350-M-DMA-0001 ACS03-C1448-820-E-DEA-0002	Zone 2	METRIX	5550-931-241-C5M	707564	Ex d	II B + H2	T6	II 2 G	IP 66
610	ACS03-350-I-1202	J	Celes Vibrimi (Vibration Switch)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-1020-350-M-DMA-0001 ACS03-C1448-820-E-DEA-0002	Zone 2	METRIX	5550-931-241-C5M	707574	Ex d	II B + H2	T6	II 2 G	IP 66
611	ACS03-350-I-1203	J	Celes Vibrimi (Vibration Switch)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-1020-350-M-DMA-0001 ACS03-C1448-820-E-DEA-0002	Zone 2	METRIX	5550-931-241-C5M	707610	Ex d	II B + H2	T6	II 2 G	IP 66
612	ACS03-350-I-1301	J	Celes Vibrimi (Vibration Switch)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-1020-350-M-DMA-0001 ACS03-C1448-820-E-DEA-0002	Zone 2	METRIX	5550-931-241-C5M	707586	Ex d	II B + H2	T6	II 2 G	IP 66
613	ACS03-350-I-1302	J	Celes Vibrimi (Vibration Switch)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-1020-350-M-DMA-0001 ACS03-C1448-820-E-DEA-0002	Zone 2	METRIX	5550-931-241-C5M	777987	Ex d	II B + H2	T6	II 2 G	IP 66
614	ACS03-350-I-1303	J	Celes Vibrimi (Vibration Switch)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-1020-350-M-DMA-0001 ACS03-C1448-820-E-DEA-0002	Zone 2	METRIX	5550-931-241-C5M	707570	Ex d	II B + H2	T6	II 2 G	IP 66
615	ACS03-350-I-1401	J	Celes Vibrimi (Vibration Switch)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-1020-350-M-DMA-0001 ACS03-C1448-820-E-DEA-0002	Zone 2	METRIX	5550-931-241-C5M	707577	Ex d	II B + H2	T6	II 2 G	IP 66
616	ACS03-350-I-1402	J	Celes Vibrimi (Vibration Switch)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-1020-350-M-DMA-0001 ACS03-C1448-820-E-DEA-0002	Zone 2	METRIX	5550-931-241-C5M	S.N: 707568	Ex d	II B + H2	T6	II 2 G	IP 66
617	ACS03-350-I-1403	J	Celes Vibrimi (Vibration Switch)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-1020-350-M-DMA-0001 ACS03-C1448-820-E-DEA-0002	Zone 2	METRIX	5550-931-241-C5M	707567	Ex d	II B + H2	T6	II 2 G	IP 66
618	ACS03-350-I-1501	J	Celes Vibrimi (Vibration Switch)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-1020-350-M-DMA-0001 ACS03-C1448-820-E-DEA-0002	Zone 2	METRIX	5550-931-241-C5M	707566	Ex d	II B + H2	T6	II 2 G	IP 66
619	ACS03-350-I-1502	J	Celes Vibrimi (Vibration Switch)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-1020-350-M-DMA-0001 ACS03-C1448-820-E-DEA-0002	Zone 2	METRIX	5550-931-241-C5M	707563	Ex d	II B + H2	T6	II 2 G	IP 66
620	ACS03-350-I-1503	J	Celes Vibrimi (Vibration Switch)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-1020-350-M-DMA-0001 ACS03-C1448-820-E-DEA-0002	Zone 2	METRIX	5550-931-241-C5M	707583	Ex d	II B + H2	T6	II 2 G	IP 66
621	ACS03-350-I-2101	J	Celes Vibrimi (Vibration Switch)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-1020-350-M-DMA-0002 ACS03-C1448-820-E-DEA-0002	Zone 2	METRIX	5550-931-241-C5M	707596	Ex d	II B + H2	T6	II 2 G	IP 66
622	ACS03-350-I-2102	J	Celes Vibrimi (Vibration Switch)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-1020-350-M-DMA-0002 ACS03-C1448-820-E-DEA-0002	Zone 2	METRIX	5550-931-241-C5M	707603	Ex d	II B + H2	T6	II 2 G	IP 66
623	ACS03-350-I-2103	J	Celes Vibrimi (Vibration Switch)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-1020-350-M-DMA-0002 ACS03-C1448-820-E-DEA-0002	Zone 2	METRIX	5550-931-241-C5M	777985	Ex d	II B + H2	T6	II 2 G	IP 66
624	ACS03-350-I-2201	J	Celes Vibrimi (Vibration Switch)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-1020-350-M-DMA-0002 ACS03-C1448-820-E-DEA-0002	Zone 2	METRIX	5550-931-241-C5M	705580	Ex d	II B + H2	T6	II 2 G	IP 66
625	ACS03-350-I-2202	J	Celes Vibrimi (Vibration Switch)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-1020-350-M-DMA-0002 ACS03-C1448-820-E-DEA-0002	Zone 2	METRIX	5550-931-241-C5M	707579	Ex d	II B + H2	T6	II 2 G	IP 66
626	ACS03-350-I-2203	J	Celes Vibrimi (Vibration Switch)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-1020-350-M-DMA-0002 ACS03-C1448-820-E-DEA-0002	Zone 2	METRIX	5550-931-241-C5M	707582	Ex d	II B + H2	T6	II 2 G	IP 66

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
627	ACS03-350-I-2301	J	Celes Vibrimi (Vibration Switch)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448.1020-350-M-DMA-0002 ACS03-C1448-820-E-DEA-0002	Zone 2	METRIX	5550-931-241-C5M	707569	Ex d	II B + H2	T6	II 2 G	IP 66
628	ACS03-350-I-2302	J	Celes Vibrimi (Vibration Switch)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448.1020-350-M-DMA-0002 ACS03-C1448-820-E-DEA-0002	Zone 2	METRIX	5550-931-241-C5M	707609	Ex d	II B + H2	T6	II 2 G	IP 66
629	ACS03-350-I-2303	J	Celes Vibrimi (Vibration Switch)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448.1020-350-M-DMA-0002 ACS03-C1448-820-E-DEA-0002	Zone 2	METRIX	5550-931-241-C5M	707572	Ex d	II B + H2	T6	II 2 G	IP 66
630	ACS03-350-I-2401	J	Celes Vibrimi (Vibration Switch)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448.1020-350-M-DMA-0002 ACS03-C1448-820-E-DEA-0002	Zone 2	METRIX	5550-931-241-C5M	707598	Ex d	II B + H2	T6	II 2 G	IP 66
631	ACS03-350-I-2402	J	Celes Vibrimi (Vibration Switch)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448.1020-350-M-DMA-0002 ACS03-C1448-820-E-DEA-0002	Zone 2	METRIX	5550-931-241-C5M	707587	Ex d	II B + H2	T6	II 2 G	IP 66
632	ACS03-350-I-2403	J	Celes Vibrimi (Vibration Switch)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448.1020-350-M-DMA-0002 ACS03-C1448-820-E-DEA-0002	Zone 2	METRIX	5550-931-241-C5M	707590	Ex d	II B + H2	T6	II 2 G	IP 66
633	ACS03-350-JB-0101	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222205	Ex e	II C	T6	II 2 G	IP 66
634	ACS03-350-JB-1001	J	Kuti Shperndarese (Junction Box)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222158	Ex ia	II C	T6	II 2 G	IP 66
635	ACS03-350-JB-1002	J	Kuti Shperndarese (Junction Box)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222165	Ex ia	II C	T6	II 2 G	IP 66
636	ACS03-350-JB-1003	J	Kuti Shperndarese (Junction Box)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222156	Ex ia	II C	T6	II 2 G	IP 66
637	ACS03-350-JB-1004	J	Kuti Shperndarese (Junction Box)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222152	Ex ia	II C	T6	II 2 G	IP 66
638	ACS03-350-JB-1005	J	Kuti Shperndarese (Junction Box)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222163	Ex ia	II C	T6	II 2 G	IP 66
639	ACS03-350-M-1101	E	Motorr Elektrik (Electrical Motor)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-320-E-DEA-0002	Zone 2	CEMP	AB70r 225ML8	1703578011Y17	Ex d	II B	T4	II 2 G	IP 55
640	ACS03-350-M-1102	E	Motorr Elektrik (Electrical Motor)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-320-E-DEA-0002	Zone 2	CEMP	AB70r 225ML8	1703578010Y17	Ex d	II B	T4	II 2 G	IP 55
641	ACS03-350-M-1103	E	Motorr Elektrik (Electrical Motor)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-320-E-DEA-0002	Zone 2	CEMP	AB70r 225ML8	S.N: 1703578014Y17	Ex d	II B	T4	II 2 G	IP 55
642	ACS03-350-M-1201	E	Motorr Elektrik (Electrical Motor)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-320-E-DEA-0002	Zone 2	CEMP	AB70r 225ML8	1703578002Y17	Ex d	II B	T4	II 2 G	IP 55
643	ACS03-350-M-1202	E	Motorr Elektrik (Electrical Motor)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-320-E-DEA-0002	Zone 2	CEMP	AB70r 225ML8	1703578012Y17	Ex d	II B	T4	II 2 G	IP 55
644	ACS03-350-M-1203	E	Motorr Elektrik (Electrical Motor)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-320-E-DEA-0002	Zone 2	CEMP	AB70r 225ML8	1703578007Y17	Ex d	II B	T4	II 2 G	IP 55
645	ACS03-350-M-1301	E	Motorr Elektrik (Electrical Motor)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-320-E-DEA-0002	Zone 2	CEMP	AB70r 225ML8	1703578003Y17	Ex d	II B	T4	II 2 G	IP 55
646	ACS03-350-M-1302	E	Motorr Elektrik (Electrical Motor)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-320-E-DEA-0002	Zone 2	CEMP	AB70r 225ML8	1703578013Y17	Ex d	II B	T4	II 2 G	IP 55
647	ACS03-350-M-1303	E	Motorr Elektrik (Electrical Motor)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-320-E-DEA-0002	Zone 2	CEMP	AB70r 225ML8	1703578004Y17	Ex d	II B	T4	II 2 G	IP 55
648	ACS03-350-M-1401	E	Motorr Elektrik (Electrical Motor)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-320-E-DEA-0002	Zone 2	CEMP	AB70r 225ML8	1703578008Y17	Ex d	II B	T4	II 2 G	IP 55
649	ACS03-350-M-1402	E	Motorr Elektrik (Electrical Motor)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-320-E-DEA-0002	Zone 2	CEMP	AB70r 225ML8	1703578015Y17	Ex d	II B	T4	II 2 G	IP 55
650	ACS03-350-M-1403	E	Motorr Elektrik (Electrical Motor)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-320-E-DEA-0002	Zone 2	CEMP	AB70r 225ML8	1703578009Y17	Ex d	II B	T4	II 2 G	IP 55
651	ACS03-350-M-1501	E	Motorr Elektrik (Electrical Motor)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-320-E-DEA-0002	Zone 2	CEMP	AB70r 225ML8	1703578006Y17	Ex d	II B	T4	II 2 G	IP 55
652	ACS03-350-M-1502	E	Motorr Elektrik (Electrical Motor)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-320-E-DEA-0002	Zone 2	CEMP	AB70r 225ML8	1703578001Y17	Ex d	II B	T4	II 2 G	IP 55
653	ACS03-350-M-1503	E	Motorr Elektrik (Electrical Motor)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-320-E-DEA-0002	Zone 2	CEMP	AB70r 225ML8	1703578005Y17	Ex d	II B	T4	II 2 G	IP 55
654	ACS03-350-M-2101	E	Motorr Elektrik (Electrical Motor)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-320-E-DEA-0002	Zone 2	CEMP	AB70r 200LC8	1703579002Y17	Ex d	II B	T4	II 2 G	IP 55
655	ACS03-350-M-2102	E	Motorr Elektrik (Electrical Motor)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-320-E-DEA-0002	Zone 2	CEMP	AB70r 200LC8	1703579006Y17	Ex d	II B	T4	II 2 G	IP 55
656	ACS03-350-M-2103	E	Motorr Elektrik (Electrical Motor)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-320-E-DEA-0002	Zone 2	CEMP	AB70r 200LC8	1703579003Y17	Ex d	II B	T4	II 2 G	IP 55
657	ACS03-350-M-2201	E	Motorr Elektrik (Electrical Motor)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-320-E-DEA-0002	Zone 2	CEMP	AB70r 200LC8	1703579007Y17	Ex d	II B	T4	II 2 G	IP 55
658	ACS03-350-M-2202	E	Motorr Elektrik (Electrical Motor)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-320-E-DEA-0002	Zone 2	CEMP	AB70r 200LC8	1703579001Y17	Ex d	II B	T4	II 2 G	IP 55
659	ACS03-350-M-2203	E	Motorr Elektrik (Electrical Motor)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-320-E-DEA-0002	Zone 2	CEMP	AB70r 200LC8	1703579008Y17	Ex d	II B	T4	II 2 G	IP 55
660	ACS03-350-M-2301	E	Motorr Elektrik (Electrical Motor)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-320-E-DEA-0002	Zone 2	CEMP	AB70r 200LC8	1703579009Y17	Ex d	II B	T4	II 2 G	IP 55
661	ACS03-350-M-2302	E	Motorr Elektrik (Electrical Motor)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-320-E-DEA-0002	Zone 2	CEMP	AB70r 200LC8	1703579012Y17	Ex d	II B	T4	II 2 G	IP 55
662	ACS03-350-M-2303	E	Motorr Elektrik (Electrical Motor)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-320-E-DEA-0002	Zone 2	CEMP	AB70r 200LC8	1703579010Y17	Ex d	II B	T4	II 2 G	IP 55
663	ACS03-350-M-2401	E	Motorr Elektrik (Electrical Motor)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-320-E-DEA-0002	Zone 2	CEMP	AB70r 200LC8	1703579005Y17	Ex d	II B	T4	II 2 G	IP 55

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
664	ACS03-350-M-2402	E	Motorr Elektrik (Electrical Motor)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-320-E-DEA-0002	Zone 2	CEMP	AB70r 200LC8	1703579004Y17	Ex d	II B	T4	II 2 G	IP 55
665	ACS03-350-M-2403	E	Motorr Elektrik (Electrical Motor)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0300	ACS03-C1448-320-E-DEA-0002	Zone 2	CEMP	AB70r 200LC8	1703579011Y17	Ex d	II B	T4	II 2 G	IP 55
666	ACS03-350-MV-1110	E	Valvul e motorrizuar (Motor Operated Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	AUMA	SAEX 07.2-F10/-a3a1	2617MD54519	Ex de	II C	T3	II 2 G	IP 68
667	ACS03-350-MV-1116	E	Valvul e motorrizuar (Motor Operated Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	AUMA	SAEX 07.2-F10/-a3a1	2617MD54520	Ex de	II C	T3	II 2 G	IP 68
668	ACS03-350-MV-1150	E	Valvul e motorrizuar (Motor Operated Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	AUMA	SAEX 07.2-F10/-a3a1	2617MD54521	Ex de	II C	T3	II 2 G	IP 68
669	ACS03-350-MV-1156	E	Valvul e motorrizuar (Motor Operated Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	AUMA	SAEX 07.2-F10/-a3a1	2617MD54522	Ex de	II C	T3	II 2 G	IP 68
670	ACS03-350-MV-1210	E	Valvul e motorrizuar (Motor Operated Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	AUMA	SAEX 07.2-F10/-a3a1	2617MD54523	Ex de	II C	T3	II 2 G	IP 68
671	ACS03-350-MV-1216	E	Valvul e motorrizuar (Motor Operated Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	AUMA	SAEX 07.2-F10/-a3a1	2617MD54524	Ex de	II C	T3	II 2 G	IP 68
672	ACS03-350-MV-1250	E	Valvul e motorrizuar (Motor Operated Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	AUMA	SAEX 07.2-F10/-a3a1	2617MD54525	Ex de	II C	T3	II 2 G	IP 68
673	ACS03-350-MV-1256	E	Valvul e motorrizuar (Motor Operated Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	AUMA	SAEX 07.2-F10/-a3a1	2617MD54526	Ex de	II C	T3	II 2 G	IP 68
674	ACS03-350-MV-1310	E	Valvul e motorrizuar (Motor Operated Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	AUMA	SAEX 07.2-F10/-a3a1	2617MD54527	Ex de	II C	T3	II 2 G	IP 68
675	ACS03-350-MV-1316	E	Valvul e motorrizuar (Motor Operated Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	AUMA	SAEX 07.2-F10/-a3a1	2617MD54528	Ex de	II C	T3	II 2 G	IP 68
676	ACS03-350-MV-1350	E	Valvul e motorrizuar (Motor Operated Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	AUMA	SAEX 07.2-F10/-a3a1	2617MD54529	Ex de	II C	T3	II 2 G	IP 68
677	ACS03-350-MV-1356	E	Valvul e motorrizuar (Motor Operated Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	AUMA	SAEX 07.2-F10/-a3a1	2617MD54530	Ex de	II C	T3	II 2 G	IP 68
678	ACS03-350-MV-1410	E	Valvul e motorrizuar (Motor Operated Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	AUMA	SAEX 07.2-F10/-a3a1	2617MD54531	Ex de	II C	T3	II 2 G	IP 68
679	ACS03-350-MV-1416	E	Valvul e motorrizuar (Motor Operated Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	AUMA	SAEX 07.2-F10/-a3a1	2617MD54532	Ex de	II C	T3	II 2 G	IP 68
680	ACS03-350-MV-1450	E	Valvul e motorrizuar (Motor Operated Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	AUMA	SAEX 07.2-F10/-a3a1	2617MD54533	Ex de	II C	T3	II 2 G	IP 68
681	ACS03-350-MV-1456	E	Valvul e motorrizuar (Motor Operated Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	AUMA	SAEX 07.2-F10/-a3a1	2617MD54534	Ex de	II C	T3	II 2 G	IP 68
682	ACS03-350-MV-1510	E	Valvul e motorrizuar (Motor Operated Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	AUMA	SAEX 07.2-F10/-a3a1	2617MD54535	Ex de	II C	T3	II 2 G	IP 68
683	ACS03-350-MV-1516	E	Valvul e motorrizuar (Motor Operated Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	AUMA	SAEX 07.2-F10/-a3a1	2617MD54536	Ex de	II C	T3	II 2 G	IP 68
684	ACS03-350-MV-1550	E	Valvul e motorrizuar (Motor Operated Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	AUMA	SAEX 07.2-F10/-a3a1	2617MD54537	Ex de	II C	T3	II 2 G	IP 68
685	ACS03-350-MV-1556	E	Valvul e motorrizuar (Motor Operated Valve)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	AUMA	SAEX 07.2-F10/-a3a1	2617MD54538	Ex de	II C	T3	II 2 G	IP 68
686	ACS03-350-PIT-1000	J	Transmetues presioni(Pressure Transmitter)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0400	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DS III	N1JN239000094	Ex d	II C	T4/T6	II 1/2 G	IP 66
687	ACS03-350-TIT-1001	J	Transmetues Temperature (Temperature Transmitter)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0400	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS TH300	N1JN004479	Ex d	II C	T6	II 1/2 G	IP 65
688	ACS03-350-TIT-1003	J	Transmetues Temperature (Temperature Transmitter)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0400	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS TH300	N1JN004480	Ex d	II C	T6	II 1/2 G	IP 65
689	ACS03-350-TIT-2002	J	Transmetues Temperature (Temperature Transmitter)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS TH300	N1JN004481	Ex d	II C	T6	II 1/2 G	IP 65
690	ACS03-350-TIT-2003	J	Transmetues Temperature (Temperature Transmitter)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS TH300	N1JN004482	Ex d	II C	T6	II 1/2 G	IP 65
691	ACS03-350-TZIT-1000-A	J	Transmetues Temperature (Temperature Transmitter)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0400	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS TH300	N1JN004460	Ex d	II C	T6	II 1/2 G	IP 65
692	ACS03-350-TZIT-1000-B	J	Transmetues Temperature (Temperature Transmitter)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0400	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS TH300	N1JN004461	Ex d	II C	T6	II 1/2 G	IP 65
693	ACS03-350-TZIT-1000-C	J	Transmetues Temperature (Temperature Transmitter)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0400	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS TH300	N1JN004462	Ex d	II C	T6	II 1/2 G	IP 65
694	ACS03-350-TZIT-2001-A	J	Transmetues Temperature (Temperature Transmitter)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS TH300	N1JN004483	Ex d	II C	T6	II 1/2 G	IP 65
695	ACS03-350-TZIT-2001-B	J	Transmetues Temperature (Temperature Transmitter)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS TH300	N1JN004484	Ex d	II C	T6	II 1/2 G	IP 65
696	ACS03-350-TZIT-2001-C	J	Transmetues Temperature (Temperature Transmitter)	Matja e Gazit	ACS03-330	ACS03-330-0600	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS TH300	N1JN004485	Ex d	II C	T6	II 1/2 G	IP 65
697	ACS03-350-ZSC/O-1110	J	Celesa fundor (Limit Switches)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	WESTLOCK	ACCUTRAK	256038-1 065	Ex ia	II C	T6/T1	II 1 G	IP 66/67
698	ACS03-350-ZSC/O-1116	J	Celesa fundor (Limit Switches)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	WESTLOCK	ACCUTRAK	256038-1 063	Ex ia	II C	T6/T1	II 1 G	IP 66/67
699	ACS03-350-ZSC/O-1150	J	Celesa fundor (Limit Switches)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	WESTLOCK	ACCUTRAK	256038-1 032	Ex ia	II C	T6/T1	II 1 G	IP 66/67
700	ACS03-350-ZSC/O-1156	J	Celesa fundor (Limit Switches)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	WESTLOCK	ACCUTRAK	256038-1 041	Ex ia	II C	T6/T1	II 1 G	IP 66/67

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
701	ACS03-350-ZSC/O-1210	J	Celesa fundor (Limit Switches)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	WESTLOCK	ACCUTRAK	256038-1 002	Ex ia	II C	T6/T1	II 1 G	IP 66/67
702	ACS03-350-ZSC/O-1216	J	Celesa fundor (Limit Switches)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	WESTLOCK	ACCUTRAK	256038-1 004	Ex ia	II C	T6/T1	II 1 G	IP 66/67
703	ACS03-350-ZSC/O-1250	J	Celesa fundor (Limit Switches)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	WESTLOCK	ACCUTRAK	256038-1 064	Ex ia	II C	T6/T1	II 1 G	IP 66/67
704	ACS03-350-ZSC/O-1256	J	Celesa fundor (Limit Switches)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	WESTLOCK	ACCUTRAK	256038-1 011	Ex ia	II C	T6/T1	II 1 G	IP 66/67
705	ACS03-350-ZSC/O-1310	J	Celesa fundor (Limit Switches)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	WESTLOCK	ACCUTRAK	256038-1 013	Ex ia	II C	T6/T1	II 1 G	IP 66/67
706	ACS03-350-ZSC/O-1316	J	Celesa fundor (Limit Switches)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	WESTLOCK	ACCUTRAK	256038-1 027	Ex ia	II C	T6/T1	II 1 G	IP 66/67
707	ACS03-350-ZSC/O-1350	J	Celesa fundor (Limit Switches)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	WESTLOCK	ACCUTRAK	256038-1 017	Ex ia	II C	T6/T1	II 1 G	IP 66/67
708	ACS03-350-ZSC/O-1356	J	Celesa fundor (Limit Switches)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	WESTLOCK	ACCUTRAK	256038-1 016	Ex ia	II C	T6/T1	II 1 G	IP 66/67
709	ACS03-350-ZSC/O-1410	J	Celesa fundor (Limit Switches)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	WESTLOCK	ACCUTRAK	256038-1 071	Ex ia	II C	T6/T1	II 1 G	IP 66/67
710	ACS03-350-ZSC/O-1416	J	Celesa fundor (Limit Switches)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	WESTLOCK	ACCUTRAK	256038-1 026	Ex ia	II C	T6/T1	II 1 G	IP 66/67
711	ACS03-350-ZSC/O-1450	J	Celesa fundor (Limit Switches)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	WESTLOCK	ACCUTRAK	256038-1 025	Ex ia	II C	T6/T1	II 1 G	IP 66/67
712	ACS03-350-ZSC/O-1456	J	Celesa fundor (Limit Switches)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	WESTLOCK	ACCUTRAK	256038-1 060	Ex ia	II C	T6/T1	II 1 G	IP 66/67
713	ACS03-350-ZSC/O-1510	J	Celesa fundor (Limit Switches)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	WESTLOCK	ACCUTRAK	256038-1 005	Ex ia	II C	T6/T1	II 1 G	IP 66/67
714	ACS03-350-ZSC/O-1516	J	Celesa fundor (Limit Switches)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	WESTLOCK	ACCUTRAK	256038-1 001	Ex ia	II C	T6/T1	II 1 G	IP 66/67
715	ACS03-350-ZSC/O-1550	J	Celesa fundor (Limit Switches)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	WESTLOCK	ACCUTRAK	256038-1 070	Ex ia	II C	T6/T1	II 1 G	IP 66/67
716	ACS03-350-ZSC/O-1556	J	Celesa fundor (Limit Switches)	Ftohesit e Gazit (GAS COOLERS)	ACS03-350	ACS03-350-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	WESTLOCK	ACCUTRAK	256038-1 040	Ex ia	II C	T6/T1	II 1 G	IP 66/67
717	ACS03-360-HS-0010	J	çeles paneli lokal (Local Panel Hand Switch)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	QUINTEX	CB-P6/16353	64747	Ex db eb	II C	T4	II 2 G	IP 66
718	ACS03-360-HS-0011	J	çeles paneli lokal (Local Panel Hand Switch)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	CORTEM	SA301410/P	17/325338	Ex de	II C	T6	II 2 GD	IP 66
719	ACS03-360-HS-0040	J	çeles paneli lokal (Local Panel Hand Switch)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	QUINTEX	CB-P6/16353	64737	Ex de	II C	T4	II 2 G	IP 66
720	ACS03-360-HS-0041	J	çeles paneli lokal (Local Panel Hand Switch)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	QUINTEX	CB-P6/16353	64729	Ex de / Ex db eb	II C	T4	II 2 G	IP 66
721	ACS03-360-HS-0070	J	Celes Manual (Hand Switch)	FUEL GAS	ACS03-534	ACS03-534-0400	ACS03-C1448-856-J-DJA-0001	Zone 2	QUINTEX	CB-P6/16353	64753	Ex de	II C	T4	II 2 G	IP 66
722	ACS03-360-HS-0080	J	çeles paneli lokal (Local Panel Hand Switch)	CENTRAL HEATING SYSTEMS	ACS03-552	ACS03-552-1100	ACS03-C1448-856-J-DJA-0001	Zone 2	QUINTEX	CB-P6/16353	64709	Ex de	II C	T4	II 2 G	IP 66
723	ACS03-360-HS-1030	J	çeles paneli lokal (Local Panel Hand Switch)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	QUINTEX	CB-P6/16353	64750	Ex db eb	II C	T4	II 2 G	IP 66
724	ACS03-360-HS-1031	J	çeles paneli lokal (Local Panel Hand Switch)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	CORTEM	SA301410/P	17/325338	Ex de	II C	T6	II 2 GD	IP 66
725	ACS03-360-HS-2030	J	çeles paneli lokal (Local Panel Hand Switch)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	QUINTEX	CB-P6/16353	64718	Ex de	II C	T4	II 2 G	IP 66
726	ACS03-360-HS-2031	J	çeles paneli lokal (Local Panel Hand Switch)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	CORTEM	SA301410/P	17/325338	Ex de	II C	T6	II 2 GD	IP 66
727	ACS03-360-JB-0001	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222200	Ex e	II C	T6	II 2 GD	IP 66
728	ACS03-360-JB-0002	J	Instrumentation Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224523	Ex e	II C	T6	II 2 G	IP 66
729	ACS03-360-JB-0100	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222203	Ex e	II C	T6	II 2 GD	IP 66
730	ACS03-360-JB-0200	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222188	Ex e	II C	T6	II 2 GD	IP 66
731	ACS03-360-JB-0201	J	Instrumentation Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224533	Ex e	II C	T6	II 2 G	IP 66
732	ACS03-360-JB-0202	J	Kuti Shperndarese (Junction Box)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222190	Ex e	II C	T6	II 2 GD	IP 66
733	ACS03-360-JB-1001	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222161	Ex ia	II C	T6	II 2 G	IP 66
734	ACS03-360-JB-1002	J	Kuti Shperndarese (Junction Box)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222153	Ex ia	II C	T6	II 2 GD	IP 66
735	ACS03-360-JB-1003	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222162	Ex ia	II C	T6	II 2 GD	IP 66
736	ACS03-360-JB-1004	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222164	Ex ia	II C	T6	II 2 Gb	IP 66
737	ACS03-360-JB-1005	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224552	Ex ia	II C	T6	II 2 Gb	IP 66

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
738	ACS03-360-MCV-0051	E	Motor Operated Control Valve	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	AUMA	D-79379	2617MD55058	Ex de	II C	T3	II 2 G	IP 68
739	ACS03-360-MV-0020	E	Valvul e motorizuar (Motor Operated Valve)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	AUMA	SAEX 14.2-F14/-a3a1	2617MD54998 / S.N.: 3717MD73233	Ex de	II C	T3	II 2 G	IP 68
740	ACS03-360-MV-0021	E	Valvul e motorizuar (Motor Operated Valve)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	AUMA	SAEX 07.2-F10/-a3a1	3717MD72510	Ex de	II C	T3	II 2 G	IP 68 / IP x
741	ACS03-360-MV-0030	E	Valvul e motorizuar (Motor Operated Valve)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	AUMA	SAEX 10.2-F14/-a3a1	2717MD56402	Ex de	II C	T3	II 2 G	IP 68
742	ACS03-360-MV-0031	E	Valvul e motorizuar (Motor Operated Valve)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	AUMA	SAEX 07.2-F10/-a3a1	3717MD72505	Ex de	II C	T3	II 2 G	IP 68
743	ACS03-360-PDIT-0010	J	Transmetues presioni(Pressure Transmitter)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300		Zone 2	SIEMENS	SITRANS P DS III 7MF4433-1GA02-2RB7-Z	N1JN239120100	Ex d	II C	T6/ T4	II 1/2 G	IP 66
744	ACS03-360-PDIT-0020	J	Transmetues presioni(Pressure Transmitter)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300		Zone 2	SIEMENS	SITRANS P DS III 7MF4433-1GA02-2RB7-Z	N1JN239120101	Ex d	II C	T6/ T4	II 1/2 G	IP 66
745	ACS03-360-PDIT-0030	J	Transmetues presioni(Pressure Transmitter)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DS III 7MF4433-1GA02-2RB7-Z	N1JN239120072	Ex d	II C	T6/ T4	II 1/2 G	IP 66
746	ACS03-360-PDIT-0040	J	Transmetues presioni(Pressure Transmitter)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DS III 7MF4433-1GA02-2RB7-Z	N1JN239120073	Ex d	II C	T6/ T4	II 1/2 G	IP 66
747	ACS03-360-PDIT-1030	J	Transmetues presioni(Pressure Transmitter)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DS III 7MF4433-1GA02-2RB7-Z	N1JN239120074	Ex d	II C	T6/ T4	II 1/2 G	IP 66
748	ACS03-360-PDIT-2030	J	Transmetues presioni(Pressure Transmitter)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1JN239120075	Ex d	II C	T4/T6	II 1/2 G	IP 66
749	ACS03-360-PIT-0001	J	Transmetues presioni(Pressure Transmitter)	CENTRAL HEATING SYSTEMS	ACS03-552	ACS03-552-1100	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1JN239120071	Ex d	II C	T4/T6	II 1/2 G	IP 66
750	ACS03-360-PIT-0027	J	Transmetues presioni(Pressure Transmitter)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DS III 7MF4433-1GA02-2RB7-Z	N1JN239000083	Ex d	II C	T6/ T4	II 1/2 G	IP 66
751	ACS03-360-PIT-0070	J	Transmetues presioni(Pressure Transmitter)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DS III 7MF4033-1FA00-2RB7-Z	N1JN239000095	Ex d	II C	T6/ T4	II 1/2 G	IP 66
752	ACS03-360-PIT-2027	J	Transmetues presioni(Pressure Transmitter)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1JN239000096	Ex d	II C	T4/T6	II 1/2 G	IP 66
753	ACS03-360-PZIT-0060-A	J	Transmetues presioni(Pressure Transmitter)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1JN239000102	Ex d	II C	T4/T6	II 1/2 G	IP 66
754	ACS03-360-PZIT-0060-B	J	Transmetues presioni(Pressure Transmitter)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1JN239000103	Ex d	II C	T4/T6	II 1/2 G	IP 66
755	ACS03-360-PZIT-0060-C	J	Transmetues presioni(Pressure Transmitter)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1JN239000104	Ex d	II C	T4/T6	II 1/2 G	IP 66
756	ACS03-360-PZIT-1050-A	J	Transmetues presioni(Pressure Transmitter)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DS III 7MF4033-1FA00-2RB7-Z	N1JN239000088	Ex d	II C	T6/ T4	II 1/2 G	IP 66
757	ACS03-360-PZIT-1050-B	J	Transmetues presioni(Pressure Transmitter)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DS III 7MF4033-1FA00-2RB7-Z	N1JN239000089	Ex d	II C	T6/ T4	II 1/2 G	IP 66
758	ACS03-360-PZIT-1050-C	J	Transmetues presioni(Pressure Transmitter)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DS III 7MF4033-1FA00-2RB7-Z	N1JN239000090	Ex d	II C	T6/ T4	II 1/2 G	IP 66
759	ACS03-360-PZIT-2050-A	J	Transmetues presioni(Pressure Transmitter)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DS III 7MF4033-1FA00-2RB7-Z	N1JN239000091	Ex d	II C	T6	II 1/2 G	IP 66
760	ACS03-360-PZIT-2050-B	J	Transmetues presioni(Pressure Transmitter)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DS III 7MF4033-1FA00-2RB7-Z	N1JN239000092	Ex d	II C	T6	II 1/2 G	IP 66
761	ACS03-360-PZIT-2050-C	J	Transmetues presioni(Pressure Transmitter)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DS III 7MF4033-1FA00-2RB7-Z	N1JN239000093	Ex d	II C	T6	II 1/2 G	IP 66
762	ACS03-360-SSV-1020-JB2	E	Kuti Shperndarese Slam Shut Valve Heater (Junction Box)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8150/1-0176-0116-091-3311	18440771/10110002	Ex e	II C	T6	II 2 G	IP 66
763	ACS03-360-SSV-2020-JB2	E	Kuti Shperndarese Slam Shut Valve Heater (Junction Box)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8150/1-0176-0116-091-3311	18440771/10110005	Ex e	II C	T6	II 2 G	IP 66
764	ACS03-360-YV-0010	J	Valvul Solenoid (Solenoid Valve)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	61370/1	Ex eb mb	II C	T4	II 2 GD	IP 66 / x8
765	ACS03-360-YV-0011	J	Valvul Solenoid (Solenoid Valve)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	69146/3	Ex eb mb	II C	T4	II 2 GD	IP 66 / x9
766	ACS03-360-YV-0040	J	Valvul Solenoid (Solenoid Valve)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	61370/1	Ex eb mb	II C	T4	II 2 GD	IP 66
767	ACS03-360-YV-0041	J	Valvul Solenoid (Solenoid Valve)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	61370/1	Ex eb mb	II C	T4	II 2 GD	IP 66
768	ACS03-360-YV-0070	J	Valvul Solenoid (Solenoid Valve)	FUEL GAS	ACS03-534	ACS03-534-0400	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	61370/1	Ex e m	II C	T4	II 2 G	IP 66
769	ACS03-360-YV-0080	J	Valvul Solenoid (Solenoid Valve)	CENTRAL HEATING SYSTEMS	ACS03-552	ACS03-552-1100	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	61370/1	Ex e m	II C	T4	II 2 G	IP 66
770	ACS03-360-YV-1030	J	Valvul Solenoid (Solenoid Valve)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	61370/1	Ex eb mb	II C	T4	II 2 GD	IP 66
771	ACS03-360-YV-1031	J	Valvul Solenoid (Solenoid Valve)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex eb mb	II C	T4	II 2 GD	IP 66
772	ACS03-360-YV-2030	J	Valvul Solenoid (Solenoid Valve)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	61370/1	Ex eb mb	II C	T4	II 2 GD	IP 66
773	ACS03-360-YV-2031	J	Valvul Solenoid (Solenoid Valve)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex eb mb	II C	T4	II 2 GD	IP 66
774	ACS03-360-YZV-0010	J	Valvul Solenoid (Solenoid Valve)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	61370/1	Ex eb mb	II C	T4	II 2 GD	IP 66/X8

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
775	ACS03-360-YZV-0011	J	Valvul Solenoid (Solenoid Valve)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex eb mb	II C	T4	II 2 GD	IP 66/X8
776	ACS03-360-YZV-0040	J	Valvul Solenoid (Solenoid Valve)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	61370/1	Ex eb mb	II C	T4	II 2 GD	IP 66/X8
777	ACS03-360-YZV-0041	J	Valvul Solenoid (Solenoid Valve)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	61370/1	Ex eb mb	II C	T4	II 2 GD	IP 66/X8
778	ACS03-360-YZV-0070	J	Valvul Solenoid (Solenoid Valve)	FUEL GAS	ACS03-534	ACS03-534-0400	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	61370/1	Ex eb mb	II C	T4	II 2 GD	IP 66/X8
779	ACS03-360-YZV-0080	J	Valvul Solenoid (Solenoid Valve)	CENTRAL HEATING SYSTEMS	ACS03-552	ACS03-552-1100	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	61370/1	Ex e m	II C	T4	II 2 G	IP 66
780	ACS03-360-YZV-1030	J	Valvul Solenoid (Solenoid Valve)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	61370/1	Ex eb mb	II C	T4	II 2 GD	IP 66/X8
781	ACS03-360-YZV-1031	J	Valvul Solenoid (Solenoid Valve)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex eb mb	II C	T4	II 2 GD	IP 66/X8
782	ACS03-360-YZV-2030	J	Valvul Solenoid (Solenoid Valve)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	61370/1	Ex eb mb	II C	T4	II 2 GD	IP 66/X8
783	ACS03-360-YZV-2031	J	Valvul Solenoid (Solenoid Valve)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex eb mb	II C	T4	II 2 GD	IP 66/X8
784	ACS03-360-ZSC/O-0010	J	Celesa fundor (Limit Switches)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GISMORGS2PN2P5S2DW	37198	Ex ia	II C	T6 / T1	II 1 G	IP 66/67
785	ACS03-360-ZSC/O-0011	J	Celesa fundor (Limit Switches)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P5S2	37382	Ex ia	II C	T6 / T1	II 2 G	IP 66/67
786	ACS03-360-ZSC/O-0020	J	Celesa fundor (Limit Switches)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	WESTLOCK	ACCUTRAK	258038-1 055	Ex ia	II C	T6/T1	II 1/2 G	IP 66/67
787	ACS03-360-ZSC/O-0021	J	Celesa fundor (Limit Switches)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P5S2	37382	Ex ia	II C	T6/T1	II 2 G	IP 66/67
788	ACS03-360-ZSC/O-0030	J	Celesa fundor (Limit Switches)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	WESTLOCK	ACCUTRAK 3347RBYS00023ECU-AR1	256038-1 028	Ex ia	II C	T6 / T1	II 1 G	IP 66/67
789	ACS03-360-ZSC/O-0031	J	Celesa fundor (Limit Switches)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P5S2	37382	Ex ia	II C	T6 / T1	II 2 G	IP 66/67
790	ACS03-360-ZSC/O-0040	J	Celesa fundor (Limit Switches)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GISMORGS2PN2P5S2DW	37198	Ex ia	II C	T6	II 1 G	IP 66/67
791	ACS03-360-ZSC/O-0041	J	Celesa fundor (Limit Switches)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GISMORGS2PN2P5S2DW	37198	Ex ia	II C	T6/T1	II 2 G	IP 66/67
792	ACS03-360-ZSC/O-0051	J	Celesa fundor (Limit Switches)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P5S2	37382	Ex ia	II C	T6/ T1	II 2 G	IP 66/67
793	ACS03-360-ZSC/O-0070	J	Celesa fundor (Limit Switches)	FUEL GAS	ACS03-534	ACS03-534-0400	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GISMORGS2PN2P5S2DW	37198	Ex ia	II C	T6/T1	II 2 G	IP 66/67
794	ACS03-360-ZSC/O-0080	J	Celesa fundor (Limit Switches)	CENTRAL HEATING SYSTEMS	ACS03-552	ACS03-552-1100	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GISMORGS2PN2P5S2DW	37198	Ex ia	II C	T6/T1	II 2 G	IP 66/67
795	ACS03-360-ZSC/O-1020	J	Celes Fundor (Celes Fundor i mbyllur (Limit Switch Close) & Open)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	STAHL	8150/2-0176-0176-091-3311	17440018/1011000	Ex ia ib	II C	T6	II 2 G	IP 66
796	ACS03-360-ZSC/O-1030	J	Celesa fundor (Limit Switches)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GISMORGS2PN2P5S2DW	37198	Ex ia	II C	T6/T1	II 2 G	IP 66/67
797	ACS03-360-ZSC/O-1031	J	Celesa fundor (Limit Switches)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P5S2	37382	Ex ia	II C	T6/ T1	II 2 G	IP 66/67
798	ACS03-360-ZSC/O-2020	J	Celes Fundor (Celes Fundor i mbyllur (Limit Switch Close) & Open)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	STAHL	8150/2-0176-0176-091-3311	17440018/3011000	Ex ia ib	II C	T6	II 2 G	IP 66
799	ACS03-360-ZSC/O-2030	J	Celesa fundor (Limit Switches)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GISMORGS2PN2P5S2DW	37198	Ex ia	II C	T6/T1	II 2 G	IP 66/67
800	ACS03-360-ZSC/O-2031	J	Celesa fundor (Limit Switches)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P5S2	37382	Ex ia	II C	T6/ T1	II 2 G	IP 66/67
801	ACS03-381-A-0002	E	Sistem Tokezimi Sistem tokzimi (Grounding System)	CONDENSATE TANKS	ACS03-381	ACS03-381-0000		Zone 2	CORTEM	GRD-4200/24	18/333193	Ex d [ia Ga]	II B + H2	T6	II 2 (1) G	IP 66
802	ACS03-381-EHD-0002	J	Paneli I kontrollit te detektimit te rrjedhjeve Leak Detection Control Cabinet	CONDENSATE TANKS	ACS03-381	ACS03-381-0000		Safe Area	ASSYTECH	LDS08/P/H/L/00/04	2418006/2018		II A	T3	II 2 G	IP 44 / N/A
803	ACS03-381-EHZ-0001	E	Llampe sinjalizuese Llampe sinjalizuese (Signal Light)	CONDENSATE TANKS	ACS03-381	ACS03-381-0000		Zone 2	CORTEM	CCA-02E / S132D24	18/333192	Ex db	II C	T6	II 2 GD	IP 66
804	ACS03-381-EHZ-0002	E	Bori Horn	CONDENSATE TANKS	ACS03-381	ACS03-381-0000		Zone 2	CORTEM	CCA-02E / S11LDA24	537	Ex d	II C	T6	II 2 G	IP 66 / 65
805	ACS03-381-JB-0001	J	Kuti Shperndarese (Junction Box)	CONDENSATE TANKS	ACS03-381	ACS03-381-0000	ACS03-C1448-856-J-DJA-0001	Zone 1	TECHNOR ITALSMEA	SB-282816	I/17/224555	Ex e	II C	T6	II 2 GD	IP 66
806	ACS03-381-JB-0002	J	Kuti Shperndarese (Junction Box)	CONDENSATE TANKS	ACS03-381	ACS03-381-0000		Zone 2	LIMATHERM / STAHL	XD-JB85	N/A / 1815754410440000	Ex d	II C	N/A	II 2 G	N/A
807	ACS03-381-JB-1100	J	Kuti Shperndarese (Junction Box)	CONDENSATE TANKS	ACS03-381	ACS03-381-0000	ACS03-C1448-856-J-DJA-0001	Zone 1	TECHNOR ITALSMEA	SB-282816	I/17/224537	Ex ia	II C	T6	II 2 GD	IP 66
808	ACS03-381-LI-0003-B	J	Indikator lokal Indikator lokal (Local Indicator)	CONDENSATE TANKS	ACS03-381	ACS03-381-0000		Zone 1	SIEMENS	SITRANS TF 7NG3130-4AB11-Z	N1JN229842	Ex d	II C	T6/ T5	II 2 G	IP 67
809	ACS03-381-LIT-0003	J	Transmetues Nivelit (Level Transmitter) (Guided wave)	CONDENSATE TANKS	ACS03-381	ACS03-381-0000	ACS03-C1448-856-J-DJA-0001	Zone 1	SIEMENS	SITRANS TF 7NG3130-4AB11-Z	N1JN229841	Ex d	II C	T6/ T5	II 2 G	IP 67
810	ACS03-381-LZIT-0002	J	Transmetues Nivelit (Level Transmitter) (Guided wave)	CONDENSATE TANKS	ACS03-381	ACS03-381-0000	ACS03-C1448-856-J-DJA-0001	Zone 1	SIEMENS	SITRANS LG250	38485821	Ex ia	II C	T6/ T1	II 1/2 G	IP 66
811	ACS03-381-PAL-0006-A	J	Fener alarmi (General Alarm)	CONDENSATE TANKS	ACS03-381	ACS03-381-0000	ACS03-C1448-856-J-DJA-0001	Zone 1	AES	EVC50	1831	Ex d	II C	T6	II 2 G	IP 65

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
812	ACS03-381-PAL-0006-B	J	Bori alarmuese (Horn for General Alarm)	CONDENSATE TANKS	ACS03-381	ACS03-381-0000	ACS03-C1448-856-J-DJA-0001	Zone 1	AES	ETH20 MD-32	1690 / S.N: 1608	Ex d	II C	T4	II 2 G	IP 66
813	ACS03-381-PIT-0006	J	Gauge Transmetues presioni(Pressure Transmitter)	CONDENSATE TANKS	ACS03-381	ACS03-381-0000	ACS03-C1448-856-J-DJA-0001	Zone 1	SIEMENS	SITRANS P DSIII	N1JN239000067	Ex d	II C	T4/T6	II 1/2 G	IP 66
814	ACS03-381-PZIT-0005	J	Gauge Transmetues presioni(Pressure Transmitter)	CONDENSATE TANKS	ACS03-381	ACS03-381-0000	ACS03-C1448-856-J-DJA-0001	Zone 1	SIEMENS	SITRANS P DSIII	N1JN239000068	Ex d	II C	T4/T6	II 1/2 G	IP 66
815	ACS03-381-YV-0001	J	Valvul Solenoid (Solenoid Valve)	CONDENSATE TANKS	ACS03-381	ACS03-381-0000	ACS03-C1448-381-P-DPE-0001	Zone 2	IMI BUSCHJOST	86757036240	2518	Ex e m	II C	T3	II 2 G	IP 66
816	ACS03-381-YV-0001	J	Valvul Solenoid (Solenoid Valve)	CONDENSATE TANKS	ACS03-381	ACS03-381-0000	ACS03-C1448-381-P-DPE-0001	Zone 2	STAHL	8146/1051	1916784240440010	Ex eb	II C	T6	II 2 G	IP 66
817	ACS03-525-LIT-0001	J	Level Indicator Trasmmitter	POTABLE WATER SYSTEM	ACS03-525	ACS03-525-0200	ACS03-C1448-710-H-DHB-0002	Safe Area	OROBICHE SPA	LSR2	102466/1.1	Ex d	II C	T6	II 2 G	IP 66
818	ACS03-532-JB-0101	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222204	Ex e	II C	T6	II 2 G	IP 66
819	ACS03-534-A-5001A	E	Celes Ventilatori (Switch fan)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0500	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8265/53	1815754410440001	Ex d	II C	T4	II 2 G	IP 66
820	ACS03-534-A-5001B	E	Celes Ventilatori (Switch fan)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0500	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8265/53	1815754410440002	Ex db	II C	T4	II 2 G	IP 66
821	ACS03-534-EHD-P-1040	J	Korrektues Volumi Korrektues volumi 1040 JB - Fuel Gas Building	FUEL GAS	ACS03-534	ACS03-534-0201	ACS03-C1448-856-J-DJA-0001	Zone 2	ELSTER	FE-260-SVB	1588450	Ex ia	II B	T4	II 2 G	IP 65
822	ACS03-534-EHD-P-2040	J	Korrektues volumi 2040 JB - Fuel Gas Building	FUEL GAS	ACS03-534	ACS03-534-0201	ACS03-C1448-856-J-DJA-0001	Zone 2	ELSTER	FE-260-SVB	1588455 / S.N: 83051436/2017	Ex ia	II B	T4	II 2 G	IP 65
823	ACS03-534-EHD-P-3040	J	Korrektues volumi 3040 JB - Fuel Gas Building	FUEL GAS	ACS03-534	ACS03-534-0301	ACS03-C1448-856-J-DJA-0001	Zone 2	ELSTER	FE260-SVB	1588451	Ex Na	II B	T4	II 3 G	IP 65
824	ACS03-534-EHD-P-4040	J	Korrektues volumi 4040 JB - Fuel Gas Building	FUEL GAS	ACS03-534	ACS03-534-0301	ACS03-C1448-856-J-DJA-0001	Zone 2	ELSTER	FE260-SVB	1588449	Ex Na	II B	T4	II 3 G	IP 65
825	ACS03-534-EHF-0001	E	Ndricues LF5 - 2X58W - Fluor.Type	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1100	ACS03-C1448-534-E-DEB-0003	Zone 2	STAHL	6401/...-00-15-232	10001829651057	Ex nA	II C	T4	II 3 G	IP 66/67
826	ACS03-534-EHF-0002	E	Ndricues LF5 - 2X58W - Fluor.Type	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1100	ACS03-C1448-534-E-DEB-0003	Zone 2	STAHL	6401/...-00-15-232	10001829556057	Ex nA	II C	T4	II 3 G	IP 66/67
827	ACS03-534-EHF-0003	E	Ndricues LF5 - 2X58W - Fluor.Type	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1100	ACS03-C1448-534-E-DEB-0003	Zone 2	STAHL	6401/...-00-15-232	10001829556057	Ex nA	II C	T4	II 3 G	IP 66/67
828	ACS03-534-EHF-0004	E	Ndricues LF5 - 2X58W - Fluor.Type	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1100	ACS03-C1448-534-E-DEB-0003	Zone 2	STAHL	6401/542-8..8	10001829596057	Ex nA	II C	T4	II 3 G	IP 66/67
829	ACS03-534-EHF-0005	E	Ndricues LF5 - 2X58W - Fluor.Type	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1100	ACS03-C1448-534-E-DEB-0003	Zone 2	STAHL	6401/542-8..8	10001829598057	Ex nA	II C	T4	II 3 G	IP 66/67
830	ACS03-534-EHF-0006	E	Ndricues LF5 - 2X58W - Fluor.Type	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1100	ACS03-C1448-534-E-DEB-0003	Zone 2	STAHL	6401/542-8..8	10001829555057	Ex nA	II C	T4	II 3 G	IP 66/67
831	ACS03-534-EHF-0007	E	Ndricues LF5 - 2X58W - Fluor.Type	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1100	ACS03-C1448-534-E-DEB-0003	Zone 2	STAHL	6401/...-00-15-232	10001829651057	Ex nA	II C	T4	II 3 G	IP 66/67
832	ACS03-534-EHF-0008	E	Ndricues LF5 - 2X58W - Fluor.Type	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1100	ACS03-C1448-534-E-DEB-0003	Zone 2	STAHL	6401/...-00-15-232	10001829651057	Ex nA	II C	T4	II 3 G	IP 66/67
833	ACS03-534-EHF-0009	E	Ndricues LF5 - 2X58W - Fluor.Type	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1100	ACS03-C1448-534-E-DEB-0003	Zone 2	STAHL	6401/...-00-15-232	10001829649057	Ex nA	II C	T4	II 3 G	IP 66/67
834	ACS03-534-EHF-0010	E	Ndricues LF5 - 2X58W - Fluor.Type	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1100	ACS03-C1448-534-E-DEB-0003	Zone 2	STAHL	6401/...-00-15-232	1000182970257	Ex nA	II C	T4	II 3 G	IP 66/67
835	ACS03-534-EHF-0011	E	Ndricues LF5 - 2X58W - Fluor.Type	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1100	ACS03-C1448-534-E-DEB-0003	Zone 2	STAHL	6401/...-00-15-232	1000182955057	Ex nA	II C	T4	II 3 G	IP 66/67
836	ACS03-534-EHF-0012	E	Ndricues LF5 - 2X58W - Fluor.Type	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1100	ACS03-C1448-534-E-DEB-0003	Zone 2	STAHL	6401/...-00-15-232	10001829651057	Ex nA	II C	T4	II 3 G	IP 66/67
837	ACS03-534-EHF-0021	E	Ndricues LF 9 - 70W - Pendant type	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1100	ACS03-C1448-534-E-DEB-0003	Zone 2	STAHL	6470/2153-3071-100-2	1815726840570003	Ex nR	II C	T4	II 3 G	IP 66
838	ACS03-534-EHF-0022	E	Ndricues LF 9 - 70W - Pendant type	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1100	ACS03-C1448-534-E-DEB-0003	Zone 2	STAHL	6470/2153-3071-100-2	1815726840570004	Ex nR	II C	T4	II 3 G	IP 66
839	ACS03-534-EHF-0023	E	Ndricues LF 9 - 70W - Pendant type	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1100	ACS03-C1448-534-E-DEB-0003	Zone 2	STAHL	6470/2153-3071-100-2	1815726840570001	Ex nR	II C	T4	II 3 G	IP 66
840	ACS03-534-EHF-0024	E	Ndricues LF 9 - 70W - Pendant type	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1100	ACS03-C1448-534-E-DEB-0003	Zone 2	STAHL	6470/2153-3071-100-2	1815726840570002	Ex nR	II C	T4	II 3 G	IP 66
841	ACS03-534-EHJ-L-0001	E	Kuti Shperndares	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1100	ACS03-C1448-534-E-DEB-0003	Zone 2	STAHL	8146/1051	1815738950440142	Ex e	II C	T4	II 2 G	IP 66
842	ACS03-534-EHJ-L-0002	E	Kuti Shperndares	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1100	ACS03-C1448-534-E-DEB-0003	Zone 2	STAHL	8146/1051	1815738950440061	Ex e	II C	T4	II 2 G	IP 66
843	ACS03-534-EHJ-L-0003	E	Kuti Shperndares	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1100	ACS03-C1448-534-E-DEB-0003	Zone 2	STAHL	8146/1051	1815738950440059	Ex e	II C	T4	II 2 G	IP 66
844	ACS03-534-EHJ-L-0004	E	Kuti Shperndares	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1100	ACS03-C1448-534-E-DEB-0003	Zone 2	STAHL	8146/1051	1815738950440000	Ex e	II C	T4	II 2 G	IP 66
845	ACS03-534-EHJ-L-0005	E	Kuti Shperndares	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1100	ACS03-C1448-534-E-DEB-0003	Zone 2	STAHL	8146/1051	1815738950440057	Ex e	II C	T4	II 2 G	IP 66
846	ACS03-534-EHJ-L-0006	E	Kuti Shperndares	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1100	ACS03-C1448-534-E-DEB-0003	Zone 2	STAHL	8146/1051	1815738950440091	Ex e	II C	T4	II 2 G	IP 66
847	ACS03-534-EHJ-L-0007	E	Kuti Shperndares	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1100	ACS03-C1448-534-E-DEB-0003	Zone 2	STAHL	8146/1051	1815738950440072	Ex e	II C	T4	II 2 G	IP 66
848	ACS03-534-EHJ-L-0008	E	Kuti Shperndares	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1100	ACS03-C1448-534-E-DEB-0003	Zone 2	STAHL	8146/1051	1815738950440079	Ex e	II C	T4	II 2 G	IP 66

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
849	ACS03-534-EHJ-L-0009	E	Kuti Shperndares	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1100	ACS03-C1448-534-E-DEB-0003	Zone 2	STAHL	8146/1051	1815738950440000	Ex e	II C	T4	II 2 G	IP 66
850	ACS03-534-EHJ-L-0021	E	Kuti Shperndares	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1100	ACS03-C1448-534-E-DEB-0003	Zone 2	STAHL	8146/1051	1815738950440000	Ex e	II C	T4	II 2 G	IP 66
851	ACS03-534-EHJ-L-0022	E	Kuti Shperndares	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1100	ACS03-C1448-534-E-DEB-0003	Zone 2	STAHL	8146/1051	1815738950440088	Ex e	II C	T4	II 2 G	IP 66
852	ACS03-534-EHJ-L-0023	E	Kuti Shperndares	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1100	ACS03-C1448-534-E-DEB-0003	Zone 2	STAHL	8146/1051	1815738950440077	Ex e	II C	T4	II 2 G	IP 66
853	ACS03-534-EHJ-L-0024	E	Kuti Shperndares	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1100	ACS03-C1448-534-E-DEB-0003	Zone 2	STAHL	8146/1051	1815738950440064	Ex e	II C	T4	II 2 G	IP 66
854	ACS03-534-EHJ-L-0100	E	Kuti Shperndares	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1100	ACS03-C1448-534-E-DEB-0003	Zone 2	STAHL	8146/1051	1815738950440092	Ex e	II C	T4	II 2 G	IP 66
855	ACS03-534-EHJ-L-0100-1	E	Celes Ex Push Button 2	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1100		Zone 2	STAHL	8146/5051	1815739700440009	Ex de	II C	T4	II 2 G	IP 66
856	ACS03-534-EHJ-L-0100-2	E	Celes Ex Push Button 2	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1100		Zone 2	STAHL	8146/5051	1815739700440001	Ex de	II C	T4	II 2 G	IP 66
857	ACS03-534-EHJ-L-0200	E	Kuti Shperndarese	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1100	ACS03-C1448-534-E-DEB-0003	Zone 2	STAHL	8146/1051	1815738950440058	Ex e	II C	T4	II 2 G	IP 66
858	ACS03-534-EHJ-L-0200-1	E	Celes Ex Push Button 2	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1100		Zone 2	STAHL	8146/5051	1815739700440020	Ex de	II C	T4	II 2 G	IP 66
859	ACS03-534-EHJ-L-0200-2	E	Celes Ex Push Button 2	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1100		Zone 2	STAHL	8146/5051	1815739700440014	Ex de	II C	T4	II 2 G	IP 66
860	ACS03-534-EHJ-R-3020	E	Kuti Shperndarese	FUEL GAS	ACS03-534	ACS03-534-0302		Zone 2	STAHL	8146/1083	1916452790440002	Ex e	II C	T4	II 2 G	IP 66
861	ACS03-534-EHJ-R-4020	E	Kuti Shperndarese	FUEL GAS	ACS03-534	ACS03-534-0303		Zone 2	STAHL	8146/1083	1916452790440001	Ex e	II C	T4	II 2 G	IP 66
862	ACS03-534-EHJ-Z-1001A	E	Kuti Shperndarese (Junction Box)	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS03-820	ACS03-820-0902		Zone 2	THERMON	ZP-WP	18-0404	Ex eb	II C	T4	II 2 G	IP 66
863	ACS03-534-EHJ-Z-1001B	E	Kuti Shperndarese (Junction Box)	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS03-820	ACS03-820-0902		Zone 2	THERMON	ZP-WP	18-0404	Ex e	II C	T4/T6	II 2 G	IP 66
864	ACS03-534-EHS-0001	E	Prize (Power Socket) 1	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0500		Zone 2	STAHL	8146/5093	1815753360440004	Ex de	II C	T4	II 2 G	IP 66
865	ACS03-534-EHS-0002	E	Prize (Power Socket) 2	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0500		Zone 2	STAHL	8146/5093	1815753360440006	Ex de	II C	T4	II 2 G	IP 66
866	ACS03-534-ERF-0001	E	Ndicues Emergjence Ndicues Emergjence 2x36W	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0902	ACS03-C1448-534-E-DEB-0003	Zone 2	CEAG	eLLK 92036/36 CG-S	993986G	Ex de ib m	II C	T4	II 2 G	IP 66/67
867	ACS03-534-ERF-0002	E	Ndicues Evakuimi (Ndicues Evakuimi - Right Direction)	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0902	ACS03-C1448-534-E-DEB-0003	Zone 2	EATON	EXIT V-CG-S	1119	Ex e ib m	II C	T4	II 2 G	IP 66
868	ACS03-534-ERF-0003	E	Ndicues Evakuimi Ndicues Evakuimi - Left Direction	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0902	ACS03-C1448-534-E-DEB-0003	Zone 2	EATON	EXIT V-CG-S	1468	Ex e ib m	II C	T4	II 2 G	IP 66
869	ACS03-534-ERF-0004	E	Ndicues Evakuimi Ndicues Evakuimi - Exit	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0902	ACS03-C1448-534-E-DEB-0003	Zone 2	EATON	EXIT V-CG-S	1298	Ex e ib m	II C	T4	II 2 G	IP 66
870	ACS03-534-ERF-0005	E	Ndicues Evakuimi (Ndicues Evakuimi - Right Direction)	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0902	ACS03-C1448-534-E-DEB-0003	Zone 2	EATON	EXIT V-CG-S	1088	Ex e ib m	II C	T4	II 2 G	IP 66
871	ACS03-534-ERF-0006	E	Ndicues Evakuimi - Left Direction	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0902	ACS03-C1448-534-E-DEB-0003	Zone 2	EATON	EXIT V-CG-S	1468	Ex e ib m	II C	T4	II 2 G	IP 66
872	ACS03-534-ERF-0007	E	Ndicues Evakuimi - Exit	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0902	ACS03-C1448-534-E-DEB-0003	Zone 2	EATON	EXIT V-CG-S	1388	Ex e ib m	II C	T4	II 2 G	IP 66
873	ACS03-534-ERF-0008	E	Ndicues Emergjence 2x18W	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0902	ACS03-C1448-534-E-DEB-0003	Zone 2	EATON	eLLK 92018/18 V-CG-S	0136405R2	Ex de ib m	II C	T4	II 2 G	IP 66/67
874	ACS03-534-ERF-0009	E	Ndicues Emergjence 2x18W	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0902	ACS03-C1448-534-E-DEB-0003	Zone 2	EATON	eLLK 92018/18 V-CG-S	019850102	Ex de ib m	II C	T4	II 2 G	IP 66/67
875	ACS03-534-ERJ-P-001	E	Kuti Shperndarese Fuel Gas Building Damper Inlet/Discharge JB	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0500		Zone 2	STAHL	8146/1041	1815738940440032	Ex e	II C	T4	II 2 G	IP 66
876	ACS03-534-ERJ-S-5001-A	E	Kuti Shperndarese Fuel Gas Building Damper JB	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0500		Zone 2	STAHL	8146/1051	1815738950440085	Ex e	II C	T4	II 2 G	IP 66
877	ACS03-534-ERJ-S-5001-B	E	Kuti Shperndarese Fuel Gas Building Damper JB	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0500		Zone 2	STAHL	8146/1051	1815738950440080	Ex e	II C	T4	II 2 G	IP 66
878	ACS03-534-ERJ-S-5002-A	E	Kuti Shperndarese Fuel Gas Building Damper JB	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0500		Zone 2	STAHL	8146/1051	1815738930440037	Ex e	II C	T4	II 2 G	IP 66
879	ACS03-534-ERJ-S-5002-B	E	Kuti Shperndarese Fuel Gas Building Damper JB	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0500		Zone 2	STAHL	8146/1051	1815738950440042	Ex e	II C	T4	II 2 G	IP 66
880	ACS03-534-ERJ-S-5003-A	E	Kuti Shperndarese Fuel Gas Building Damper JB	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0500		Zone 2	STAHL	8146/1051	1815738950440150	Ex e	II C	T4	II 2 G	IP 66
881	ACS03-534-ERJ-S-5003-B	E	Kuti Shperndarese Fuel Gas Building Damper JB	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0500		Zone 2	STAHL	8146/1051	1815738950440162	Ex e	II C	T4	II 2 G	IP 66
882	ACS03-534-ERJ-S-5004-A	E	Kuti Shperndarese Fuel Gas Building Damper JB	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0500		Zone 2	STAHL	8146/1051	1815738950440084	Ex e	II C	T4	II 2 G	IP 66
883	ACS03-534-ERJ-S-5004-B	E	Kuti Shperndarese Fuel Gas Building Damper JB	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0500		Zone 2	STAHL	8146/1051	1815738950440067	Ex e	II C	T4	II 2 G	IP 66
884	ACS03-534-ERJ-S-5005-A	E	Kuti Shperndarese Fuel Gas Building Damper JB	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0500		Zone 2	STAHL	8146/1051	1815738950440063	Ex e	II C	T4	II 2 G	IP 66
885	ACS03-534-ERJ-S-5005-B	E	Kuti Shperndarese Fuel Gas Building Damper JB	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0500		Zone 2	STAHL	8146/1051	1815738950440066	Ex e	II C	T4	II 2 G	IP 66

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
886	ACS03-534-ERJ-S-5006-A	E	Kuti Shperndarese Fuel Gas Building Damper JB	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0500		Zone 2	STAHL	8146/1051	1815738950440071	Ex e	II C	T4	II 2 G	IP 66
887	ACS03-534-ERJ-S-5006-B	E	Kuti Shperndarese Fuel Gas Building Damper JB	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0500		Zone 2	STAHL	8146/1051	1815738950440065	Ex e	II C	T4	II 2 G	IP 66
888	ACS03-534-ERJ-S-5007-A	E	Kuti Shperndarese Fuel Gas Building Damper JB	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0500		Zone 2	STAHL	8146/1051	1815738950440105	Ex e	II C	T4	II 2 G	IP 66
889	ACS03-534-ERJ-S-5007-B	E	Kuti Shperndarese Fuel Gas Building Damper JB	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0500		Zone 2	STAHL	8146/1051	1815738950440000	Ex e	II C	T4	II 2 G	IP 66
890	ACS03-534-ERJ-S-5008-A	E	Kuti Shperndarese Fuel Gas Building Damper JB	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0500		Zone 2	STAHL	8146/1051	1815738950440081	Ex e	II C	T4	II 2 G	IP 66
891	ACS03-534-ERJ-S-5008-B	E	Kuti Shperndarese Fuel Gas Building Damper JB	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0500		Zone 2	STAHL	8146/1051	1815738950440068	Ex e	II C	T4	II 2 G	IP 66
892	ACS03-534-ERJ-S-5009-A	E	Kuti Shperndarese Fuel Gas Building Damper JB	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0500		Zone 2	STAHL	8146/1051	1815738950440000	Ex e	II C	T4	II 2 G	IP 66
893	ACS03-534-ERJ-S-5009-B	E	Kuti Shperndarese Fuel Gas Building Damper JB	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0500		Zone 2	STAHL	8146/1051	1815738950440000	Ex e	II C	T4	II 2 G	IP 66
894	ACS03-534-FB-0201-A	J	Fener per sinjalizues zjarri (Fire Alarm Beacon)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-534-T-DTG-0001	Zone 2	AES	EVC50	2115	Ex d	II C	T6	II 2 G	IP 65
895	ACS03-534-FB-0202-A	J	Fener per sinjalizues zjarri (Fire Alarm Beacon)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-534-T-DTG-0001	Zone 2	AES	EVC50	2183	Ex d	II C	T6	II 2 G	IP 65
896	ACS03-534-FB-0203-A	J	Fener per sinjalizues zjarri (Fire Alarm Beacon)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-534-T-DTG-0001	Zone 2	AES	EVC50	2174	Ex d	II C	T6	II 2 G	IP 65
897	ACS03-534-FD-0201	J	Detektor Zjarri (Flame Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-534-T-DTG-0001	Zone 2	HONEYWELL	FS24X-9	205001	Ex d	II C	T6	II 2 G	IP 66
898	ACS03-534-FD-0202	J	Detektor Zjarri (Flame Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-534-T-DTG-0001	Zone 2	HONEYWELL	FS24X-9	203946	Ex d	II C	T6	II 2 G	IP 66
899	ACS03-534-FD-0203	J	Detektor Zjarri (Flame Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-534-T-DTG-0001	Zone 2	HONEYWELL	FS24X-9	204028	Ex d	II C	T6	II 2 G	IP 66
900	ACS03-534-FD-0204	J	Detektor Zjarri (Flame Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-534-T-DTG-0001	Zone 2	HONEYWELL	FS24X-9	205403	Ex d	II C	T6	II 2 G	IP 66
901	ACS03-534-FH-0201-A	J	Bori sinjalizuese zjarri (Fire Alarm Horn)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-534-T-DTG-0001	Zone 2	AES	ETH20 MD-32	2145	Ex d	II C	T4	II 2 G	IP 66
902	ACS03-534-FH-0202-A	J	Bori sinjalizuese zjarri (Fire Alarm Horn)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-534-T-DTG-0001	Zone 2	AES	ETH20 MD-32	1724	Ex d	II C	T4	II 2 G	IP 66
903	ACS03-534-FH-0203-A	J	Bori sinjalizuese zjarri (Fire Alarm Horn)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-534-T-DTG-0001	Zone 2	AES	ETH20 MD-32	1703	Ex d	II C	T4	II 2 G	IP 66
904	ACS03-534-FIT-1125	J	Transmetues i prurjes (dP Flow Transmitter)	Sistemi i Ujit te nxehte (HOT WATER SYSTEM)	ACS03-520	ACS03-520-0100	ACS03-C1448.1010-534-P-DPE-0001	Zone 2	ABB	VORTEX MASTER	244175377/X001/002555	Ex ia	II C	T4/T6	II 1 G	IP 66/67
905	ACS03-534-FIT-2125	J	Transmetues i prurjes (dP Flow Transmitter)	Sistemi i Ujit te nxehte (HOT WATER SYSTEM)	ACS03-520	ACS03-520-0100	ACS03-C1448.1010-534-P-DPE-0001	Zone 2	ABB	VORTEX MASTER	244175377/X002/002556	Ex ia	II C	T4/T6	II 1 G	IP 66/67
906	ACS03-534-GB-0201-B	J	Fener alarmues I prezences se gazit Flammable Gas Alarm Beacon	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-534-T-DTG-0002	Zone 2	AES	EVC50	2163	Ex d	II C	T6	II 2 G	IP 65
907	ACS03-534-GB-0202-B	J	Fener alarmues I prezences se gazit Flammable Gas Alarm Beacon	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-534-T-DTG-0002	Zone 2	AES	EVC50	2105	Ex d	II C	T6	II 2 G	IP 65
908	ACS03-534-GB-0203-B	J	Fener alarmues I prezences se gazit Flammable Gas Alarm Beacon	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-534-T-DTG-0002	Zone 2	AES	EVC50	2136	Ex d	II C	T6	II 2 G	IP 65
909	ACS03-534-GD-0206	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-534-T-DTG-0002	Zone 2	CROWCON	IRmax	W274214/01-003	Ex d	II C	T6	II 2 G	IP 66
910	ACS03-534-GD-0208	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-534-T-DTG-0002	Zone 2	CROWCON	IRmax	W274210/01-007	Ex d	II C	T6	II 2 G	IP 66
911	ACS03-534-GD-0212	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-534-T-DTG-0002	Zone 2	CROWCON	IRmax	W274211/01-023	Ex d	II C	T6	II 2 G	IP 66
912	ACS03-534-GD-0214	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-534-T-DTG-0002	Zone 2	CROWCON	IRmax	W274211/01-016	Ex d	II C	T6	II 2 G	IP 66
913	ACS03-534-GD-0215	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-534-T-DTG-0002	Zone 2	CROWCON	IRmax	W274211/01-018	Ex d	II C	T6	II 2 G	IP 66
914	ACS03-534-GD-0216	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-534-T-DTG-0002	Zone 2	CROWCON	IRmax	W274211/01-006	Ex d	II C	T6	II 2 G	IP 66
915	ACS03-534-GD-0217	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-534-T-DTG-0002	Zone 2	CROWCON	IRmax	W274211/01-029	Ex d	II C	T6	II 2 G	IP 66
916	ACS03-534-GD-0218	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-534-T-DTG-0002	Zone 2	CROWCON	IRmax	W274211/01-001	Ex d	II C	T6	II 2 G	IP 66
917	ACS03-534-GD-0219	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-534-T-DTG-0002	Zone 2	CROWCON	IRmax	W274211/01-011	Ex d	II C	T6	II 2 G	IP 66
918	ACS03-534-GD-0220	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-534-T-DTG-0002	Zone 2	CROWCON	IRmax	W274211/01-011	Ex d	II C	T6	II 2 G	IP 66
919	ACS03-534-GH-0201-B	J	Bori alarmi per prezence gazi(Gas Alarm Horn)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-534-T-DTG-0002	Zone 2	AES	ETH20 MD-32	1737	Ex d	II C	T4	II 2 G	IP 66
920	ACS03-534-GH-0202-B	J	Bori alarmi per prezence gazi(Gas Alarm Horn)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-534-T-DTG-0002	Zone 2	AES	ETH20 MD-32	1731	Ex d	II C	T4	II 2 G	IP 66
921	ACS03-534-GH-0203-B	J	Bori alarmi per prezence gazi(Gas Alarm Horn)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-534-T-DTG-0002	Zone 2	AES	ETH20 MD-32	1693	Ex d	II C	T4	II 2 G	IP 66
922	ACS03-534-HS-0001	J	çeles paneli lokal (Local Panel Hand Switch)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	CORTEM	SA301410/P	17/325338	Ex de	II C	T6	II 2 G	IP 66

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
923	ACS03-534-JB-0001	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858-0100	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	AD VIGANO	CSX 453019	17.07.379	Ex e	II C	T5	II 2 G	IP 66
924	ACS03-534-JB-0002	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858-0100	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	AD VIGANO	CSX 453019	17.07.388	Ex e	II C	T5	II 2 G	IP 66
925	ACS03-534-JB-0003	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858-0100	ACS03-858-0100		Zone 2	AD VIGANO	CSX 453019	N/A	Ex e	II C	T5	II 2 G	IP 66
926	ACS03-534-JB-0101	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858-0100	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	AD VIGANO	CSX 302019	17.07.401	Ex e	II C	T5	II 2 G	IP 66
927	ACS03-534-JB-0102	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858-0100	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	AD VIGANO	CSX 302019	17.17.397	Ex e	II C	T5	II 2 G	IP 66
928	ACS03-534-JB-1001	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858-0100	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	AD VIGANO	CSX 302019	17.07.407	Ex e	II C	T5	II 2 G	IP 66
929	ACS03-534-JB-1002	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858-0100	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	AD VIGANO	CSX 302019	17.07.391	Ex e	II C	T5	II 2 G	IP 66
930	ACS03-534-JB-1003	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858-0100	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	AD VIGANO	CSX 453019	17.07.389	Ex e	II C	T5	II 2 G	IP 66
931	ACS03-534-JB-1004	J	Kuti Shperndarese (Junction Box)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0500	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222171	Ex ia	II C	T6	II 2 G	IP 66
932	ACS03-534-JB-1005	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858-0100	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	AD VIGANO	CSX 453019	17.07.390	Ex e	II C	T5	II 2 G	IP 66
933	ACS03-534-JB-1101	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858-0100	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	AD VIGANO	CSX 453019	17.07.382	Ex e	II C	T5	II 2 G	IP 66
934	ACS03-534-JB-1102	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858-0100	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	AD VIGANO	CSX 453019	17.07.377	Ex e	II C	T5	II 2 G	IP 66
935	ACS03-534-JB-1103	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858-0100	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	AD VIGANO	CSX 453019	17.07.395	Ex e	II C	T5	II 2 G	IP 66
936	ACS03-534-JB-1104	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858-0100	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	AD VIGANO	CSX 302019	17.07.396	Ex e	II C	T5	II 2 G	IP 66
937	ACS03-534-JB-1105	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858-0100	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	AD VIGANO	CSX 453019	17.07.387	Ex e	II C	T5	II 2 G	IP 66
938	ACS03-534-JB-1106	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858-0100	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	AD VIGANO	CSX 302019	17.07.396	Ex e	II C	T5	II 2 G	IP 66
939	ACS03-534-M-5001	E	Njesi qendrore ventilimi Central Ventilation Unit (Fuel Gas Building)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0500	ACS03-C1448-534-P-DPE-0003	Zone 2	EUROMOTORI	MAK 90 L-2	2005520	Ex d	II B	T4	II 2 G	IP 66
940	ACS03-534-MAC-0201	J	Celes alarmi (Manual Call Point)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-534-T-DTG-0001	Zone 2	MEDC	BG-IB	212196474 10 16	Ex ia	II C	T4	II 1 G	IP 65
941	ACS03-534-MAC-0202	J	Celes alarmi (Manual Call Point)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-534-T-DTG-0001	Zone 2	MEDC	BG-IB	212196474 10 22	Ex ia	II C	T4	II 1 GD	IP 65
942	ACS03-534-MAC-0203	J	Celes alarmi (Manual Call Point)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-534-T-DTG-0001	Zone 2	MEDC	BG-IB	212196474 20 21	Ex ia	II C	T4	II 1 G	IP 65
943	ACS03-534-MAC-0204	J	Celes alarmi (Manual Call Point)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-534-T-DTG-0001	Zone 2	MEDC	BG-IB	212196474 10 02	Ex ia	II C	T4	II 1 G	IP 65
944	ACS03-534-SCD-0205	J	Detektor Tymi (Multicriteria Smoke Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-534-T-DTG-0001	Zone 2	APOLLO	ORB-OH-53028/MB-50018-APO	082118	Ex ia	II C	T5	II 1 G	IP 40
945	ACS03-534-SCD-0207	J	Detektor Tymi (Multicriteria Smoke Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-534-T-DTG-0001	Zone 2	APOLLO	ORB-OH-53028/MB-50018-APO	082614	Ex ia	II C	T5	II 1 G	IP 40
946	ACS03-534-SCD-0209	J	Detektor Tymi (Multicriteria Smoke Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-534-T-DTG-0001	Zone 2	APOLLO	ORB-OH-5038/MB-50018-APO	084716	Ex ia	II C	T5	II 1 G	IP 40
947	ACS03-534-SCD-0210	J	Detektor Tymi (Multicriteria Smoke Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-534-T-DTG-0001	Zone 2	APOLLO	ORB-OH-53028/MB-50018-APO	080216	Ex ia	II C	T5	II 1 G	IP 40
948	ACS03-534-SCD-0211	J	Detektor Tymi (Multicriteria Smoke Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-534-T-DTG-0001	Zone 2	APOLLO	ORB-OH-53028/MB-50018-APO	082921	Ex ia	II C	T5	II 1 G	IP 40
949	ACS03-534-SCD-0213	J	Detektor Tymi (Multicriteria Smoke Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-534-T-DTG-0001	Zone 2	APOLLO	ORB-OH-53028/MB-50018-APO	082022	Ex ia	II C	T5	II 1 G	IP 40
950	ACS03-534-TIT-3020	J	534-W-3020 Gas Pre-Heater Transmetues Temperature (Temperature Transmitter)	FUEL GAS	ACS03-534	ACS03-534-0301	ACS03-C1448-1010-534-P-DPE-0001	Zone 2	HONEYWELL	STT850	17W30	Ex ia	II C	T4	II 1 G	IP 66
951	ACS03-534-TIT-3022	J	534-W-3020 Outlet Transmetues Temperature (Temperature Transmitter)	FUEL GAS	ACS03-534	ACS03-534-0301	ACS03-C1448-1010-534-P-DPE-0001	Zone 2	HONEYWELL	STT850	17W29	Ex ia	II C	T4	II 1 G	IP 66
952	ACS03-534-TIT-4020	J	534-W-4020 Gas Pre-Heater Transmetues Temperature (Temperature Transmitter)	FUEL GAS	ACS03-534	ACS03-534-0301	ACS03-C1448-1010-534-P-DPE-0001	Zone 2	HONEYWELL	STT850	17W30	Ex ia	II C	T4	II 1 G	IP 66
953	ACS03-534-TIT-4022	J	534-W-4020 Outlet Transmetues Temperature (Temperature Transmitter)	FUEL GAS	ACS03-534	ACS03-534-0301	ACS03-C1448-1010-534-P-DPE-0001	Zone 2	HONEYWELL	STT850	17W29	Ex ia	II C	T4	II 1 G	IP 66
954	ACS03-534-TIT-5002-A	J	Transmetues Temperature (Temperature Transmitter)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0500	ACS03-C1448-534-P-DPE-0003	Zone 2	SIEMENS	SITRANS TF	N1JN229879	Ex d	II C	T5/T6	II 2 G	IP 67
955	ACS03-534-TIT-5002-B	J	Transmetues Temperature (Temperature Transmitter)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0500	ACS03-C1448-534-P-DPE-0003	Zone 2	SIEMENS	SITRANS TF	N1JN229866	Ex d	II C	T5/T6	II 2 G	IP 67
956	ACS03-534-W-3020	E	Ngrohes Gazi Fuel Gas Unit - Pre-Heater A	FUEL GAS	ACS03-534	ACS03-534-0301	ACS03-C1448-1010-534-P-DPE-0001	Zone 2	METRON	FLGT200	111/2017	Ex d	II C	T3	II 2 G	IP 66
957	ACS03-534-W-4020	E	Ngrohes Gazi Fuel Gas Unit - Pre-Heater B	FUEL GAS	ACS03-534	ACS03-534-0301	ACS03-C1448-1010-534-P-DPE-0001	Zone 2	METRON	FLGT200	112/2017	Ex d	II C	T3	II 2 G	IP 66
958	ACS03-534-W-5001A	E	Ventilator ventilator 1	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0500	ACS03-C1448-534-E-DEB-0005	Zone 2	CEMP	AB30r 71A63	1809792006Y18	Ex d	II B	T4	II 2 G	IP 55
959	ACS03-534-W-5001B	E	Ventilator ventilator 1	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0500	ACS03-C1448-534-E-DEB-0005	Zone 2	CEMP	AB30r 71A63	1809792004Y18	Ex d	II B	T4	II 2 G	IP 55

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
960	ACS03-534-YV-0001	J	Valvul Solenoid (Solenoid Valve)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
961	ACS03-534-YZV-0001	J	Valvul Solenoid (Solenoid Valve)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
962	ACS03-534-ZSC/O-0001	J	Celesa fundor (Limit Switches)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P552	37382	Ex ia	II C	T6/T1	II 2 G	IP 66/67
963	ACS03-534-ZSC/O-1020	J	Celesa fundor (Limit Switches)	Sistemi i Ujit te nxehte (HOT WATER SYSTEM)	ACS03-520	ACS03-520-0100		Zone 2	AUMA	ACEXC01.2	3317MA80992/3	Ex de	II C	T4	II 2 G	IP 68
964	ACS03-534-ZSC/O-2020	J	Celesa fundor (Limit Switches)	Sistemi i Ujit te nxehte (HOT WATER SYSTEM)	ACS03-520	ACS03-520-0100		Zone 2	AUMA	ACEXC01.2	3317MA80992/3	Ex de	II C	T4	II 2 G	IP 68
965	ACS03-537-JB-0100	J	Instrumentation Kuti Shperndarese (Junction Box)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222206	Ex e	II C	T6	II 2 G	IP 66
966	ACS03-537-JB-0201	J	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS03-858	ACS03-858-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224531	Ex e	II C	T6	II 2 GD	IP 66
967	ACS03-537-JB-0202-A	J	Kuti Shperndarese (Junction Box)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224530	Ex e	II C	T6	II 2 G	IP 66
968	ACS03-537-JB-0202-B	J	Kuti Shperndarese (Junction Box)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/222185	Ex e	II C	T6	II 2 G	IP 66
969	ACS03-537-JB-0202-C	J	Kuti Shperndarese (Junction Box)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224532	Ex e	II C	T6	II 2 G	IP 66
970	ACS03-537-JB-1002-A	J	Kuti Shperndarese (Junction Box)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-352720	I/17/226207	Ex ia	II C	T6	II 2 G	IP 66
971	ACS03-537-JB-1002-B	J	Kuti Shperndarese (Junction Box)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-352720	I/17/226206	Ex ia	II C	T6	II 2 G	IP 66
972	ACS03-537-JB-1002-C	J	Kuti Shperndarese (Junction Box)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-352720	I/17/222169	Ex ia	II C	T6	II 2 G	IP 66
973	ACS03-537-PIT-1001	J	Transmetues presioni(Pressure Transmitter)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1JN239000084	Ex d	II C	T4/T6	II 1/2 G	IP 66
974	ACS03-537-PIT-2001	J	Transmetues presioni(Pressure Transmitter)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1JN239000097	Ex d	II C	T4/T6	II 1/2 G	IP 66
975	ACS03-537-PIT-3001	J	Transmetues presioni(Pressure Transmitter)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1JN239000098	Ex d	II C	T4/T6	II 1/2 G	IP 66
976	ACS03-537-YV-1010	J	Valvul Solenoid (Solenoid Valve)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex eb mb	II C	T4	II 2 GD	IP 66/X8
977	ACS03-537-YV-1020	J	Valvul Solenoid (Solenoid Valve)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
978	ACS03-537-YV-1030	J	Valvul Solenoid (Solenoid Valve)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex eb mb	II C	T4	II 2 GD	IP 66/X8
979	ACS03-537-YV-1040	J	Valvul Solenoid (Solenoid Valve)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
980	ACS03-537-YV-1050	J	Valvul Solenoid (Solenoid Valve)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
981	ACS03-537-YV-1060	J	Valvul Solenoid (Solenoid Valve)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
982	ACS03-537-YV-1080	J	Valvul Solenoid (Solenoid Valve)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex eb mb	II C	T4	II 2 GD	IP 66/X8
983	ACS03-537-YV-2040	J	Valvul Solenoid (Solenoid Valve)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
984	ACS03-537-YV-2050	J	Valvul Solenoid (Solenoid Valve)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
985	ACS03-537-YV-2060	J	Valvul Solenoid (Solenoid Valve)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
986	ACS03-537-YV-3040	J	Valvul Solenoid (Solenoid Valve)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
987	ACS03-537-YV-3050	J	Valvul Solenoid (Solenoid Valve)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
988	ACS03-537-YV-3060	J	Valvul Solenoid (Solenoid Valve)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
989	ACS03-537-YZV-1001	J	Valvul Solenoid (Solenoid Valve)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62594/1	Ex e m / Ex eb mb	II C	T4	II 2 G	IP 66
990	ACS03-537-YZV-1010	J	Valvul Solenoid (Solenoid Valve)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
991	ACS03-537-YZV-1020	J	Valvul Solenoid (Solenoid Valve)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex eb mb	II C	T4	II 2 GD	IP 66/X8
992	ACS03-537-YZV-1030	J	Valvul Solenoid (Solenoid Valve)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex eb mb	II C	T4	II 2 GD	IP 66/X8
993	ACS03-537-YZV-1040	J	Valvul Solenoid (Solenoid Valve)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
994	ACS03-537-YZV-1050	J	Valvul Solenoid (Solenoid Valve)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
995	ACS03-537-YZV-1060	J	Valvul Solenoid (Solenoid Valve)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
996	ACS03-537-YZV-1080	J	Valvul Solenoid (Solenoid Valve)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex eb mb	II C	T4	II 2 GD	IP 66/X8

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
997	ACS03-537-YZV-2001	J	Valvul Solenoid (Solenoid Valve)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62594/1	Ex e m / Ex eb mb	II C	T4	II 2 G	IP 66
998	ACS03-537-YZV-2040	J	Valvul Solenoid (Solenoid Valve)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
999	ACS03-537-YZV-2050	J	Valvul Solenoid (Solenoid Valve)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
1000	ACS03-537-YZV-2060	J	Valvul Solenoid (Solenoid Valve)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
1001	ACS03-537-YZV-3001	J	Valvul Solenoid (Solenoid Valve)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62594/1	Ex e m / Ex eb mb	II C	T4	II 2 G	IP 66
1002	ACS03-537-YZV-3040	J	Valvul Solenoid (Solenoid Valve)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
1003	ACS03-537-YZV-3050	J	Valvul Solenoid (Solenoid Valve)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
1004	ACS03-537-YZV-3060	J	Valvul Solenoid (Solenoid Valve)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	IMI MAXSEAL	ICO3S	62146/3	Ex e m	II C	T4	II 2 G	IP 66
1005	ACS03-537-ZIT-1001	J	Transmetues Pozicioni (Position Transmitter)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	YOUNG TECH	YT-3400	N/A	Ex d	II C	T5/T6	II 2 G	IP 66
1006	ACS03-537-ZIT-2001	J	Transmetues Pozicioni (Position Transmitter)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	YOUNG TECH	YT-3400	N/A	Ex d	II C	T5/T6	II 2 G	IP 66
1007	ACS03-537-ZIT-3001	J	Transmetues Pozicioni (Position Transmitter)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	YOUNG TECH	YT-3400	N/A	Ex d	II C	T5/T6	II 2 G	IP 66
1008	ACS03-537-ZSC/O-1010	J	Celesa fundor (Limit Switches)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P5S2	37382	Ex ia	II C	T6/ T1	II 2 G	IP 66/67
1009	ACS03-537-ZSC/O-1020	J	Celesa fundor (Limit Switches)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P5S2	37382	Ex ia	II C	T6	II 2 G	IP 66/67
1010	ACS03-537-ZSC/O-1030	J	Celesa fundor (Limit Switches)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P5S2	37382	Ex ia	II C	T6	II 2 G	IP 66/67
1011	ACS03-537-ZSC/O-1040	J	Celesa fundor (Limit Switches)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P5S2	37382	Ex ia	II C	T6	II 2 G	IP 66/67
1012	ACS03-537-ZSC/O-1050	J	Celesa fundor (Limit Switches)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P5S2	37382	Ex ia	II C	T6	II 2 G	IP 66/67
1013	ACS03-537-ZSC/O-1060	J	Celesa fundor (Limit Switches)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P5S2	37382	Ex ia	II C	T6	II 2 G	IP 66/67
1014	ACS03-537-ZSC/O-1080	J	Celesa fundor (Limit Switches)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P5S2	37382	Ex ia	II C	T6	II 2 G	IP 66/67
1015	ACS03-537-ZSC/O-2040	J	Celesa fundor (Limit Switches)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P5S2	37382	Ex ia	II C	T6	II 2 G	IP 66/67
1016	ACS03-537-ZSC/O-2050	J	Celesa fundor (Limit Switches)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P5S2	37382	Ex ia	II C	T6	II 2 G	IP 66/67
1017	ACS03-537-ZSC/O-2060	J	Celesa fundor (Limit Switches)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P5S2	37382	Ex ia	II C	T6	II 2 G	IP 66/67
1018	ACS03-537-ZSC/O-3040	J	Celesa fundor (Limit Switches)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P5S2	37382	Ex ia	II C	T6	II 2 G	IP 66/67
1019	ACS03-537-ZSC/O-3050	J	Celesa fundor (Limit Switches)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P5S2	37382	Ex ia	II C	T6	II 2 G	IP 66/67
1020	ACS03-537-ZSC/O-3060	J	Celesa fundor (Limit Switches)	VENT AND BLOW DOWN FACILITY	ACS03-537	ACS03-537-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	EISENBAU	GIAMOLIS2PN2P5S2	37382	Ex ia	II C	T6	II 2 G	IP 66/67
1021	ACS03-539-EHZ-0001	E	Panel Tokezimi (Grounding Panelr)	DIESEL FUEL SYSTEM	ACS03-539	ACS03-539-0100		Zone 2	CORTEM	GRD-4200	18/333193	Ex d ia	II B + H2	T6	II 2 G	IP 66
1022	ACS03-539-FSL-0010	J	Flow Switch Low	DIESEL FUEL SYSTEM	ACS03-539	ACS03-539-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	KOBOLD	PSR-224BRI	PS003970	Ex ia	II C	T4/T3	II 1 G	IP 66
1023	ACS03-539-JB-0001	J	Kuti Spherndarese (Junction Box)	DIESEL FUEL SYSTEM	ACS03-539	ACS03-539-0100		Zone 2	TECHNOR ITALSMEA	AR-2	I/19/46338	Ex e	II C	T6	II 2 G	IP 66
1024	ACS03-539-JB-0002	J	Kuti Spherndarese (Junction Box)	DIESEL FUEL SYSTEM	ACS03-539	ACS03-539-0100		Zone 2	TECHNOR ITALSMEA	AR-2	I/19/46342	Ex e	II C	T6	II 2 G	IP 66
1025	ACS03-539-JB-0003	J	Kuti Spherndarese (Junction Box)	DIESEL FUEL SYSTEM	ACS03-539	ACS03-539-0100		Zone 2	TECHNOR ITALSMEA	AR-2	I/19/46341	Ex e	II C	T6	II 2 G	IP 66
1026	ACS03-539-JB-0004	J	Kuti Spherndarese (Junction Box)	DIESEL FUEL SYSTEM	ACS03-539	ACS03-539-0100		Zone 2	TECHNOR ITALSMEA	AR-2	I/19/46358	Ex e	II C	T6	II 2 G	IP 66
1027	ACS03-539-JB-0005	J	Kuti Spherndarese (Junction Box)	DIESEL FUEL SYSTEM	ACS03-539	ACS03-539-0100		Zone 2	TECHNOR ITALSMEA	AR-2	I/19/463420	Ex e	II C	T6	II 2 G	IP 66
1028	ACS03-539-JB-LIT-1001	J	Transmetues Nivelii (Level Transmitter) JB	DIESEL FUEL SYSTEM	ACS03-539	ACS03-539-0100	ACS03-C1448-539-P-DPE-0002	Zone 2	LIMATHERM	XD-JB85	ZP/18/2470/00109	Ex d	II C	T5/T6	II 2 G	IP 66
1029	ACS03-539-JB-LIT-2001	J	Transmetues Nivelii (Level Transmitter) JB	DIESEL FUEL SYSTEM	ACS03-539	ACS03-539-0100	ACS03-C1448-539-P-DPE-0002	Zone 2	LIMATHERM	XD-JB85	ZP/18/2470/001010	Ex d	II C	T5/T6	II 2 G	IP 66
1030	ACS03-539-JB-LIT-3001	J	Transmetues Nivelii (Level Transmitter) JB	DIESEL FUEL SYSTEM	ACS03-539	ACS03-539-0100	ACS03-C1448-539-P-DPE-0002	Zone 2	LIMATHERM	XD-JB85	ZP/18/2470/001010	Ex d	II C	T5/T6	II 2 G	IP 66
1031	ACS03-539-LAH-0001-A	J	Alarm Pamor (Visible Alarm)	DIESEL FUEL SYSTEM	ACS03-539	ACS03-539-0100	ACS03-C1448-539-P-DPE-0001	Safe Area	E2S	BEXCS110-05D-P	18/1CS220111113	Ex d	II B	T5	II 2 G	IP 65
1032	ACS03-539-LAH-0001-B	J	Alarm Pamor (Visible Alarm)	DIESEL FUEL SYSTEM	ACS03-539	ACS03-539-0100	ACS03-C1448-539-P-DPE-0001	Safe Area	AES	ETH20 MD-32	1844	Ex d	II C	T6	II 2 G	IP 65
1033	ACS03-539-LI-0001	J	Indikator Sistemi (System Indication)	DIESEL FUEL SYSTEM	ACS03-539	ACS03-539-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	FAFNIR	VISY-STICK	5114019	Ex d	II C	T4	II 2 G	IP 66

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizitimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
1034	ACS03-539-LIT-0001	J	Magnetic Transmetues Nivel (Level Transmitter)	DIESEL FUEL SYSTEM	ACS03-539	ACS03-539-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	FAFNIR	VISY-STICK	N/A	Ex ia	II C	T4	II 2 G	IP 68
1035	ACS03-539-LIT-1001	J	Magnetic Transmetues Nivel (Level Transmitter)	DIESEL FUEL SYSTEM	ACS03-539	ACS03-539-0100	ACS03-C1448-539-P-DPE-0002	Zone 2	FAFNIR	VISY-STICK	122448	Ex ia	II C	T4	II 2 G	IP 68
1036	ACS03-539-LIT-2001	J	Magnetic Transmetues Nivel (Level Transmitter)	DIESEL FUEL SYSTEM	ACS03-539	ACS03-539-0100	ACS03-C1448-539-P-DPE-0002	Zone 2	FAFNIR	VISY-STICK	122442	Ex ia	II C	T4	II 2 G	IP 68
1037	ACS03-539-LIT-3001	J	Transmetues Nivel (Magnetic Level Transmitter)	DIESEL FUEL SYSTEM	ACS03-539	ACS03-539-0100	ACS03-C1448-539-P-DPE-0002	Zone 2	FAFNIR	VISY-STICK	122444	Ex ia	II C	T4	II 2 G	IP 68
1038	ACS03-539-PIT-0006	J	Transmetues presioni(Pressure Transmitter)	DIESEL FUEL SYSTEM	ACS03-539	ACS03-539-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1JN239000069	Ex d	II C	T4/T6	II 1/2 G	IP 66
1039	ACS03-551-A-5011	E	ventilator	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0100	ACS03-C1448-951-E-DEB-0026	Zone 2	STAHL	8265/53	1815754400440004	Ex d	II C	T4	II 2 G	IP 66
1040	ACS03-551-A-5012	E	ventilator	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0100	ACS03-C1448-951-E-DEB-0026	Zone 2	STAHL	8265/53	1815754400440005	Ex d	II C	T4	II 2 G	IP 66
1041	ACS03-551-A-5013	E	ventilator	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0100	ACS03-C1448-951-E-DEB-0026	Zone 2	STAHL	8265/53	1815754400440012	Ex d	II C	T4	II 2 G	IP 66
1042	ACS03-551-A-5014	E	ventilator	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0100	ACS03-C1448-951-E-DEB-0026	Zone 2	STAHL	8265/53	1815754400440004	Ex d	II C	T4	II 2 G	IP 66
1043	ACS03-551-A-5015	E	ventilator	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0100	ACS03-C1448-951-E-DEB-0026	Zone 2	STAHL	8265/53	1815754400440008	Ex d	II C	T4	II 2 G	IP 66
1044	ACS03-551-A-5021	E	ventilator	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0200	ACS03-C1448-951-E-DEB-0026	Zone 2	STAHL	8265/53	1815754400440010	Ex d	II C	T4	II 2 G	IP 66
1045	ACS03-551-A-5022	E	ventilator	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0200	ACS03-C1448-951-E-DEB-0026	Zone 2	STAHL	8265/53	1815754400440013	Ex d	II C	T4	II 2 G	IP 66
1046	ACS03-551-A-5023	E	ventilator	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0200	ACS03-C1448-951-E-DEB-0026	Zone 2	STAHL	8265/53	1815754400440014	Ex d	II C	T4	II 2 G	IP 66
1047	ACS03-551-A-5024	E	ventilator	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0200	ACS03-C1448-951-E-DEB-0026	Zone 2	STAHL	8265/53	1815754400440001	Ex d	II C	T4	II 2 G	IP 66
1048	ACS03-551-A-5025	E	ventilator	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0200	ACS03-C1448-951-E-DEB-0026	Zone 2	STAHL	8265/53	1815754400440009	Ex d	II C	T4	II 2 G	IP 66
1049	ACS03-551-A-5031	E	ventilator	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0300	ACS03-C1448-951-E-DEB-0007	Zone 2	STAHL	8265/53	1815754400440003	Ex d	II C	T4	II 2 G	IP 66
1050	ACS03-551-A-5032	E	ventilator	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0300	ACS03-C1448-951-E-DEB-0007	Zone 2	STAHL	8265/53	1815754400440007	Ex d	II C	T4	II 2 G	IP 66
1051	ACS03-551-A-5033	E	ventilator	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0300	ACS03-C1448-951-E-DEB-0007	Zone 2	STAHL	8265/53	1815754400440015	Ex d	II C	T4	II 2 G	IP 66
1052	ACS03-551-A-5034	E	ventilator	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0300	ACS03-C1448-951-E-DEB-0007	Zone 2	STAHL	8265/53	1815754400440006	Ex d	II C	T4	II 2 G	IP 66
1053	ACS03-551-A-5035	E	ventilator	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0300	ACS03-C1448-951-E-DEB-0007	Zone 2	STAHL	8265/53	1815754400440011	Ex d	II C	T4	II 2 G	IP 66
1054	ACS03-551-EHJ-P-1001	E	Kuti Shperndarese Compressor building Air heater JB Circuit 1	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0100		Zone 2	STAHL	8146/1071	1815739750440008	Ex e	II C	T4	II 2 G	IP 66
1055	ACS03-551-EHJ-P-2001	E	Kuti Shperndarese Compressor building Air heater JB Circuit 2	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0200		Zone 2	STAHL	8146/1071	1815739750440006	Ex e	II C	T4	II 2 G	IP 66
1056	ACS03-551-EHJ-P-3001	E	Kuti Shperndarese Compressor building Air heater JB Circuit 3	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0300		Zone 2	STAHL	8146/1071	1815739750440001	Ex e	II C	T4	II 2 G	IP 66
1057	ACS03-552-FIT-0001	J	Mates Positive Displacement Meter	CENTRAL HEATING SYSTEMS	ACS03-552	ACS03-552-1100	ACS03-C1448-856-J-DJA-0001	Safe Area	ELSTER	RABO G65 DN50	77073852/2018	Ex ia	II C	T4	II 2 G	IP 66
1058	ACS03-552-FIT-0001(EK-220)	J	Transmetues I prurjes Flow Transmitter(Volume Conversion Device)	CENTRAL HEATING SYSTEMS	ACS03-552	ACS03-552-1100	ACS03-C1448-856-J-DJA-0001	Zone 2	ELSTER	EK220	45108100 / S.N: 4493496	Ex ia	II C	T4	II 2 G	IP 66
1059	ACS03-552-FIT-0001(FE-260)	J	Transmetues I prurjes Flow Transmitter(Volume Conversion Device)	CENTRAL HEATING SYSTEMS	ACS03-552	ACS03-552-1100	ACS03-C1448-856-J-DJA-0001	Zone 2	ELSTER	FE-260-SVB	158897 / S.N: 73017231	Ex nA	II B	T4	II 2 G	IP 66
1060	ACS03-552-MV-5001-JB	J	Kuti shperndarese JB for 552-MV-5001	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0500	ACS03-C1448-534-H-DHB-0001	Zone 2	TECHNOR ITALSMEA	AR-2	I/19/46339	Ex e	II C	T6	II 2 G	IP 66
1061	ACS03-552-PIT-0002	J	Gauge Transmetues presioni(Pressure Transmitter)	FUEL GAS	ACS03-534	ACS03-534-0400	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	SITRANS P DSIII	N1JN239000070	Ex d	II C	T4/T6	II 1/2 G	IP 66
1062	ACS03-710-JB-0001	J	Instrumentation Kuti Shperndarese (Junction Box)	FIRE WATER SYSTEMS	ACS03-710	ACS03-710-1200	ACS03-C1448-856-J-DJA-0001	Safe Area	TECHNOR ITALSMEA	SB-282816	I/17/224485	Ex e	II C	T6	II 2 G	IP 66
1063	ACS03-710-JB-0100	J	Instrumentation Kuti Shperndarese (Junction Box)	FIRE WATER SYSTEMS	ACS03-710	ACS03-710-1200	ACS03-C1448-856-J-DJA-0001	Safe Area	TECHNOR ITALSMEA	SB-282816	I/17/224499	Ex e	II C	T6	II 2 G	IP 66
1064	ACS03-710-JB-0200	J	Instrumentation Kuti Shperndarese (Junction Box)	FIRE WATER SYSTEMS	ACS03-710	ACS03-710-1200	ACS03-C1448-856-J-DJA-0001	Safe Area	TECHNOR ITALSMEA	SB-282816	I/17/224534	Ex e	II C	T6	II 2 G	IP 66
1065	ACS03-710-JB-1001	J	Instrumentation Kuti Shperndarese (Junction Box)	FIRE WATER SYSTEMS	ACS03-710	ACS03-710-1200	ACS03-C1448-856-J-DJA-0001	Safe Area	TECHNOR ITALSMEA	SB-282816	I/17/224550	Ex ia	II C	T6	II 2 G	IP 66
1066	ACS03-710-LIT-0002	J	Transmetues Nivel (Level Transmitter) (Pulse Radar)	FIRE WATER SYSTEMS	ACS03-710	ACS03-710-1200	ACS03-C1448-856-J-DJA-0001	Safe Area	SIEMENS	SITRANS LR250	PBD/JN270071	Ex Na	II C	T4	II 3 G	IP 67/68
1067	ACS03-710-LIT-2005	J	Transmetues i nivelit (Radar Transmetues Nivel (Level Transmitter))	FIRE WATER SYSTEMS	ACS03-710	ACS03-710-1200	ACS03-C1448-710-P-DPE-0002	Safe Area	ROSEMOUNT	3105HA2FRCI1	JBG1052287	Ex ia	II C	T6	II 1 G	IP 66
1068	ACS03-710-LSHH-0003	J	Nivel (Level Switch High High)	FIRE WATER SYSTEMS	ACS03-710	ACS03-710-1200	ACS03-C1448-856-J-DJA-0001	Safe Area	ROSEMOUNT	ROSEMOUNT 2120	1239956	Ex d	II C	T6/T2	II 1/2 G	IP 66/67
1069	ACS03-710-LSLL-0015	J	Nivel (Level Switch Low Low)	FIRE WATER SYSTEMS	ACS03-710	ACS03-710-1200	ACS03-C1448-856-J-DJA-0001	Safe Area	ROSEMOUNT	ROSEMOUNT 2120	1239957	Ex d	II C	T6	II 1/2 G	IP 66/67
1070	ACS03-710-TIT-0016	J	Transmetues Temperature (Temperature Transmitter)	FIRE WATER SYSTEMS	ACS03-710	ACS03-710-1200	ACS03-C1448-856-J-DJA-0001	Safe Area	SIEMENS	SITRANS TH300	N1JN004474	Ex d	II C	T6	II 1/2 G	IP 65

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
1071	ACS03-740-FB-0001	J	Alarm sinjalizues zjarri Fire Alarm Beacon	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1118	ACS03-C1448-856-J-DJA-0001	Zone 2	AES	ETH20 MD-32	1856	Ex d	II C	T6	II 2 G	IP 65
1072	ACS03-740-FB-0002	J	Alarm sinjalizues zjarri Fire Alarm Beacon	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	AES	EVC50	1528 / S.N: 1853	Ex d	II C	T6	II 2 G	IP 65
1073	ACS03-740-FB-0003	J	Alarm sinjalizues zjarri Fire Alarm Beacon	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	AES	EVC50	1839	Ex d	II C	T6	II 2 G	IP 65
1074	ACS03-740-FB-0004	J	Alarm sinjalizues zjarri Fire Alarm Beacon	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	AES	EVC50	1824/ S.N: 1840	Ex d	II C	T6	II 2 G	IP 65
1075	ACS03-740-FB-0005	J	Alarm sinjalizues zjarri Fire Alarm Beacon	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	AES	EVC50	1798	Ex d	II C	T6	II 2 G	IP 65
1076	ACS03-740-FB-0006	J	Alarm sinjalizues zjarri Fire Alarm Beacon	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	AES	EVC50	1813/ S.N: 1860	Ex d	II C	T6	II 2 G	IP 65
1077	ACS03-740-FB-0007	J	Alarm sinjalizues zjarri Fire Alarm Beacon	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	AES	ETH20 MD-32	1844	Ex d	II C	T6	II 2 G	IP 65
1078	ACS03-740-FB-0008	J	Alarm sinjalizues zjarri Fire Alarm Beacon	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	AES	EVC50	1863	Ex d	II C	T6	II 2 G	IP 65
1079	ACS03-740-FD-0001	J	Detektor Zjarri (Flame Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1118	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	FS24X-9	S.N: 203961	Ex d	II C	T4/T6	II 2 G	IP 66
1080	ACS03-740-FD-0002	J	Detektor Zjarri (Flame Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1118	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	FS24X-9	S.N: 209277	Ex d	II C	T4/T6	II 2 G	IP 66
1081	ACS03-740-FD-0003	J	Detektor Zjarri (Flame Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1118	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	FS24X-9	S.N: 209270	Ex d	II C	T4/T6	II 2 G	IP 66
1082	ACS03-740-FD-0004	J	Detektor Zjarri (Flame Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1118	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	FS24X-9	S.N: 208529	Ex d	II C	T4/T6	II 2 G	IP 66
1083	ACS03-740-FD-0005	J	Detektor Zjarri (Flame Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1118	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	FS24X-9	S.N: 205010	Ex d	II C	T4/T6	II 2 G	IP 66
1084	ACS03-740-FD-0006	J	Detektor Zjarri (Flame Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1118	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	FS24X-9	S.N: 204985	Ex d	II C	T4/T6	II 2 G	IP 66
1085	ACS03-740-FD-0007	J	Detektor Zjarri (Flame Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1118	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	FS24X-9	205176	Ex db	II C	T6	II 2 G	IP 66
1086	ACS03-740-FD-0008	J	Detektor Zjarri (Flame Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1118	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	FS24X-9	205387	Ex db	II C	T6	II 2 G	IP 66
1087	ACS03-740-FD-0009	J	Detektor Zjarri (Flame Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1118	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	FS24X-9	S.N: 208609	Ex d	II C	T4/T6	II 2 G	IP 66
1088	ACS03-740-FD-0010	J	Detektor Zjarri (Flame Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1118	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	FS24X-9	208623	Ex db	II C	T6	II 2 G	IP 66
1089	ACS03-740-FD-0011	J	Detektor Zjarri (Flame Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	FS24X-9	205042	Ex d	II C	T4/T6	II 2 G	IP 66
1090	ACS03-740-FD-0012	J	Detektor Zjarri (Flame Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	FS24X-9	204242 / S.N: 204042	Ex db	II C	T6	II 2 G	IP 66
1091	ACS03-740-FD-0013	J	Detektor Zjarri (Flame Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	FS24X-9	205046	Ex db	II C	T6	II 2 G	IP 66
1092	ACS03-740-FD-0014	J	Detektor Zjarri (Flame Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	FS24X-9	204047	Ex d	II C	T4/T6	II 2 G	IP 66
1093	ACS03-740-FD-0015	J	Detektor Zjarri (Flame Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	FS24X-9	205166	Ex d	II C	T4/T6	II 2 G	IP 66
1094	ACS03-740-FD-0016	J	Detektor Zjarri (Flame Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	FS24X-9	204979	Ex db	II C	T6	II 2 G	IP 66
1095	ACS03-740-FD-0017	J	Detektor Zjarri (Flame Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	FS24X-9	203994	Ex d	II C	T4/T6	II 2 G	IP 66
1096	ACS03-740-FD-0018	J	Alarm sinjalizues zjarri Fire Alarm Beacon	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	FS24X-9	205041	Ex db	II C	T6/ T4	II 2 G	IP 66
1097	ACS03-740-FD-0019	J	Alarm sinjalizues zjarri Fire Alarm Beacon	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	FS24X-9	203978	Ex db	II C	T6	II 2 G	IP 66
1098	ACS03-740-FD-0020	J	Alarm sinjalizues zjarri Fire Alarm Beacon	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	FS24X-9	205371	Ex db	II C	T6	II 2 G	IP 66
1099	ACS03-740-FD-0021	J	Alarm sinjalizues zjarri Fire Alarm Beacon	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	FS24X-9	209360	Ex d	II C	T4/T6	II 2 G	IP 66
1100	ACS03-740-FD-0022	J	Alarm sinjalizues zjarri Fire Alarm Beacon	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	FS24X-9	205374	Ex d	II C	T4/T6	II 2 G	IP 66
1101	ACS03-740-FD-0023	J	Alarm sinjalizues zjarri Fire Alarm Beacon	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	FS24X-9	209244	Ex d	II C	T4/T6	II 2 G	IP 66
1102	ACS03-740-FD-0024	J	Alarm sinjalizues zjarri Fire Alarm Beacon	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	FS24X-9	204981	Ex db	II C	T6	II 2 G	IP 66
1103	ACS03-740-FD-0025	J	Alarm sinjalizues zjarri Fire Alarm Beacon	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	FS24X-9	203992	Ex db	II C	T6	II 2 G	IP 66
1104	ACS03-740-FD-0026	J	Detektor Zjarri (Flame Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	FS24X-9	203839	Ex db	II C	T6	II 2 G	IP 66
1105	ACS03-740-FD-0027	J	Detektor Zjarri (Flame Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	FS24X-9	205404	Ex d	II C	T4/T6	II 2 G	IP 66
1106	ACS03-740-FD-0028	J	Detektor Zjarri (Flame Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	FS24X-9	204978	Ex d	II C	T4/T6	II 2 G	IP 66
1107	ACS03-740-FD-0029	J	Detektor Zjarri (Flame Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	FS24X-9	205167	Ex db	II C	T6	II 2 G	IP 66

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
1145	ACS03-740-FD-0067	J	Detektor Zjarri (Flame Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	FS24X-9	203948	Ex d	II C	T4/T6	II 2 G	IP 66
1146	ACS03-740-FD-0068	J	Detektor Zjarri (Flame Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	FS24X-9	208570	Ex d	II C	T4/T6	II 2 G	IP 66
1147	ACS03-740-FD-0069	J	Detektor Zjarri (Flame Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	FS24X-9	205006	Ex d	II C	T4/T6	II 2 G	IP 66
1148	ACS03-740-FD-0070	J	Detektor Zjarri (Flame Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	FS24X-9	204045	Ex d	II C	T4/T6	II 2 G	IP 66
1149	ACS03-740-FD-0071	J	Detektor Zjarri (Flame Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	FS24X-9	204046	Ex d	II C	T4/T6	II 2 G	IP 66
1150	ACS03-740-FD-0072	J	Detektor Zjarri (Flame Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	FS24X-9	204064	Ex d	II C	T4/T6	II 2 G	IP 66
1151	ACS03-740-FD-0073	J	Detektor Zjarri (Flame Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	FS24X-9	205442	Ex d	II C	T4/T6	II 2 G	IP 66
1152	ACS03-740-FD-0074	J	Detektor Zjarri (Flame Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	FS24X-9	209284	Ex db	II C	T6	II 2 G	IP 66
1153	ACS03-740-FD-0075	J	Detektor Zjarri (Flame Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	FS24X-9	14982	Ex d	II B + H2	T6	II 2 G	IP 66
1154	ACS03-740-GB-0001	J	Ndricues I Alarmit te gazit Flammable Gas Alarm Beacon	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	AES	EVC50	1892/ S.N: 1802	Ex d	II C	T6	II 2 G	IP 65
1155	ACS03-740-GB-0002	J	Ndricues I Alarmit te gazit Flammable Gas Alarm Beacon	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	AES	EVC50	1794	Ex d	II C	T6	II 2 G	IP 65
1156	ACS03-740-GB-0003	J	Ndricues I Alarmit te gazit Flammable Gas Alarm Beacon	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	AES	EVC50	1840/ S.N: 1824	Ex d	II C	T6	II 2 G	IP 65
1157	ACS03-740-GB-0004	J	Ndricues I Alarmit te gazit Flammable Gas Alarm Beacon	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	AES	EVC50	1795	Ex d	II C	T6	II 2 G	IP 65
1158	ACS03-740-GB-0005	J	Ndricues I Alarmit te gazit Flammable Gas Alarm Beacon	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	AES	EVC50	1803	Ex d	II C	T6	II 2 G	IP 65
1159	ACS03-740-GB-0006	J	Ndricues I Alarmit te gazit Flammable Gas Alarm Beacon	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1118		Zone 2	AES	ETH20 MD-32	1797	Ex d	II C	T6	II 2 G	IP 66/ 65
1160	ACS03-740-GB-0007	J	Ndricues I Alarmit te gazit Flammable Gas Alarm Beacon	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	AES	EVC50	1815	Ex d	II C	T6	II 2 G	IP 65
1161	ACS03-740-GB-0008	J	Ndricues I Alarmit te gazit Flammable Gas Alarm Beacon	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	AES	EVC50	1799	Ex d	II C	T6	II 2 G	IP 65
1162	ACS03-740-GD-0001	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	CROWCON	IRmax	W274212/01-025	Ex d	II C	T6/ T4	II 2 G	IP 66
1163	ACS03-740-GD-0002	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	CROWCON	IRmax	W274209/01-002	Ex d	II C	T6/ T4	II 2 G	IP 66
1164	ACS03-740-GD-0003	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	CROWCON	IRmax	W274211/01-013	Ex d	II C	T6/ T4	II 2 G	IP 66
1165	ACS03-740-GD-0004	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	CROWCON	IRmax	W274204/01-030	Ex d	II C	T6/ T4	II 2 G	IP 66
1166	ACS03-740-GD-0005	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	CROWCON	IRmax	W274204/01-024	Ex d	II C	T6/ T4	II 2 G	IP 66
1167	ACS03-740-GD-0006	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	CROWCON	IRmax	W274209/01-003	Ex d	II C	T6/ T4	II 2 G	IP 66
1168	ACS03-740-GD-0007	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	CROWCON	IRmax	W274216/01-002	Ex d	II C	T6/ T4	II 2 G	IP 66
1169	ACS03-740-GD-0008	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	CROWCON	IRmax	W274219/01-013	Ex d	II C	T6/ T4	II 2 G	IP 66
1170	ACS03-740-GD-0009	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	CROWCON	IRmax	W274219/01-014	Ex d	II C	T6/ T4	II 2 G	IP 66
1171	ACS03-740-GD-0010	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	CROWCON	IRmax	W274219/01-017	Ex d	II C	T6/ T4	II 2 G	IP 66
1172	ACS03-740-GD-0011	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	CROWCON	IRmax	W274211/01-007	Ex d	II C	T6/ T4	II 2 G	IP 66
1173	ACS03-740-GD-0012	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	CROWCON	IRmax	W274204/01-022	Ex d	II C	T6	II 2 G	IP 66
1174	ACS03-740-GD-0013	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	CROWCON	IRmax	W274210/01-017/ S.N: W274219/01-019	Ex d	II C	T6	II 2 G	IP 66
1175	ACS03-740-GD-0014	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	CROWCON	IRmax	W274214/01-023	Ex d	II C	T6	II 2 G	IP 66
1176	ACS03-740-GD-0015	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	CROWCON	IRmax	W274210/01-008	Ex d	II C	T6	II 2 G	IP 66
1177	ACS03-740-GD-0016	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	CROWCON	IRmax	W274204/01-026	Ex d	II C	T6	II 2 G	IP 66
1178	ACS03-740-GD-0017	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	CROWCON	IRmax	W274210/01-020	Ex d	II C	T6	II 2 G	IP 66
1179	ACS03-740-GD-0018	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	CROWCON	IRmax	W274210/01-009	Ex d	II C	T6	II 2 G	IP 66
1180	ACS03-740-GD-0019	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	CROWCON	IRmax	W274210/01-026	Ex d	II C	T6	II 2 G	IP 66
1181	ACS03-740-GD-0020	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	CROWCON	IRmax	W274211/01-017	Ex d	II C	T6	II 2 G	IP 66

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
1256	ACS03-740-GD-0097	J	Detektor Gazi	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1118	ACS03-C1448-856-J-DJA-0001	Zone 2	CROWCON	IRmax	2274216/01-027	Ex d	II C	T4	II 2 G	IP 66
1257	ACS03-740-GD-0098	J	Detektor Gazi	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1118	ACS03-C1448-856-J-DJA-0001	Zone 2	CROWCON	IRMAX-AA-AC-011-AF-00	W274217/01-020	Ex d	II C	T6	II 2 GD	IP 66
1258	ACS03-740-GD-0099	J	Detektor Gazi	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1118	ACS03-C1448-856-J-DJA-0001	Zone 2	CROWCON	IRmax	W274217/01-002	Ex d	II C	T4	II 2 G	IP 66
1259	ACS03-740-GD-0100	J	Detektor Gazi	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1118	ACS03-C1448-856-J-DJA-0001	Zone 2	CROWCON	IRMAX-AA-AC-011-AF-00	W274217/01-023	Ex d	II C	T6	II 2 GD	IP 66
1260	ACS03-740-GD-0101	J	Detektor Gazi	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1118	ACS03-C1448-856-J-DJA-0001	Zone 2	CROWCON	IRMAX-AA-AC-011-AF-00	W274217/01-012	Ex d	II C	T6	II 2 GD	IP 66
1261	ACS03-740-GD-0102	J	Detektor Gazi	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1118	ACS03-C1448-856-J-DJA-0001	Zone 2	CROWCON	IRMAX-AA-AC-011-AF-00	W274217/01-022	Ex d	II C	T6	II 2 GD	IP 66
1262	ACS03-740-GD-0103	J	Detektor Gazi	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1118	ACS03-C1448-856-J-DJA-0001	Zone 2	CROWCON	IRMAX-AA-AC-011-AF-00	W274216/01-016 / S.N: W274217/01-028	Ex d	II C	T6	II 2 GD	IP 66
1263	ACS03-740-GD-0104	J	Detektor Gazi	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1118	ACS03-C1448-856-J-DJA-0001	Zone 2	CROWCON	IRMAX-AA-AC-011-AF-00	W274219/01-012	Ex d	II C	T6	II 2 GD	IP 66
1264	ACS03-740-GD-0105	J	Detektor Gazi	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1118	ACS03-C1448-856-J-DJA-0001	Zone 2	CROWCON	IRmax	W274219/01-012	Ex d	II C	T4	II 2 G	IP 66
1265	ACS03-740-GD-0106	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	SEARCHLINE	2186939 18	Ex d (ia)	II C	T6/T4	II 2 (1) G	IP 66
1266	ACS03-740-GD-0107	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	SEARCHLINE	7115958/21/11/7/010	Ex d op is	II C	T6	II 2 G	IP 66
1267	ACS03-740-GD-0108	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	SEARCHLINE	2186938 18	Ex d (ia)	II C	T6/T4	II 2 (1) G	IP 66
1268	ACS03-740-GD-0109	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	OTB122	7115992	Ex e	II C	T6	II 2 G	IP 66
1269	ACS03-740-GD-0110	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	SEARCHLINE	11/17/327	Ex d	II C	T6	II 2 G	IP 66
1270	ACS03-740-GD-0111	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	SEARCHLINE	7115163/11/17/371	Ex d op is	II C	T6	II 2 G	IP 66
1271	ACS03-740-GD-0112	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	SEARCHLINE	218695918	Ex d (ia)	II C	T6/T4	II 2 (1) G	IP 66
1272	ACS03-740-GD-0113	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	SEARCHLINE	7115995/11/17/310	Ex d op is	II C	T6	II 2 G	IP 66
1273	ACS03-740-GD-0114	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	SEARCHLINE	2186941 18	Ex d (ia)	II C	T6/T4	II 2 (1) G	IP 66
1274	ACS03-740-GD-0115	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	SEARCHLINE	7115986/12/17/007	Ex d op is	II C	T6	II 2 G	IP 66
1275	ACS03-740-GD-0116	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	SEARCHLINE	2186960 18 + S.N: 03/18/246	Ex d (ia)	II C	T6/T4	II 2 (1) G	IP 66
1276	ACS03-740-GD-0117	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	OTB122	7115996 + S.N: 11/17/297	Ex e	II C	T6	II 2 G	IP 66
1277	ACS03-740-GD-0118	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	CROWCON	IRmax	S.N: 11/17/368 + S.N: 2186945	Ex d	II C	T6	II 2 G	IP 66
1278	ACS03-740-GD-0119	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	OTB122	7116028 + S.N: 12/17/066	Ex e	II C	T6	II 2 G	IP 66
1279	ACS03-740-GD-0120	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	SEARCHLINE	49171284 18 + S.N: 11/17/362	Ex d (ia)	II C	T6/T4	II 2 (1) G	IP 66
1280	ACS03-740-GD-0121	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	SEARCHLINE	7116014 + S.N: 11/17/293	Ex d op is	II C	T6	II 2 G	IP 66
1281	ACS03-740-GD-0121	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	OTB122	N/A	Ex e	II C	T6	II 2 G	IP 66
1282	ACS03-740-GD-0122	J	Gas Detector	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1118	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	SEARCHLINE	49171281 18 + S.N: 11/17/259	Ex d	II C	T6/T4	II 2 G	IP 66
1283	ACS03-740-GD-0123	J	Gas Detector	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1118	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	SEARCHLINE	N/A	Ex d	II C	T6	II 2 G	IP 66
1284	ACS03-740-GD-0124	J	Gas Detector	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1118	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	SEARCHLINE	2186942 18 + S.N: 11/17/259	Ex d	II C	T6/T4	II 2 G	IP 66
1285	ACS03-740-GD-0125	J	Gas Detector	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1118	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	SEARCHLINE	S.N: 12/17/068	Ex e	II C	T6	II 2 G	IP 66
1286	ACS03-740-GD-0126	J	Gas Detector	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1118	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	SEARCHLINE	N/A	Ex de	II C	T6	II 2 G	IP 66
1287	ACS03-740-GD-0127	J	Gas Detector	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1118	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	SEARCHLINE	N/A + S.N: 11/17/364	Ex d	II C	T6	II 2 G	IP 66
1288	ACS03-740-GD-0128	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	SEARCHLINE	2186943 18 + S.N: 09/17/133	Ex d	II C	T6/T4	II 2 G	IP 66
1289	ACS03-740-GD-0129	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	OTB122	7116039 + S.N: 11/17/369	Ex e	II C	T6	II 2 G	IP 66
1290	ACS03-740-GD-0130	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	SEARCHLINE	49171266 18 + S.N: 11/17/319	Ex d (ia)	II C	T6/T4	II 2 (1) G	IP 66
1291	ACS03-740-GD-0131	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	OTB122	7115977 + S.N: 12/17/064	Ex e	II C	T6	II 2 G	IP 66
1292	ACS03-740-GD-0132	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	SEARCHLINE	2186951 18 + S.N: 11/17/357	Ex d (ia)	II C	T6/T4	II 2 (1) G	IP 66

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
1293	ACS03-740-GD-0133	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	OTB122	7115169 + S.N: 12/17/144	Ex e	II C	T6	II 2 G	IP 66
1294	ACS03-740-GD-0134	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	SEARCHLINE	49171292 18 + S.N: 11/17/320	Ex d (ia)	II C	T6/T4	II 2 (1) G	IP 66
1295	ACS03-740-GD-0135	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	HONEYWELL	OTB122	7115993, S.N: 11/17/055	Ex e	II C	T6	II 2 G	IP 66
1296	ACS03-740-GD-0136	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	CROWCON	IRmax	W274211/01-004	Ex d	II C	T4	II 2 G	IP 66
1297	ACS03-740-GD-0137	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	CROWCON	IRmax	W274217/01-026	Ex d	II C	T4	II 2 G	IP 66
1298	ACS03-740-JB-0701	J	Kuti Shperndarese (Junction Box)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-384520	I/17/225993	Ex e	II C	T6	II 2 G	IP 66
1299	ACS03-740-JB-0702	J	Kuti Shperndarese (Junction Box)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-384520	I/17/225995	Ex e	II C	T6	II 2 G	IP 66
1300	ACS03-740-JB-0703	J	Kuti Shperndarese (Junction Box)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-384520	I/17/226007	Ex e	II C	T6	II 2 G	IP 66
1301	ACS03-740-JB-0705	J	Kuti Shperndarese (Junction Box)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-384520	I/17/224501	Ex e	II C	T6	II 2 G	IP 66
1302	ACS03-740-JB-0706	J	Kuti Shperndarese (Junction Box)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-384520	I/17/226004	Ex e	II C	T6	II 2 G	IP 66
1303	ACS03-740-JB-0707	J	Kuti Shperndarese (Junction Box)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224494	Ex e	II C	T6	II 2 G	IP 66
1304	ACS03-740-JB-0709	J	Kuti Shperndarese (Junction Box)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-384520	I/17/225998	Ex e	II C	T6	II 2 G	IP 66
1305	ACS03-740-JB-0710	J	Kuti Shperndarese (Junction Box)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-384520	I/17/225988	Ex e	II C	T6	II 2 G	IP 66
1306	ACS03-740-JB-0711	J	Kuti Shperndarese (Junction Box)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-384520	I/17/226010	Ex e	II C	T6	II 2 GD	IP 66
1307	ACS03-740-JB-0712	J	Kuti Shperndarese (Junction Box)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224506	Ex e	II C	T6	II 2 GD	IP 66
1308	ACS03-740-JB-0714	J	Kuti Shperndarese (Junction Box)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-384520	I/17/226003	Ex e	II C	T6	II 2 GD	IP 66
1309	ACS03-740-JB-0716	J	Kuti Shperndarese (Junction Box)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101		Zone 2	TECHNOR ITALSMEA	SB-384520	I/17/226005	Ex e	II C	T6	II 2 GD	IP 66
1310	ACS03-740-JB-0717	J	Kuti Shperndarese (Junction Box)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101		Zone 2	TECHNOR ITALSMEA	SB-384520	I/17/225990	Ex e	II C	T6	II 2 GD	IP 66
1311	ACS03-740-JB-0719	J	Kuti Shperndarese (Junction Box)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1118	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-384520	I/17/225991	Ex e	II C	T6	II 2 GD	IP 66
1312	ACS03-740-JB-0720	J	Kuti Shperndarese (Junction Box)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1118	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-384520	I/17/225994	Ex e	II C	T6	II 2 GD	IP 66
1313	ACS03-740-JB-0721	J	Kuti Shperndarese (Junction Box)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224508	Ex e	II C	T6	II 2 GD	IP 66
1314	ACS03-740-JB-0722	J	Kuti Shperndarese (Junction Box)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224557	Ex e	II C	T6	II 2 G	IP 66
1315	ACS03-740-JB-0723	J	Kuti Shperndarese (Junction Box)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224556	Ex e	II C	T6	II 2 G	IP 66
1316	ACS03-740-JB-0724	J	Kuti Shperndarese (Junction Box)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222145	Ex e	II C	T6	II 2 GD	IP 66
1317	ACS03-740-JB-0725	J	Kuti Shperndarese (Junction Box)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-384520	I/17/225999	Ex e	II C	T6	II 2 G	IP 66
1318	ACS03-740-JB-0726	J	Kuti Shperndarese (Junction Box)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-384520	I/17/225987	Ex e	II C	T6	II 2 G	IP 66
1319	ACS03-740-JB-0727	J	Kuti Shperndarese (Junction Box)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224493	Ex e	II C	T6	II 2 GD	IP 66
1320	ACS03-740-JB-0728	J	Kuti Shperndarese (Junction Box)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224496	Ex e	II C	T6	II 2 GD	IP 66
1321	ACS03-740-JB-0729	J	Kuti Shperndarese (Junction Box)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224495	Ex e	II C	T6	II 2 GD	IP 66
1322	ACS03-740-JB-0730	J	Kuti Shperndarese (Junction Box)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-384520	I/17/225984	Ex e	II C	T6	II 2 G	IP 66
1323	ACS03-740-JB-0731	J	Kuti Shperndarese (Junction Box)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224510	Ex e	II C	T6	II 2 G	IP 66
1324	ACS03-740-JB-0732	J	Kuti Shperndarese (Junction Box)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224511	Ex e	II C	T6	II 2 G	IP 66
1325	ACS03-740-JB-0733	J	Kuti Shperndarese (Junction Box)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-384520	I/17/225992	Ex e	II C	T6	II 2 G	IP 66
1326	ACS03-740-JB-0734	J	Kuti Shperndarese (Junction Box)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224512	Ex e	II C	T6	II 2 GD	IP 66
1327	ACS03-740-JB-0735	J	Kuti Shperndarese (Junction Box)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-384520	I/17/225983	Ex e	II C	T6	II 2 GD	IP 66
1328	ACS03-740-JB-0736	J	Kuti Shperndarese (Junction Box)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224513	Ex e	II C	T6	II 2 G	IP 66
1329	ACS03-740-JB-0737	J	Kuti Shperndarese (Junction Box)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-384520	I/17/225997	Ex e	II C	T6	II 2 GD	IP 66

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
1367	ACS03-740-JB-1760	J	Kuti Shperndarese (Junction Box)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-353520	I/17/222173	Ex ia	II C	T6	II 2 G	IP 66
1368	ACS03-740-JB-1761	J	Kuti Shperndarese (Junction Box)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224548	Ex ia	II C	T6	II 2 G	IP 66
1369	ACS03-740-MAC-0001	J	Celes alarmi (Manual Call Point)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1118	ACS03-C1448-856-J-DJA-0001	Zone 2	MEDC	BGI	212196474 10 21	Ex ia	II C	T4	II 1 GD	IP 65
1370	ACS03-740-MAC-0002	J	Celes alarmi (Manual Call Point)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	MEDC / EATON	BGI	212196474 20 13	Ex ia	II C	T4	II 1 GD	IP 65
1371	ACS03-740-MAC-0003	J	Celes alarmi (Manual Call Point)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	MEDC	BGI	212196474 30 31	Ex ia	II C	T4	II 1 GD	IP 65
1372	ACS03-740-MAC-0004	J	Celes alarmi (Manual Call Point)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	MEDC	BGI	212196474 30 12	Ex ia	II C	T4	II 1 G	IP 65
1373	ACS03-740-MAC-0005	J	Celes alarmi (Manual Call Point)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	MEDC	BGI	212196474 20 22	Ex ia	II C	T4	II 1 G	IP 65
1374	ACS03-740-MAC-0006	J	Celes alarmi (Manual Call Point)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	MEDC	BGI	212196474 20 20	Ex ia	II C	T4	II 1 G	IP 65
1375	ACS03-740-MAC-0007	J	Celes alarmi (Manual Call Point)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	MEDC	BGI	212196474 20 26	Ex ia	II C	T4	II 1 G	IP 65
1376	ACS03-740-MAC-0008	J	Celes alarmi (Manual Call Point)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	MEDC	BGI	212196474 20 30	Ex ia	II C	T4	II 1 G	IP 65
1377	ACS03-740-MAC-0009	J	Celes alarmi (Manual Call Point)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	MEDC	BGI	212196474 10 07	Ex ia	II C	T4	II 1 G	IP 65
1378	ACS03-740-MAC-0010	J	Celes alarmi (Manual Call Point)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	MEDC	BGI	212196474 10 24	Ex ia	II C	T4	II 1 G	IP 65
1379	ACS03-740-MAC-0011	J	Celes alarmi (Manual Call Point)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	MEDC	BGI	212196474 30 20	Ex ia	II C	T4	II 1 GD	IP 65
1380	ACS03-740-MAC-0012	J	Celes alarmi (Manual Call Point)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-856-J-DJA-0001	Zone 2	MEDC	BGI	212196474 22/ S.N: 2121964743022	Ex ia	II C	T4	II 1 G	IP 65
1381	ACS03-770-LD-0031-A	J	Autoparlant Utility Building Indoor AVAS Loudspeaker	WARNING SYSTEMS	ACS03-770	ACS03-770-0100	ACS03-C1448.5000-770-T-DTA-0007	Zone 2	BOSCH	LH3-UC25XS	450221385707100082	Ex de m	II B + H2	T4	II 2 G	IP 66/67
1382	ACS03-770-LD-0049-A	J	Autoparlant Electrical Building Indoor AVAS Loudspeaker	WARNING SYSTEMS	ACS03-770	ACS03-770-0100	ACS03-C1448.5000-770-T-DTA-0005	Zone 2	BOSCH	LH3-UC25XS		Ex de m	II B + H2	T4	II 2 G	IP 66/67
1383	ACS03-770-LD-0050-A	J	Autoparlant Electrical Building Indoor AVAS Loudspeaker	WARNING SYSTEMS	ACS03-770	ACS03-770-0100	ACS03-C1448.5000-770-T-DTA-0005	Not on ITR	BOSCH	LH3-UC25XS	Not on ITR	Ex de m	II B + H2	T4	II 2 G	IP 66/67
1384	ACS03-770-LD-0053-A	J	Autoparlant Diesel Generators Area AVAS Loudspeaker	WARNING SYSTEMS	ACS03-770	ACS03-770-0100	ACS03-C1448.5000-770-T-DTA-0004	Zone 2	BOSCH	LH3-UC25XS	450221385707100071	Ex de m	II B + H2	T4	II 2 G	IP 66/67
1385	ACS03-770-LD-0054-A	J	Autoparlant Extinguishing Water Supply Building Outdoor AVAS Loudspeaker	WARNING SYSTEMS	ACS03-770	ACS03-770-0100	ACS03-C1448.5000-770-T-DTA-0004	Safe Area	BOSCH	LH3-UC25XS	450221385707100076	Ex de m	II B + H2	T4	II 2 G	IP 66/67
1386	ACS03-770-LD-0055-A	J	Autoparlant Fuel Gas Building Indoor AVAS Loudspeaker	WARNING SYSTEMS	ACS03-770	ACS03-770-0100	ACS03-C1448.5000-770-T-DTA-0004	Zone 2	BOSCH	LH3-UC25XS	450221385707100164	Ex de m	II B + H2	T4	II 2 G	IP 66/67
1387	ACS03-770-LD-0056-A	J	Autoparlant Outdoor Area Fuel Gas Building AVAS Loudspeaker	WARNING SYSTEMS	ACS03-770	ACS03-770-0100	ACS03-C1448.5000-770-T-DTA-0004	Safe Area	BOSCH	LH3-UC25XS		Ex de m	II B + H2	T4	II 2 G	IP 66/67
1388	ACS03-770-LD-0057-A	J	Autoparlant Outdoor Area Fuel Gas Building AVAS Loudspeaker	WARNING SYSTEMS	ACS03-770	ACS03-770-0100	ACS03-C1448.5000-770-T-DTA-0004	Safe Area	BOSCH	LH3-UC25XS		Ex de m	II B + H2	T4	II 2 G	IP 66/67
1389	ACS03-770-LD-0058-A	J	Autoparlant Outdoor Area Fuel Gas Building AVAS Loudspeaker	WARNING SYSTEMS	ACS03-770	ACS03-770-0100	ACS03-C1448.5000-770-T-DTA-0004	Safe Area	BOSCH	LH3-UC25XS	450221385707100170	Ex de m	II B + H2	T4	II 2 G	IP 66/67
1390	ACS03-770-LD-0059-A	J	Autoparlant Compressor Building 1 Indoor AVAS Loudspeaker	WARNING SYSTEMS	ACS03-770	ACS03-770-0100	ACS03-C1448.5000-770-T-DTA-0009	Zone 2	BOSCH	LH3-UC25XS	450221385707100143	Ex de m	II B + H2	T4	II 2 G	IP 66/67
1391	ACS03-770-LD-0060-A	J	Autoparlant Compressor Building 1 Indoor AVAS Loudspeaker	WARNING SYSTEMS	ACS03-770	ACS03-770-0100	ACS03-C1448.5000-770-T-DTA-0009	Zone 2	BOSCH	LH3-UC25XS	450221385707100146	Ex de m	II B + H2	T4	II 2 G	IP 66/67
1392	ACS03-770-LD-0061-A	J	Autoparlant Compressor Building 1 Indoor AVAS Loudspeaker	WARNING SYSTEMS	ACS03-770	ACS03-770-0100	ACS03-C1448.5000-770-T-DTA-0009	Not on ITR	BOSCH	LH3-UC25XS	450221385707100141	Ex de m	II B + H2	T4	II 2 G	IP 66/67
1393	ACS03-770-LD-0062-A	J	Autoparlant Compressor Building 1 Indoor AVAS Loudspeaker	WARNING SYSTEMS	ACS03-770	ACS03-770-0100	ACS03-C1448.5000-770-T-DTA-0009	Zone 2	BOSCH	LH3-UC25XS	450221385707100147	Ex de m	II B + H2	T4	II 2 G	IP 66/67
1394	ACS03-770-LD-0063-A	J	Autoparlant Compressor Building 1 Indoor AVAS Loudspeaker	WARNING SYSTEMS	ACS03-770	ACS03-770-0100	ACS03-C1448.5000-770-T-DTA-0009	Zone 2	BOSCH	LH3-UC25XS	450221385707100155	Ex de m	II B + H2	T4	II 2 G	IP 66/67
1395	ACS03-770-LD-0064-A	J	Autoparlant Compressor Building 2 Outdoor AVAS Loudspeaker	WARNING SYSTEMS	ACS03-770	ACS03-770-0100	ACS03-C1448.5000-770-T-DTA-0009	Safe Area	BOSCH	LH3-UC25XS	450221385707100151	Ex de m	II B + H2	T4	II 2 G	IP 66/67
1396	ACS03-770-LD-0065-A	J	Autoparlant Compressor Building 2 Outdoor AVAS Loudspeaker	WARNING SYSTEMS	ACS03-770	ACS03-770-0100	ACS03-C1448.5000-770-T-DTA-0009	Zone 2	BOSCH	LH3-UC25XS	450221385707100160	Ex de m	II B + H2	T4	II 2 G	IP 66/67
1397	ACS03-770-LD-0066-A	J	Autoparlant Compressor Building 2 Outdoor AVAS Loudspeaker	WARNING SYSTEMS	ACS03-770	ACS03-770-0100	ACS03-C1448.5000-770-T-DTA-0009	Zone 2	BOSCH	LH3-UC25XS	450221385707100165	Ex de m	II B + H2	T4	II 2 G	IP 66/67
1398	ACS03-770-LD-0067-A	J	Autoparlant Compressor Building 3 Outdoor AVAS Loudspeaker	WARNING SYSTEMS	ACS03-770	ACS03-770-0100	ACS03-C1448.5000-770-T-DTA-0009	Zone 2	BOSCH	LH3-UC25XS	450221385707100153	Ex de m	II B + H2	T4	II 2 G	IP 66/67
1399	ACS03-770-LD-0068-A	J	Autoparlant Compressor Building 3 Outdoor AVAS Loudspeaker	WARNING SYSTEMS	ACS03-770	ACS03-770-0100	ACS03-C1448.5000-770-T-DTA-0009	Zone 2	BOSCH	LH3-UC25XS	450221385707100144	Ex de m	II B + H2	T4	II 2 G	IP 66/67
1400	ACS03-770-LD-0069-A	J	Autoparlant Gas Analyser Building Indoor AVAS Loudspeaker	WARNING SYSTEMS	ACS03-770	ACS03-770-0100		Safe Area	BOSCH	LH3-UC25XS	450221385707100148	Ex de m	II B + H2	T4	II 2 G	IP 66/67
1401	ACS03-770-LD-0070-A	J	Autoparlant Outdoor Process Area AVAS Loudspeaker	WARNING SYSTEMS	ACS03-770	ACS03-770-0100	ACS03-C1448.5000-770-T-DTA-0004	Safe Area	BOSCH	LH3-UC25XS	450221385707100169	Ex de m	II B + H2	T4	II 2 G	IP 66/67
1402	ACS03-770-LD-0071-A	J	Autoparlant Outdoor Process Area AVAS Loudspeaker	WARNING SYSTEMS	ACS03-770	ACS03-770-0100	ACS03-C1448.5000-770-T-DTA-0004	Safe Area	BOSCH	LH3-UC25XS	450221385707100168	Ex de m	II B + H2	T4	II 2 G	IP 66/67
1403	ACS03-770-LD-0072-A	J	Autoparlant Outdoor Process Area AVAS Loudspeaker	WARNING SYSTEMS	ACS03-770	ACS03-770-0100	ACS03-C1448.5000-770-T-DTA-0004	Safe Area	BOSCH	LH3-UC25XS	450221385707100154	Ex de m	II B + H2	T4	II 2 G	IP 66/67

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
1404	ACS03-770-LD-0073-A	J	Autoparlant Outdoor Process Area AVAS Loudspeaker	WARNING SYSTEMS	ACS03-770	ACS03-770-0100	ACS03-C1448.5000-770-T-DTA-0004	Zone 2	BOSCH	LH3-UC25XS	450221385707100163	Ex de m	II B + H2	T4	II 2 G	IP 66/67
1405	ACS03-770-LD-0074-A	J	Autoparlant Start Up Gas Cooler AVAS Loudspeaker	WARNING SYSTEMS	ACS03-770	ACS03-770-0100	ACS03-C1448.5000-770-T-DTA-0004	Zone 2	BOSCH	LH3-UC25XS	450221385707100150	Ex de m	II B + H2	T4	II 2 G	IP 66/67
1406	ACS03-770-LD-0075-A	J	Autoparlant Start Up Gas Cooler AVAS Loudspeaker	WARNING SYSTEMS	ACS03-770	ACS03-770-0100	ACS03-C1448.5000-770-T-DTA-0004	Zone 2	BOSCH	LH3-UC25XS	450221385707100142	Ex de m	II B + H2	T4	II 2 G	IP 66/67
1407	ACS03-770-LD-0076-A	J	Autoparlant Start Up Gas Cooler AVAS Loudspeaker	WARNING SYSTEMS	ACS03-770	ACS03-770-0100	ACS03-C1448.5000-770-T-DTA-0004	Zone 2	BOSCH	LH3-UC25XS	450221385707100145	Ex de m	II B + H2	T4	II 2 G	IP 66/67
1408	ACS03-770-LD-0077-A	J	Autoparlant Start Up Gas Cooler AVAS Loudspeaker	WARNING SYSTEMS	ACS03-770	ACS03-770-0100	ACS03-C1448.5000-770-T-DTA-0004	Zone 2	BOSCH	LH3-UC25XS	450221385707100159	Ex de m	II B + H2	T4	II 2 G	IP 66/67
1409	ACS03-770-LD-0078-A	J	Autoparlant Gas Generator Building Indoor AVAS Loudspeaker	WARNING SYSTEMS	ACS03-770	ACS03-770-0100		Safe Area	BOSCH	LH3-UC25XS	450221385707100070	Ex de m	II B + H2	T4	II 2 G	IP 66/67
1410	ACS03-770-LD-0079-A	J	Autoparlant Gas Generator Building Outdoor AVAS Loudspeaker	WARNING SYSTEMS	ACS03-770	ACS03-770-0100	ACS03-C1448.5000-770-T-DTA-0004	Zone 2	BOSCH	LH3-UC25XS	450221385707100149	Ex de m	II B + H2	T4	II 2 G	IP 66/67
1411	ACS03-800-1400-1.13A / Zevendesuar me tag ACS03-957-SW-1.13A	E	celes dritash	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1400	ACS03-C1448-957-E-DEB-0009	Zone 2	STAHL	8040/11-V30-035-S	1916055750440019	Ex de	II C	T6	II 2 G	IP 66
1412	ACS03-800-1400-1.13B / Zevendesuar me tag ACS03-957-SW-1.13B	E	celes dritash	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1400	ACS03-C1448-957-E-DEB-0009	Zone 2	STAHL	8040/11-V30-035-S	1916055750440020	Ex de	II C	T6	II 2 G	IP 66
1413	ACS03-800-1400-1.14A / Zevendesuar me tag ACS03-957-SW-1.14A	E	celes dritash	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1400	ACS03-C1448-957-E-DEB-0009	Zone 2	STAHL	8040/11-V30-035-S	1916055750440016	Ex de	II C	T6	II 2 G	IP 66
1414	ACS03-800-1400-1.14B / Zevendesuar me tag ACS03-957-SW-1.14B	E	celes dritash	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1400	ACS03-C1448-957-E-DEB-0009	Zone 2	STAHL	8040/11-V30-035-S	1916106950440000	Ex de	II C	T6	II 2 G	IP 66
1415	ACS03-810-PIT-0001	J	Transmetues presioni(Pressure Transmitter)	ELECTRICAL POWER GENERATION	ACS03-810	ACS03-810-0100		Safe Area	SIEMENS	SITRANS P DSIII	N1L6109000076	Ex d	II C	T4/T6	II 1/2 G	IP 66
1416	ACS03-820-EHJ-H-0001	E	Kuti shperndarese Filter Separators (Condensate Heat Tracing) JB1	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS03-820	ACS03-820-0902	ACS03-C1448.3500-820-E-DFB-0001	Zone 2	SPINA	JBPN-252512	18/02718	Ex e	II C	T4	II 2 G	IP 66
1417	ACS03-820-EHJ-H-0001-001	E	Kuti Shperndarese Filter Separators (Condensate Heat Tracing) JB1 - Subdistribution 001	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS03-820	ACS03-820-0902	ACS03-C1448.3500-820-E-DFB-0001	Zone 2	ELTHERM	ELAK-EX-3.7 / 0X80057	2198	Ex e	II C	T4 / T6	II 2 G	IP 66
1418	ACS03-820-EHJ-H-0001-002	E	Kuti Shperndarese Filter Separators (Condensate Heat Tracing) JB1 - Subdistribution 002	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS03-820	ACS03-820-0902	ACS03-C1448.3500-820-E-DFB-0001	Zone 2	ELTHERM	ELAK-EX-3.7 / 0X80057	2196	Ex e	II C	T4 / T6	II 2 G	IP 66
1419	ACS03-820-EHJ-H-0001-003	E	Kuti Shperndarese Filter Separators (Condensate Heat Tracing) JB1 - Subdistribution 003	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS03-820	ACS03-820-0902	ACS03-C1448.3500-820-E-DFB-0001	Zone 2	ELTHERM	ELAK-EX-3.7 / 0X80057	2204	Ex e	II C	T4 / T6	II 2 G	IP 66
1420	ACS03-820-EHJ-H-0001-004	E	Kuti Shperndarese Filter Separators (Condensate Heat Tracing) JB1 - Subdistribution 004	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS03-820	ACS03-820-0902	ACS03-C1448.3500-820-E-DFB-0001	Zone 2	ELTHERM	ELAK-EX-3.7 / 0X80057	2164	Ex e	II C	T4 / T6	II 2 G	IP 66
1421	ACS03-820-EHJ-H-0001-005	E	Kuti Shperndarese Filter Separators (Condensate Heat Tracing) JB1 - Subdistribution 005	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS03-820	ACS03-820-0902	ACS03-C1448.3500-820-E-DFB-0001	Zone 2	ELTHERM	ELAK-EX-3.7 / 0X80057	2168	Ex e	II C	T4	II 2 G	IP 66
1422	ACS03-820-EHJ-H-0002	E	Kuti Shperndarese Filter Separators (Condensate Heat Tracing) JB2	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS03-820	ACS03-820-0902	ACS03-C1448.3500-820-E-DFB-0001	Zone 2	SPINA	JBPN-252512	18/02719	Ex e	II C	T4	II 2 G	IP 66
1423	ACS03-820-EHJ-H-0002-001	E	Kuti Shperndarese Filter Separators (Condensate Heat Tracing) JB2 - Subdistribution 001	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS03-820	ACS03-820-0902	ACS03-C1448.3500-820-E-DFB-0001	Zone 2	ELTHERM	ELAK-EX-3.7 / 0X80057	2163	Ex e	II C	T6	II 2 G	IP 66
1424	ACS03-820-EHJ-H-0002-002	E	Kuti Shperndarese Filter Separators (Condensate Heat Tracing) JB2 - Subdistribution 002	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS03-820	ACS03-820-0902	ACS03-C1448.3500-820-E-DFB-0001	Zone 2	ELTHERM	ELAK-EX-3.7 / 0X80057	2162	Ex e	II C	T4	II 2 G	IP 66
1425	ACS03-820-EHJ-H-0002-003	E	Kuti Shperndarese Filter Separators (Condensate Heat Tracing) JB2 - Subdistribution 003	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS03-820	ACS03-820-0902	ACS03-C1448.3500-820-E-DFB-0001	Zone 2	ELTHERM	ELAK-EX-3.7 / 0X80057	2203	Ex e	II C	T4	II 2 G	IP 66
1426	ACS03-820-EHJ-H-0002-004	E	Kuti Shperndarese Filter Separators (Condensate Heat Tracing) JB2 - Subdistribution 004	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS03-820	ACS03-820-0902	ACS03-C1448.3500-820-E-DFB-0001	Zone 2	ELTHERM	ELAK-EX-3.7 / 0X80057	2175	Ex e	II C	T4	II 2 G	IP 66
1427	ACS03-820-EHJ-H-0002-005	E	Kuti Shperndarese Filter Separators (Condensate Heat Tracing) JB2 - Subdistribution 005	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS03-820	ACS03-820-0902	ACS03-C1448.3500-820-E-DFB-0001	Zone 2	ELTHERM	ELAK-EX-3.7 / 0X80057	2161	Ex e	II C	T4	II 2 G	IP 66
1428	ACS03-820-EHJ-H-0003	E	Kuti Shperndarese Filter Separators (Condensate Heat Tracing) JB3	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS03-820	ACS03-820-0902	ACS03-C1448.3500-820-E-DFB-0001	Zone 2	SPINA	JBPN-252512	18/02720	Ex e	II C	T4	II 2 G	IP 66
1429	ACS03-820-EHJ-H-0003-001	E	Kuti Shperndarese Filter Separators (Condensate Heat Tracing) JB3 - Subdistribution 001	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS03-820	ACS03-820-0902	ACS03-C1448.3500-820-E-DFB-0001	Zone 2	ELTHERM	ELAK-EX-3.7 / 0X80057	2189	Ex e	II C	T4	II 2 G	IP 66
1430	ACS03-820-EHJ-H-0003-002	E	Kuti Shperndarese Filter Separators (Condensate Heat Tracing) JB3 - Subdistribution 002	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS03-820	ACS03-820-0902	ACS03-C1448.3500-820-E-DFB-0001	Zone 2	ELTHERM	ELAK-EX-3.7 / 0X80057	2200	Ex e	II C	T4	II 2 G	IP 66
1431	ACS03-820-EHJ-H-0003-003	E	Kuti Shperndarese Filter Separators (Condensate Heat Tracing) JB3 - Subdistribution 003	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS03-820	ACS03-820-0902	ACS03-C1448.3500-820-E-DFB-0001	Zone 2	ELTHERM	ELAK-EX-3.7 / 0X80057	2174	Ex e	II C	T4	II 2 G	IP 66
1432	ACS03-820-EHJ-H-0003-004	E	Kuti Shperndarese Filter Separators (Condensate Heat Tracing) JB3 - Subdistribution 004	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS03-820	ACS03-820-0902	ACS03-C1448.3500-820-E-DFB-0001	Zone 2	ELTHERM	ELAK-EX-3.7 / 0X80057	2000	Ex e	II C	T4 / T6	II 2 G	IP 66
1433	ACS03-820-EHJ-H-0003-005	E	Kuti Shperndarese Filter Separators (Condensate Heat Tracing) JB3 - Subdistribution 005	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS03-820	ACS03-820-0902	ACS03-C1448.3500-820-E-DFB-0001	Zone 2	ELTHERM	ELAK-EX-3.7 / 0X80057	2150	Ex e	II C	T4 / T6	II 2 G	IP 66
1434	ACS03-820-EHJ-H-0004	E	Kuti Shperndarese Compressor 1 (Gas Heat Tracing) Lines 320-1401/1402 JB	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS03-820	ACS03-820-0902	ACS03-C1448.3500-820-E-DFB-0001	Zone 2	SPINA	JBPN-252512	18/02732	Ex e	II C	T4	II 2 G	IP 66
1435	ACS03-820-EHJ-H-0004-001	E	Kuti Shperndarese Compressor 1 (Gas Heat Tracing) Lines 320-1401/1402 JB - Subdistribution 001	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS03-820	ACS03-820-0902	ACS03-C1448.3500-820-E-DFB-0001	Zone 2	ELTHERM	EL-CT (2)-65	28/2018-06	Ex d	II C	T6	II 2 G	IP 66
1436	ACS03-820-EHJ-H-0004-002	E	Kuti Shperndarese Compressor 1 (Gas Heat Tracing) Lines 320-1401/1402 JB - Subdistribution 002	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS03-820	ACS03-820-0902	ACS03-C1448.3500-820-E-DFB-0001	Zone 2	ELTHERM	EL-CT (2)-65	28/2018-02	Ex d	II C	T6	II 2 G	IP 66
1437	ACS03-820-EHJ-H-0004-003	E	Kuti Shperndarese Compressor 1 (Gas Heat Tracing) Lines 320-1401/1402 JB - Subdistribution 003	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS03-820	ACS03-820-0902	ACS03-C1448.3500-820-E-DFB-0001	Zone 2	ELTHERM	EL-CT (2)-65	28/2018-07	Ex d	II C	T6	II 2 G	IP 66
1438	ACS03-820-EHJ-H-0005	E	Kuti Shperndarese Compressor 2 (Gas Heat Tracing) Lines 320-2401/2402 JB	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS03-820	ACS03-820-0902	ACS03-C1448.3500-820-E-DFB-0001	Zone 2	SPINA	JBPN-252512	18/02733	Ex e	II C	T4	II 2 G	IP 66
1439	ACS03-820-EHJ-H-0005-001	E	Kuti Shperndarese Compressor 2 (Gas Heat Tracing) Lines 320-2401/2402 JB - Subdistribution 001	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS03-820	ACS03-820-0902	ACS03-C1448.3500-820-E-DFB-0001	Zone 2	ELTHERM	EL-CT (2)-65	28/2018-04	Ex d	II C	T6	II 2 G	IP 66
1440	ACS03-820-EHJ-H-0005-002	E	Kuti Shperndarese Compressor 2 (Gas Heat Tracing) Lines 320-2401/2402 JB - Subdistribution 002	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS03-820	ACS03-820-0902	ACS03-C1448.3500-820-E-DFB-0001	Zone 2	ELTHERM	EL-CT (2)-65	28/2018-03	Ex d	II C	T6	II 2 G	IP 66

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
1478	ACS03-820-EHJ-H-0015-002	E	Kuti Shperndarese (Junction Box)	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL	ACS03-820	ACS03-820-0902	ACS03-C1448.3500-820-E-DFB-0001	Safe Area	ELTHERM	ELAK-EX-3.7 / 0X80057	2193	Ex e	II C	T4	II 2 G	IP 66
1479	ACS03-820-EHJ-H-0015-003	E	Kuti Shperndarese (Junction Box)	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL	ACS03-820	ACS03-820-0902	ACS03-C1448.3500-820-E-DFB-0001	Safe Area	ELTHERM	ELAK-EX-3.7 / 0X80057	2172	Ex e	II C	T4	II 2 G	IP 66
1480	ACS03-820-EHJ-H-0016-001	E	Kuti Shperndarese (Junction Box)	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL	ACS03-820	ACS03-820-0902	ACS03-C1448.3500-820-E-DFB-0001	Zone 2	ABTECH	ZAG 9.9	1068944	Ex e	II C	T6	II 2 G	IP 66/67
1481	ACS03-820-EHJ-H-0016-001C	E	Kuti Shperndarese (Junction Box)	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL	ACS03-820	ACS03-820-0902	ACS03-C1448.3500-820-E-DFB-0001	Zone 2	ELTHERM	ELAK-EX-3.8 / 0X80058	2015	Ex e	II C	T6	II 2 G	IP 66
1482	ACS03-820-EHJ-H-0017-001	E	Kuti Shperndarese (Junction Box)	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL	ACS03-820	ACS03-820-0902	ACS03-C1448.3500-820-E-DFB-0001	Zone 2	ABTECH	ZAG 9.9	1068943	Ex e	II C	T6	II 2 G	IP 66/67
1483	ACS03-820-EHJ-H-0017-001C	E	Kuti Shperndarese (Junction Box)	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL	ACS03-820	ACS03-820-0902	ACS03-C1448.3500-820-E-DFB-0001	Zone 2	ELTHERM	ELAK-EX-3.8 / 0X80058	2009	Ex e	II C	T6	II 2 G	IP 66
1484	ACS03-820-EHJ-H-0018-001	E	Kuti Shperndarese (Junction Box)	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL	ACS03-820	ACS03-820-0902	ACS03-C1448.3500-820-E-DFB-0001	Zone 2	ABTECH	ZAG 9.9	1868942	Ex e	II C	T6	II 2 G	IP 66/67
1485	ACS03-820-EHJ-H-0018-001C	E	Kuti Shperndarese (Junction Box)	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL	ACS03-820	ACS03-820-0902	ACS03-C1448.3500-820-E-DFB-0001	Zone 2	ELTHERM	ELAK-EX-3.8 / 0X80058	2006	Ex e	II C	T6	II 2 G	IP 66
1486	ACS03-820-EHJ-H-0019-001	E	Kuti Shperndarese (Junction Box)	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL	ACS03-820	ACS03-820-0903	ACS03-C1448.3500-820-E-DFB-0001	Zone 1	ELTHERM	ELAK-EX-3.7 / 0X80057	2188	Ex e	II C	T4	II 2 G	IP 66
1487	ACS03-820-EHJ-H-0019-001C	E	Kuti Shperndarese (Junction Box)	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL	ACS03-820	ACS03-820-0903	ACS03-C1448.3500-820-E-DFB-0001	Zone 1	ELTHERM	ELAK-EX-3.7 / 0X80057	2205	Ex e	II C	T4	II 2 G	IP 66
1488	ACS03-820-EHJ-H-0021	E	Kuti Shperndarese (Junction Box)	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL	ACS03-820	ACS03-820-0902		Zone 2	STAHL	8146/1051	1815738950440138	Ex e	II C	T4	II 2 G	IP 66
1489	ACS03-820-EHJ-H-0022	E	Kuti Shperndarese (Junction Box)	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL	ACS03-820	ACS03-820-0902		Safe Area	STAHL	8146/1051	1916784240440000	Ex e	II C	T6	II 2 G	IP 66
1490	ACS03-820-EHJ-H-0023	E	Kuti Shperndarese (Junction Box)	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL	ACS03-820	ACS03-820-0902		Zone 2	ELTHERM	ELAK-EX-3.8 / 0X80058	2027	Ex e	II C	T6	II 2 G	IP 66
1491	ACS03-820-EHJ-H-0024	E	Kuti Shperndarese (Junction Box)	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL	ACS03-820	ACS03-820-0902		Zone 2	ELTHERM	ELAK-EX-3.7 / 0X80057	2197	Ex e	II C	T6	II 2 G	IP 66
1492	ACS03-820-EHJ-H-1678	E	Kuti Shperndarese (Junction Box)	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL	ACS03-820	ACS03-820-0902		Zone 2	STAHL	8146/1S71	1916248840440000	Ex e	II C	T4	II 2 G	IP 66
1493	ACS03-820-EHS-P-1001	E	Kuti Shperndarese (Junction Box)	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1301	ACS03-820-E-DEA-0002	Zone 2	STAHL	8146/5000	1815754500440002	Ex de	II C	T4	II 2 G	IP 66
1494	ACS03-820-EHS-P-1002	E	Prize (Power Socket) 1	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1301	ACS03-820-E-DEA-0002	Zone 2	STAHL	8146/5000	1815754500440008	Ex de	II C	T4	II 2 G	IP 66
1495	ACS03-820-EHS-P-1003	E	Prize (Power Socket) 1	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1301	ACS03-820-E-DEA-0002	Zone 2	STAHL	8146/5000	10001836258044	Ex de	II C	T4	II 2 G	IP 66
1496	ACS03-820-EHS-P-2001	E	Kuti Shperndarese (Junction Box)	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1301	ACS03-820-E-DEA-0002	Zone 2	STAHL	8146/5000	1815754500440009	Ex de	II C	T4	II 2 G	IP 66
1497	ACS03-820-EHS-P-2002	E	Prize (Power Socket) 1	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1301	ACS03-820-E-DEA-0002	Zone 2	STAHL	8146/5000	1815754500440001	Ex de	II C	T4	II 2 G	IP 66
1498	ACS03-820-EHS-P-2002	E	Prize (Power Socket) 1	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1301	ACS03-820-E-DEA-0002	Zone 2	STAHL	8146/5000	1815754500440001	Ex de	II C	T4	II 2 G	IP 66
1499	ACS03-820-EHS-P-2002	E	Prize (Power Socket) 1	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1301	ACS03-820-E-DEA-0002	Zone 2	STAHL	8265/56	1815754500440001	Ex db eb	II C	T4	II 2 G	IP 66
1500	ACS03-820-EHS-P-2002	E	Prize (Power Socket) 1	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1301	ACS03-820-E-DEA-0002	Zone 2	STAHL	8570/15-306	NOT ILLEGIBLE	Ex eb	II C	T6	II 2 GD	IP 66
1501	ACS03-820-EHS-P-2002	E	Prize (Power Socket) 1	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1301	ACS03-820-E-DEA-0002	Zone 2	STAHL	8570/15-506	10001820656044	Ex eb	II C	T6	II 2 GD	IP 66
1502	ACS03-820-EHS-P-2003	E	Prize (Power Socket) 1	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1301	ACS03-820-E-DEA-0002	Zone 2	STAHL	8571/15-506	10001824168044	Ex db eb	II C	T5	II 2 GD	IP 66
1503	ACS03-820-EHS-P-3001	E	Kuti Shperndarese (Junction Box)	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1301	ACS03-820-E-DEA-0002	Zone 2	STAHL	8146/5000	1815754500440004	Ex de	II C	T4	II 2 G	IP 66
1504	ACS03-820-EHS-P-3002	E	Prize (Power Socket) 1	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1301	ACS03-820-E-DEA-0002	Zone 2	STAHL	8146/5000	1815754500440007	Ex db eb	II C	T4	II 2 G	IP 66
1505	ACS03-820-EHS-P-3002	E	Prize (Power Socket) 1	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1301	ACS03-820-E-DEA-0002	Zone 2	STAHL	8265/56	1815754500440007	Ex db eb	II C	T4	II 2 G	IP 66
1506	ACS03-820-EHS-P-3002	E	Prize (Power Socket) 1	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1301	ACS03-820-E-DEA-0002	Zone 2	STAHL	8570/15-306	10001836246044	Ex eb	II C	T6	II 2 GD	IP 66
1507	ACS03-820-EHS-P-3002	E	Prize (Power Socket) 1	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1301	ACS03-820-E-DEA-0002	Zone 2	STAHL	8570/15-506	10001820858044	Ex eb	II C	T6	II 2 GD	IP 66
1508	ACS03-820-EHS-P-3002	E	Prize (Power Socket) 1	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1301	ACS03-820-E-DEA-0002	Zone 2	STAHL	8571/15-506	10001820858044	Ex db eb	II C	T5	II 2 GD	IP 66
1509	ACS03-820-EHS-P-3003	E	Prize (Power Socket) 1	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1301	ACS03-820-E-DEA-0002	Zone 2	STAHL	8146/5000	1815754500440003	Ex de	II C	T4	II 2 G	IP 66
1510	ACS03-820-EHS-P-3003	E	Prize (Power Socket) 1	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1301	ACS03-820-E-DEA-0002	Zone 2	STAHL	8265/56	1815754500440003	Ex db eb	II C	T4	II 2 G	IP 66
1511	ACS03-820-EHS-P-3003	E	Prize (Power Socket) 1	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1301	ACS03-820-E-DEA-0002	Zone 2	STAHL	8570/15-306	10001836250044	Ex eb	II C	T6	II 2 GD	IP 66
1512	ACS03-820-EHS-P-3003	E	Prize (Power Socket) 1	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1301	ACS03-820-E-DEA-0002	Zone 2	STAHL	8570/15-506	10001820861044	Ex eb	II C	T6	II 2 GD	IP 66
1513	ACS03-820-EHS-P-3003	E	Prize (Power Socket) 1	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1301	ACS03-820-E-DEA-0002	Zone 2	STAHL	8571/15-506	10001822135044	Ex db eb	II C	T5	II 2 GD	IP 66
1514	ACS03-950-EHF-0508	E	Ndricues (LF 14 - 2X36W - Fluor. Pole mounted)	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1301	ACS03-C1448-820-E-DEB-0002	Zone 2	STAHL	6401/...-00-15-232	10001829594057	Ex nA	II C	T4	II 3 G	IP 66/67

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
1959	ACS03-951-EHF-3018	E	Ndricues (Indoor Lighting - Compressor bldg 3 - Circuit 1.1 L.Fixture 3018	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700	ACS03-C1448-951-E-DEB-0029	Zone 2	STAHL	6401/...-00.-15-232	10001831899057	Ex nA	II C	T4	II 3 G	IP 66/67
1960	ACS03-951-EHF-3019	E	Ndricues (Indoor Lighting - Compressor bldg 3 - Circuit 1.4 L.Fixture 3019	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700	ACS03-C1448-951-E-DEB-0029	Zone 2	STAHL	6401/...-00.-15-232	10001831851057	Ex nA	II C	T4	II 3 G	IP 66/67
1961	ACS03-951-EHF-3020	E	Ndricues (Indoor Lighting - Compressor bldg 3 - Circuit 1.2 L.Fixture 3020	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700	ACS03-C1448-951-E-DEB-0029	Zone 2	STAHL	6401/...-00.-15-232	10001831861057	Ex nA	II C	T4	II 3 G	IP 66/67
1962	ACS03-951-EHF-3021	E	Ndricues (Indoor Lighting - Compressor bldg 3 - Circuit 1.5 L.Fixture 3021	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700	ACS03-C1448-951-E-DEB-0029	Zone 2	STAHL	6401/...-00.-15-232	10001831850057	Ex nA	II C	T4	II 3 G	IP 66/67
1963	ACS03-951-EHF-3022	E	Ndricues (Indoor Lighting - Compressor bldg 3 - Circuit 1.1 L.Fixture 3022	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700	ACS03-C1448-951-E-DEB-0029	Zone 2	STAHL	6401/...-00.-15-232	10001831894057	Ex nA	II C	T4	II 3 G	IP 66/67
1964	ACS03-951-EHF-3023	E	Ndricues (Indoor Lighting - Compressor bldg 3 - Circuit 1.4 L.Fixture 3023	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700	ACS03-C1448-951-E-DEB-0029	Zone 2	STAHL	6401/...-00.-15-232	10001831914057	Ex nA	II C	T4	II 3 G	IP 66/67
1965	ACS03-951-EHF-3024	E	Ndricues (Indoor Lighting - Compressor bldg 3 - Circuit 1.2 L.Fixture 3024	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700	ACS03-C1448-951-E-DEB-0029	Zone 2	STAHL	6401/...-00.-15-232	10001831893057	Ex nA	II C	T4	II 3 G	IP 66/67
1966	ACS03-951-EHF-3025	E	Ndricues (Indoor Lighting - Compressor bldg 3 - Circuit 1.5 L.Fixture 3025	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700	ACS03-C1448-951-E-DEB-0029	Zone 2	STAHL	6401/...-00.-15-232	10001831904057	Ex nA	II C	T4	II 3 G	IP 66/67
1967	ACS03-951-EHF-3026	E	Ndricues (Indoor Lighting - Compressor bldg 3 - Circuit 1.2 L.Fixture 3026	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700	ACS03-C1448-951-E-DEB-0029	Zone 2	STAHL	6401/...-00.-15-232	10001831898057	Ex nA	II C	T4	II 3 G	IP 66/67
1968	ACS03-951-EHF-303	E	Lighting fixture 303	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700		Zone 2	STAHL	6401/...-00.-15-232	10001829644057	Ex nA	II C	T4	II 3 G	IP 66/67
1969	ACS03-951-EHF-3031	E	Ndricues Outdoor Lighting - Compressor bldg 3 - Circuit 1.7 L.Fixture 3031	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700	ACS03-C1448-951-E-DEB-0029	Zone 2	STAHL	6470/2253-3152-100-2	180108730320003	Ex nR	II C	T4	II 3 G	IP 66
1970	ACS03-951-EHF-3032	E	Ndricues Outdoor Lighting - Compressor bldg 3 - Circuit 1.7 L.Fixture 3032	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700	ACS03-C1448-951-E-DEB-0029	Zone 2	STAHL	6470/2253-3152-100-2	180108730320004	Ex nR	II C	T4	II 3 G	IP 66
1971	ACS03-951-EHF-3033	E	Ndricues Outdoor Lighting - Compressor bldg 3 - Circuit 1.7 L.Fixture 3033	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700	ACS03-C1448-951-E-DEB-0029	Zone 2	STAHL	6470/2253-3152-100-2	180108730320010	Ex nR	II C	T4	II 3 G	IP 66
1972	ACS03-951-EHF-3034	E	Ndricues Outdoor Lighting - Compressor bldg 3 - Circuit 1.7 L.Fixture 3034	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700	ACS03-C1448-951-E-DEB-0029	Zone 2	STAHL	6470/2253-3152-100-2	180108730320011	Ex nR	II C	T4	II 3 G	IP 66
1973	ACS03-951-EHF-304	E	Ndricues Lighting fixture 304	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700		Zone 2	STAHL	6401/542-8..8	10001829646047	Ex nA	II C	T4	II 3 G	IP 66/67
1974	ACS03-951-EHF-3040	E	Ndricues (LF 11 - 2X18W - Fluor.Type	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700	ACS03-C1448-951-E-DEB-0031	Zone 2	STAHL	6401/...-00.-15-232	10001834747057	Ex nA	II C	T4	II 3 G	IP 66/67
1975	ACS03-951-EHF-3041	E	Ndricues (LF 11 - 2X18W - Fluor.Type	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700	ACS03-C1448-951-E-DEB-0031	Zone 2	STAHL	6401/...-00.-15-232	10001834746057	Ex nA	II C	T4	II 3 G	IP 66/67
1976	ACS03-951-EHF-3042	E	Ndricues (LF 11 - 2X18W - Fluor.Type	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700	ACS03-C1448-951-E-DEB-0031	Zone 2	STAHL	6401/...-00.-15-232	10001834741057	Ex nA	II C	T4	II 3 G	IP 66/67
1977	ACS03-951-EHF-3043	E	Ndricues (LF 11 - 2X18W - Fluor.Type	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700	ACS03-C1448-951-E-DEB-0031	Zone 2	STAHL	6401/...-00.-15-232	10001831420057	Ex nA	II C	T4	II 3 G	IP 66/67
1978	ACS03-951-EHF-3044	E	Ndricues (LF 11 - 2X18W - Fluor.Type	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700	ACS03-C1448-951-E-DEB-0031	Zone 2	STAHL	6401/...-00.-15-232	10001834744057	Ex nA	II C	T4	II 3 G	IP 66/67
1979	ACS03-951-EHF-3045	E	Ndricues (LF 11 - 2X18W - Fluor.Type	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700	ACS03-C1448-951-E-DEB-0031	Zone 2	STAHL	6401/...-00.-15-232	10001831421057	Ex nA	II C	T4	II 3 G	IP 66/67
1980	ACS03-951-EHF-3046	E	Ndricues (LF 11 - 2X18W - Fluor.Type	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700	ACS03-C1448-951-E-DEB-0031	Zone 2	STAHL	6401/...-00.-15-232	10001834745057	Ex nA	II C	T4	II 3 G	IP 66/67
1981	ACS03-951-EHF-3047	E	Ndricues (LF 11 - 2X18W - Fluor.Type	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700	ACS03-C1448-951-E-DEB-0031	Zone 2	STAHL	6401/...-00.-15-232	10001834740057	Ex nA	II C	T4	II 3 G	IP 66/67
1982	ACS03-951-EHF-3048	E	LF 4 - 2X18W - Fluor.Type	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700	ACS03-C1448-951-E-DEB-0031	Zone 2	STAHL	6401/...-00.-15-232		Ex nA	II C	T4	II 3 G	IP 66/67
1983	ACS03-951-EHF-3049	E	LF 4 - 2X18W - Fluor.Type	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700	ACS03-C1448-951-E-DEB-0031	Zone 2	STAHL	6401/...-00.-15-232	10001831407057	Ex nA	II C	T4	II 3 G	IP 66/67
1984	ACS03-951-EHF-3050	E	LF 4 - 2X18W - Fluor.Type	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700	ACS03-C1448-951-E-DEB-0031	Zone 2	STAHL	6401/...-00.-15-232	10001831426057	Ex nA	II C	T4	II 3 G	IP 66/67
1985	ACS03-951-EHJ-C-1000	E	Kuti Shperndarese L&P JB 1 J	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0100	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/1071	1815739600440000	Ex e	II C	T4	II 2 G	IP 66
1986	ACS03-951-EHJ-C-2000	E	Kuti Shperndarese L&P JB 1 J	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0200	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/1071	1815739600440000	Ex e	II C	T4	II 2 G	IP 66
1987	ACS03-951-EHJ-C-3000	E	Kuti Shperndarese L&P JB 1 J	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0300	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/1071	1815739600440000	Ex e	II C	T4	II 2 G	IP 66
1988	ACS03-951-EHJ-L-001-3	E	Celes EX SWITCH 2	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1500		Zone 2	STAHL	8146/5051	18157990530440006	Ex de	II C	T4	II 2 G	IP 66
1989	ACS03-951-EHJ-L-001-5	E	Celes EX SWITCH 2	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1500		Zone 2	STAHL	8146/5051	18157990530440009	Ex de	II C	T4	II 2 G	IP 66
1990	ACS03-951-EHJ-L-001-6	E	Celes EX SWITCH 2	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1500		Zone 2	STAHL	8146/5051	18157990530440004	Ex de	II C	T4	II 2 G	IP 66
1991	ACS03-951-EHJ-L-001-JB1	E	Kuti Shperndarese L&P JB 1 G	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1500		Zone 2	STAHL	8146/1061	1815739640440018	Ex e	II C	T4	II 2 G	IP 66
1992	ACS03-951-EHJ-L-001-JB2	E	Kuti Shperndarese L&P JB 1 G	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1500		Zone 2	STAHL	8146/1061	1815739640440023	Ex e	II C	T4	II 2 G	IP 66
1993	ACS03-951-EHJ-L-001-JB4	E	Kuti Shperndarese L&P JB 1 G	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1500		Zone 2	STAHL	8146/1061	1815739640440017	Ex e	II C	T4	II 2 G	IP 66
1994	ACS03-951-EHJ-L-002-3	E	Celes EX SWITCH 2	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1600		Zone 2	STAHL	8146/5051	1815990530440007	Ex de	II C	T4	II 2 G	IP 66
1995	ACS03-951-EHJ-L-002-5	E	Celes EX SWITCH 2	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1600		Zone 2	STAHL	8146/5051	18157990530440001	Ex de	II C	T4	II 2 G	IP 66

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi i Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
2144	ACS03-951-EHJ-L-3100	E	Kuti shperndarese L&P JB	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/(1071	1815739750440004	Ex e	II C	T4	II 2 G	IP 66
2145	ACS03-951-EHJ-L-3100-1	E	Ndricues (Indoor Lighting - Compressor bldg 3 - Circuit 1.1&1.2 Push Button 1	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700		Zone 2	STAHL	8146/5051	1815739700440013	Ex de	II C	T4	II 2 G	IP 66
2146	ACS03-951-EHJ-L-3100-2	E	Ndricues (Indoor Lighting - Compressor bldg 3 - Circuit 1.1&1.2 Push Button 2	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700		Zone 2	STAHL	8146/5051	1815739700440012	Ex de	II C	T4	II 2 G	IP 66
2147	ACS03-951-EHJ-L-3100-3	E	Ndricues (Indoor Lighting - Compressor bldg 3 - Circuit 1.1&1.2 Push Button 3	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700		Zone 2	STAHL	8146/5051	1815739700440002	Ex de	II C	T4	II 2 G	IP 66
2148	ACS03-951-EHJ-L-3100-4	E	Ndricues (Indoor Lighting - Compressor bldg 3 - Circuit 1.1&1.2 Push Button 4	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700		Zone 2	STAHL	8146/5051	1815739700440004	Ex de	II C	T4	II 2 G	IP 66
2149	ACS03-951-EHJ-L-3200	E	Kuti shperndarese JB 2 B	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/(1071	1815739750440007	Ex e	II C	T4	II 2 G	IP 66
2150	ACS03-951-EHJ-L-3200-1	E	Ndricues (Indoor Lighting - Compressor bldg 3 - Circuit 1.4&1.5 Push Button 1	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700		Zone 2	STAHL	8146/5051	1815739700440027	Ex de	II C	T4	II 2 G	IP 66
2151	ACS03-951-EHJ-L-3200-2	E	Ndricues (Indoor Lighting - Compressor bldg 3 - Circuit 1.4&1.5 Push Button 2	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700		Zone 2	STAHL	8146/5051	1815739700440022	Ex de	II C	T4	II 2 G	IP 66
2152	ACS03-951-EHJ-L-3200-3	E	Ndricues (Indoor Lighting - Compressor bldg 3 - Circuit 1.4&1.5 Push Button 3	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700		Zone 2	STAHL	8146/5051	1815739700440004	Ex de	II C	T4	II 2 G	IP 66
2153	ACS03-951-EHJ-L-3200-4	E	Ndricues (Indoor Lighting - Compressor bldg 3 - Circuit 1.4&1.5 Push Button 4	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700		Zone 2	STAHL	8146/5051	1815739700440005	Ex de	II C	T4	II 2 G	IP 66
2154	ACS03-951-EHJ-P-001	E	Kuti Shperndarese (Junction Box)	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1500		Zone 2	STAHL	8146/1051	1815739750440011	Ex e	II C	T4	II 2 G	IP 66
2155	ACS03-951-EHJ-P-1000	E	Kuti shperndarese Compressor Building 1 Ventilation JB- Panel	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0100	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/(1071	1815739690440000	Ex e	II C	T4	II 2 G	IP 66
2156	ACS03-951-EHJ-P-2000	E	Kuti shperndarese Compressor Building 2 Ventilation JB- Panel	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0200	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/(1071	1815739690440000	Ex e	II C	T4	II 2 G	IP 66
2157	ACS03-951-EHJ-P-3000	E	Kuti shperndarese Compressor Building 3 Ventilation JB- Panel	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0300	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/(1071	1815739690440000	Ex e	II C	T4	II 2 G	IP 66
2158	ACS03-951-EHJ-P-3010	E	Prize Socket Comb. cabinet 3 - Comp. building 3 - JB - Circuit 3.1 JB 3010	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700	ACS03-C1448-951-E-DEB-0029	Zone 2	STAHL	8146/1083	1815739704400002	Ex e	II C	T4	II 2 G	IP 66
2159	ACS03-951-EHJ-P-3011	E	Prize Socket Outlets - Compressor building 3- Circuit 2.1 JB 3011	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700	ACS03-C1448-951-E-DEB-0029	Zone 2	STAHL	8146/(1071	1815739750440000	Ex e	II C	T4	II 2 G	IP 66
2160	ACS03-951-EHP-0001	E	Kuti shperndarese L&P PB 1 E	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1500		Zone 2	STAHL	8146/5051	1815739610440003	Ex de	II C	T4	II 2 G	IP 66
2161	ACS03-951-EHP-0002	E	Kuti shperndarese L&P PB 1 C	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1600		Zone 2	STAHL	8146/5051	1815739700440009	Ex de	II C	T4	II 2 G	IP 66
2162	ACS03-951-EHP-0003	E	Push Button	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1700		Zone 2	STAHL	8146/5051	1815739700440019	Ex de	II C	T4	II 2 G	IP 66
2163	ACS03-951-EHS-1001	E	Prize Socket	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0106	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5083	1815754480440016	Ex de	II C	T4	II 2 G	IP 66
2164	ACS03-951-EHS-1002	E	Prize Socket	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0106	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5083	1815754480440012	Ex de	II C	T4	II 2 G	IP 66
2165	ACS03-951-EHS-1003	E	Prize Socket	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0106	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5083	1815754480440002	Ex de	II C	T4	II 2 G	IP 66
2166	ACS03-951-EHS-1004	E	Prize Socket	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0106	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5083	1815754480440003	Ex de	II C	T4	II 2 G	IP 66
2167	ACS03-951-EHS-1011	E	Prize Socket	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0106	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5093	1815753300440011	Ex de	II C	T4	II 2 G	IP 66
2168	ACS03-951-EHS-1012	E	Prize Socket	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0106	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5093	1815753360440010	Ex de	II C	T4	II 2 G	IP 66
2169	ACS03-951-EHS-1013	E	Prize (Power Socket) 2	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0106	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5093	1815753300440007	Ex de	II C	T4	II 2 G	IP 66
2170	ACS03-951-EHS-2001	E	Prize Socket	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0206	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5083	1815754480440017	Ex de	II C	T4	II 2 G	IP 66
2171	ACS03-951-EHS-2002	E	Prize Socket	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0206	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5083	1815754480440014	Ex de	II C	T4	II 2 G	IP 66
2172	ACS03-951-EHS-2003	E	Prize Socket	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0206	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5083	1815754480440010	Ex de	II C	T4	II 2 G	IP 66
2173	ACS03-951-EHS-2004	E	Prize Socket	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0206	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5083	1815754480440005	Ex de	II C	T4	II 2 G	IP 66
2174	ACS03-951-EHS-2011	E	Prize (Power Socket) 2	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0206	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5093	1815753360440008	Ex de	II C	T4	II 2 G	IP 66
2175	ACS03-951-EHS-2012	E	Prize Socket	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0206	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5093	1815754480440003	Ex de	II C	T4	II 2 G	IP 66
2176	ACS03-951-EHS-2013	E	Prize Socket	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0206	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5093	1815754480440008	Ex de	II C	T4	II 2 G	IP 66
2177	ACS03-951-EHS-3001	E	Prize Socket	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0306	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5083	1815754480440018	Ex de	II C	T4	II 2 G	IP 66
2178	ACS03-951-EHS-3002	E	Prize Socket	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0306	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5083	1815754480440013	Ex de	II C	T4	II 2 G	IP 66
2179	ACS03-951-EHS-3003	E	Prize Socket	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0306	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5083	1815754480440008	Ex de	II C	T4	II 2 G	IP 66
2180	ACS03-951-EHS-3004	E	Prize Socket	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0306	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5083	1815754480440007	Ex de	II C	T4	II 2 G	IP 66

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
2181	ACS03-951-EHS-3011	E	Prize Socket	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0306	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5093	1815753360440009	Ex de	II C	T4	II 2 G	IP 66
2182	ACS03-951-EHS-3012	E	Prize Socket	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0306	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5093	1815753360440002	Ex de	II C	T4	II 2 G	IP 66
2183	ACS03-951-EHS-3013	E	Prize (Power Socket) 2	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0306	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/5093	1815754460440005	Ex de	II C	T4	II 2 G	IP 66
2184	ACS03-951-ERF-1001	E	Ndicues Emergence Fixture 1001	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0912	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	eLLK 92058/58-V-CG-S	0195947G2	Ex de ib m	II C	T4	II 2 G	IP 66/67
2185	ACS03-951-ERF-1002	E	Ndicues Emergence Fixture 1002	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0912	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	eLLK 92058/58-V-CG-S	0199010G2	Ex de ib m	II C	T4	II 2 G	IP 66/67
2186	ACS03-951-ERF-1003	E	Ndicues Emergence Fixture 1003	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0912	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	eLLK 92058/58-V-CG-S	0199024G2	Ex de ib m	II C	T4	II 2 G	IP 66/67
2187	ACS03-951-ERF-1011	E	Ndicues Evakuimi - Exit	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0912	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	EXIT V-CG-S	1388	Ex e ib m	II C	T4	II 2 G	IP 66
2188	ACS03-951-ERF-1012	E	Ndicues Evakuimi (Ndicues Evakuimi - Right Direction)	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0912	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	EXIT V-CG-S	1468	Ex e ib m	II C	T4	II 2 G	IP 66
2189	ACS03-951-ERF-1013	E	Ndicues Evakuimi (Ndicues Evakuimi - Right Direction)	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0912	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	EXIT V-CG-S	1468	Ex e ib m	II C	T4	II 2 G	IP 66
2190	ACS03-951-ERF-1014	E	Ndicues Evakuimi - Left Direction	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0912	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	EXIT V-CG-S	1238	Ex e ib m	II C	T4	II 2 G	IP 66
2191	ACS03-951-ERF-1015	E	Ndicues Evakuimi - Exit	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0912	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	EXIT V-CG-S	1388	Ex e ib m	II C	T4	II 2 G	IP 66
2192	ACS03-951-ERF-1016	E	Ndicues Evakuimi - Left Direction	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0912	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	EXIT V-CG-S	1468	Ex e ib m	II C	T4	II 2 G	IP 66
2193	ACS03-951-ERF-1017	E	Ndicues Evakuimi (Ndicues Evakuimi - Right Direction)	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0912	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	EXIT V-CG-S	1468	Ex e ib m	II C	T4	II 2 G	IP 66
2194	ACS03-951-ERF-1018	E	Ndicues Evakuimi - Exit	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0912	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	EXIT V-CG-S	1468	Ex e ib m	II C	T4	II 2 G	IP 66
2195	ACS03-951-ERF-1019	E	Ndicues Evakuimi (Ndicues Evakuimi - Right Direction)	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0912	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	EXIT V-CG-S	1468	Ex e ib m	II C	T4	II 2 G	IP 66
2196	ACS03-951-ERF-1020	E	Ndicues Evakuimi - Left Direction	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0912	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	EXIT V-CG-S	1468	Ex e ib mb	II C	T4	II 2 G	IP 66
2197	ACS03-951-ERF-1021	E	Ndicues Evakuimi - Left Direction	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0912	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	EXIT V-CG-S	1468	Ex e ib m	II C	T4	II 2 G	IP 66
2198	ACS03-951-ERF-1022	E	Ndicues Evakuimi - Exit	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0912	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	EXIT V-CG-S	1468	Ex e ib m	II C	T4	II 2 G	IP 66
2199	ACS03-951-ERF-1023	E	Ndicues Evakuimi (Ndicues Evakuimi - Right Direction)	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0912	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	EXIT V-CG-S	1388	Ex e ib m	II C	T4	II 2 G	IP 66
2200	ACS03-951-ERF-1024	E	Ndicues Evakuimi - Left Direction	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0912	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	EXIT V-CG-S	1468	Ex e ib m	II C	T4	II 2 G	IP 66
2201	ACS03-951-ERF-1031	E	Ndicues Emergence 2x18W	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0912	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	eLLK 92018/18-V-CG-S	0198506G2	Ex de ib m	II C	T4	II 2 G	IP 66/67
2202	ACS03-951-ERF-1032	E	Ndicues Emergence 2x18W	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0912	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	eLLK 92018/18-V-CG-S	0136411R2	Ex de ib m	II C	T4	II 2 G	IP 66/67
2203	ACS03-951-ERF-1033	E	Ndicues Emergence 2x18W	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0912	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	eLLK 92018/18-V-CG-S	0198505G2	Ex de ib m	II C	T4	II 2 G	IP 66/67
2204	ACS03-951-ERF-1034	E	Ndicues Emergence 2x18W	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0912	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	eLLK 92018/18-V-CG-S	0198520G2	Ex de ib m	II C	T4	II 2 G	IP 66/67
2205	ACS03-951-ERF-2001	E	Ndicues Compressor bldg 2 - Circuit 1.4 L.Fixture 2001	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1600	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	eLLK 92058/58-V-CG-S	0199006G2	Ex de ib m	II C	T4	II 2 G	IP 66/67
2206	ACS03-951-ERF-2002	E	Ndicues Compressor bldg 2 - Circuit 1.2 L.Fixture 2002	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1600	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	eLLK 92058/58-V-CG-S	0199027G2	Ex de ib m	II C	T4	II 2 G	IP 66/67
2207	ACS03-951-ERF-2003	E	Ndicues Compressor bldg 2 - Circuit 1.1 L.Fixture 2003	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1600	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	eLLK 92058/58-V-CG-S	0199018G2	Ex de ib m	II C	T4	II 2 G	IP 66/67
2208	ACS03-951-ERF-2011	E	Ndicues Evakuimi - Exit	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0913	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	EXIT V-CG-S	1388	Ex e ib m	II C	T4	II 2 G	IP 66
2209	ACS03-951-ERF-2012	E	Ndicues Evakuimi - Left Direction	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0913	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	EXIT V-CG-S	1468	Ex e ib m	II C	T4	II 2 G	IP 66
2210	ACS03-951-ERF-2013	E	Ndicues Evakuimi - Left Direction	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0913	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	EXIT V-CG-S	1388	Ex e ib m	II C	T4	II 2 G	IP 66
2211	ACS03-951-ERF-2014	E	Ndicues Evakuimi (Ndicues Evakuimi - Right Direction)	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0913	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	EXIT V-CG-S	1438	Ex e ib m	II C	T4	II 2 G	IP 66
2212	ACS03-951-ERF-2015	E	Ndicues Evakuimi - Exit	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0913	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	EXIT V-CG-S	1388	Ex e ib m	II C	T4	II 2 G	IP 66
2213	ACS03-951-ERF-2016	E	Ndicues Evakuimi (Ndicues Evakuimi - Right Direction)	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0913	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	EXIT V-CG-S	1298	Ex e ib m	II C	T4	II 2 G	IP 66
2214	ACS03-951-ERF-2017	E	Ndicues Evakuimi - Left Direction	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0913	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	EXIT V-CG-S	1298	Ex e ib m	II C	T4	II 2 G	IP 66
2215	ACS03-951-ERF-2018	E	Ndicues Evakuimi - Exit	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0913	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	EXIT V-CG-S	1298	Ex e ib m	II C	T4	II 2 G	IP 66
2216	ACS03-951-ERF-2019	E	Ndicues Evakuimi - Left Direction	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0913	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	EXIT V-CG-S	1438	Ex e ib m	II C	T4	II 2 G	IP 66
2217	ACS03-951-ERF-2020	E	Ndicues Evakuimi (Ndicues Evakuimi - Right Direction)	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0913	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	EXIT V-CG-S	1468	Ex e ib m	II C	T4	II 2 G	IP 66

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
2218	ACS03-951-ERF-2021	E	Ndricues Evakuimi (Ndricues Evakuimi - Right Direction)	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0913	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	EXIT V-CG-S	1468	Ex e ib m	II C	T4	II 2 G	IP 66
2219	ACS03-951-ERF-2022	E	Ndricues Evakuimi - Exit	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0913	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	EXIT V-CG-S	1298	Ex e ib m	II C	T4	II 2 G	IP 66
2220	ACS03-951-ERF-2023	E	Ndricues Evakuimi - Left Direction	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0913	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	EXIT V-CG-S		Ex e ib m	II C	T4	II 2 G	IP 66
2221	ACS03-951-ERF-2024	E	Ndricues Evakuimi (Ndricues Evakuimi - Right Direction)	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0913	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	EXIT V-CG-S	1468	Ex e ib m	II C	T4	II 2 G	IP 66
2222	ACS03-951-ERF-2031	E	Ndricues Emergjence 2x18W	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0913	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	eLLK 92018/18-V-CG-S	0198500G2	Ex de ib m	II C	T4	II 2 G	IP 66/67
2223	ACS03-951-ERF-2032	E	Ndricues Emergjence 2x18W	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0913	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	eLLK 92018/18-V-CG-S	0198503G2	Ex de ib m	II C	T4	II 2 G	IP 66/67
2224	ACS03-951-ERF-2033	E	Ndricues Emergjence 2x18W	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0913	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	eLLK 92018/18-V-CG-S	0198508G2	Ex de ib m	II C	T4	II 2 G	IP 66/67
2225	ACS03-951-ERF-2034	E	Ndricues Emergjence 2x18W	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0913	ACS03-C1448-951-E-DEB-0028	Zone 2	EATON	eLLK 92018/18-V-CG-S	0136416R2	Ex de ib m	II C	T4	II 2 G	IP 66/67
2226	ACS03-951-ERF-3001	E	Ndricues Emergjence 2x58W	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0914	ACS03-C1448-951-E-DEB-0029	Zone 2	EATON	eLLK 92058/58-V-CG-S	0189017G2	Ex de ib m	II C	T4	II 2 G	IP 66/67
2227	ACS03-951-ERF-3002	E	Ndricues Emergjence 2x58W	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0914	ACS03-C1448-951-E-DEB-0029	Zone 2	EATON	eLLK 92058/58-V-CG-S	0199007G2	Ex de ib m	II C	T4	II 2 G	IP 66/67
2228	ACS03-951-ERF-3003	E	Ndricues Emergjence 2x58W	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0914	ACS03-C1448-951-E-DEB-0029	Zone 2	EATON	eLLK 92058/58-V-CG-S	0199008G2	Ex de ib m	II C	T4	II 2 G	IP 66/67
2229	ACS03-951-ERF-3011	E	Ndricues Evakuimi - Exit	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0914	ACS03-C1448-951-E-DEB-0029	Zone 2	EATON	EXIT V-CG-S	1348	Ex e ib m	II C	T4	II 2 G	IP 66
2230	ACS03-951-ERF-3012	E	Ndricues Evakuimi (Ndricues Evakuimi - Right Direction)	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0914	ACS03-C1448-951-E-DEB-0029	Zone 2	EATON	EXIT V-CG-S	1345	Ex e ib m	II C	T4	II 2 G	IP 66
2231	ACS03-951-ERF-3013	E	Ndricues Evakuimi (Ndricues Evakuimi - Right Direction)	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0914	ACS03-C1448-951-E-DEB-0029	Zone 2	EATON	EXIT V-CG-S	1345	Ex e ib m	II C	T4	II 2 G	IP 66
2232	ACS03-951-ERF-3014	E	Ndricues Evakuimi - Left Direction	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0914	ACS03-C1448-951-E-DEB-0029	Zone 2	EATON	EXIT V-CG-S	1468	Ex e ib m	II C	T4	II 2 G	IP 66
2233	ACS03-951-ERF-3015	E	Ndricues Evakuimi - Exit	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0914	ACS03-C1448-951-E-DEB-0029	Zone 2	EATON	EXIT V-CG-S	1288	Ex e ib m	II C	T4	II 2 G	IP 66
2234	ACS03-951-ERF-3016	E	Ndricues Evakuimi - Left Direction	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0914	ACS03-C1448-951-E-DEB-0029	Zone 2	EATON	EXIT V-CG-S	1468	Ex e ib m	II C	T4	II 2 G	IP 66
2235	ACS03-951-ERF-3017	E	Ndricues Evakuimi (Ndricues Evakuimi - Right Direction)	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0914	ACS03-C1448-951-E-DEB-0029	Zone 2	EATON	EXIT V-CG-S	1468	Ex e ib m	II C	T4	II 2 G	IP 66
2236	ACS03-951-ERF-3018	E	Ndricues Evakuimi - Exit	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0914	ACS03-C1448-951-E-DEB-0029	Zone 2	EATON	EXIT V-CG-S	1298	Ex e ib m	II C	T4	II 2 G	IP 66
2237	ACS03-951-ERF-3019	E	Ndricues Evakuimi (Ndricues Evakuimi - Right Direction)	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0914	ACS03-C1448-951-E-DEB-0029	Zone 2	EATON	EXIT V-CG-S	1238	Ex e ib m	II C	T4	II 2 G	IP 66
2238	ACS03-951-ERF-3020	E	Ndricues Evakuimi - Left Direction	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0914	ACS03-C1448-951-E-DEB-0029	Zone 2	EATON	EXIT V-CG-S	1348	Ex e ib m	II C	T4	II 2 G	IP 66
2239	ACS03-951-ERF-3021	E	Ndricues Evakuimi - Left Direction	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0914	ACS03-C1448-951-E-DEB-0029	Zone 2	EATON	EXIT V-CG-S	1468	Ex e ib m	II C	T4	II 2 G	IP 66
2240	ACS03-951-ERF-3022	E	Ndricues Evakuimi - Exit	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0914	ACS03-C1448-951-E-DEB-0029	Zone 2	EATON	EXIT V-CG-S	1298	Ex e ib m	II C	T4	II 2 G	IP 66
2241	ACS03-951-ERF-3023	E	Ndricues Evakuimi (Ndricues Evakuimi - Right Direction)	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0914	ACS03-C1448-951-E-DEB-0029	Zone 2	EATON	EXIT V-CG-S	1468	Ex e ib m	II C	T4	II 2 G	IP 66
2242	ACS03-951-ERF-3024	E	Ndricues Evakuimi - Left Direction	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0914	ACS03-C1448-951-E-DEB-0029	Zone 2	EATON	EXIT V-CG-S	1468	Ex e ib m	II C	T4	II 2 G	IP 66
2243	ACS03-951-ERF-3031	E	Ndricues Emergjence 2x18W	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0914	ACS03-C1448-951-E-DEB-0029	Zone 2	EATON	eLLK 92018/18-V-CG-S	0198504G2	Ex de ib m	II C	T4	II 2 G	IP 66/67
2244	ACS03-951-ERF-3032	E	Ndricues Emergjence 2x18W	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0914	ACS03-C1448-951-E-DEB-0029	Zone 2	EATON	eLLK 92018/18-V-CG-S	0198502G2	Ex de ib m	II C	T4	II 2 G	IP 66/67
2245	ACS03-951-ERF-3033	E	Ndricues Emergjence 2x18W	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0914	ACS03-C1448-951-E-DEB-0029	Zone 2	EATON	eLLK 92018/18-V-CG-S	0136421R2	Ex de ib m	II C	T4	II 2 G	IP 66/67
2246	ACS03-951-ERF-3034	E	Ndricues Emergjence 2x18W	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0914	ACS03-C1448-951-E-DEB-0029	Zone 2	EATON	eLLK 92018/18-V-CG-S	0198515G2	Ex de ib m	II C	T4	II 2 G	IP 66/67
2247	ACS03-951-ERJ-P-001-01	E	Kuti shperndarese Compressor Building 1 Damper Inlet/Discharge JB	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0100	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/1071	1815739690440000	Ex e	II C	T4	II 2 G	IP 66
2248	ACS03-951-ERJ-P-002-01	E	Kuti shperndarese Compressor Building 2 Damper Inlet/Discharge JB	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0200	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/1071	1815739690440000	Ex e	II C	T4	II 2 G	IP 66
2249	ACS03-951-ERJ-P-003-01	E	Kuti shperndarese Compressor Building 3 Damper Inlet/Discharge JB	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0200	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL	8146/1071	1815739690440001	Ex e	II C	T4	II 2 G	IP 66
2250	ACS03-951-FB-0101	J	Fener per sinjalizues zjarri (Fire Alarm Beacon)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0001	Zone 2	AES	EVC50	2141	Ex d	II C	T6	II 2 G	IP 65
2251	ACS03-951-FB-0102	J	Fener per sinjalizues zjarri (Fire Alarm Beacon)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0001	Zone 2	AES	EVC50	2165	Ex d	II C	T6	II 2 G	IP 65
2252	ACS03-951-FB-0103	J	Fener per sinjalizues zjarri (Fire Alarm Beacon)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0001	Zone 2	AES	EVC50	2147	Ex d	II C	T6	II 2 G	IP 65
2253	ACS03-951-FB-0104	J	Fener per sinjalizues zjarri (Fire Alarm Beacon)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0001	Zone 2	AES	EVC50	2167	Ex d	II C	T6	II 2 G	IP 65
2254	ACS03-951-FB-0105	J	Fener per sinjalizues zjarri (Fire Alarm Beacon)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0001	Zone 2	AES	EVC50	2187	Ex d	II C	T6	II 2 G	IP 65

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
2329	ACS03-951-GD-0209	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0003	Zone 2	CROWCON	IRmax	W274209/01-022	Ex d	II C	T6	II 2 G	IP 66
2330	ACS03-951-GD-0210	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0003	Zone 2	CROWCON	IRmax	W274203/01-021	Ex d	II C	T6	II 2 G	IP 66
2331	ACS03-951-GD-0211	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0003	Zone 2	CROWCON	IRmax	W274212/01-007	Ex d	II C	T6	II 2 G	IP 66
2332	ACS03-951-GD-0301	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0004	Zone 2	CROWCON	IRmax	W274211/01-014	Ex d	II C	T6	II 2 G	IP 66
2333	ACS03-951-GD-0302	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0004	Zone 2	CROWCON	IRmax	W274204/01-027	Ex d	II C	T6	II 2 G	IP 66
2334	ACS03-951-GD-0303	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0004	Zone 2	CROWCON	IRmax	W274212/01-029	Ex d	II C	T6	II 2 G	IP 66
2335	ACS03-951-GD-0304	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0004	Zone 2	CROWCON	IRmax	W274210/01-011	Ex d	II C	T6	II 2 G	IP 66
2336	ACS03-951-GD-0305	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0004	Zone 2	CROWCON	IRmax	W274216/01-030	Ex d	II C	T6	II 2 G	IP 66
2337	ACS03-951-GD-0306	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0004	Zone 2	CROWCON	IRmax	W274217/01-010	Ex d	II C	T6	II 2 G	IP 66
2338	ACS03-951-GD-0307	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0004	Zone 2	CROWCON	IRmax	W274218/01-030	Ex d	II C	T6	II 2 G	IP 66
2339	ACS03-951-GD-0308	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0004	Zone 2	CROWCON	IRmax	W274210/01-014	Ex d	II C	T6	II 2 G	IP 66
2340	ACS03-951-GD-0309	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0004	Zone 2	CROWCON	IRmax	W274211/01-028	Ex d	II C	T6	II 2 G	IP 66
2341	ACS03-951-GD-0310	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0004	Zone 2	CROWCON	IRmax	W274211/01-026	Ex d	II C	T6	II 2 G	IP 66
2342	ACS03-951-GD-0311	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0004	Zone 2	CROWCON	IRmax	W274210/01-029	Ex d	II C	T6	II 2 G	IP 66
2343	ACS03-951-GH-0101	J	Bori alarmi per prezence gazi(Gas Alarm Horn)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0003	Zone 2	AES	ETH20 MD-32	1672	Ex d	II C	T4	II 2 G	IP 66
2344	ACS03-951-GH-0102	J	Bori alarmi per prezence gazi(Gas Alarm Horn)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0003	Zone 2	AES	ETH20 MD-32	1718	Ex d	II C	T4	II 2 G	IP 66
2345	ACS03-951-GH-0103	J	Bori alarmi per prezence gazi(Gas Alarm Horn)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0003	Zone 2	AES	ETH20 MD-32	1680	Ex d	II C	T4	II 2 G	IP 66
2346	ACS03-951-GH-0104	J	Bori alarmi per prezence gazi(Gas Alarm Horn)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0003	Zone 2	AES	ETH20 MD-32	1685	Ex d	II C	T4	II 2 G	IP 66
2347	ACS03-951-GH-0105	J	Bori alarmi per prezence gazi(Gas Alarm Horn)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0003	Zone 2	AES	ETH20 MD-32	1671	Ex d	II C	T4	II 2 G	IP 66
2348	ACS03-951-GH-0201	J	Bori alarmi per prezence gazi(Gas Alarm Horn)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0003	Zone 2	AES	ETH20 MD-32	1723	Ex d	II C	T4	II 2 G	IP 66
2349	ACS03-951-GH-0202	J	Bori alarmi per prezence gazi(Gas Alarm Horn)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0003	Zone 2	AES	ETH20 MD-32	1713	Ex d	II C	T4	II 2 G	IP 66
2350	ACS03-951-GH-0203	J	Bori alarmi per prezence gazi(Gas Alarm Horn)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0003	Zone 2	AES	ETH20 MD-32	1688	Ex d	II C	T4	II 2 G	IP 66
2351	ACS03-951-GH-0204	J	Bori alarmi per prezence gazi(Gas Alarm Horn)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0003	Zone 2	AES	ETH20 MD-32	1735	Ex d	II C	T4	II 2 G	IP 66
2352	ACS03-951-GH-0301	J	Bori alarmi per prezence gazi(Gas Alarm Horn)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0004	Zone 2	AES	ETH20 MD-32	1684	Ex d	II C	T4	II 2 G	IP 66
2353	ACS03-951-GH-0302	J	Bori alarmi per prezence gazi(Gas Alarm Horn)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0004	Zone 2	AES	ETH20 MD-32	1658	Ex d	II C	T4	II 2 G	IP 66
2354	ACS03-951-GH-0303	J	Bori alarmi per prezence gazi(Gas Alarm Horn)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0004	Zone 2	AES	ETH20 MD-32	1670	Ex d	II C	T4	II 2 G	IP 66
2355	ACS03-951-GH-0304	J	Bori alarmi per prezence gazi(Gas Alarm Horn)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0004	Zone 2	AES	ETH20 MD-32	1732	Ex d	II C	T4	II 2 G	IP 66
2356	ACS03-951-GH-0305	J	Bori alarmi per prezence gazi(Gas Alarm Horn)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0004	Zone 2	AES	ETH20 MD-32	1750	Ex d	II C	T4	II 2 G	IP 66
2357	ACS03-951-JB-0100-A	J	Kuti Shperndarese (Junction Box)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224498	Ex e	II C	T6	II 2 G	IP 66
2358	ACS03-951-JB-0100-B	J	Kuti Shperndarese (Junction Box)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224500	Ex e	II C	T6	II 2 G	IP 66
2359	ACS03-951-JB-0100-C	J	Kuti Shperndarese (Junction Box)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224502	Ex e	II C	T6	II 2 G	IP 66
2360	ACS03-951-JB-1001-A	J	Kuti Shperndarese (Junction Box)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-352720	I/17/226212	Ex ia	II C	T6	II 2 G	IP 66
2361	ACS03-951-JB-1001-B	J	Kuti Shperndarese (Junction Box)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-352720	I/17/226209	Ex ia	II C	T6	II 2 G	IP 66
2362	ACS03-951-JB-1001-C	J	Kuti Shperndarese (Junction Box)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-352720	I/17/226213	Ex ia	II C	T6	II 2 G	IP 66
2363	ACS03-951-JB-1002-A	J	Kuti Shperndarese (Junction Box)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0100	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224521	Ex e	II C	T6	II 2 G	IP 66
2364	ACS03-951-JB-1002-B	J	Kuti Shperndarese (Junction Box)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0200	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224519	Ex e	II C	T6	II 2 G	IP 66
2365	ACS03-951-JB-1002-C	J	Kuti Shperndarese (Junction Box)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0300	ACS03-C1448-856-J-DJA-0001	Zone 2	TECHNOR ITALSMEA	SB-282816	I/17/224517	Ex e	II C	T6	II 2 G	IP 66

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
2403	ACS03-951-LP-3003	E	Panel Kontrolli Compressor Building Ventilation Motor Local Control Panel	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0300	ACS03-C1448.1090-551-E-DJW-0001	Zone 2	AD VIGANO	CSA 12	18.05.411	Ex e	II C	T6	II 2 G	IP 66
2404	ACS03-951-LP-3004	E	Panel Kontrolli Compressor Building Ventilation Motor Local Control Panel	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0300	ACS03-C1448.1090-551-E-DJW-0001	Zone 2	AD VIGANO	CSA 12	18.05.415	Ex e	II C	T6	II 2 G	IP 66
2405	ACS03-951-LP-3005	E	Kuti Shperndarese (Junction Box)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0300	ACS03-C1448.1090-551-E-DJW-0001	Zone 2	BARTEC	AS 11	18/1239.1.9	Ex e	II C	T6	II 2 G	IP 66
2406	ACS03-951-LP-3006	E	Panel Kontrolli Compressor Building Ventilation Motor Local Control Panel	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0300	ACS03-C1448.1090-551-E-DJW-0001	Zone 2	AD VIGANO	CSA 12	18.05.418 / S.N: 18/1239.1.11	Ex e	II C	T6	II 2 G	IP 66
2407	ACS03-951-LP-3007	E	Panel Kontrolli Compressor Building Ventilation Motor Local Control Panel	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0300	ACS03-C1448.1090-551-E-DJW-0001	Zone 2	AD VIGANO	CSA 12	18.05.419/ S.N: 18/1239.1.22	Ex e	II C	T6	II 2 G	IP 66
2408	ACS03-951-LP-3008	E	Kuti Shperndarese (Junction Box)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0300	ACS03-C1448.1090-551-E-DJW-0001	Zone 2	BARTEC	AS 11	18/1239.1.15	Ex e	II C	T6	II 2 G	IP 66
2409	ACS03-951-LP-3006 / Zv me tag ACS03-951-LP-3009	E	Kuti Shperndarese (Junction Box)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0300	ACS03-C1448.1090-551-E-DJW-0001	Zone 2	BARTEC	AS 11	18/1239.1.11	Ex e	II C	T6	II 2 G	IP 66
2410	ACS03-951-LP-3007 / Zv me tag ACS03-951-LP-3010	E	Kuti Shperndarese (Junction Box)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0300	ACS03-C1448.1090-551-E-DJW-0001	Zone 2	BARTEC	AS 11	18/1239.1.22	Ex e	II C	T6	II 2 G	IP 66
2411	ACS03-951-MAC-0101	J	Buton ALARMI Manual Call Point	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0001	Zone 2	MEDC	BGI	212196474 10 08	Ex ia	II C	T4	II 1 G	IP 65
2412	ACS03-951-MAC-0102	J	Buton ALARMI Manual Call Point	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0001	Zone 2	MEDC	BGI	212196474 30 41	Ex ia	II C	T4	II 1 G	IP 65
2413	ACS03-951-MAC-0103	J	Buton ALARMI Manual Call Point	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0001	Zone 2	MEDC	BGI	212196474 20 02	Ex ia	II C	T4	II 1 G	IP 65
2414	ACS03-951-MAC-0104	J	Buton ALARMI Manual Call Point	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0001	Zone 2	MEDC	BGI	212196474 10 03	Ex ia	II C	T4	II 1 G	IP 65
2415	ACS03-951-MAC-0105	J	Buton ALARMI Manual Call Point	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0001	Zone 2	MEDC	BG-IB	212196474 10 11	Ex ia	II C	T4	II 1 G	IP 65
2416	ACS03-951-MAC-0106	J	Buton ALARMI Manual Call Point	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0001	Zone 2	MEDC	BGI	212196474 20 16/ S.N: 2121964742017	Ex ia	II C	T4	II 1 G	IP 65
2417	ACS03-951-MAC-0201	J	Buton ALARMI Manual Call Point	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0001	Zone 2	MEDC	BG-IB	212196474 30 19	Ex ia	II C	T4	II 1 G	IP 65
2418	ACS03-951-MAC-0202	J	Buton ALARMI Manual Call Point	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0001	Zone 2	MEDC	BG-IB	212196474 20 32	Ex ia	II C	T4	II 1 G	IP 65
2419	ACS03-951-MAC-0203	J	Buton ALARMI Manual Call Point	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0001	Zone 2	MEDC	BGI	212196474 20 28	Ex ia	II C	T4	II 1 G	IP 65
2420	ACS03-951-MAC-0204	J	Buton ALARMI Manual Call Point	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0001	Zone 2	MEDC	BG-IB	212196474 30 19	Ex ia	II C	T4	II 1 G	IP 65
2421	ACS03-951-MAC-0205	J	Buton ALARMI Manual Call Point	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0001	Zone 2	MEDC	BG-IB	212196474 30 36	Ex ia	II C	T4	II 1 G	IP 65
2422	ACS03-951-MAC-0206	J	Buton ALARMI Manual Call Point	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0001	Zone 2	MEDC	BGI	216307512 10 01	Ex ia	II C	T4	II 1 G	IP 65
2423	ACS03-951-MAC-0301	J	Buton ALARMI Manual Call Point	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0002	Zone 2	MEDC	BGI	212196474 10 04	Ex ia	II C	T4	II 1 G	IP 65
2424	ACS03-951-MAC-0302	J	Buton ALARMI Manual Call Point	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0002	Zone 2	MEDC	BG-IB	212196474 20 23	Ex ia	II C	T4	II 1 G	IP 65
2425	ACS03-951-MAC-0303	J	Buton ALARMI Manual Call Point	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0002	Zone 2	MEDC	BGI	212196474 10 06	Ex ia	II C	T4	II 1 G	IP 65
2426	ACS03-951-MAC-0304	J	Buton ALARMI Manual Call Point	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0002	Zone 2	MEDC	BG-IB	212196474 20 12	Ex ia	II C	T4	II 1 G	IP 65
2427	ACS03-951-MAC-0305	J	Buton ALARMI Manual Call Point	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0002	Zone 2	MEDC	BG-IB	212196474 20 18	Ex ia	II C	T4	II 1 G	IP 65
2428	ACS03-951-MAC-0306	J	Buton ALARMI Manual Call Point	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0002	Zone 2	MEDC	BGI	212196474 20 31	Ex ia	II C	T4	II 1 G	IP 65
2429	ACS03-951-MT-1001	E	Motorri I Ventilimit Compressor Building 1 Ventilation Motor 1 (1)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0100	ACS03-C1448.1090-551-E-DJW-0001	Zone 2	EUROMOTORI	MAK V 180 M - 4/8	2005946	Ex d	II B	T3	II 2 G	IP 55
2430	ACS03-951-MT-1002	E	Motorri I Ventilimit Compressor Building 1 Ventilation Motor 2 (1)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0100	ACS03-C1448.1090-551-E-DJW-0001	Zone 2	EUROMOTORI	MAK V 180 M - 4/8	2005957	Ex d	II B	T3	II 2 G	IP 55
2431	ACS03-951-MT-1003	E	Motorri I Ventilimit Compressor Building 1 Ventilation Motor 3 (1)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0100	ACS03-C1448.1090-551-E-DJW-0001	Zone 2	EUROMOTORI	MAK V 180 M - 4/8	2005950	Ex d	II B	T3	II 2 G	IP 55
2432	ACS03-951-MT-1004	E	Motorri I Ventilimit Compressor Building 1 Ventilation Motor 4 (1)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0100	ACS03-C1448.1090-551-E-DJW-0001	Zone 2	EUROMOTORI	MAK V 180 M - 4/8	2005947	Ex d	II B	T3	II 2 G	IP 55
2433	ACS03-951-MT-2001	E	Motorri I Ventilimit Compressor Building 2 Ventilation Motor 1 (1)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0200	ACS03-C1448.1090-551-E-DJW-0001	Zone 2	EUROMOTORI	MAK V 180 M - 4/8	2005951	Ex d	II B	T3	II 2 G	IP 55
2434	ACS03-951-MT-2002	E	Motorri I Ventilimit Compressor Building 2 Ventilation Motor 2 (1)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0200	ACS03-C1448.1090-551-E-DJW-0001	Zone 2	EUROMOTORI	MAK V 180 M - 4/8	2005956	Ex d	II B	T3	II 2 G	IP 55
2435	ACS03-951-MT-2003	E	Motorri I Ventilimit Compressor Building 2 Ventilation Motor 3 (1)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0200	ACS03-C1448.1090-551-E-DJW-0001	Zone 2	EUROMOTORI	MAK V 180 M - 4/8	2005952	Ex d	II B	T3	II 2 G	IP 55
2436	ACS03-951-MT-2004	E	Motorri I Ventilimit Compressor Building 2 Ventilation Motor 4 (1)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0200	ACS03-C1448.1090-551-E-DJW-0001	Zone 2	EUROMOTORI	MAK V 180 M - 4/8	2005963	Ex d	II B	T3	II 2 G	IP 55
2437	ACS03-951-MT-3001	E	Motorri I Ventilimit Compressor Building 3 Ventilation Motor 1 (1)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0300	ACS03-C1448.1090-551-E-DJW-0001	Zone 2	EUROMOTORI	MAK V 180 M - 4/8	2005958	Ex d	II B	T3	II 2 G	IP 55
2438	ACS03-951-MT-3002	E	Motorri I Ventilimit Compressor Building 3 Ventilation Motor 2 (1)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0300	ACS03-C1448.1090-551-E-DJW-0001	Zone 2	EUROMOTORI	MAK V 180 M - 4/8	2005962	Ex d	II B	T3	II 2 G	IP 55
2439	ACS03-951-MT-3003	E	Motorri I Ventilimit Compressor Building 3 Ventilation Motor 3 (1)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0300	ACS03-C1448.1090-551-E-DJW-0001	Zone 2	EUROMOTORI	MAK V 180 M - 4/8	2005948	Ex d	II B	T3	II 2 G	IP 55

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizitimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
2440	ACS03-951-MT-3004	E	Motorri I Ventilimit Compressor Building 3 Ventilation Motor 4 (1)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0300	ACS03-C1448.1090-551-E-DJW-0001	Zone 2	EUROMOTORI	MAK V 180 M - 4/8	2005955	Ex d	II B	T3	II 2 G	IP 55
2441	ACS03-951-PDSH-1006	J	Celes Presioni Diferencial Pressure Differential Switch High	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0100	ACS03-C1448.1090-551-E-DJW-0001	Zone 2	UNITED ELECTRIC CONTROLS	H100K-540	2451079	Ex ia	II C	T6	II 1 G	IP 66
2442	ACS03-951-PDSH-1007	J	Celes Presioni Diferencial Pressure Differential Switch High	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0100	ACS03-C1448.1090-551-E-DJW-0001	Zone 2	UNITED ELECTRIC CONTROLS	H100K-540	2451078	Ex ia	II C	T6	II 1 G	IP 66
2443	ACS03-951-PDSH-2006	J	Celes Presioni Diferencial Pressure Differential Switch High	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0200	ACS03-C1448.1090-551-E-DJW-0001	Zone 2	UNITED ELECTRIC CONTROLS	H100K-540	2451079	Ex ia	II C	T6	II 1 G	IP 66
2444	ACS03-951-PDSH-2007	J	Celes Presioni Diferencial Pressure Differential Switch High	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0200	ACS03-C1448.1090-551-E-DJW-0001	Zone 2	UNITED ELECTRIC CONTROLS	H100K-540	2451078	Ex ia	II C	T6	II 1 G	IP 66
2445	ACS03-951-PDSH-3006	J	Celes Presioni Diferencial Pressure Differential Switch High	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0300	ACS03-C1448.1090-551-E-DJW-0001	Zone 2	UNITED ELECTRIC CONTROLS	H100K-540		Ex ia	II C	T6	II 1 G	IP 66
2446	ACS03-951-PDSH-3007	J	Celes Presioni Diferencial Pressure Differential Switch High	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0300	ACS03-C1448.1090-551-E-DJW-0001	Zone 2	UNITED ELECTRIC CONTROLS	H100K-540		Ex ia	II C	T6	II 1 G	IP 66
2447	ACS03-951-SCD-0101	J	Detektor Tymi (Multicriteria Smoke Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0001	Zone 2	APOLLO	ORB-OH-53028/MB-50018-APO	081321	Ex ia	II C	T5	II 1 G	IP 23d
2448	ACS03-951-SCD-0102	J	Detektor Tymi (Multicriteria Smoke Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0001	Zone 2	APOLLO	ORB-OH-53028/MB-50018-APO	080018	Ex ia	II C	T5	II 1 G	IP 23d
2449	ACS03-951-SCD-0103	J	Detektor Tymi (Multicriteria Smoke Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0001	Zone 2	APOLLO	ORB-OH-53028/MB-50018-APO	080120	Ex ia	II C	T5	II 1 G	IP 23d
2450	ACS03-951-SCD-0104	J	Detektor Tymi (Multicriteria Smoke Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0001	Zone 2	APOLLO	ORB-OH-53028/MB-50018-APO	084117	Ex ia	II C	T5	II 1 G	IP 23d
2451	ACS03-951-SCD-0105	J	Detektor Tymi (Multicriteria Smoke Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0001	Zone 2	APOLLO	ORB-OH-53028/MB-50018-APO	082715	Ex ia	II C	T5	II 1 G	IP 23d
2452	ACS03-951-SCD-0106	J	Detektor Tymi (Multicriteria Smoke Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0001	Zone 2	APOLLO	ORB-OH-53028/MB-50018-APO	081311	Ex ia	II C	T5	II 1 G	IP 23d
2453	ACS03-951-SCD-0107	J	Detektor Tymi (Multicriteria Smoke Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0001	Zone 2	APOLLO	ORB-OH-53028/MB-50018-APO	082317	Ex ia	II C	T5	II 1 G	IP 23d
2454	ACS03-951-SCD-0108	J	Detektor Tymi (Multicriteria Smoke Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0001	Zone 2	APOLLO	ORB-OH-53028/MB-50018-APO	082613	Ex ia	II C	T5	II 1 G	IP 23d
2455	ACS03-951-SCD-0109	J	Detektor Tymi (Multicriteria Smoke Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0001	Zone 2	APOLLO	ORB-OH-53028/MB-50018-APO	084218	Ex ia	II C	T5	II 1 G	IP 23d
2456	ACS03-951-SCD-0110	J	Detektor Tymi (Multicriteria Smoke Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0001	Zone 2	APOLLO	ORB-OH-53028/MB-50018-APO	081619	Ex ia	II C	T5	II 1 G	IP 23d
2457	ACS03-951-SCD-0201	J	Detektor Tymi (Multicriteria Smoke Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0001	Zone 2	APOLLO	ORB-OH-53028/MB-50018-APO	080917	Ex ia	II C	T5	II 1 G	IP 23d
2458	ACS03-951-SCD-0202	J	Detektor Tymi (Multicriteria Smoke Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0001	Zone 2	APOLLO	ORB-OH-53028/MB-50018-APO	084621	Ex ia	II C	T5	II 1 G	IP 23d
2459	ACS03-951-SCD-0203	J	Detektor Tymi (Multicriteria Smoke Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0001	Zone 2	APOLLO	ORB-OH-53028/MB-50018-APO	085918	Ex ia	II C	T5	II 1 G	IP 23d
2460	ACS03-951-SCD-0204	J	Detektor Tymi (Multicriteria Smoke Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0001	Zone 2	APOLLO	ORB-OH-53028/MB-50018-APO	083620	Ex ia	II C	T5	II 1 G	IP 23d
2461	ACS03-951-SCD-0205	J	Detektor Tymi (Multicriteria Smoke Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0001	Zone 2	APOLLO	ORB-OH-53028/MB-50018-APO	081720	Ex ia	II C	T5	II 1 G	IP 23d
2462	ACS03-951-SCD-0206	J	Detektor Tymi (Multicriteria Smoke Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0001	Zone 2	APOLLO	ORB-OH-53028/MB-50018-APO	08114	Ex ia	II C	T5	II 1 G	IP 23d
2463	ACS03-951-SCD-0207	J	Detektor Tymi (Multicriteria Smoke Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0001	Zone 2	APOLLO	ORB-OH-53028/MB-50018-APO	145335	Ex ia	II C	T5	II 1 G	IP 23d
2464	ACS03-951-SCD-0208	J	Detektor Tymi (Multicriteria Smoke Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0001	Zone 2	APOLLO	ORB-OH-53028/MB-50018-APO	083722	Ex ia	II C	T5	II 1 G	IP 23d
2465	ACS03-951-SCD-0209	J	Detektor Tymi (Multicriteria Smoke Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0001	Zone 2	APOLLO	ORB-OH-53028/MB-50018-APO	080813	Ex ia	II C	T5	II 1 G	IP 23d
2466	ACS03-951-SCD-0210	J	Detektor Tymi (Multicriteria Smoke Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0001	Zone 2	APOLLO	ORB-OH-53028/MB-50018-APO	083919	Ex ia	II C	T5	II 1 G	IP 23d
2467	ACS03-951-SCD-0301	J	Detektor Tymi (Multicriteria Smoke Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0002	Zone 2	APOLLO	ORB-OH-53028/MB-50018-APO	084515	Ex ia	II C	T5	II 1 G	IP 23d
2468	ACS03-951-SCD-0302	J	Detektor Tymi (Multicriteria Smoke Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0002	Zone 2	APOLLO	ORB-OH-53028/MB-50018-APO	081015	Ex ia	II C	T5	II 1 G	IP 23d
2469	ACS03-951-SCD-0303	J	Detektor Tymi (Multicriteria Smoke Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0002	Zone 2	APOLLO	ORB-OH-53028/MB-50018-APO	081716	Ex ia	II C	T5	II 1 G	IP 23d
2470	ACS03-951-SCD-0304	J	Detektor Tymi (Multicriteria Smoke Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0002	Zone 2	APOLLO	ORB-OH-53028/MB-50018-APO	084910	Ex ia	II C	T5	II 1 G	IP 23d
2471	ACS03-951-SCD-0305	J	Detektor Tymi (Multicriteria Smoke Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0002	Zone 2	APOLLO	ORB-OH-53028/MB-50018-APO	084212	Ex ia	II C	T5	II 1 G	IP 23d
2472	ACS03-951-SCD-0306	J	Detektor Tymi (Multicriteria Smoke Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0002	Zone 2	APOLLO	ORB-OH-53028/MB-50018-APO	141136	Ex ia	II C	T5	II 1 G	IP 23d
2473	ACS03-951-SCD-0307	J	Detektor Tymi (Multicriteria Smoke Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0002	Zone 2	APOLLO	ORB-OH-53028/MB-50018-APO	085614	Ex ia	II C	T5	II 1 G	IP 23d
2474	ACS03-951-SCD-0308	J	Detektor Tymi (Multicriteria Smoke Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0002	Zone 2	APOLLO	ORB-OH-53028/MB-50018-APO	084114	Ex ia	II C	T5	II 1 G	IP 23d
2475	ACS03-951-SCD-0309	J	Detektor Tymi (Multicriteria Smoke Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0002	Zone 2	APOLLO	ORB-OH-53028/MB-50018-APO	085520	Ex ia	II C	T5	II 1 G	IP 23d
2476	ACS03-951-SCD-0310	J	Detektor Tymi (Multicriteria Smoke Detector)	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-1101	ACS03-C1448-951-T-DTG-0002	Zone 2	APOLLO	ORB-OH-53028/MB-50018-APO	080422	Ex ia	II C	T5	II 1 G	IP 23d

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
2551	ACS03-957-EHJ-P-2.12/2	E	Kuti shperndarese Socket circuit JB	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1400	ACS03-C1448-957-E-DEB-0009	Zone 2	STAHL	8146/1041	1815738940440001	Ex e	II C	T4	II 2 G	IP 66
2552	ACS03-957-EHJ-P-2.12/3	E	Kuti shperndarese Socket circuit JB	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1400	ACS03-C1448-957-E-DEB-0009	Zone 2	STAHL	8146/1041	1815738940440081	Ex e	II C	T4	II 2 G	IP 66
2553	ACS03-957-EHS-0012	E	Prize dalese Socket Outlet	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1400	ACS03-C1448-957-E-DEB-0009	Zone 2	STAHL	8146/5083	1815754480440009	Ex de	II C	T4	II 2 G	IP 66
2554	ACS03-957-EHS-0013	E	Prize dalese Socket Outlet	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1400	ACS03-C1448-957-E-DEB-0009	Zone 2	STAHL	8146/5083	1815754480440001	Ex de	II C	T4	II 2 G	IP 66
2555	ACS03-957-EHS-0014	E	Prize dalese Socket Outlet	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1400	ACS03-C1448-957-E-DEB-0009	Zone 2	STAHL	8146/5083	1815754480440016	Ex de	II C	T4	II 2 G	IP 66
2556	ACS03-957-EHS-0015	E	Prize dalese Socket Outlet	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1400	ACS03-C1448-957-E-DEB-0009	Zone 2	STAHL	8146/5083	1815754480440011	Ex de	II C	T4	II 2 G	IP 66
2557	ACS03-957-ERF-0002	E	Ndicues Emergjence Fixture 2X36W	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1400	ACS03-C1448-957-E-DEB-0009	Zone 2	CEAG	eLLK 92036/36 CG-S	993990G	Ex de ib m	II C	T4	II 2 G	IP 66/67
2558	ACS03-957-ERF-0030	E	Ndicues Emergjence Fixture 2X36W	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1400	ACS03-C1448-957-E-DEB-0009	Zone 2	EATON	EXIT V-CG-S	1059	Ex e ib m	II C	T4	II 2 G	IP 66
2559	ACS03-957-ERJ-L-0002/0030/0046	E	Kuti shperndarese per Ndicues Emergjence	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-1400	ACS03-C1448-957-E-DEB-0009	Zone 2	STAHL	8146/1041	1815738940440037	Ex e	II C	T4	II 2 G	IP 66
2560	ACS03-957-FB-2024	J	Fener Sinjalizues Flashing Beacon	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-0600	ACS03-C1448-957-T-DTA-0005	Zone 2	KROMA MEC	EVA50	18/0640	Ex d	II C	T6	II 2 G	IP 66
2561	ACS03-957-FH-2023	J	Autoparlant	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-0600	ACS03-C1448-957-T-DTA-0005	Zone 2	KROMA MEC	ETH20 MD	18/228	Ex d	II B + H2	T6/T5	II 2 G	IP 66
2562	ACS03-957-MAC-2022	J	Buton Alarmi Manual Call Point	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-0600	ACS03-C1448-957-T-DTA-0005	Zone 2	CO.SI.ME	N/A	17-09397	Ex d	II C	T5	II 2 G	IP 66
2563	ACS03-957-SCD-1016	J	Sensor nxehtesie edhe tymi Combined Somoke-Heat Sensor Loop 'A'	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-0600	ACS03-C1448-957-T-DTA-0005	Zone 2	APOLLO	ORBIS	123531	Ex ia	II C	T5	II 1 G	IP 23d
2564	ACS03-957-SCD-2020	J	Sensor nxehtesie edhe tymi Combined Somoke-Heat Sensor Loop 'B'	FIRE AND GAS MONITORING	ACS03-740	ACS03-740-0600	ACS03-C1448-957-T-DTA-0005	Zone 2	APOLLO	ORBIS	124132	Ex ia	II C	T5	II 1 G	IP 23d
2565	JB-1601(JB201)	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0106	ACS03-C1448-856-J-DJA-0001	Zone 2	WEIDMULLER	KLIPPON TBMH 453820 S4E3	XA-DE-A-4546364	Ex ia	II C	T4	II 1 G	IP 66
2566	JB-1602(JB202)	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0106	ACS03-C1448-856-J-DJA-0001	Zone 2	WEIDMULLER	KLIPPON TBMH 453820 S4E3	XA-DE-A-4551712	Ex ia	II C	T4	II 1 G	IP 66
2567	JB-1603(JB203)	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0109	ACS03-C1448-856-J-DJA-0001	Zone 2	WEIDMULLER	KLIPPON TBMH 453820 S4E3	XA-DE-A-4573103	Ex ia	II C	T4	II 1 G	IP 66
2568	JB-1604(JB204)	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0109	ACS03-C1448-856-J-DJA-0001	Zone 2	WEIDMULLER	KLIPPON TBMH 453820 S4E3	XA-DE-A-4551712	Ex ia	II C	T4	II 1 G	IP 66
2569	JB-1611(JB220)	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0110	ACS03-C1448-856-J-DJA-0001	Zone 2	HAWKE	S2	P102861/16	Ex e	II C	T6	II 2 G	IP 66
2570	JB-1995(JB-171)	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0108	ACS03-C1448-856-J-DJA-0001	Zone 2	ABTECH	SX 1.200	992415	Ex e	II C	T5	II 2 G	IP 66
2571	JB-1996(JB-172)	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0108	ACS03-C1448-856-J-DJA-0001	Zone 2	ABTECH	SX 1.200	992409	Ex e	II C	T5	II 2 G	IP 66
2572	JB-1998(JB-161)	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0104	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	N/A	F2H601391/ S.N: XA/GB/ML/0001234	Ex nA nC	II C	T4	II 3 (2) G	IP 66
2573	JB-2601(JB201)	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0206	ACS03-C1448-856-J-DJA-0001	Zone 2	WEIDMULLER	KLIPPON TBMH 453820 S4E3	XA-DE-A-4574150	Ex ia	II C	T4	II 1 G	IP 66
2574	JB-2602(JB202)	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0206	ACS03-C1448-856-J-DJA-0001	Zone 2	WEIDMULLER	KLIPPON TBMH 453820 S4E3	XA-DE-A-4568891	Ex ia	II C	T4	II 1 G	IP 66
2575	JB-2603(JB203)	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0209	ACS03-C1448-856-J-DJA-0001	Zone 2	WEIDMULLER	KLIPPON TBMH 453820 S4E3	XA-DE-A-4589156	Ex ia	II C	T4	II 1 G	IP 66
2576	JB-2604(JB204)	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0209	ACS03-C1448-856-J-DJA-0001	Zone 2	WEIDMULLER	KLIPPON TBMH 453820 S4E3	XA-DE-A-4546364	Ex ia	II C	T4	II 1 G	IP 66
2577	JB-2611(JB220)	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0210	ACS03-C1448-856-J-DJA-0001	Zone 2	HAWKE	S2	P102856/16	Ex e	II C	T6	II 2 G	IP 66
2578	JB-2995(JB-171)	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0208	ACS03-C1448-856-J-DJA-0001	Zone 2	ABTECH	SX 1.200	992419	Ex e	II C	T5	II 2 G	IP 66
2579	JB-2996(JB-172)	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0208	ACS03-C1448-856-J-DJA-0001	Zone 2	ABTECH	SX 1.200	992410	Ex e	II C	T5	II 2 G	IP 66
2580	JB-2998(JB-361)	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0204	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	N/A	F2H9023022/ S.N: XA/GB/ML/0001233	Ex nA nC	II C	T4	II 3 (2) G	IP 66
2581	JB-3601(JB201)	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0306	ACS03-C1448-856-J-DJA-0001	Zone 2	WEIDMULLER	KLIPPON TBMH 453820 S4E3	XA-DE-A-4601582	Ex ia	II C	T4	II 1 G	IP 66
2582	JB-3602(JB202)	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0306	ACS03-C1448-856-J-DJA-0001	Zone 2	WEIDMULLER	KLIPPON TBMH 453820 S4E3	XA-DE-A-4606067	Ex ia	II C	T4	II 1 G	IP 66
2583	JB-3603(JB203)	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0309	ACS03-C1448-856-J-DJA-0001	Zone 2	WEIDMULLER	KLIPPON TBMH 453820 S4E3	XA-DE-A-4801623	Ex ia	II C	T4	II 1 G	IP 66
2584	JB-3604(JB204)	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0309	ACS03-C1448-856-J-DJA-0001	Zone 2	WEIDMULLER	KLIPPON TBMH 453820 S4E3	XA-DE-A-4801623/ S.N: XA-DE-4606067	Ex ia	II C	T4	II 1 G	IP 66
2585	JB-3611(JB220)	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0310	ACS03-C1448-856-J-DJA-0001	Zone 2	HAWKE	S2	P102854/16	Ex e	II C	T6	II 2 G	IP 66
2586	JB-3995(JB-171)	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0308	ACS03-C1448-856-J-DJA-0001	Zone 2	ABTECH	SX 1.200	992420	Ex e	II C	T5	II 2 G	IP 66
2587	JB-3996(JB-172)	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0308	ACS03-C1448-856-J-DJA-0001	Zone 2	ABTECH	SX 1.200	992411	Ex e	II C	T5	II 2 G	IP 66

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
2588	JB-3998(JB-361)	J	Kuti Shperndarese (Junction Box)	Komprimimi i Gazit (GAS COMPRESSION)	ACS03-320	ACS03-320-0304	ACS03-C1448-856-J-DJA-0001	Zone 2	SIEMENS	N/A	F2HH024523	Ex nA nC	II C	T4	II 3 (2) G	IP 66
2589	ACS03-360-SSV-1020-JB1	J	Kuti Shperndarese (Junction Box)	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-820-E-DEA-0002	Zone 2	STAHL/ Weidmuller	8150/2-0176-0176-091-3311	17440018/10110004/ S.N.: XA/GB/ML/0001232	Ex ia ib	II C	T6	II 2 G	IP 66
2590	ACS03-360-ZSO-1020	J	Celes Fundor Limit Switch	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-820-E-DEA-0002	Zone 2	PEPPERL + FUCHS	NCN4-12GM35-N0-5M	N/A	Ex ia	II C	T6	II 1 G	IP 67
2591	ACS03-360-ZSC-1020	J	Celes Fundor Limit Switch	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-820-E-DEA-0002	Zone 2	PEPPERL + FUCHS	NCN4-12GM35-N0-5M	N/A	Ex ia	II C	T6	II 1 G	IP 67
2592	ACS03-360-ZSO-2020	J	Celes Fundor Limit Switch	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-820-E-DEA-0002	Zone 2	PEPPERL + FUCHS	NCN4-12GM35-N0-5M	N/A	Ex ia	II C	T6	II 1 G	IP 67
2593	ACS03-360-ZSC-2020	J	Celes Fundor Limit Switch	Tubacionet (PIPING)	ACS03-360	ACS03-360-0300	ACS03-C1448-820-E-DEA-0002	Zone 2	PEPPERL + FUCHS	NCN4-12GM35-N0-5M	N/A	Ex ia	II C	T6	II 1 G	IP 67
2594	ACS03-534-ZSC/O-2020-JB	J	Kuti shperndarese per Limit Switch JB					Zone 2	CE	SFH26-HA1.2	16-025	Ex db	II C	T6	II 2 G	IP 66/67
2595	ACS03-850-HZS-1004	J	Buton Emergjence Emergency Push Button					Safe Area	EATON MEDC	SM87PBLD	217583338 10 05	Ex d	II C	T6	II 2 G	IP 66 / 67
2596	ACS03-110-FI-2001	J	Tregues prurjesh Flow Indicator					Zone 2	HONEYWELL	DIGITAL FLOW CTF878	NOT VISIBLE	Ex d	II C	T6	II 2 G	
2597	ACS03-856-EJE-J-0002	J	Kuti shperndarese Trace Heating JB					Zone 2	THERMON	TERMINATOR ZL-WP	18-0044	EEX e	II	T4	II 2 GD	IP 66
2598	ACS03-856-EJE-J-0001	J	Kuti shperndarese Trace Heating JB					Zone 2	THERMON	TERMINATOR ZL-WP	18-0044	EEX e	II	T4	II 2 GD	IP 66
2599	ACS03-920-EHS-0009	J	Prize Socket	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-0300		Safe Area	STAHL	8146/5083	1815754480440010	Ex db eb	II C	T4	II 2 G	IP 66
2600	ACS03-920-EHS-0009	J	Prize Socket	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-0300		Safe Area	STAHL	8570/15-306	10001845709044	Ex db eb	II C	T6	II 2 G	IP 66
2601	ACS03-920-EHJ-P-0132A	J	Celes Switch	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-0300		Safe Area	STAHL	8146/5051	1815738990440003	Ex db eb	II C	T4	II 2 G	IP 66
2602	ACS03-920-EHJ-P-0133A	J	Celes Switch	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-0300		Safe Area	STAHL	8146/5051	1815738990440001	Ex db eb	II C	T4	II 2 G	IP 66
2603	ACS03-920-EHJ-P-0132B	J	Celes Switch	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-0300		Safe Area	STAHL	8146/5051	1815738990440000	Ex db eb	II C	T4	II 2 G	IP 66
2604	ACS03-920-EHJ-P-0133B	J	Celes Switch	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-0300		Safe Area	STAHL	8146/5051	1815738990440004	Ex db eb	II C	T4	II 2 G	IP 66
2605	ACS03-551-TT-1020	J	Transmetues Temperature (Temperature Transmitter)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0703		Safe Area	SCHISCHEK	EXCOS-D	056.3040 18470056	Ex e ma [ia Ga]	II C	T6	II 2 (1) G	IP 66
2606	ACS03-551-TT-1012	J	Transmetues Temperature (Temperature Transmitter)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0703		Safe Area	SCHISCHEK	EXCOS-D	056.3040 18470054	Ex e ma [ia Ga]	II C	T6	II 2 (1) G	IP 66
2607	ACS03-920-ERF-0038	E	Safety Ndricues Evakuimi Fixture	STATION EMERGENCY / ESSENTIAL POWER UPS	ACS03-830	ACS03-830-0906		Safe Area	EATON	EXIT V-CG-S	1109	Ex e ib mb	II C	T4	II 2 G	IP 66
2608	ACS03-920-EHS-0014	E	Prize Socket	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-0300		Safe Area	STAHL	8146/5083	1815754480440004	Ex db eb	II C	T4	II 2 G	IP 66
2609	ACS03-920-EHS-0014	E	Prize Socket	Furnizimi me Energji elektrike i Stacionit	ACS03-800	ACS03-800-0300		Safe Area	STAHL	8570/15-306	10001845713044	Ex db eb	II C	T6	II 2 G	IP 66
2610	ACS03-539-EHD-0003	J	Kabinet per detektuesit e rrjedhjeve Leak Detection Control Cabinet	CONDENSATE TANKS	ACS03-381	ACS03-381-0000	IPR01-C5521.1010-534-E-DEA-0002-01	Safe Area	ASSYTECH	LDS08/P/H/L/00/04	2418006/2018		II A	T3	II 2 G	IP 44
2611	ACS03-330-26BP05	J	Manometer Presioni Tube Pressure Gauge	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	WIKA	232.30.063	14245495	EEx ia	II C	T6	II 1 G	IP 65
2612	ACS03-330-25BP05	J	Manometer Presioni Tube Pressure Gauge	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	WIKA	232.30.063	14245495	EEx ia	II C	T6	II 1 G	IP 65
2613	ACS03-330-21BP05	J	Manometer Presioni Tube Pressure Gauge	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	WIKA	232.30.063	14245495	EEx ia	II C	T6	II 1 G	IP 65
2614	ACS03-330-21BP15	J	Manometer Presioni Tube Pressure Gauge	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	WIKA	232.30.063	14245495	EEx ia	II C	T6	II 1 G	IP 65
2615	ACS03-330-32EB05	E	Ngrohes Heater	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	INTERLEC	SL BLOCKTHERM DKA 50 T4	NOT VISIBLE	Ex db	II C	T4	II 2 G	IP 66
2616	ACS03-330-31EB05	E	Ngrohes Heater	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	INTERLEC	SL BLOCKTHERM DKA 50 T4	NOT VISIBLE	Ex db	II C	T4	II 2 G	IP 66
2617	IPR01-330-32FL05	E	Thermostat	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	INTERLEC	TEMPERATURE SWITCH	NOT VISIBLE	Ex db	II C	T6	II 2 G	IP 66
2618	IPR01-330-32FL05	E	Thermostat	Matja e Gazit	ACS03-330	ACS03-330-0400		Zone 1	INTERLEC	TEMPERATURE SWITCH	NOT VISIBLE	Ex db	II C	T6	II 2 G	IP 66
2619	ACS03-951-ZSO-5001 / Zv me tag ACS03-534-ZSO-5001	J	Celes Fundor Celes Fundor i hapurr (Limit Switch Open) (ACTUATOR)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0300	ACS03-C1448-951-P-DPE-0001	Zone 2	SCHISCHEK	ExMax-30-SF		Ex d [ia]	II C	T6	II 2 (1) G	IP 66
2620	ACS03-951-ZSO-5002 / Zv me tag ACS03-534-ZSO-5002	J	Celes Fundor Celes Fundor i hapurr (Limit Switch Open) (ACTUATOR)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0300	ACS03-C1448-951-P-DPE-0001	Zone 2	SCHISCHEK	ExMax-30-SF		Ex d [ia]	II C	T6	II 2 (1) G	IP 66
2621	ACS03-951-ZSO-5003 / Zv me tag ACS03-534-ZSO-5003	J	Celes Fundor Celes Fundor i hapurr (Limit Switch Open) (ACTUATOR)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0300	ACS03-C1448-951-P-DPE-0001	Zone 2	SCHISCHEK	ExMax-30-SF		Ex d [ia]	II C	T6	II 2 (1) G	IP 66
2622	ACS03-951-ZSO-5004 / Zv me tag ACS03-534-ZSO-5004	J	Celes Fundor Celes Fundor i hapurr (Limit Switch Open) (ACTUATOR)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0300	ACS03-C1448-951-P-DPE-0001	Zone 2	SCHISCHEK	ExMax-30-SF		Ex d [ia]	II C	T6	II 2 (1) G	IP 66
2623	ACS03-951-ZSO-5005 / Zv me tag ACS03-534-ZSO-5005	J	Celes Fundor Celes Fundor i hapurr (Limit Switch Open) (ACTUATOR)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0300	ACS03-C1448-951-P-DPE-0001	Zone 2	SCHISCHEK	ExMax-30-SF		Ex d [ia]	II C	T6	II 2 (1) G	IP 66
2624	ACS03-951-ZSO-5006 / Zv me tag ACS03-534-ZSO-5006	J	Celes Fundor Celes Fundor i hapurr (Limit Switch Open) (ACTUATOR)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0300	ACS03-C1448-951-P-DPE-0001	Zone 2	SCHISCHEK	ExMax-30-SF		Ex d [ia]	II C	T6	II 2 (1) G	IP 66

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizitimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
2625	ACS03-951-ZSO-5007 / Zv me tag ACS03-534-ZSO-5007	J	Celes Fundor Celes Fundor i hapurr (Limit Switch Open) (ACTUATOR)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0300	ACS03-C1448-951-P-DPE-0001	Zone 2	SCHISCHEK	ExMax-30-SF		Ex d [ia]	II C	T6	II 2 (1) G	IP 66
2626	ACS03-951-ZSO-5008 / Zv me tag ACS03-534-ZSO-5008	J	Celes Fundor Celes Fundor i hapurr (Limit Switch Open) (ACTUATOR)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0300	ACS03-C1448-951-P-DPE-0001	Zone 2	SCHISCHEK	ExMax-30-SF		Ex d [ia]	II C	T6	II 2 (1) G	IP 66
2627	ACS03-951-ZSO-5009 / Zv me tag ACS03-534-ZSO-5009	J	Celes Fundor Celes Fundor i hapurr (Limit Switch Open) (ACTUATOR)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS03-551	ACS03-551-0300	ACS03-C1448-951-P-DPE-0001	Zone 2	SCHISCHEK	ExMax-30-SF		Ex d [ia]	II C	T6	II 2 (1) G	IP 66
2628	ACS03-534-TIT-1023	J	Transmetues Temperature (Temperature Transmitter)	FUEL GAS	ACS03-534	ACS03-534-0301	ACS03-C1448-1010-534-P-DPE-0001	Zone 2	HONEYWELL	STT850-T-0-C-BHC-13C-B.41A0-F1.FE-000	17W29 C4000005357257	Ex ia	II C	T4	II 1 G	IP 66
2629	ACS03-534-TE-1023	J	Temperature element	FUEL GAS	ACS03-534	ACS03-534-0301	ACS03-C1448-1010-534-P-DPE-0001	Zone 2	THERMO ELECTRIC	2P131B1	17-3064-01-13	Ex d	II C	Process Condition Dependent	II 2 GD	IP 65
2630	ACS03-534-TIT-1034	J	Transmetues Temperature (Temperature Transmitter)	FUEL GAS	ACS03-534	ACS03-534-0301	ACS03-C1448-1010-534-P-DPE-0001	Zone 2	HONEYWELL	STT850-T-0-C-BHC-13C-B.41A0-F1.FE-000	17W29 C4000005357263	Ex ia	II C	T4	II 1 G	IP 66
2631	ACS03-534-TE-1034	J	Temperature element	FUEL GAS	ACS03-534	ACS03-534-0301	ACS03-C1448-1010-534-P-DPE-0001	Zone 2	THERMO ELECTRIC	2P131B1	17-3063-01-05	Ex d	II C	Process Condition Dependent	II 2 GD	IP 65
2632	ACS03-534-TIT-1065	J	Transmetues Temperature (Temperature Transmitter)	FUEL GAS	ACS03-534	ACS03-534-0301	ACS03-C1448-1010-534-P-DPE-0001	Zone 2	HONEYWELL	STT850-T-0-C-BHC-13C-B.41A0-F1.FE-000	17W29 C4000005357265	Ex ia	II C	T4	II 1 G	IP 66
2633	ACS03-534-TE-1065	J	Temperature element	FUEL GAS	ACS03-534	ACS03-534-0301	ACS03-C1448-1010-534-P-DPE-0001	Zone 2	THERMO ELECTRIC	2P131B1	NOT ILLEGIBLE	Ex d	II C	Process Condition Dependent	II 2 GD	IP 65
2634	ACS03-534-TIT-3065	J	Transmetues Temperature (Temperature Transmitter)	FUEL GAS	ACS03-534	ACS03-534-0301	ACS03-C1448-1010-534-P-DPE-0001	Zone 2	HONEYWELL	STT850-T-0-C-BHC-13C-B.41A0-F1.FE-000	17W29 C4000005357268	Ex ia	II C	T4	II 1 G	IP 66
2635	ACS03-534-TE-3065	J	Temperature element	FUEL GAS	ACS03-534	ACS03-534-0301	ACS03-C1448-1010-534-P-DPE-0001	Zone 2	THERMO ELECTRIC	2P131B1	17-3064-01-04	Ex d	II C	Process Condition Dependent	II 2 GD	IP 65
2636	ACS03-534-LIT-2210	J	Tregues Niveli Level Indicator	FUEL GAS	ACS03-534	ACS03-534-0301	ACS03-C1448-1010-534-P-DPE-0001	Zone 2	HONEYWELL	STR82D-11DS120-AFABA40JK-C-BHC-13C-B-01-	17W36 C4000005357234	Ex ia	II C	T4	II 1 G	IP 66

ANEX 6

Fleta 6.2 - ACS02 - ATEX Register

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
1	820-EHJ-H-0001	E	Filter Separators (Condensate Heat Tracing) JB1	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS02-820	ACS02-820-0902	ACS02-C1448.3500-820-E-DFB-0001	ZONE 2	SPINA	JBPN-252512	18/02748	Ex e	II C	T4	II 2 G	IP 66
2	820-EHJ-H-0001-001	E	Filter Separators (Condensate Heat Tracing) JB1 - Subdistribution 001	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS02-820	ACS02-820-0902	ACS02-C1448.3500-820-E-DFB-0001	ZONE 2	ELTHERM	ELAK-Ex-3.7 / 0X80057	1901	Ex e	II C	T6	II 2 G	IP 66
3	820-EHJ-H-0001-002	E	Filter Separators (Condensate Heat Tracing) JB1 - Subdistribution 002	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS02-820	ACS02-820-0902	ACS02-C1448.3500-820-E-DFB-0001	ZONE 2	ELTHERM	ELAK-Ex-3.7 / 0X80057	1878	Ex e	II C	T6	II 2 G	IP 66
4	820-EHJ-H-0001-003	E	Filter Separators (Condensate Heat Tracing) JB1 - Subdistribution 003	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS02-820	ACS02-820-0902	ACS02-C1448.3500-820-E-DFB-0001	ZONE 2	ELTHERM	ELAK-Ex-3.7 / 0X80057	1950	Ex e	II C	T6	II 2 G	IP 66
5	820-EHJ-H-0001-004	E	Filter Separators (Condensate Heat Tracing) JB1 - Subdistribution 004	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS02-820	ACS02-820-0902	ACS02-C1448.3500-820-E-DFB-0001	ZONE 2	ELTHERM	ELAK-Ex-3.7 / 0X80057	1887	Ex e	II C	T6	II 2 G	IP 66
6	820-EHJ-H-0001-005	E	Filter Separators (Condensate Heat Tracing) JB1 - Subdistribution 005	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS02-820	ACS02-820-0902	ACS02-C1448.3500-820-E-DFB-0001	ZONE 2	ELTHERM	ELAK-Ex-3.7 / 0X80057	1921	Ex e	II C	T6	II 2 G	IP 66
7	820-EHJ-H-0002	E	Filter Separators (Condensate Heat Tracing) JB2	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS02-820	ACS02-820-0902	ACS02-C1448.3500-820-E-DFB-0001	ZONE 2	SPINA	JBPN-252512	18/02749	Ex e	II C	T4	II 2 G	IP 66
8	820-EHJ-H-0002-001	E	Filter Separators (Condensate Heat Tracing) JB2 - Subdistribution 001	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS02-820	ACS02-820-0902	ACS02-C1448.3500-820-E-DFB-0001	ZONE 2	ELTHERM	ELAK-Ex-3.7 / 0X80057	1911	Ex e	II C	T6	II 2 G	IP 66
9	820-EHJ-H-0002-002	E	Filter Separators (Condensate Heat Tracing) JB2 - Subdistribution 002	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS02-820	ACS02-820-0902	ACS02-C1448.3500-820-E-DFB-0001	ZONE 2	ELTHERM	ELAK-Ex-3.7 / 0X80057	1913	Ex e	II C	T6	II 2 G	IP 66
10	820-EHJ-H-0002-003	E	Filter Separators (Condensate Heat Tracing) JB2 - Subdistribution 003	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS02-820	ACS02-820-0902	ACS02-C1448.3500-820-E-DFB-0001	ZONE 2	ELTHERM	ELAK-Ex-3.7 / 0X80057	1912	Ex e	II C	T6	II 2 G	IP 66
11	820-EHJ-H-0002-004	E	Filter Separators (Condensate Heat Tracing) JB2 - Subdistribution 004	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS02-820	ACS02-820-0902	ACS02-C1448.3500-820-E-DFB-0001	ZONE 2	ELTHERM	ELAK-Ex-3.7 / 0X80057	1900	Ex e	II C	T6	II 2 G	IP 66
12	820-EHJ-H-0002-005	E	Filter Separators (Condensate Heat Tracing) JB2 - Subdistribution 005	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS02-820	ACS02-820-0902	ACS02-C1448.3500-820-E-DFB-0001	ZONE 2	ELTHERM	ELAK-Ex-3.7 / 0X80057	1860	Ex e	II C	T6	II 2 G	IP 66
13	820-EHJ-H-0003	E	Filter Separators (Condensate Heat Tracing) JB3	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS02-820	ACS02-820-0902	ACS02-C1448.3500-820-E-DFB-0001	ZONE 2	SPINA	JBPN-252512	18/02750	Ex e	II C	T4	II 2 G	IP 66
14	820-EHJ-H-0003-001	E	Filter Separators (Condensate Heat Tracing) JB3 - Subdistribution 001	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS02-820	ACS02-820-0902	ACS02-C1448.3500-820-E-DFB-0001	ZONE 2	ELTHERM	ELAK-Ex-3.7 / 0X80057	1863	Ex e	II C	T6	II 2 G	IP 66
15	820-EHJ-H-0003-002	E	Filter Separators (Condensate Heat Tracing) JB3 - Subdistribution 002	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS02-820	ACS02-820-0902	ACS02-C1448.3500-820-E-DFB-0001	ZONE 2	ELTHERM	ELAK-Ex-3.7 / 0X80057	1963	Ex e	II C	T6	II 2 G	IP 66
16	820-EHJ-H-0003-003	E	Filter Separators (Condensate Heat Tracing) JB3 - Subdistribution 003	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS02-820	ACS02-820-0902	ACS02-C1448.3500-820-E-DFB-0001	ZONE 2	ELTHERM	ELAK-Ex-3.7 / 0X80057	1896	Ex e	II C	T6	II 2 G	IP 66
17	820-EHJ-H-0003-004	E	Filter Separators (Condensate Heat Tracing) JB3 - Subdistribution 004	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS02-820	ACS02-820-0902	ACS02-C1448.3500-820-E-DFB-0001	ZONE 2	ELTHERM	ELAK-Ex-3.7 / 0X80057	1861	Ex e	II C	T6	II 2 G	IP 66
18	820-EHJ-H-0003-005	E	Filter Separators (Condensate Heat Tracing) JB3 - Subdistribution 005	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS02-820	ACS02-820-0902	ACS02-C1448.3500-820-E-DFB-0001	ZONE 2	ELTHERM	ELAK-Ex-3.7 / 0X80057	1967	Ex e	II C	T6	II 2 G	IP 66
19	820-EHJ-H-0004	E	Condensate Tank Heat Tracing (Gas Heat Tracing) JB1	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS02-820	ACS02-820-0903	ACS02-C1448.3500-820-E-DFB-0001	ZONE 1	SPINA	JBPN-162609	18/02729	Ex e	II C	T4	II 2 G	IP 66
20	820-EHJ-H-0004-001	E	Condensate Tank Heat Tracing (Gas Heat Tracing) JB1 - Subdistribution 001	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS02-820	ACS02-820-0903	ACS02-C1448.3500-820-E-DFB-0001	ZONE 1	ELTHERM	ELAK-Ex-3.7 / 0X80057	1885	Ex e	II C	T6	II 2 G	IP 66
21	820-EHJ-H-0004-002	E	Condensate Tank Heat Tracing (Gas Heat Tracing) JB1 - Subdistribution 002	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS02-820	ACS02-820-0903	ACS02-C1448.3500-820-E-DFB-0001	ZONE 1	ELTHERM	ELAK-Ex-3.7 / 0X80057	1879	Ex e	II C	T6	II 2 G	IP 66
22	820-EHJ-H-0004-003	E	Condensate Tank Heat Tracing (Gas Heat Tracing) JB1 - Subdistribution 003	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS02-820	ACS02-820-0903	ACS02-C1448.3500-820-E-DFB-0001	ZONE 1	ELTHERM	ELAK-Ex-3.7 / 0X80057	1881	Ex e	II C	T6	II 2 G	IP 66
23	820-EHJ-H-0005	E	Vent Heat Tracing (Gas Heat Tracing) JB1	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS02-820	ACS02-820-0902	ACS02-C1448.3500-820-E-DFB-0001	SAFE AREA	SPINA	JBPN-162609	18/02730	Ex e	II C	T4	II 2 G	IP 66
24	820-EHJ-H-0005-001	E	Vent Heat Tracing (Gas Heat Tracing) JB1 - Subdistribution 001	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS02-820	ACS02-820-0902	ACS02-C1448.3500-820-E-DFB-0001	SAFE AREA	ELTHERM	ELAK-Ex-3.7 / 0X80057	1862	Ex e	II C	T6	II 2 G	IP 66
25	820-EHJ-H-0005-002	E	Vent Heat Tracing (Gas Heat Tracing) JB1 - Subdistribution 002	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS02-820	ACS02-820-0902	ACS02-C1448.3500-820-E-DFB-0001	SAFE AREA	ELTHERM	ELAK-Ex-3.7 / 0X80057	1898	Ex e	II C	T6	II 2 G	IP 66
26	820-EHJ-H-0005-003	E	Vent Heat Tracing (Gas Heat Tracing) JB1 - Subdistribution 003	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS02-820	ACS02-820-0902	ACS02-C1448.3500-820-E-DFB-0001	SAFE AREA	ELTHERM	ELAK-Ex-3.7 / 0X80057	1959	Ex e	II C	T6	II 2 G	IP 66
27	820-EHJ-H-0006	E	Fire Water Tank (Water Heat Tracing) JB	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS02-820	ACS02-820-0902	ACS02-C1448.3500-820-E-DFB-0001	SAFE AREA	SPINA	JBPN-162609	18/02731	Ex e	II C	T4	II 2 G	IP 66
28	820-EHJ-H-0006-001	E	Fire Water Tank (Water Heat Tracing) JB - Subdistribution 001	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS02-820	ACS02-820-0902	ACS02-C1448.3500-820-E-DFB-0001	SAFE AREA	ELTHERM	ELAK-Ex-3.7 / 0X80057	1922	Ex e	II C	T6	II 2 G	IP 66
29	820-EHJ-H-0006-002	E	Fire Water Tank (Water Heat Tracing) JB - Subdistribution 002	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS02-820	ACS02-820-0902	ACS02-C1448.3500-820-E-DFB-0001	SAFE AREA	ELTHERM	ELAK-Ex-3.7 / 0X80057	1897	Ex e	II C	T6	II 2 G	IP 66
30	820-EHJ-H-0007-001	E	Vent Heat Tracing (Gas Heat Tracing) JB2	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS02-820	ACS02-820-0902	ACS02-C1448.3500-820-E-DFB-0001	SAFE AREA	ABTECH	ZAG 9.9	1060941	Ex e	II C	T6	II 2 G	IP 66/67
31	820-EHJ-H-0007-001C	E	Vent Heat Tracing (Gas Heat Tracing) - Control Box	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS02-820	ACS02-820-0902	ACS02-C1448.3500-820-E-DFB-0001	SAFE AREA	ELTHERM	ELAK-Ex-3.8 / 0X80058	2011	Ex e	II C	T6	II 2 G	IP 66
32	820-EHJ-H-0008-001	E	Condensate Tank Heat Tracing (Gas Heat Tracing) JB2	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS02-820	ACS02-820-0903	ACS02-C1448.3500-820-E-DFB-0001	ZONE 2	ELTHERM	ELAK-Ex-3.7 / 0X80057	1883	Ex e	II C	T6	II 2 G	IP 66
33	820-EHJ-H-0008-001C	E	Condensate Tank Heat Tracing (Gas Heat Tracing) - Control Box	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL)	ACS02-820	ACS02-820-0903	ACS02-C1448.3500-820-E-DFB-0001	ZONE 2	ELTHERM	ELAK-Ex-3 / 0X80057	2014	Ex e	II C	T6	II 2 G	IP 66
34	950-EHJ-L-0007-03	E	Secondary Routing Lighting Circuit Kuti Shperndarese (Junction Box)	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-1301	ACS02-C1448-820-E-DEB-0002	SAFE AREA	STAHL	8146/1051	1815739710440000	Ex e	II C	T4	II 2 G	IP 66
35	950-EHJ-L-0007-04	E	Ex-Three Pole Switch	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-1301	ACS02-C1448-820-E-DEB-0002	SAFE AREA	STAHL	8146/5061	1815738980440000	Ex de	II C	T4	II 2 G	IP 66

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
36	950-EHJ-L-0723	E	Lighting 723 JB	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-1301	ACS02-C1448-820-E-DEB-0002	ZONE 1	STAHL	8146/1061	1815739670440002	Ex e	II C	T4	II 2 G	IP 66
37	950-EHJ-L-0724	E	Lighting 724 JB	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-1301	ACS02-C1448-820-E-DEB-0002	SAFE AREA	STAHL	8146/1061	1815739670440008	Ex e	II C	T4	II 2 G	IP 66
38	950-EHJ-L-0725	E	Lighting 725 JB	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-1301	ACS02-C1448-820-E-DEB-0002	ZONE 2	STAHL	8146/1061	1815739670440007	Ex e	II C	T4	II 2 G	IP 66
39	950-EHJ-L-0726	E	Lighting 726 JB	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-1301	ACS02-C1448-820-E-DEB-0002	SAFE AREA	STAHL	8146/1061	1815739670440000	Ex e	II C	T4	II 2 G	IP 66
40	950-EHJ-L-0727	E	Lighting 727 JB	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-1301	ACS02-C1448-820-E-DEB-0002	ZONE 2	STAHL	8146/1061	1815739670440005	Ex e	II C	T4	II 2 G	IP 66
41	950-EHJ-L-0728	E	Lighting 728 JB	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-1301	ACS02-C1448-820-E-DEB-0002	SAFE AREA	STAHL	8146/1061	1815739670440000	Ex e	II C	T4	II 2 G	IP 66
42	950-EHJ-L-0729	E	Lighting 729 JB	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-1301	ACS02-C1448-820-E-DEB-0002	ZONE 2	STAHL	8146/1061	1815739670440003	Ex e	II C	T4	II 2 G	IP 66
43	950-EHJ-L-0730	E	Lighting 730 JB	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-1301	ACS02-C1448-820-E-DEB-0002	ZONE 2	STAHL	8146/1061	1815739670440001	Ex e	II C	T4	II 2 G	IP 66
44	ACS02-110-MV-1001	M	Valvul e motorizuar (Motor Operated Valve)	PIG TRAP	ACS02-110	ACS02-110-0100	ACS02-C1448-820-E-DEA-0002	ZONE 2	AUMA	SAEX 14.6 - F14 / - a3a1	2316MD68161	Ex de	II C	T4	II 2 G	IP 68
45	ACS02-110-MV-2001	M	Valvul e motorizuar (Motor Operated Valve)	PIG TRAP	ACS02-110	ACS02-110-0200	ACS02-C1448-820-E-DEA-0002	ZONE 2	AUMA	SAEX 14.6 - F14 / - a3a1	3817MD74333	Ex de	II C	T4	II 2 G	IP 68
46	ACS02-110-ZSC-1001-A	J	Celes Fundor i mbyllur (Limit Switch Close)	PIG TRAP	ACS02-110	ACS02-110-0100	ACS02-C1448-820-E-DEA-0002	ZONE 2	EUROTEC	EAE 2103-73-IA-DAE	2016-87433	Ex ia	II C	T6	II 2 G	IP 67
47	ACS02-110-ZSC-2001-A	J	Celes Fundor i mbyllur (Limit Switch Close)	PIG TRAP	ACS02-110	ACS02-110-0200	ACS02-C1448-820-E-DEA-0002	ZONE 2	EUROTEC	EAE 2103-73-IA-DAE	2016-86334	Ex ia	II C	T6	II 2 G	IP 67
48	ACS02-310-FIT-1030	J	Transmetues i prurjes (dP Flow Transmitter)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	SIEMENS	7MF4433-1EA02-2RB7-Z	N1JD189120130	Ex d	II C	T4 / T6	II 1/2 G	IP 66
49	ACS02-310-FIT-2030	J	Transmetues i prurjes (dP Flow Transmitter)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0200	ACS02-C1448-856-J-DJA-0001	ZONE 2	SIEMENS	7MF4433-1EA02-2RB7-Z	N1JD189120131	Ex d	II C	T4 / T6	II 1/2 G	IP 66
50	ACS02-310-FIT-3030	J	Transmetues i prurjes (dP Flow Transmitter)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	SIEMENS	7MF4433-1EA02-2RB7-Z	N1JD189120132	Ex d	II C	T4 / T6	II 1/2 G	IP 66
51	ACS02-310-HS-1108-B	J	çeles paneli lokal (Local Panel Hand Switch)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	CORTEM	SA301410/P	17/325338	Ex de	II C	T6	II 2 G	IP 66
52	ACS02-310-HS-1208-B	J	çeles paneli lokal (Local Panel Hand Switch)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	CORTEM	SA301410/P	17/325338	Ex de	II C	T6	II 2 G	IP 66
53	ACS02-310-HS-2108-B	J	çeles paneli lokal (Local Panel Hand Switch)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0200	ACS02-C1448-856-J-DJA-0001	ZONE 2	CORTEM	SA301410/P	17/325338	Ex de	II C	T6	II 2 G	IP 66
54	ACS02-310-HS-2208-B	J	çeles paneli lokal (Local Panel Hand Switch)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0200	ACS02-C1448-856-J-DJA-0001	ZONE 2	CORTEM	SA301410/P	17/325338	Ex de	II C	T6	II 2 G	IP 66
55	ACS02-310-HS-3108-B	J	çeles paneli lokal (Local Panel Hand Switch)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	CORTEM	SA301410/P	17/325338	Ex de	II C	T6	II 2 G	IP 66
56	ACS02-310-HS-3208-B	J	çeles paneli lokal (Local Panel Hand Switch)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	CORTEM	SA301410/P	17/325338	Ex de	II C	T6	II 2 G	IP 66
57	ACS02-310-JB-0001-A	E	Kuti Shperndarese (Junction Box)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0100	ACS02-C1448-856-J-DJA-0001	SAFE AREA	TECHNOR ITALSMEA	SB-282816	I/17/224527	Ex e	II C	T6	II 2 G	IP 66
58	ACS02-310-JB-0001-B	E	Kuti Shperndarese (Junction Box)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0200	ACS02-C1448-856-J-DJA-0001	SAFE AREA	TECHNOR ITALSMEA	SB-282816	I/17/224528	Ex e	II C	T6	II 2 G	IP 66
59	ACS02-310-JB-0001-C	E	Kuti Shperndarese (Junction Box)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0300	ACS02-C1448-856-J-DJA-0001	SAFE AREA	TECHNOR ITALSMEA	SB-282816	I/17/224526	Ex e	II C	T6	II 2 G	IP 66
60	ACS02-310-JB-0002-A	E	Kuti Shperndarese (Junction Box)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0100	ACS02-C1448-856-J-DJA-0001	SAFE AREA	TECHNOR ITALSMEA	SB-282816	I/17/224481	Ex e	II C	T6	II 2 G	IP 66
61	ACS02-310-JB-0002-B	E	Kuti Shperndarese (Junction Box)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0200	ACS02-C1448-856-J-DJA-0001	SAFE AREA	TECHNOR ITALSMEA	SB-282816	I/17/224479	Ex e	II C	T6	II 2 G	IP 66
62	ACS02-310-JB-0002-C	E	Kuti Shperndarese (Junction Box)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0300	ACS02-C1448-856-J-DJA-0001	SAFE AREA	TECHNOR ITALSMEA	SB-282816	I/17/224478	Ex e	II C	T6	II 2 G	IP 66
63	ACS02-310-JB-0100-A	E	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS02-858	ACS02-858-0100	ACS02-C1448-856-J-DJA-0001	SAFE AREA	TECHNOR ITALSMEA	SB-353520	I/17/222218	Ex e	II C	T6	II 2 G	IP 66
64	ACS02-310-JB-0100-B	E	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS02-858	ACS02-858-0100	ACS02-C1448-856-J-DJA-0001	SAFE AREA	TECHNOR ITALSMEA	SB-353520	I/17/222222	Ex e	II C	T6	II 2 G	IP 66
65	ACS02-310-JB-0100-C	E	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS02-858	ACS02-858-0100	ACS02-C1448-856-J-DJA-0001	SAFE AREA	TECHNOR ITALSMEA	SB-353520	I/17/222220	Ex e	II C	T6	II 2 G	IP 66
66	ACS02-310-JB-0200-A	E	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS02-858	ACS02-858-0100	ACS02-C1448-856-J-DJA-0001	SAFE AREA	TECHNOR ITALSMEA	SB-353520	I/17/222216	Ex e	II C	T6	II 2 G	IP 66
67	ACS02-310-JB-0200-B	E	Kuti Shperndarese (Junction Box)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0200	ACS02-C1448-856-J-DJA-0001	SAFE AREA	TECHNOR ITALSMEA	SB-353520	I/17/222217	Ex e	II C	T6	II 2 G	IP 66
68	ACS02-310-JB-0200-C	E	Kuti Shperndarese (Junction Box)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0300	ACS02-C1448-856-J-DJA-0001	SAFE AREA	TECHNOR ITALSMEA	SB-353520	I/17/222215	Ex e	II C	T6	II 2 G	IP 66
69	ACS02-310-JB-1001-A	E	Kuti Shperndarese (Junction Box)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0100	ACS02-C1448-856-J-DJA-0001	SAFE AREA	TECHNOR ITALSMEA	SB-353520	I/17/222208	Ex ia	II C	T6	II 2 G	IP 66
70	ACS02-310-JB-1001-B	E	Kuti Shperndarese (Junction Box)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0200	ACS02-C1448-856-J-DJA-0001	SAFE AREA	TECHNOR ITALSMEA	SB-353520	I/17/222209	Ex ia	II C	T6	II 2 G	IP 66
71	ACS02-310-JB-1001-C	E	Kuti Shperndarese (Junction Box)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0300	ACS02-C1448-856-J-DJA-0001	SAFE AREA	TECHNOR ITALSMEA	SB-353520	I/17/222210	Ex ia	II C	T6	II 2 G	IP 66
72	ACS02-310-JB-1002	E	Kuti Shperndarese (Junction Box)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0100	ACS02-C1448-856-J-DJA-0001	SAFE AREA	TECHNOR ITALSMEA	SB-352720	I/17/226202	Ex ia	II C	T6	II 2 G	IP 66

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
73	ACS02-310-LIT-1102	J	GWR Transmetues Nivel (Level Transmitter)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	SIEMENS	SITRANS LG270	38485266	Ex db	II C	T6 / T1	II 1/2 G	IP 66/68
74	ACS02-310-LIT-1202	J	GWR Transmetues Nivel (Level Transmitter)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	SIEMENS	SITRANS LG270	38485267	Ex db	II C	T6 / T1	II 1/2 G	IP 66/68
75	ACS02-310-LIT-2102	J	GWR Transmetues Nivel (Level Transmitter)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0200	ACS02-C1448-856-J-DJA-0001	ZONE 2	SIEMENS	SITRANS LG270	38485268	Ex db	II C	T6 / T1	II 1/2 G	IP 66/68
76	ACS02-310-LIT-2202	J	GWR Transmetues Nivel (Level Transmitter)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0200	ACS02-C1448-856-J-DJA-0001	ZONE 2	SIEMENS	SITRANS LG270	38485269	Ex db	II C	T6 / T1	II 1/2 G	IP 66/68
77	ACS02-310-LIT-3102	J	Transmetues i nivelit (Radar Transmetues Nivel (Level Transmitter))	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	SIEMENS	SITRANS LG270	38485270	Ex db	II C	T6 / T1	II 1/2 G	IP 66/68
78	ACS02-310-LIT-3202	J	Transmetues i nivelit (Radar Transmetues Nivel (Level Transmitter))	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	SIEMENS	SITRANS LG270	38485271	Ex db	II C	T6 / T1	II 1/2 G	IP 66/68
79	ACS02-310-LSHH-1104	J	Nivel (Level Switch High High)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	ROSEMOUNT	2120 VIBRATING FORK LEVEL SWITCH	1239931	Ex db	II C	T6 / T2	II 1/2 G	IP 66/67
80	ACS02-310-LSHH-1204	J	Nivel (Level Switch High High)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	ROSEMOUNT	2120 VIBRATING FORK LEVEL SWITCH	1239932	Ex db	II C	T6 / T2	II 1/2 G	IP 66/67
81	ACS02-310-LSHH-2104	J	Nivel (Level Switch High High)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0200	ACS02-C1448-856-J-DJA-0001	ZONE 2	ROSEMOUNT	2120 VIBRATING FORK LEVEL SWITCH	1239933	Ex db	II C	T6 / T2	II 1/2 G	IP 66/67
82	ACS02-310-LSHH-2204	J	Nivel (Level Switch High High)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0200	ACS02-C1448-856-J-DJA-0001	ZONE 2	ROSEMOUNT	2120 VIBRATING FORK LEVEL SWITCH	1239934	Ex db	II C	T6 / T2	II 1/2 G	IP 66/67
83	ACS02-310-LSHH-3104	J	Nivel (Level Switch High High)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	ROSEMOUNT	2120 VIBRATING FORK LEVEL SWITCH	1239935	Ex db	II C	T6 / T2	II 1/2 G	IP 66/67
84	ACS02-310-LSHH-3204	J	Nivel (Level Switch High High)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	ROSEMOUNT	2120 VIBRATING FORK LEVEL SWITCH	1239936	Ex db	II C	T6 / T2	II 1/2 G	IP 66/67
85	ACS02-310-LZSSL-1103	J	Nivel (Level Switch Low Low)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	ROSEMOUNT	2130 VIBRATING FORK LEVEL SWITCH	1309178	Ex db	II C	T6 / T2	II 1/2 G	IP 66/67
86	ACS02-310-LZSSL-1203	J	Nivel (Level Switch Low Low)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	ROSEMOUNT	2130 VIBRATING FORK LEVEL SWITCH	1292608	Ex db	II C	T6 / T2	II 1/2 G	IP 66/67
87	ACS02-310-LZSSL-2103	J	Nivel (Level Switch Low Low)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0200	ACS02-C1448-856-J-DJA-0001	ZONE 2	ROSEMOUNT	2130 VIBRATING FORK LEVEL SWITCH	1292838	Ex db	II C	T6 / T2	II 1/2 G	IP 66/67
88	ACS02-310-LZSSL-2203	J	Nivel (Level Switch Low Low)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0200	ACS02-C1448-856-J-DJA-0001	ZONE 2	ROSEMOUNT	2130 VIBRATING FORK LEVEL SWITCH	1292607	Ex db	II C	T6 / T2	II 1/2 G	IP 66/67
89	ACS02-310-LZSSL-3103	J	Nivel (Level Switch Low Low)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	ROSEMOUNT	2130 VIBRATING FORK LEVEL SWITCH	1290838	Ex db	II C	T6 / T2	II 1/2 G	IP 66/67
90	ACS02-310-LZSSL-3203	J	Nivel (Level Switch Low Low)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	ROSEMOUNT	2130 VIBRATING FORK LEVEL SWITCH	1290835	Ex db	II C	T6 / T2	II 1/2 G	IP 66/67
91	ACS02-310-MV-1010	M	Valvul e motorizuar (Motor Operated Valve)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0100	ACS02-C1448-820-E-DEA-0002	ZONE 2	AUMA	SAEX 07.6 - F10 / - a3a1	2217MD48780	Ex de	II C	T3	II 2 G	IP 68
92	ACS02-310-MV-2010	M	Valvul e motorizuar (Motor Operated Valve)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0100	ACS02-C1448-820-E-DEA-0002	ZONE 2	AUMA	SAEX 07.6 - F10 / - a3a1	2217MD48781	Ex de	II C	T3	II 2 G	IP 68
93	ACS02-310-MV-3010	M	Valvul e motorizuar (Motor Operated Valve)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0100	ACS02-C1448-820-E-DEA-0002	ZONE 2	AUMA	SAEX 07.6 - F10 / - a3a1	2217MD48782	Ex de	II C	T3	II 2 G	IP 68
94	ACS02-310-PDIT-0001	J	Diff. Transmetues presioni(Pressure Transmitter)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	SIEMENS	7MF4433-1FA02-2RB7-Z	N1JN239120056	Ex d	II C	T4 / T6	II 1/2 G	IP 66
95	ACS02-310-PDIT-1010	J	Diff. Transmetues presioni(Pressure Transmitter)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	SIEMENS	7MF4433-1GA02-2RB7-Z	N1JN239120057	Ex d	II C	T4 / T6	II 1/2 G	IP 66
96	ACS02-310-PDIT-2010	J	Diff. Transmetues presioni(Pressure Transmitter)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	SIEMENS	7MF4433-1GA02-2RB7-Z	N1JN239120058	Ex d	II C	T4 / T6	II 1/2 G	IP 66
97	ACS02-310-PDIT-3010	J	Diff. Transmetues presioni(Pressure Transmitter)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	SIEMENS	7MF4433-1GA02-2RB7-Z	N1JN239120059	Ex d	II C	T4 / T6	II 1/2 G	IP 66
98	ACS02-310-PIT-1021	J	Transmetues presioni(Pressure Transmitter)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	SIEMENS	7MF4033-1FA00-2RB7-Z	N1JN239000057	Ex d	II C	T4 / T6	II 1/2 G	IP 66
99	ACS02-310-PIT-2021	J	Transmetues presioni(Pressure Transmitter)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0200	ACS02-C1448-856-J-DJA-0001	ZONE 2	SIEMENS	7MF4033-1FA00-2RB7-Z	N1JN239000058	Ex d	II C	T4 / T6	II 1/2 G	IP 66
100	ACS02-310-PIT-3021	J	Transmetues presioni(Pressure Transmitter)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	SIEMENS	7MF4033-1FA00-2RB7-Z	N1JN239000059	Ex d	II C	T4 / T6	II 1/2 G	IP 66
101	ACS02-310-YV-1102	M	Valvul Solenoid (Solenoid Valve)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	IMI MAXSEAL	ICO 3S YZ13CE1H1DS-90	62146/3	Ex e m	II C	T4	II 2 G	IP 66/X8
102	ACS02-310-YV-1108	M	Solenoid per valvul (Solenoid Globe Valve)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	IMI MAXSEAL	ICO 3S YZ13CE1H1DS-90	62146/3	Ex e m	II C	T4	II 2 G	IP 66/X8
103	ACS02-310-YV-1202	M	Valvul Solenoid (Solenoid Valve)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	IMI MAXSEAL	ICO 3S YZ13CE1H1DS-90	62146/3	Ex e m	II C	T4	II 2 G	IP 66/X8
104	ACS02-310-YV-1208	M	Solenoid per valvul (Solenoid Globe Valve)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	IMI MAXSEAL	ICO 3S YZ13CE1H1DS-90	62146/3	Ex e m	II C	T4	II 2 G	IP 66/X8
105	ACS02-310-YV-2102	M	Valvul Solenoid (Solenoid Valve)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0200	ACS02-C1448-856-J-DJA-0001	ZONE 2	IMI MAXSEAL	ICO 3S YZ13CE1H1DS-90	62146/3	Ex e m	II C	T4	II 2 G	IP 66/X8
106	ACS02-310-YV-2108	M	Solenoid per valvul (Solenoid Globe Valve)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0200	ACS02-C1448-856-J-DJA-0001	ZONE 2	IMI MAXSEAL	ICO 3S YZ13CE1H1DS-90	62146/3	Ex e m	II C	T4	II 2 G	IP 66/X8
107	ACS02-310-YV-2202	M	Valvul Solenoid (Solenoid Valve)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0200	ACS02-C1448-856-J-DJA-0001	ZONE 2	IMI MAXSEAL	ICO 3S YZ13CE1H1DS-90	62146/3	Ex e m	II C	T4	II 2 G	IP 66/X8
108	ACS02-310-YV-2208	M	Solenoid per valvul (Solenoid Globe Valve)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0200	ACS02-C1448-856-J-DJA-0001	ZONE 2	IMI MAXSEAL	ICO 3S YZ13CE1H1DS-90	62146/3	Ex e m	II C	T4	II 2 G	IP 66/X8
109	ACS02-310-YV-3102	M	Valvul Solenoid (Solenoid Valve)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	IMI MAXSEAL	ICO 3S YZ13CE1H1DS-90	62146/3	Ex e m	II C	T4	II 2 G	IP 66/X8

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
110	ACS02-310-YV-3108	M	Solenoid per valvul (Solenoid Globe Valve)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	IMI MAXSEAL	ICO 3S YZ13CE1H1DS-90	62146/3	Ex e m	II C	T4	II 2 G	IP 66/X8
111	ACS02-310-YV-3202	M	Valvul Solenoid (Solenoid Valve)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	IMI MAXSEAL	ICO 3S YZ13CE1H1DS-90	62146/3	Ex e m	II C	T4	II 2 G	IP 66/X8
112	ACS02-310-YV-3208	M	Solenoid per valvul (Solenoid Globe Valve)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	IMI MAXSEAL	ICO 3S YZ13CE1H1DS-90	62146/3	Ex e m	II C	T4	II 2 G	IP 66/X8
113	ACS02-310-YZV-1108	M	Valvul Solenoid (Solenoid Valve)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	IMI MAXSEAL	ICO 3S YZ13CE1H1DS-90	62146/3	Ex e m	II C	T4	II 2 G	IP 66/X8
114	ACS02-310-YZV-1208	M	Valvul Solenoid (Solenoid Valve)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	IMI MAXSEAL	ICO 3S YZ13CE1H1DS-90	62146/3	Ex e m	II C	T4	II 2 G	IP 66/X8
115	ACS02-310-YZV-2108	M	Valvul Solenoid (Solenoid Valve)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0200	ACS02-C1448-856-J-DJA-0001	ZONE 2	IMI MAXSEAL	ICO 3S YZ13CE1H1DS-90	62146/3	Ex e m	II C	T4	II 2 G	IP 66/X8
116	ACS02-310-YZV-2208	M	Valvul Solenoid (Solenoid Valve)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0200	ACS02-C1448-856-J-DJA-0001	ZONE 2	IMI MAXSEAL	ICO 3S YZ13CE1H1DS-90	62146/3	Ex e m	II C	T4	II 2 G	IP 66/X8
117	ACS02-310-YZV-3108	M	Valvul Solenoid (Solenoid Valve)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	IMI MAXSEAL	ICO 3S YZ13CE1H1DS-90	62146/3	Ex e m	II C	T4	II 2 G	IP 66/X8
118	ACS02-310-YZV-3208	M	Valvul Solenoid (Solenoid Valve)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	IMI MAXSEAL	ICO 3S YZ13CE1H1DS-90	62146/3	Ex e m	II C	T4	II 2 G	IP 66/X8
119	ACS02-310-ZSC-1010-A	J	Celes Fundor i mbyllur (Limit Switch Close)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	WESTLOCK CONTROLS	3347RBYS00023ECU-AR1	256038-1 012	Ex ia	II C	T6 / T1	II 1/2 G	IP 66/67
120	ACS02-310-ZSC-1102	J	Celes Fundor i mbyllur (Limit Switch Close)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	EISENBAU	GI SERIES	N/A	Ex ia	II C	T6 / T1	II 1/2 G	IP 66/67
121	ACS02-310-ZSC-1108	J	Celes Fundor i mbyllur (Limit Switch Close)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	EISENBAU	GIAMOLIS2PN2P5S2	N/A	Ex ia	II C	T6 / T1	II 1/2 G	IP 66/67
122	ACS02-310-ZSC-1202	J	Celes Fundor i mbyllur (Limit Switch Close)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	EISENBAU	GIAMOLIS2PN2P5S2	N/A	Ex ia	II C	T6 / T1	II 1/2 G	IP 66/67
123	ACS02-310-ZSC-1208	J	Celes Fundor i mbyllur (Limit Switch Close)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	EISENBAU	GIAMOLIS2PN2P5S2	N/A	Ex ia	II C	T6 / T1	II 1/2 G	IP 66/67
124	ACS02-310-ZSC-2010-A	J	Celes Fundor i mbyllur (Limit Switch Close)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	WESTLOCK CONTROLS	3347RBYS00023ECU-AR1	256038-1 009	Ex ia	II C	T6 / T1	II 1/2 G	IP 66/67
125	ACS02-310-ZSC-2102	J	Celes Fundor i mbyllur (Limit Switch Close)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0200	ACS02-C1448-856-J-DJA-0001	ZONE 2	EISENBAU	GIAMOLIS2PN2P5S2	N/A	Ex ia	II C	T6 / T1	II 1/2 G	IP 66/67
126	ACS02-310-ZSC-2108	J	Celes Fundor i mbyllur (Limit Switch Close)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0200	ACS02-C1448-856-J-DJA-0001	ZONE 2	EISENBAU	GIAMOLIS2PN2P5S2	N/A	Ex ia	II C	T6 / T1	II 1/2 G	IP 66/67
127	ACS02-310-ZSC-2202	J	Celes Fundor i mbyllur (Limit Switch Close)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0200	ACS02-C1448-856-J-DJA-0001	ZONE 2	EISENBAU	GIAMOLIS2PN2P5S2	N/A	Ex ia	II C	T6 / T1	II 1/2 G	IP 66/67
128	ACS02-310-ZSC-2208	J	Celes Fundor i mbyllur (Limit Switch Close)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0200	ACS02-C1448-856-J-DJA-0001	ZONE 2	EISENBAU	GIAMOLIS2PN2P5S2	N/A	Ex ia	II C	T6 / T1	II 1/2 G	IP 66/67
129	ACS02-310-ZSC-3010-A	J	Celes Fundor i mbyllur (Limit Switch Close)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	WESTLOCK CONTROLS	3347RBYS00023ECU-AR1	256038-1 008	Ex ia	II C	T6 / T1	II 1/2 G	IP 66/67
130	ACS02-310-ZSC-3102	J	Celes Fundor i mbyllur (Limit Switch Close)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	EISENBAU	GIAMOLIS2PN2P5S2	N/A	Ex ia	II C	T6 / T1	II 1/2 G	IP 66/67
131	ACS02-310-ZSC-3108	J	Celes Fundor i mbyllur (Limit Switch Close)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	EISENBAU	GIAMOLIS2PN2P5S2	N/A	Ex ia	II C	T6 / T1	II 1/2 G	IP 66/67
132	ACS02-310-ZSC-3202	J	Celes Fundor i mbyllur (Limit Switch Close)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	EISENBAU	GIAMOLIS2PN2P5S2	N/A	Ex ia	II C	T6 / T1	II 1/2 G	IP 66/67
133	ACS02-310-ZSC-3208	J	Celes Fundor i mbyllur (Limit Switch Close)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	EISENBAU	GIAMOLIS2PN2P5S2	N/A	Ex ia	II C	T6 / T1	II 1/2 G	IP 66/67
134	ACS02-330-FIT-1001	J	Mates i prurjes me ultratinguj (Ultrasonic Flowmeter)	Matja e Gazit	ACS02-330	ACS02-330-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	ELSTER	Q. SONIC PLUS	69511696	Ex d	II B + H2	T6	II 2 G	IP 66
135	ACS02-330-FIT-1002	J	Mates i prurjes me ultratinguj (Ultrasonic Flowmeter)	Matja e Gazit	ACS02-330	ACS02-330-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	ELSTER	Q. SONIC PLUS	69511700	Ex d	II B + H2	T6	II 2 G	IP 66
136	ACS02-330-FIT-2001	J	Mates i prurjes me ultratinguj (Ultrasonic Flowmeter)	Matja e Gazit	ACS02-330	ACS02-330-0200	ACS02-C1448-856-J-DJA-0001	ZONE 2	ELSTER	Q. SONIC PLUS	69511702	Ex d	II B + H2	T6	II 2 G	IP 66
137	ACS02-330-FIT-2002	J	Mates i prurjes me ultratinguj (Ultrasonic Flowmeter)	Matja e Gazit	ACS02-330	ACS02-330-0200	ACS02-C1448-856-J-DJA-0001	ZONE 2	ELSTER	Q. SONIC PLUS	69511703	Ex d	II B + H2	T6	II 2 G	IP 66
138	ACS02-330-FIT-3001	J	Mates i prurjes me ultratinguj (Ultrasonic Flowmeter)	Matja e Gazit	ACS02-330	ACS02-330-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	ELSTER	Q. SONIC PLUS	69511706	Ex d	II B + H2	T6	II 2 G	IP 66
139	ACS02-330-FIT-3002	J	Mates i prurjes me ultratinguj (Ultrasonic Flowmeter)	Matja e Gazit	ACS02-330	ACS02-330-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	ELSTER	Q. SONIC PLUS	69511707	Ex d	II B + H2	T6	II 2 G	IP 66
140	ACS02-330-JB-0100	E	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS02-858	ACS02-858-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	TECHNOR ITALSMEA	SB-282816	I/17/224468	Ex e	II C	T6	II 2 G	IP 66
141	ACS02-330-JB-0102	E	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS02-858	ACS02-858-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	TECHNOR ITALSMEA	SB-282816	I/17/224467	Ex e	II C	T6	II 2 G	IP 66
142	ACS02-330-JB-1001	E	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS02-858	ACS02-858-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	TECHNOR ITALSMEA	SB-352720	I/17/226201	Ex ia	II C	T6	II 2 G	IP 66
143	ACS02-330-JB-1002	E	Kuti Shperndarese (Junction Box)	Matja e Gazit	ACS02-330	ACS02-330-0600	ACS02-C1448-856-J-DJA-0001	ZONE 2	TECHNOR ITALSMEA	SB-353520	I/17/222212	Ex ia	II C	T6	II 2 G	IP 66
144	ACS02-330-JB-1003	E	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS02-858	ACS02-858-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	TECHNOR ITALSMEA	SB-282816	I/17/224491	Ex ia	II C	T6	II 2 G	IP 66
145	ACS02-330-MV-0010	M	Valvul e motorizuar (Motor Operated Valve)	Matja e Gazit	ACS02-330	ACS02-330-0600	ACS02-C1448-820-E-DEA-0002	ZONE 2	AUMA	SAEX 14.2 - F14 / - a3 a1	2617MD54995	Ex de	II C	T3	II 2 G	IP 68
146	ACS02-330-MV-0011	M	Valvul e motorizuar (Motor Operated Valve)	Matja e Gazit	ACS02-330	ACS02-330-0600	ACS02-C1448-820-E-DEA-0002	ZONE 2	AUMA	SAEX 07.2 - F10 / - a3 a1	3717MD72501	Ex de	II C	T3	II 2 G	IP 68
147	ACS02-330-MV-1010	M	Valvul e motorizuar (Motor Operated Valve)	Matja e Gazit	ACS02-330	ACS02-330-0100	ACS02-C1448-820-E-DEA-0002	ZONE 2	AUMA	SAEX 07.2 - F10 / - a3 a1	2217MD49440	Ex de	II C	T3	II 2 G	IP 68
148	ACS02-330-MV-2010	M	Valvul e motorizuar (Motor Operated Valve)	Matja e Gazit	ACS02-330	ACS02-330-0200	ACS02-C1448-820-E-DEA-0002	ZONE 2	AUMA	SAEX 07.2 - F10 / - a3 a1	2217MD49441	Ex de	II C	T3	II 2 G	IP 68
149	ACS02-330-MV-3010	M	Valvul e motorizuar (Motor Operated Valve)	Matja e Gazit	ACS02-330	ACS02-330-0300	ACS02-C1448-820-E-DEA-0002	ZONE 2	AUMA	SAEX 07.2 - F10 / - a3 a1	2217MD49442	Ex de	II C	T3	II 2 G	IP 68
150	ACS02-330-PDIT-0010	J	Diff. Transmetues presioni(Pressure Transmitter)	Matja e Gazit	ACS02-330	ACS02-330-0600	ACS02-C1448-856-J-DJA-0001	ZONE 2	SIEMENS	7MF4433-1GA02-2RB7-Z	N1JN239120060	Ex d	II C	T4 / T6	II 1/2 G	IP 66
151	ACS02-330-PDIT-1010	J	Diff. Transmetues presioni(Pressure Transmitter)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0400	ACS02-C1448-856-J-DJA-0001	ZONE 2	SIEMENS	7MF4433-1GA02-2RB7-Z	N1JN239120061	Ex d	II C	T4 / T6	II 1/2 G	IP 66

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
152	ACS02-330-PDIT-2010	J	Diff. Transmetues presioni(Pressure Transmitter)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0400	ACS02-C1448-856-J-DJA-0001	ZONE 2	SIEMENS	7MF4433-1GA02-2RB7-Z	N1JN239120062	Ex d	II C	T4 / T6	II 1/2 G	IP 66
153	ACS02-330-PDIT-3010	J	Diff. Transmetues presioni(Pressure Transmitter)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0400	ACS02-C1448-856-J-DJA-0001	ZONE 2	SIEMENS	7MF4433-1GA02-2RB7-Z	N1JN239120063	Ex d	II C	T4 / T6	II 1/2 G	IP 66
154	ACS02-330-PIT-1001	J	Transmetues presioni(Pressure Transmitter)	Matja e Gazit	ACS02-330	ACS02-330-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	HONEYWELL	ST 800	17W49 C4000005418323	Ex ia	II C	T4	II 1 G	IP 66/67
155	ACS02-330-PIT-1002	J	Transmetues presioni(Pressure Transmitter)	Matja e Gazit	ACS02-330	ACS02-330-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	HONEYWELL	ST 800	17W49 C4000005418319	Ex ia	II C	T4	II 1 G	IP 66/67
156	ACS02-330-PIT-1011	J	Transmetues presioni(Pressure Transmitter)	Matja e Gazit	ACS02-330	ACS02-330-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	SIEMENS	7MF4033-1FA00-2RB7-Z	N1JN239000060	Ex d	II C	T4 / T6	II 1/2 G	IP 66
157	ACS02-330-PIT-2001	J	Transmetues presioni(Pressure Transmitter)	Matja e Gazit	ACS02-330	ACS02-330-0200	ACS02-C1448-856-J-DJA-0001	ZONE 2	HONEYWELL	ST 800	17W49 C4000005418313	Ex ia	II C	T4	II 1 G	IP 66/67
158	ACS02-330-PIT-2002	J	Transmetues presioni(Pressure Transmitter)	Matja e Gazit	ACS02-330	ACS02-330-0200	ACS02-C1448-856-J-DJA-0001	ZONE 2	HONEYWELL	ST 800	17W49 C4000005418326	Ex ia	II C	T4	II 1 G	IP 66/67
159	ACS02-330-PIT-2011	J	Transmetues presioni(Pressure Transmitter)	Matja e Gazit	ACS02-330	ACS02-330-0200	ACS02-C1448-856-J-DJA-0001	ZONE 2	SIEMENS	7MF4033-1FA00-2RB7-Z	N1JN239000061	Ex d	II C	T4 / T6	II 1/2 G	IP 66
160	ACS02-330-PIT-3001	J	Transmetues presioni(Pressure Transmitter)	Matja e Gazit	ACS02-330	ACS02-330-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	HONEYWELL	ST 800	17W49 C4000005418321	Ex ia	II C	T4	II 1 G	IP 66/67
161	ACS02-330-PIT-3002	J	Transmetues presioni(Pressure Transmitter)	Matja e Gazit	ACS02-330	ACS02-330-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	HONEYWELL	ST 800	17W49 C4000005418264	Ex ia	II C	T4	II 1 G	IP 66/67
162	ACS02-330-PIT-3011	J	Transmetues presioni(Pressure Transmitter)	Matja e Gazit	ACS02-330	ACS02-330-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	SIEMENS	7MF4033-1FA00-2RB7-Z	N1JN239000062	Ex d	II C	T4 / T6	II 1/2 G	IP 66
163	ACS02-330-TIT-1001	J	Transmetues Temperature (Temperature Transmitter)	Matja e Gazit	ACS02-330	ACS02-330-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	HONEYWELL	STT850	18W24 C4000005418338	Ex ia	II C	T4	II 1 G	IP 66/67
164	ACS02-330-TIT-1002	J	Transmetues Temperature (Temperature Transmitter)	Matja e Gazit	ACS02-330	ACS02-330-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	HONEYWELL	STT850	18W24 C4000005418342	Ex ia	II C	T4	II 1 G	IP 66/67
165	ACS02-330-TIT-2001	J	Transmetues Temperature (Temperature Transmitter)	Matja e Gazit	ACS02-330	ACS02-330-0200	ACS02-C1448-856-J-DJA-0001	ZONE 2	HONEYWELL	STT850	18W24 C4000005418336	Ex ia	II C	T4	II 1 G	IP 66/67
166	ACS02-330-TIT-2002	J	Transmetues Temperature (Temperature Transmitter)	Matja e Gazit	ACS02-330	ACS02-330-0200	ACS02-C1448-856-J-DJA-0001	ZONE 2	HONEYWELL	STT850	18W24 C4000005418349	Ex ia	II C	T4	II 1 G	IP 66/67
167	ACS02-330-TIT-3001	J	Transmetues Temperature (Temperature Transmitter)	Matja e Gazit	ACS02-330	ACS02-330-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	HONEYWELL	STT850	18W24 C4000005418346	Ex ia	II C	T4	II 1 G	IP 66/67
168	ACS02-330-TIT-3002	J	Transmetues Temperature (Temperature Transmitter)	Matja e Gazit	ACS02-330	ACS02-330-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	HONEYWELL	STT850	18W24 C4000005418344	Ex ia	II C	T4	II 1 G	IP 66/67
169	ACS02-330-U-1001_package	J	Mates me ultratinguj (Ultrasonic Meter)	Matja e Gazit	ACS02-330	ACS02-330-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	ELSTER	Q-SONIC PLUS	69511696	Ex d ia (ia)	II B + H2	T6	II 2 G	IP 66
170	ACS02-330-U-2001_package	J	Mates me ultratinguj (Ultrasonic Meter)	Matja e Gazit	ACS02-330	ACS02-330-0200	ACS02-C1448-856-J-DJA-0001	ZONE 2	ELSTER	Q-SONIC PLUS	69511702	Ex d ia (ia)	II B + H2	T6	II 2 G	IP 66
171	ACS02-330-U-3001_package	J	Mates me ultratinguj (Ultrasonic Meter)	Matja e Gazit	ACS02-330	ACS02-330-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	ELSTER	Q-SONIC PLUS	69511706	Ex d ia (ia)	II B + H2	T6	II 2 G	IP 66
172	ACS02-330-ZSC-0010-A	J	Celes Fundor i mbyllur (Limit Switch Close)	Matja e Gazit	ACS02-330	ACS02-330-0600	ACS02-C1448-856-J-DJA-0001	ZONE 2	WESTLOCK CONTROLS	3347RBYS00023ECU-AR1	256038-1 051	Ex ia	II C	T6 / T1	II 1 G	IP 66/67
173	ACS02-330-ZSC-0011-A	J	Celes Fundor i mbyllur (Limit Switch Close)	Matja e Gazit	ACS02-330	ACS02-330-0600	ACS02-C1448-856-J-DJA-0001	ZONE 2	EISENBAU	GIAMOLIS2PN2P5S2	N/A	Ex ia	II C	T6 / T1	II 1/2 G	IP 66/67
174	ACS02-330-ZSC-1010-A	J	Celes Fundor i mbyllur (Limit Switch Close)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0400	ACS02-C1448-856-J-DJA-0001	ZONE 2	WESTLOCK CONTROLS	3347RBYS00023ECU-AR1	256038-1 030	Ex ia	II C	T6 / T1	II 1/2 G	IP 66/67
175	ACS02-330-ZSC-1020	J	Celes Fundor i mbyllur (Limit Switch Close)	Matja e Gazit	ACS02-330	ACS02-330-0600	ACS02-C1448-856-J-DJA-0001	ZONE 2	SOLDO CONTROLS	SS3A22E-20B11A6	N/A	Ex ia	II C	T6 / T4	II 2 G	IP 66/67
176	ACS02-330-ZSC-2010-A	J	Celes Fundor i mbyllur (Limit Switch Close)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0400	ACS02-C1448-856-J-DJA-0001	ZONE 2	WESTLOCK CONTROLS	3347RBYS00023ECU-AR1	256038-1 024	Ex ia	II C	T6 / T1	II 1/2 G	IP 66/67
177	ACS02-330-ZSC-2020	J	Celes Fundor i mbyllur (Limit Switch Close)	Matja e Gazit	ACS02-330	ACS02-330-0600	ACS02-C1448-856-J-DJA-0001	ZONE 2	SOLDO CONTROLS	SS3A22E-20B11A6	N/A	Ex ia	II C	T6 / T4	II 2 G	IP 66/67
178	ACS02-330-ZSC-3010-A	J	Celes Fundor i mbyllur (Limit Switch Close)	Filtrimi dhe ndarja e gazit (GAS SEPARATION AND FILTERING)	ACS02-310	ACS02-310-0400	ACS02-C1448-856-J-DJA-0001	ZONE 2	WESTLOCK CONTROLS	3347RBYS00023ECU-AR1	256038-1 054	Ex ia	II C	T6 / T1	II 1/2 G	IP 66/67
179	ACS02-330-ZSC-3020	J	Celes Fundor i mbyllur (Limit Switch Close)	Matja e Gazit	ACS02-330	ACS02-330-0600	ACS02-C1448-856-J-DJA-0001	ZONE 2	SOLDO CONTROLS	SS3A22E-20B11A6	N/A	Ex ia	II C	T6 / T4	II 2 G	IP 66/67
180	ACS02-360-HS-0010-B	J	çeles paneli lokal (Local Panel Hand Switch)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	QUINTEX	CB-P6/16353	64725	Ex de	II C	T4	II 2 G	IP 66
181	ACS02-360-HS-0011-B	J	çeles paneli lokal (Local Panel Hand Switch)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	CORTEM	SA301410/P	17 / 325328	Ex de	II C	T6	II 2 G	IP 66
182	ACS02-360-HS-0040-B	J	çeles paneli lokal (Local Panel Hand Switch)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	QUINTEX	CB-P6/16353	64713	Ex de	II C	T4	II 2 G	IP 66
183	ACS02-360-HS-0041-B	J	çeles paneli lokal (Local Panel Hand Switch)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	CORTEM	SA301410/P	17 / 325328	Ex de	II C	T6	II 2 G	IP 66
184	ACS02-360-JB-0001	E	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS02-858	ACS02-858-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	TECHNOR ITALSMEA	SB-282816	I/17/224480	Ex e	II C	T6	II 2 G	IP 66
185	ACS02-360-JB-0100	E	Kuti Shperndarese (Junction Box)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	TECHNOR ITALSMEA	SB-282816	I/17/224469	Ex e	II C	T6	II 2 G	IP 66
186	ACS02-360-JB-0101	E	Kuti Shperndarese (Junction Box)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	TECHNOR ITALSMEA	SB-353520	I/17/222219	Ex e	II C	T6	II 2 G	IP 66
187	ACS02-360-JB-0200	E	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS02-858	ACS02-858-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	TECHNOR ITALSMEA	SB-353520	I/17/222214	Ex e	II C	T6	II 2 G	IP 66
188	ACS02-360-JB-0201	E	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS02-858	ACS02-858-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	TECHNOR ITALSMEA	SB-282816	I/17/224487	Ex e	II C	T6	II 2 G	IP 66
189	ACS02-360-JB-1001	E	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS02-858	ACS02-858-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	TECHNOR ITALSMEA	SB-282816	I/17/224489	Ex ia	II C	T6	II 2 G	IP 66
190	ACS02-360-JB-1002	E	Kuti Shperndarese (Junction Box)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	TECHNOR ITALSMEA	SB-353520	I/17/222213	Ex ia	II C	T6	II 2 G	IP 66
191	ACS02-360-JB-1003	E	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS02-858	ACS02-858-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	TECHNOR ITALSMEA	SB-352720	I/17/226203	Ex ia	II C	T6	II 2 G	IP 66
192	ACS02-360-JB-1004	E	Kuti Shperndarese (Junction Box)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	TECHNOR ITALSMEA	SB-353520	I/17/222211	Ex e (ia)	II C	T6	II 2 G	IP 66
193	ACS02-360-MV-0020	M	Valvul e motorizuar (Motor Operated Valve)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-820-E-DEA-0002	ZONE 2	AUMA	SAEX 14.2 - F14 / - a3 a1	2617MD54997	Ex de	II C	T3	II 2 G	IP 68
194	ACS02-360-MV-0021	M	Valvul e motorizuar (Motor Operated Valve)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-820-E-DEA-0002	ZONE 2	AUMA	SAEX 07.2 - F10 / - a3 a1	3717MD72509	Ex de	II C	T3	II 2 G	IP 68
195	ACS02-360-MV-0030	M	Valvul e motorizuar (Motor Operated Valve)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-820-E-DEA-0002	ZONE 2	AUMA	SAEX 14.2 - F14 / - a3 a1	2617MD54996	Ex de	II C	T3	II 2 G	IP 68
196	ACS02-360-MV-0031	M	Valvul e motorizuar (Motor Operated Valve)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-820-E-DEA-0002	ZONE 2	AUMA	SAEX 07.2-F10	3717MD72502	Ex de	II C	T3	II 2 G	IP 68
197	ACS02-360-MV-1030	M	Valvul e motorizuar (Motor Operated Valve)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-820-E-DEA-0002	ZONE 2	AUMA	SAEX 07.6 - F10 / - a3a1	2217MD48783	Ex de	II C	T3	II 2 G	IP 68
198	ACS02-360-MV-1031	M	Valvul e motorizuar (Motor Operated Valve)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-820-E-DEA-0002	ZONE 2	AUMA	SAEX 07.2 - F10 / - a3 a1	3717MD72503	Ex de	II C	T3	II 2 G	IP 68
199	ACS02-360-MV-2030	M	Valvul e motorizuar (Motor Operated Valve)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-820-E-DEA-0002	ZONE 2	AUMA	SAEX 07.6 - F10 / - a3a1	2217MD48784	Ex de	II C	T3	II 2 G	IP 68
200	ACS02-360-MV-2031	M	Valvul e motorizuar (Motor Operated Valve)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-820-E-DEA-0002	ZONE 2	AUMA	SAEX 07.2 - F10 / - a3 a1	3717MD72504	Ex de	II C	T3	II 2 G	IP 68
201	ACS02-360-PDIT-0010	J	Diff. Transmetues presioni(Pressure Transmitter)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	SIEMENS	SITRANS P DS III	N1JN239120064	Ex d	II C	T4 / T6	II 1/2 G	IP 66

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
202	ACS02-360-PDIT-0020	J	Diff. Transmetues presioni(Pressure Transmitter)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	SIEMENS	7MF4433-1GA02-2RB7-Z	N1JN239120065	Ex d	II C	T4 / T6	II 1/2 G	IP 66
203	ACS02-360-PDIT-0030	J	Diff. Transmetues presioni(Pressure Transmitter)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	SIEMENS	7MF4433-1GA02-2RB7-Z	N1JN239120052	Ex d	II C	T4 / T6	II 1/2 G	IP 66
204	ACS02-360-PDIT-0040	J	Diff. Transmetues presioni(Pressure Transmitter)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	SIEMENS	SITRANS P DS III	N1JN239120053	Ex d	II C	T4 / T6	II 1/2 G	IP 66
205	ACS02-360-PDIT-1030	J	Diff. Transmetues presioni(Pressure Transmitter)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	SIEMENS	7MF4433-1GA02-2RB7-Z	N1JN239120054	Ex d	II C	T4 / T6	II 1/2 G	IP 66
206	ACS02-360-PDIT-2030	J	Diff. Transmetues presioni(Pressure Transmitter)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	SIEMENS	7MF4433-1GA02-2RB7-Z	N1JN239120055	Ex d	II C	T4 / T6	II 1/2 G	IP 66
207	ACS02-360-PIT-0027	J	Transmetues presioni(Pressure Transmitter)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	SIEMENS	7MF4033-1FA00-2RB7-Z	N1JN239000063	Ex d	II C	T4 / T6	II 1/2 G	IP 66
208	ACS02-360-PIT-0070	J	Transmetues presioni(Pressure Transmitter)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	SIEMENS	7MF4033-1FA00-2RB7-Z	N1JN239000064	Ex d	II C	T4 / T6	II 1/2 G	IP 66
209	ACS02-360-PIT-2027	J	Transmetues presioni(Pressure Transmitter)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	SIEMENS	7MF4033-1FA00-2RB7-Z	N1JN239000065	Ex d	II C	T4 / T6	II 1/2 G	IP 66
210	ACS02-360-YV-0010	M	Valvul Solenoid (Solenoid Valve)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	IMI MAXSEAL	ICO 3S	61370/1	Ex e m	II C	T4	II 2 G	IP 66/X8
211	ACS02-360-YV-0011	M	Solenoid per valvul (Solenoid Globe Valve)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	IMI MAXSEAL	ICO 3S YZ13CE1H1DS-90	62146/3	Ex e m	II C	T4	II 2 G	IP 66/X8
212	ACS02-360-YV-0040	M	Valvul Solenoid (Solenoid Valve)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	IMI MAXSEAL	ICO 3S	61370/1	Ex e m	II C	T4	II 2 G	IP 66/X8
213	ACS02-360-YV-0041	M	Solenoid per valvul (Solenoid Globe Valve)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	IMI MAXSEAL	ICO 3S YZ13CE1H1DS-90	62146/3	Ex e m	II C	T4	II 2 G	IP 66/X8
214	ACS02-360-YZV-0010	M	Valvul Solenoid (Solenoid Valve)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	IMI MAXSEAL	ICO 3S	61370/1	Ex e m	II C	T4	II 2 G	IP 66/X8
215	ACS02-360-YZV-0011	M	Valvul Solenoid (Solenoid Valve)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	IMI MAXSEAL	ICO 3S YZ13CE1H1DS-90	62146/3	Ex e m	II C	T4	II 2 G	IP 66/X8
216	ACS02-360-YZV-0040	M	Valvul Solenoid (Solenoid Valve)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	IMI MAXSEAL	ICO 3S	61370/1	Ex e m	II C	T4	II 2 G	IP 66/X8
217	ACS02-360-YZV-0041	M	Valvul Solenoid (Solenoid Valve)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	IMI MAXSEAL	ICO 3S YZ13CE1H1DS-90	62146/3	Ex e m	II C	T4	II 2 G	IP 66/X8
218	ACS02-360-ZSC-0010	J	Celes Fundor i mbyllur (Limit Switch Close)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	EISENBAU	GISMORGS2PN2P5S2DW	N/A	Ex ia	II C	T6 / T1	II 1 G	IP 66/67
219	ACS02-360-ZSC-0011	J	Celes Fundor i mbyllur (Limit Switch Close)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	EISENBAU	GIAMOLIS2PN2P5S2	N/A	Ex ia	II C	T6 / T1	II 2 G	IP 66/67
220	ACS02-360-ZSC-0020-A	J	Celes Fundor i mbyllur (Limit Switch Close)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	WESTLOCK CONTROLS	3347RBYS00023ECU-AR1	256038-1 062	Ex ia	II C	T6 / T1	II 1/2 G	IP 66/67
221	ACS02-360-ZSC-0021-A	J	Celes Fundor i mbyllur (Limit Switch Close)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	EISENBAU	GIAMOLIS2PN2P5S2	N/A	Ex ia	II C	T6 / T1	II 2 G	IP 66/67
222	ACS02-360-ZSC-0030-A	J	Celes Fundor i mbyllur (Limit Switch Close)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	WESTLOCK CONTROLS	3347RBYS00023ECU-AR1	256038-1 038	Ex ia	II C	T6 / T1	II 1/2 G	IP 66/67
223	ACS02-360-ZSC-0031-A	J	Celes Fundor i mbyllur (Limit Switch Close)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	EISENBAU	GI SERIES	N/A	Ex ia	II C	T6 / T1	II 1/2 G	IP 66/67
224	ACS02-360-ZSC-0040	J	Celes Fundor i mbyllur (Limit Switch Close)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	EISENBAU	GI SERIES	N/A	Ex ia	II C	T6 / T1	II 1/2 G	IP 66/67
225	ACS02-360-ZSC-0041	J	Celes Fundor i mbyllur (Limit Switch Close)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	EISENBAU	GI SERIES	N/A	Ex ia	II C	T6 / T1	II 1/2 G	IP 66/67
226	ACS02-360-ZSC-1030-A	J	Celes Fundor i mbyllur (Limit Switch Close)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	WESTLOCK CONTROLS	3347RBYS00023ECU-AR1	256038-1 021	Ex ia	II C	T6 / T1	II 1 G	IP 66/67
227	ACS02-360-ZSC-1031-A	J	Celes Fundor i mbyllur (Limit Switch Close)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	EISENBAU	GIAMOLIS2PN2P5S2	N/A	Ex ia	II C	T6 / T1	II 1/2 G	IP 66/67
228	ACS02-360-ZSC-2030-A	J	Celes Fundor i mbyllur (Limit Switch Close)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	WESTLOCK CONTROLS	3347RBYS00023ECU-AR1	256038-1 018	Ex ia	II C	T6 / T1	II 1/2 G	IP 66/67
229	ACS02-360-ZSC-2031-A	J	Celes Fundor i mbyllur (Limit Switch Close)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	EISENBAU	GIAMOLIS2PN2P5S2	N/A	Ex ia	II C	T6 / T1	II 2 G	IP 66/67
230	ACS02-381-A-0002	E	Sistem tokzimi (Grounding System)	CONDENSATE TANKS	ACS02-381	ACS02-381-0000	ACS02-C1448-856-J-DJA-0001	SAFE AREA	CORTEM	GRD-4200/24	18/333193	Ex d	II B + H2	T6	II 2 (1) G	IP 66
231	ACS02-381-EHD-0002	J	Leak Detection Control Cabinet	CONDENSATE TANKS	ACS02-381	ACS02-381-0000	ACS02-C1448-856-J-DJA-0001	SAFE AREA	ASSYTECH	P / N / L /00/04	2418008	N/A	N/A	N/A	II 2 G	IP 44
232	ACS02-381-EHZ-0001	J	Llame sinjalizuese (Signal Light)	CONDENSATE TANKS	ACS02-381	ACS02-381-0000	ACS02-C1448-856-J-DJA-0001	SAFE AREA	CORTEM	CCA-02E/S11LD24	18/333192	Ex d	II C	T6	II 2 G	IP 66
233	ACS02-381-EHZ-0002	J	Bori	CONDENSATE TANKS	ACS02-381	ACS02-381-0000	ACS02-C1448-856-J-DJA-0001	SAFE AREA	AES	ETH 12 MBN	536	Ex d	II C	T6	II 2 G	IP 65
234	ACS02-381-JB-0001	E	Kuti Shperndarese (Junction Box)	CONDENSATE TANKS	ACS02-381	ACS02-381-0000	ACS02-C1448-856-J-DJA-0001	SAFE AREA	TECHNOR ITALSMEA	SB-282816	I/17/224492	Ex e	II C	T6	II 2 G	IP 66
235	ACS02-381-JB-1100	E	Kuti Shperndarese (Junction Box)	CONDENSATE TANKS	ACS02-381	ACS02-381-0000	ACS02-C1448-856-J-DJA-0001	SAFE AREA	TECHNOR ITALSMEA	SB-282816	I/17/224488	Ex ia	II C	T6	II 2 G	IP 66
236	ACS02-381-LI-0003-B	J	Indikator lokal (Local Indicator)	CONDENSATE TANKS	ACS02-381	ACS02-381-0000	ACS02-C1448-856-J-DJA-0001	SAFE AREA	SIEMENS	SITRANS TF	N1JN229839	Ex d	II C	T5 / T6	II 2 G	IP 67
237	ACS02-381-LIT-0003	J	Transmetues i nivelit (Radar Transmetues Nivelit (Level Transmitter))	CONDENSATE TANKS	ACS02-381	ACS02-381-0000	ACS02-C1448-856-J-DJA-0001	ZONE 1	SIEMENS	SITRANS LG250	38485272	Ex ia	II C	T6 / T1	II 1/2 G	IP 66/68
238	ACS02-381-LZIT-0002	J	Transmetues i nivelit (Radar Transmetues Nivelit (Level Transmitter))	CONDENSATE TANKS	ACS02-381	ACS02-381-0000	ACS02-C1448-856-J-DJA-0001	ZONE 1	SIEMENS	SITRANS LG250	38485273	Ex ia	II C	T6 / T1	II 1/2 G	IP 66/68
239	ACS02-381-PAL-0006-A	J	Alarm Pamor (Visible Alarm)	CONDENSATE TANKS	ACS02-381	ACS02-381-0000	ACS02-C1448-856-J-DJA-0001	SAFE AREA	AES	EVC50 FLASH Series	1833	Ex d	II C	T5	II 2 G	IP 65
240	ACS02-381-PAL-0006-B	J	Alarm Pamor (Visible Alarm)	CONDENSATE TANKS	ACS02-381	ACS02-381-0000	ACS02-C1448-856-J-DJA-0001	SAFE AREA	AES	EVC50 FLASH Series	1828	Ex d	II C	T6	II 2 G	IP 65
241	ACS02-381-PIT-0006	J	Transmetues presioni(Pressure Transmitter)	CONDENSATE TANKS	ACS02-381	ACS02-381-0000	ACS02-C1448-856-J-DJA-0001	ZONE 1	SIEMENS	7MF4033-1DA00-2RB7-Z	N1JN239000050	Ex ia/fb	II C	T4 / T6	II 1/2 G	IP 66
242	ACS02-381-PZIT-0005	J	Transmetues presioni(Pressure Transmitter)	CONDENSATE TANKS	ACS02-381	ACS02-381-0000	ACS02-C1448-856-J-DJA-0001	ZONE 1	SIEMENS	7MF4033-1DA00-2RB7-Z	N1JN239000051	Ex d	II C	T4 / T6	II 1/2 G	IP 66
243	ACS02-510-P-1001_pump	M	Pompe per sistemin e zjarrit (Fire Water Disposal Pump)	SEWAGE / EFFLUENT TREATMENT	ACS02-510	ACS02-510-0202	ACS02-C1448-710-I-DIA-0002	SAFE AREA	WILO	REXA PRO V06-62	650368447	Ex db	II B	T4	II 2 G	IP 68
244	ACS02-510-P-2001_pump	M	Pompe per sistemin e zjarrit (Fire Water Disposal Pump)	SEWAGE / EFFLUENT TREATMENT	ACS02-510	ACS02-510-0202	ACS02-C1448-710-I-DIA-0002	SAFE AREA	WILO	REXA PRO V06-62	650368446	Ex db	II B	T4	II 2 G	IP 68
245	ACS02-532-PIT-8007	J	Transmetues presioni(Pressure Transmitter)	INSTRUMENT AIR	ACS02-532	ACS02-532-0901	ACS02-C1448-856-J-DJA-0001	SAFE AREA	SIEMENS	7MF4033-1EA00-2RB7 SITRANS P DS III	N1JN239000053	Ex d	II C	T4 / T6	II 1/2 G	IP 66
246	ACS02-532-PIT-8008	J	Transmetues presioni(Pressure Transmitter)	INSTRUMENT AIR	ACS02-532	ACS02-532-0901	ACS02-C1448-856-J-DJA-0001	SAFE AREA	SIEMENS	7MF4033-1EA00-2RB7 SITRANS P DS III	N1JN239000054	Ex d	II C	T4 / T6	II 1/2 G	IP 66
247	ACS02-532-PIT-8009	J	Transmetues presioni(Pressure Transmitter)	INSTRUMENT AIR	ACS02-532	ACS02-532-0901	ACS02-C1448-856-J-DJA-0001	SAFE AREA	SIEMENS	7MF4033-1EA00-2RB7 SITRANS P DS III	N1JN239000055	Ex d	II C	T4 / T6	II 1/2 G	IP 66
248	ACS02-532-PIT-9000	J	Transmetues presioni(Pressure Transmitter)	INSTRUMENT AIR	ACS02-532	ACS02-532-0701	ACS02-C1448-856-J-DJA-0001	SAFE AREA	SIEMENS	7MF4033-1EA00-2RB7 SITRANS P DS III	N1JN239000056	Ex d	II C	T4 / T6	II 1/2 G	IP 66
249	ACS02-532-TIT-8003	J	Transmetues Temperature (Temperature Transmitter)	INSTRUMENT AIR	ACS02-532	ACS02-532-0901	ACS02-C1448-856-J-DJA-0001	SAFE AREA	SIEMENS	SITRANS TH 300	N1JN004472	Ex d	II C	T6	II 1/2 G	IP 66
250	ACS02-537-PIT-1001	J	Transmetues presioni(Pressure Transmitter)	VENT AND BLOW DOWN FACILITY	ACS02-537	ACS02-537-0100	ACS02-C1448-856-J-DJA-0001	SAFE AREA	SIEMENS	7MF4033-1FA00-2RB7-Z	N1JN239000066	Ex d	II C	T4 / T6	II 1/2 G	IP 66
251	ACS02-537-YV-1020	M	Valvul Solenoid (Solenoid Valve)	VENT AND BLOW DOWN FACILITY	ACS02-537	ACS02-537-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	IMI MAXSEAL	ICO 3S YZ13CE1H1DS-90	62146/3	Ex e m	II C	T4	II 2 G	IP 66/X8
252	ACS02-537-YV-1030	M	Valvul Solenoid (Solenoid Valve)	VENT AND BLOW DOWN FACILITY	ACS02-537	ACS02-537-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	IMI MAXSEAL	ICO 3S YZ13CE1H1DS-90	62146/3	Ex e m	II C	T4	II 2 G	IP 66/X8
253	ACS02-537-YV-1080	M	Valvul Solenoid (Solenoid Valve)	VENT AND BLOW DOWN FACILITY	ACS02-537	ACS02-537-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	IMI MAXSEAL	ICO 3S YZ13CE1H1DS-90	62146/3	Ex e m	II C	T4	II 2 G	IP 66/X8
254	ACS02-537-YZV-1001	M	Valvul Solenoid (Solenoid Valve)	VENT AND BLOW DOWN FACILITY	ACS02-537	ACS02-537-0100	ACS02-C1448-856-J-DJA-0001	SAFE AREA	IMI MAXSEAL	ICO 3S YZ13CE1H1DS-90	62594/1	Ex e m	II C	T4	II 2 G	IP 66/X8

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
255	ACS02-537-YZV-1020	M	Valvul Solenoid (Solenoid Valve)	VENT AND BLOW DOWN FACILITY	ACS02-537	ACS02-537-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	IMI MAXSEAL	ICO 3S YZ13CE1H1DS-90	62146/3	Ex e m	II C	T4	II 2 G	IP 66/X8
256	ACS02-537-YZV-1030	M	Valvul Solenoid (Solenoid Valve)	VENT AND BLOW DOWN FACILITY	ACS02-537	ACS02-537-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	IMI MAXSEAL	ICO 3S YZ13CE1H1DS-90	62146/3	Ex e m	II C	T4	II 2 G	IP 66/X8
257	ACS02-537-YZV-1080	M	Valvul Solenoid (Solenoid Valve)	VENT AND BLOW DOWN FACILITY	ACS02-537	ACS02-537-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	IMI MAXSEAL	ICO 3S YZ13CE1H1DS-90	62146/3	Ex e m	II C	T4	II 2 G	IP 66/X8
258	ACS02-537-ZIT-1001	J	Transmetues Pozicioni (Position Transmitter)	VENT AND BLOW DOWN FACILITY	ACS02-537	ACS02-537-0100	ACS02-C1448-856-J-DJA-0001	SAFE AREA	YTC	YT-3400	Q0815567	Ex db	II C	T5 / T6	II 2 G	IP 66
259	ACS02-537-ZSC-1020	J	Celes Fundor i mbyllur (Limit Switch Close)	VENT AND BLOW DOWN FACILITY	ACS02-537	ACS02-537-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	EISENBAU	GIAMOLIS2PN2P5S2	N/A	Ex ia	II C	T6 / T1	II 2 G	IP 66/67
260	ACS02-537-ZSC-1030	J	Celes Fundor i mbyllur (Limit Switch Close)	VENT AND BLOW DOWN FACILITY	ACS02-537	ACS02-537-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	EISENBAU	GIAMOLIS2PN2P5S2	N/A	Ex ia	II C	T6 / T1	II 2 G	IP 66/67
261	ACS02-537-ZSC-1080	J	Celes Fundor i mbyllur (Limit Switch Close)	VENT AND BLOW DOWN FACILITY	ACS02-537	ACS02-537-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	EISENBAU	GIAMOLIS2PN2P5S2	N/A	Ex ia	II C	T6 / T1	II 1/2 G	IP 66/67
262	ACS02-539-EHD-0003	J	Leak Detection Control Cabinet	DIESEL FUEL SYSTEM	ACS02-539	ACS02-539-0100	ACS02-C1448-856-J-DJA-0001	SAFE AREA	ASSYTECH	P / N / L /02/02	2418007/2018	N/A	N/A	N/A	II 2 G	IP 44
263	ACS02-539-EHZ-0001	E	Sistem tokzimi (Grounding System)	DIESEL FUEL SYSTEM	ACS02-539	ACS02-539-0100	ACS02-C1448-856-J-DJA-0001	SAFE AREA	CORTEM	GRD-4200/24	18/333193	Ex d	II B + H2	T6	II 2 G	IP 66
264	ACS02-539-FSL-0010	J	Flow Switch Low	DIESEL FUEL SYSTEM	ACS02-539	ACS02-539-0100	ACS02-C1448-539-P-DPE-0001	SAFE AREA	KOBOLD	POX-2	N/A	Ex ia	II C	T4 / T3	II 1 G	IP 65
265	ACS02-539-JB-0001	J	Instrument Kuti Shperndarese (Junction Box)	DIESEL FUEL SYSTEM	ACS02-539	ACS02-539-0100	ACS02-C1448-856-J-DJA-0001	SAFE AREA	STAHL	8146/1051	1815990540440000	Ex eb	II C	T4	II 2 G	IP 66
266	ACS02-539-JB-0002	J	Instrument Kuti Shperndarese (Junction Box)	DIESEL FUEL SYSTEM	ACS02-539	ACS02-539-0100	ACS02-C1448-856-J-DJA-0001	SAFE AREA	STAHL	8146/1051	1815990540440000	Ex eb	II C	T4	II 2 G	IP 66
267	ACS02-539-JB-0003	J	Instrument Kuti Shperndarese (Junction Box)	DIESEL FUEL SYSTEM	ACS02-539	ACS02-539-0100	ACS02-C1448-856-J-DJA-0001	SAFE AREA	STAHL	8146/1061	1815990540440000	Ex eb	II C	T4	II 2 G	IP 66
268	ACS02-539-JB-0004	J	Instrument Kuti Shperndarese (Junction Box)	DIESEL FUEL SYSTEM	ACS02-539	ACS02-539-0100	ACS02-C1448-856-J-DJA-0001	SAFE AREA	STAHL	8146/1051	1815990540440000	Ex eb	II C	T4	II 2 G	IP 66
269	ACS02-539-JB-0005	J	Instrument Kuti Shperndarese (Junction Box)	DIESEL FUEL SYSTEM	ACS02-539	ACS02-539-0100	ACS02-C1448-856-J-DJA-0001	SAFE AREA	STAHL	8146/1051	1815990540440000	Ex eb	II C	T4	II 2 G	IP 66
270	ACS02-539-LAH-0001-A	J	Alarm Pamor (Visible Alarm)	DIESEL FUEL SYSTEM	ACS02-539	ACS02-539-0100	ACS02-C1448-856-J-DJA-0001	SAFE AREA	E2S	BECS110-05D-P	18 / 1CS22011114	Ex d	II B	T5	II 2 G	IP 66
271	ACS02-539-LI-0001	J	Indikator Sistemi (System Indication)	DIESEL FUEL SYSTEM	ACS02-539	ACS02-539-0100	ACS02-C1448-856-J-DJA-0001	SAFE AREA	FAFNIR	VISY-TD DISPLAY	5114013	Ex d	II C	T4	II 2 G	IP 66
272	ACS02-539-LIT-0001	J	Transmetues i nivelit (Radar Transmetues Nivelit (Level Transmitter))	DIESEL FUEL SYSTEM	ACS02-539	ACS02-539-0100	ACS02-C1448-539-P-DPE-0001	SAFE AREA	FAFNIR	VISI-STICK	N/A	Ex ia	II C	T6 / T4	II 1/2 G	IP 68
273	ACS02-539-LIT-1001	J	Transmetues i nivelit (Radar Transmetues Nivelit (Level Transmitter))	DIESEL FUEL SYSTEM	ACS02-539	ACS02-539-0100	ACS02-C1448-539-P-DPE-0001	SAFE AREA	FAFNIR	VISI-STICK	122441	Ex ia	II C	T6 / T4	II 1/2 G	IP 68
274	ACS02-539-LIT-2001	J	Transmetues i nivelit (Radar Transmetues Nivelit (Level Transmitter))	DIESEL FUEL SYSTEM	ACS02-539	ACS02-539-0100	ACS02-C1448-539-P-DPE-0001	SAFE AREA	FAFNIR	VISI-STICK	122447	Ex ia	II C	T6 / T4	II 1/2 G	IP 68
275	ACS02-539-LIT-3001	J	Transmetues i nivelit (Radar Transmetues Nivelit (Level Transmitter))	DIESEL FUEL SYSTEM	ACS02-539	ACS02-539-0100	ACS02-C1448-539-P-DPE-0001	SAFE AREA	FAFNIR	VISI-STICK	122443	Ex ia	II C	T6 / T4	II 1/2 G	IP 68
276	ACS02-539-LSHH-0008	J	Nivel (Level Switch High High)	DIESEL FUEL SYSTEM	ACS02-539	ACS02-539-0100	ACS02-C1448-539-P-DPE-0001	SAFE AREA	COPTRON	CPTL07	N/A	Ex ma	II C	T6	II 1 G	IP 68
277	ACS02-539-PIT-0006	J	Transmetues presioni(Pressure Transmitter)	DIESEL FUEL SYSTEM	ACS02-539	ACS02-539-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	SIEMENS	7MF4033-1DA00-2RB7-Z	N1JN239000052	Ex d	II C	T4 / T6	II 1 / 2 G	IP 66
278	ACS02-539-YV-0005	M	Valvul Solenoid I linjes hyrese (Solenoid Valve)	DIESEL FUEL SYSTEM	ACS02-539	ACS02-539-0100	ACS02-C1448-539-P-DPE-0001	SAFE AREA	COAX	K20 EX	18-074449	Ex me	II	T4	II 2 G	IP 65
279	ACS02-539-YV-0006	M	Valvul Solenoid I linjes hyrese (Solenoid Valve)	DIESEL FUEL SYSTEM	ACS02-539	ACS02-539-0100	ACS02-C1448-539-P-DPE-0001	SAFE AREA	IMI BUSCHJOST	Not available	8675703.6240	Ex e m	II C	T3	II 2 G	IP 66
280	ACS02-539-YV-1001	M	Valvul Solenoid I linjes hyrese (Solenoid Valve)	DIESEL FUEL SYSTEM	ACS02-539	ACS02-539-0100	ACS02-C1448-539-P-DPE-0001	SAFE AREA	ODE S.r.L	21IH5KIV200	2518010	Ex d	II C	T6 / T5	II 2 G	IP 67
281	ACS02-539-YV-2001	M	Valvul Solenoid I linjes hyrese (Solenoid Valve)	DIESEL FUEL SYSTEM	ACS02-539	ACS02-539-0100	ACS02-C1448-539-P-DPE-0001	SAFE AREA	ODE S.r.L	21IH5KIV200	2518011	Ex d	II C	T6 / T5	II 2 G	IP 67
282	ACS02-539-YV-3001	M	Valvul Solenoid I linjes hyrese (Solenoid Valve)	DIESEL FUEL SYSTEM	ACS02-539	ACS02-539-0100	ACS02-C1448-539-P-DPE-0001	SAFE AREA	ODE S.r.L	21IH5KIV200	2518009	Ex d	II C	T6 / T5	II 2 G	IP 67
283	ACS02 - 539 - LAH - 0001 - B	J	Visible Alarm	DIESEL FUEL SYSTEM	ACS02-539	ACS02-539-0100	ACS02-C1448-539-P-DPE-0001	SAFE AREA	E2S	I-012/G16T-1,5-E-S1-83	18/ICS22011114	Ex d	II B	T5	II 2 G	IP 66
284	ACS02-550-EHS-1008	E	Kuti Shperndarese e ngrohesit (Junction Box)	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL POWER DISTRIBUTION)	ACS02-820	ACS02-820-1600	ACS02-C1448.3500-820-E-DFB-0001	SAFE AREA	STAHL	8146/1051	1815990540440011	Ex eb	II C	T4	II 2 G	IP 66
285	ACS02-550-EHS-1010	E	Kuti Shperndarese e ngrohesit (Junction Box)	Sistemi i shperndarjes se energjise elektrike ne stacion (STATION ELECTRICAL POWER DISTRIBUTION)	ACS02-820	ACS02-820-1600	ACS02-C1448.3500-820-E-DFB-0001	SAFE AREA	STAHL	8146/1051	1815990540440013	Ex eb	II C	T4	II 2 G	IP 66
286	ACS02-550-TT-1021	J	Transmetues Temperature (Temperature Transmitter)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS02-551	ACS02-551-0703	ACS02-C1448-856-J-DJA-0001	SAFE AREA	SCHISCHEK	ExCos-D	056.3040 18470061	Ex e ma	II C	T6	II 2 (1) G	IP 66
287	ACS02-550-TT-1026	J	Transmetues Temperature (Temperature Transmitter)	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS02-551	ACS02-551-0703	ACS02-C1448-856-J-DJA-0001	SAFE AREA	SCHISCHEK	ExCos-D	056.3040 18470053	Ex e ma	II C	T6	II 2 (1) G	IP 66
288	ACS02-710-JB-0001	E	Kuti Shperndarese (Junction Box)	FIRE WATER SYSTEMS	ACS02-710	ACS02-710-1200	ACS02-C1448-856-J-DJA-0001	SAFE AREA	TECHNOR ITALSMEA	SB-282816	I/17/224525	Ex e	II C	T6	II 2 G	IP 66
289	ACS02-710-JB-0100	E	Kuti Shperndarese (Junction Box)	FIRE WATER SYSTEMS	ACS02-710	ACS02-710-1200	ACS02-C1448-856-J-DJA-0001	SAFE AREA	TECHNOR ITALSMEA	SB-282816	I/17/224473	Ex e	II C	T6	II 2 G	IP 66
290	ACS02-710-JB-0200	E	Kuti Shperndarese (Junction Box)	FIRE WATER SYSTEMS	ACS02-710	ACS02-710-1200	ACS02-C1448-856-J-DJA-0001	SAFE AREA	TECHNOR ITALSMEA	SB-282816	I/17/224486	Ex e	II C	T6	II 2 G	IP 66
291	ACS02-710-JB-1001	E	Kuti Shperndarese (Junction Box)	FIRE WATER SYSTEMS	ACS02-710	ACS02-710-1200	ACS02-C1448-856-J-DJA-0001	SAFE AREA	TECHNOR ITALSMEA	SB-282816	I/17/224490	Ex ia	II C	T6	II 2 G	IP 66
292	ACS02-710-LIT-0002	J	Transmetues i nivelit (Radar Transmetues Nivelit (Level Transmitter))	FIRE WATER SYSTEMS	ACS02-710	ACS02-710-1200	ACS02-C1448-856-J-DJA-0001	SAFE AREA	SIEMENS	SITRANS LR250	PBD/JN270069	Ex na	II C	T4	II 3 G	IP 67/68
293	ACS02-710-LSHH-0003	J	Nivel (Level Switch High High)	FIRE WATER SYSTEMS	ACS02-710	ACS02-710-1200	ACS02-C1448-856-J-DJA-0001	SAFE AREA	ROSEMOUNT	2120 VIBRATING FORK LEVEL SWITCH	1235712	Ex d	II C	T6 / T2	II 1/2 G	IP 66/67
294	ACS02-710-TIT-0011	J	Transmetues Temperature (Temperature Transmitter)	FIRE WATER SYSTEMS	ACS02-710	ACS02-710-1200	ACS02-C1448-856-J-DJA-0001	SAFE AREA	SIEMENS	SITRANS TH300	N1JN004473	Ex d	II C	T6	II 1/2 G	IP 66
295	ACS02-740-FB-0001	J	Fener per sinjalizues zjarri (Fire Alarm Beacon)	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-1101	ACS02-C1448-856-J-DJA-0001	SAFE AREA	AES	EVC 50/N	1838	Ex d	II C	T6	II 2 G	IP 65
296	ACS02-740-FB-0002	J	Fener per sinjalizues zjarri (Fire Alarm Beacon)	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-1101	ACS02-C1448-856-J-DJA-0001	SAFE AREA	AES	EVC 50/N	1852	Ex d	II C	T6	II 2 G	IP 65
297	ACS02-740-FB-0003	J	Fener per sinjalizues zjarri (Fire Alarm Beacon)	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-1118	ACS02-C1448-856-J-DJA-0001	SAFE AREA	AES	EVC 50/N	1835	Ex d	II C	T6	II 2 G	IP 65
298	ACS02-740-FB-0004	J	Fener per sinjalizues zjarri (Fire Alarm Beacon)	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-1101	ACS02-C1448-856-J-DJA-0001	SAFE AREA	AES	EVC 50/N	1846	Ex d	II C	T6	II 2 G	IP 65
299	ACS02-740-FB-0005	J	Fener per sinjalizues zjarri (Fire Alarm Beacon)	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-1101	ACS02-C1448-856-J-DJA-0001	SAFE AREA	AES	EVC 50/N	1837	Ex d	II C	T6	II 2 G	IP 65
300	ACS02-740-FD-0001	J	Detektor Zjarri (Flame Detector)	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-1101	ACS02-C1448-856-J-DJA-0001	SAFE AREA	HONEYWELL	FS24X-9	203656	Ex db	II C	T6 / T4	II 2 G	IP 66
301	ACS02-740-FD-0002	J	Detektor Zjarri (Flame Detector)	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-1101	ACS02-C1448-856-J-DJA-0001	SAFE AREA	HONEYWELL	FS24X-9	203977	Ex db	II C	T6 / T4	II 2 G	IP 66
302	ACS02-740-FD-0003	J	Detektor Zjarri (Flame Detector)	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-1101	ACS02-C1448-856-J-DJA-0001	SAFE AREA	HONEYWELL	FS24X-9	204072	Ex db	II C	T6 / T4	II 2 G	IP 66
303	ACS02-740-FD-0004	J	Detektor Zjarri (Flame Detector)	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-1101	ACS02-C1448-856-J-DJA-0001	SAFE AREA	HONEYWELL	FS24X-9	204315	Ex db	II C	T6 / T4	II 2 G	IP 66

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
410	ACS02-740-GD-0121	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-1118	ACS02-C1448-856-J-DJA-0001	SAFE AREA	HONEYWELL	SEARCHLINE EXCEL	03/18/127	Ex d op is	II C	T6 / T5	II 2 G	IP 66
411	ACS02-740-GD-0122	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-1118	ACS02-C1448-856-J-DJA-0001	SAFE AREA	HONEYWELL	SEARCHLINE EXCEL	09/17/025	Ex db	II C	T6	II 2 G	IP 66
412	ACS02-740-GD-0123	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-1101	ACS02-C1448-856-J-DJA-0001	SAFE AREA	HONEYWELL	SEARCHLINE EXCEL	11/17/366	Ex d op is	II C	T6	II 2 G	IP 66
413	ACS02-740-GD-0124	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-1101	ACS02-C1448-856-J-DJA-0001	SAFE AREA	HONEYWELL	SEARCHLINE EXCEL	11/17/361	Ex db	II C	T6	II 2 G	IP 66
414	ACS02-740-GD-0125	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-1101	ACS02-C1448-856-J-DJA-0001	ZONE 2	CROWCON	IR MAX + HART	W274210/01-031	Ex d	II C	T4	II 2 G	IP 66
415	ACS02-740-GD-0126	J	Detektor Gazi (Flammable Gas Detector)	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-1101	ACS02-C1448-856-J-DJA-0001	ZONE 2	CROWCON	IR MAX + HART	W274210/01-025	Ex d	II C	T4	II 2 G	IP 66
416	ACS02-740-JB-0701	J	Kuti Shperndarese (Junction Box) F&G System	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-1101	ACS02-C1448-856-J-DJA-0001	ZONE 2	TECHNOR ITALSMEA	SB-384520	I/17/226014	Ex e	II C	T6	II 2 G	IP 66
417	ACS02-740-JB-0702	J	Kuti Shperndarese (Junction Box) F&G System	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-1101	ACS02-C1448-856-J-DJA-0001	SAFE AREA	TECHNOR ITALSMEA	SB-384520	I/17/226011	Ex e	II C	T6	II 2 G	IP 66
418	ACS02-740-JB-0704	J	Kuti Shperndarese (Junction Box) F&G System	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-1101	ACS02-C1448-856-J-DJA-0001	ZONE 2	TECHNOR ITALSMEA	SB-384520	I/17/226015	Ex e	II C	T6	II 2 G	IP 66
419	ACS02-740-JB-0705	J	Kuti Shperndarese (Junction Box) F&G System	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-1101	ACS02-C1448-856-J-DJA-0001	ZONE 2	TECHNOR ITALSMEA	SB-282816	I/17/224476	Ex e	II C	T6	II 2 G	IP 66
420	ACS02-740-JB-0707	J	Kuti Shperndarese (Junction Box) F&G System	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-1101	ACS02-C1448-856-J-DJA-0001	ZONE 2	TECHNOR ITALSMEA	SB-384520	I/17/226018	Ex e	II C	T6	II 2 G	IP 66
421	ACS02-740-JB-0709	J	Kuti Shperndarese (Junction Box) F&G System	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-1101	ACS02-C1448-856-J-DJA-0001	ZONE 2	TECHNOR ITALSMEA	SB-282816	I/17/224475	Ex e	II C	T6	II 2 G	IP 66
422	ACS02-740-JB-0710	J	Kuti Shperndarese (Junction Box) F&G System	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-1101	ACS02-C1448-856-J-DJA-0001	ZONE 2	TECHNOR ITALSMEA	SB-282816	I/17/224471	Ex e	II C	T6	II 2 G	IP 66
423	ACS02-740-JB-0711	J	Kuti Shperndarese (Junction Box) F&G System	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-1101	ACS02-C1448-856-J-DJA-0001	ZONE 2	TECHNOR ITALSMEA	SB-282816	I/17/224472	Ex e	II C	T6	II 2 G	IP 66
424	ACS02-740-JB-0712	J	Kuti Shperndarese (Junction Box) F&G System	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-1101	ACS02-C1448-856-J-DJA-0001	SAFE AREA	TECHNOR ITALSMEA	SB-282816	I/17/224474	Ex e	II C	T6	II 2 G	IP 66
425	ACS02-740-JB-0713	J	Kuti Shperndarese (Junction Box) F&G System	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-1101	ACS02-C1448-856-J-DJA-0001	ZONE 2	TECHNOR ITALSMEA	SB-384520	I/17/226019	Ex e	II C	T6	II 2 G	IP 66
426	ACS02-740-JB-0714	J	Kuti Shperndarese (Junction Box) F&G System	Kablazhi (CABLING)	ACS02-858	ACS02-858-0100	ACS02-C1448-856-J-DJA-0001	SAFE AREA	TECHNOR ITALSMEA	SB-384520	I/17/226012	Ex e	II C	T6	II 2 G	IP 66
427	ACS02-740-JB-0715	J	Kuti Shperndarese (Junction Box) F&G System	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-1118	ACS02-C1448-856-J-DJA-0001	ZONE 2	TECHNOR ITALSMEA	SB-384520	I/17/226016	Ex e	II C	T6	II 2 G	IP 66
428	ACS02-740-JB-0716	J	Kuti Shperndarese (Junction Box) F&G System	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-1118	ACS02-C1448-856-J-DJA-0001	ZONE 2	TECHNOR ITALSMEA	SB-282816	I/17/224477	Ex e	II C	T6	II 2 G	IP 66
429	ACS02-740-JB-0717	J	Kuti Shperndarese (Junction Box) F&G System	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-1101	ACS02-C1448-856-J-DJA-0001	ZONE 2	TECHNOR ITALSMEA	SB-384520	I/17/226017	Ex e	II C	T6	II 2 G	IP 66
430	ACS02-740-JB-0718	J	Kuti Shperndarese (Junction Box) F&G System	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-1101	ACS02-C1448-856-J-DJA-0001	ZONE 2	TECHNOR ITALSMEA	SB-384520	I/17/226013	Ex e	II C	T6	II 2 G	IP 66
431	ACS02-740-MAC-0001	J	Buton alarmi (Manual Call Point)	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-1101	ACS02-C1448-856-J-DJA-0001	SAFE AREA	MEDC	BG I	212196474 10 23	Ex ia	II C	T4	II 1 G	IP 65
432	ACS02-740-MAC-0002	J	Buton alarmi (Manual Call Point)	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-1101	ACS02-C1448-856-J-DJA-0001	SAFE AREA	MEDC	BG I	212196474 20 09	Ex ia	II C	T4	II 1 G	IP 65
433	ACS02-740-MAC-0003	J	Buton alarmi (Manual Call Point)	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-1118	ACS02-C1448-856-J-DJA-0001	SAFE AREA	MEDC	BG I	212196474 10 12	Ex ia	II C	T4	II 1 G	IP 65
434	ACS02-740-MAC-0004	J	Buton alarmi (Manual Call Point)	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-1101	ACS02-C1448-856-J-DJA-0001	SAFE AREA	MEDC	BG I	212196474 20 07	Ex ia	II C	T4	II 1 G	IP 65
435	ACS02-740-MAC-0005	J	Buton alarmi (Manual Call Point)	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-1118	ACS02-C1448-856-J-DJA-0001	SAFE AREA	MEDC	BG I	212196474 10 18	Ex ia	II C	T4	II 1 G	IP 65
436	ACS02-740-MAC-0006	J	Buton alarmi (Manual Call Point)	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-1101	ACS02-C1448-856-J-DJA-0001	SAFE AREA	MEDC	BG I	212196474 10 17	Ex ia	II C	T4	II 1 G	IP 65
437	ACS02-740-MAC-0007	J	Buton alarmi (Manual Call Point)	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-1101	ACS02-C1448-856-J-DJA-0001	SAFE AREA	MEDC	BG I	212196474 10 10	Ex ia	II C	T4	II 1 G	IP 65
438	ACS02-740-MAC-0008	J	Buton alarmi (Manual Call Point)	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-1101	ACS02-C1448-856-J-DJA-0001	SAFE AREA	MEDC	BG I	212196474 30 01	Ex ia	II C	T4	II 1 G	IP 65
439	ACS02-740-MAC-0009	J	Buton alarmi (Manual Call Point)	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-1101	ACS02-C1448-856-J-DJA-0001	SAFE AREA	MEDC	BG I	212196474 20 25	Ex ia	II C	T4	II 1 G	IP 65
440	ACS02-740-MAC-0010	J	Buton alarmi (Manual Call Point)	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-1101	ACS02-C1448-856-J-DJA-0001	SAFE AREA	MEDC	BG I	212196474 10 14	Ex ia	II C	T4	II 1 G	IP 65
441	ACS02-770-LD-0021-A	T	Autoparlant (AteX Loudspeaker)	WARNING SYSTEMS	ACS02-770	ACS02-770-0100	ACS02-C1448.5000-770-T-DTA-0003	SAFE AREA	BOSCH	LH3-UC25XS	405221385707100034	Ex de mb	II B + H2	T4	II 2 G	IP 66/67
442	ACS02-770-LD-0022-A	T	Autoparlant (AteX Loudspeaker)	WARNING SYSTEMS	ACS02-770	ACS02-770-0100	ACS02-C1448.5000-770-T-DTA-0003	SAFE AREA	BOSCH	LH3-UC25XS	405221385707100051	Ex de mb	II B + H2	T4	II 2 G	IP 66/67
443	ACS02-770-LD-0023-A	T	Autoparlant (AteX Loudspeaker)	WARNING SYSTEMS	ACS02-770	ACS02-770-0100	ACS02-C1448.5000-770-T-DTA-0003	SAFE AREA	BOSCH	LH3-UC25XS	405221385707100035	Ex de mb	II B + H2	T4	II 2 G	IP 66/67
444	ACS02-770-LD-0024-A	T	Autoparlant (AteX Loudspeaker)	WARNING SYSTEMS	ACS02-770	ACS02-770-0100	ACS02-C1448.5000-770-T-DTA-0003	SAFE AREA	BOSCH	LH3-UC25XS	405221385707100041	Ex de mb	II B + H2	T4	II 2 G	IP 66/67
445	ACS02-770-LD-0025-A	T	Autoparlant (AteX Loudspeaker)	WARNING SYSTEMS	ACS02-770	ACS02-770-0100	ACS02-C1448.5000-770-T-DTA-0003	SAFE AREA	BOSCH	LH3-UC25XS	405221385707100072	Ex de mb	II B + H2	T4	II 2 G	IP 66/67
446	ACS02-770-LD-0026-A	T	Autoparlant (AteX Loudspeaker)	WARNING SYSTEMS	ACS02-770	ACS02-770-0100	ACS02-C1448.5000-770-T-DTA-0003	SAFE AREA	BOSCH	LH3-UC25XS	405221385707100077	Ex de mb	II B + H2	T4	II 2 G	IP 66/67
447	ACS02-770-LD-0027-A	T	Autoparlant (AteX Loudspeaker)	WARNING SYSTEMS	ACS02-770	ACS02-770-0100	ACS02-C1448.5000-770-T-DTA-0003	SAFE AREA	BOSCH	LH3-UC25XS	405221385707100167	Ex de m	II B + H2	T4	II 2 G	IP 66/67
448	ACS02-770-LD-0028-A	T	Autoparlant (AteX Loudspeaker)	WARNING SYSTEMS	ACS02-770	ACS02-770-0100	ACS02-C1448.5000-770-T-DTA-0003	SAFE AREA	BOSCH	LH3-UC25XS	405221385707100166	Ex de mb	II B + H2	T4	II 2 G	IP 66/67
449	ACS02-770-LD-0029-A	T	Autoparlant (AteX Loudspeaker)	WARNING SYSTEMS	ACS02-770	ACS02-770-0100	ACS02-C1448.5000-770-T-DTA-0003	SAFE AREA	BOSCH	LH3-UC25XS	405221385707100065	Ex de mb	II B + H2	T4	II 2 G	IP 66/67
450	ACS02-770-LD-0030-A	T	Autoparlant (AteX Loudspeaker)	WARNING SYSTEMS	ACS02-770	ACS02-770-0100	ACS02-C1448.5000-770-T-DTA-0003	SAFE AREA	BOSCH	LH3-UC25XS	405221385930100262	Ex de mb	II B + H2	T4	II 2 G	IP 66/67
451	ACS02-770-LD-0031-A	T	Autoparlant (AteX Loudspeaker)	WARNING SYSTEMS	ACS02-770	ACS02-770-0100	ACS02-C1448.5000-770-T-DTA-0003	SAFE AREA	BOSCH	LH3-UC25XS	405221385930100266	Ex de mb	II B + H2	T4	II 2 G	IP 66/67
452	ACS02-820-EHS-P-1001	E	Kuti shperndarese Power Distribution Working Area - West JB1	Sistemi shperndarese te energjise elektrike ne stacion	ACS02-820	ACS02-820-0700	ACS02-C1448-820-E-DEA-0002	ZONE 2	STAHL	8146/5000	1815754510440001	Ex de	II C	T4	II 2 G	IP 66
453	ACS02-820-EHS-P-1001	E	Njesi kontrolli (Control Unit)	Sistemi shperndarese te energjise elektrike ne stacion	ACS02-820	ACS02-820-0700	ACS02-C1448-820-E-DEA-0002	ZONE 2	STAHL	8265/56	1815754510440001	Ex de	II C	T4	II 2 G	IP 66
454	ACS02-820-EHS-P-1001	E	Prize Flange Socket	Sistemi shperndarese te energjise elektrike ne stacion	ACS02-820	ACS02-820-0700	ACS02-C1448-820-E-DEA-0002	ZONE 2	STAHL	8570/15-506	10001812924044	Ex de	II C	T6	II 2 G	IP 66
455	ACS02-820-EHS-P-1001	E	Prize Flange Socket	Sistemi shperndarese te energjise elektrike ne stacion	ACS02-820	ACS02-820-0700	ACS02-C1448-820-E-DEA-0002	ZONE 2	STAHL	8571/15-506	10001822147044	Ex de	II C	T6 / T5	II 2 G	IP 66
456	ACS02-820-EHS-P-1001	E	Prize Flange Socket	Sistemi shperndarese te energjise elektrike ne stacion	ACS02-820	ACS02-820-0700	ACS02-C1448-820-E-DEA-0002	ZONE 2	STAHL	8570/15-306	10001820644044	Ex de	II C	T6	II 2 G	IP 66
457	ACS02-820-EHS-P-1002	E	Kuti shperndarese Power Distribution Working Area - West JB2	Sistemi shperndarese te energjise elektrike ne stacion	ACS02-820	ACS02-820-0700	ACS02-C1448-820-E-DEA-0002	ZONE 2	STAHL	8146/5000	1815754510440002	Ex de	II C	T4	II 2 G	IP 66
458	ACS02-820-EHS-P-1002	E	Njesi kontrolli Control Unit	Sistemi shperndarese te energjise elektrike ne stacion	ACS02-820	ACS02-820-0700	ACS02-C1448-820-E-DEA-0002	ZONE 2	STAHL	8265/56	1815754510440002	Ex de	II C	T4	II 2 G	IP 66
459	ACS02-820-EHS-P-1002	E	Prize Flange Socket	Sistemi shperndarese te energjise elektrike ne stacion	ACS02-820	ACS02-820-0700	ACS02-C1448-820-E-DEA-0002	ZONE 2	STAHL	8570/15-506	10001812928044	Ex de	II C	T6	II 2 G	IP 66
460	ACS02-820-EHS-P-1002	E	Prize Flange Socket	Sistemi shperndarese te energjise elektrike ne stacion	ACS02-820	ACS02-820-0700	ACS02-C1448-820-E-DEA-0002	ZONE 2	STAHL	8571/15-506	10001822136044	Ex de	II C	T6 / T5	II 2 G	IP 66
461	ACS02-820-EHS-P-1002	E	Prize Flange Socket	Sistemi shperndarese te energjise elektrike ne stacion	ACS02-820	ACS02-820-0700	ACS02-C1448-820-E-DEA-0002	ZONE 2	STAHL	8570/15-306	10001820624044	Ex de	II C	T6	II 2 G	IP 66
462	ACS02-820-EHS-P-2001	E	Kuti shperndarese Power Distribution Working Area - East JB1	Sistemi shperndarese te energjise elektrike ne stacion	ACS02-820	ACS02-820-0700	ACS02-C1448-820-E-DEA-0002	ZONE 2	STAHL	8146/5000	1815754510440003	Ex de	II C	T4	II 2 G	IP 66

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
463	ACS02-820-EHS-P-2001	E	Njesi kontrolli Control Unit	Sistemi shperndarjes se energjise elektrike ne stacion	ACS02-820	ACS02-820-0700	ACS02-C1448-820-E-DEA-0002	ZONE 2	STAHL	8265/56	1815754510440003	Ex de	II C	T4	II 2 G	IP 66
464	ACS02-820-EHS-P-2001	E	Prize Flange Socket	Sistemi shperndarjes se energjise elektrike ne stacion	ACS02-820	ACS02-820-0700	ACS02-C1448-820-E-DEA-0002	ZONE 2	STAHL	8570/15-506	10001812932044	Ex de	II C	T6	II 2 G	IP 66
465	ACS02-820-EHS-P-2001	E	Prize Flange Socket	Sistemi shperndarjes se energjise elektrike ne stacion	ACS02-820	ACS02-820-0700	ACS02-C1448-820-E-DEA-0002	ZONE 2	STAHL	8571/15-506	10001822140044	Ex de	II C	T6 / T5	II 2 G	IP 66
466	ACS02-820-EHS-P-2001	E	Prize Flange Socket	Sistemi shperndarjes se energjise elektrike ne stacion	ACS02-820	ACS02-820-0700	ACS02-C1448-820-E-DEA-0002	ZONE 2	STAHL	8570/15-306	10001820645044	Ex de	II C	T6	II 2 G	IP 66
467	ACS02-820-EHS-P-2002	E	Kuti shperndarese Power Distribution Working Area - East JB2	Sistemi shperndarjes se energjise elektrike ne stacion	ACS02-820	ACS02-820-0700	ACS02-C1448-820-E-DEA-0002	ZONE 2	STAHL	8146/5000	1815754510440004	Ex de	II C	T4	II 2 G	IP 66
468	ACS02-820-EHS-P-2002	E	Njesi kontrolli Control Unit	Sistemi shperndarjes se energjise elektrike ne stacion	ACS02-820	ACS02-820-0700	ACS02-C1448-820-E-DEA-0002	ZONE 2	STAHL	8265/56	1815754510440004	Ex de	II C	T4	II 2 G	IP 66
469	ACS02-820-EHS-P-2002	E	Prize Flange Socket	Sistemi shperndarjes se energjise elektrike ne stacion	ACS02-820	ACS02-820-0700	ACS02-C1448-820-E-DEA-0002	ZONE 2	STAHL	8570/15-506	10001812929044	Ex de	II C	T6	II 2 G	IP 66
470	ACS02-820-EHS-P-2002	E	Spine Switch Socket	Sistemi shperndarjes se energjise elektrike ne stacion	ACS02-820	ACS02-820-0700	ACS02-C1448-820-E-DEA-0002	ZONE 2	STAHL	8571/15-506	10001822150044	Ex de	II C	T6 / T5	II 2 G	IP 66
471	ACS02-820-EHS-P-2002	E	Prize Flange Socket	Sistemi shperndarjes se energjise elektrike ne stacion	ACS02-820	ACS02-820-0700	ACS02-C1448-820-E-DEA-0002	ZONE 2	STAHL	8570/15-306	10001820624044	Ex de	II C	T6	II 2 G	IP 66
472	ACS02-920-EHF-0059	E	Ndicues Surface Mounted, Fluorescent Lighting Fixture	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-0300	ACS02-C1448-920-E-DEB-0001	SAFE AREA	STAHL	6401 / 00, - 15 - 232	10001829501057	Ex nA	II C	T4	II 3 G	IP 66 / 67
473	ACS02-920-EHF-0060	E	Ndicues Surface Mounted, Fluorescent Lighting Fixture	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-0300	ACS02-C1448-920-E-DEB-0001	SAFE AREA	STAHL	6401 / 00, - 15 - 232	10001829502057	Ex nA	II C	T4	II 3 G	IP 66 / 67
474	ACS02-920-EHF-0061	E	Ndicues Surface Mounted, Fluorescent Lighting Fixture	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-0300	ACS02-C1448-920-E-DEB-0001	SAFE AREA	STAHL	6401 / 00, - 15 - 232	10001829497057	Ex nA	II C	T4	II 3 G	IP 66 / 67
475	ACS02-920-EHF-0062	E	Ndicues Surface Mounted, Fluorescent Lighting Fixture	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-0300	ACS02-C1448-920-E-DEB-0001	SAFE AREA	STAHL	6401 / 00, - 15 - 232	10001829503057	Ex nA	II C	T4	II 3 G	IP 66 / 67
476	ACS02-920-EHF-0063	E	Ndicues Surface Mounted, Fluorescent Lighting Fixture	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-0300	ACS02-C1448-920-E-DEB-0001	SAFE AREA	STAHL	6401 / 00, - 15 - 232	10001829500057	Ex nA	II C	T4	II 3 G	IP 66 / 67
477	ACS02-920-EHF-0064	E	Ndicues Surface Mounted, Fluorescent Lighting Fixture	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-0300	ACS02-C1448-920-E-DEB-0001	SAFE AREA	STAHL	6401 / 00, - 15 - 232	10001829498057	Ex nA	II C	T4	II 3 G	IP 66 / 67
478	ACS02-920-EHF-0065	E	Ndicues Surface Mounted, Fluorescent Lighting Fixture	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-0300	ACS02-C1448-920-E-DEB-0001	SAFE AREA	STAHL	6401 / 00, - 15 - 232	10001829499057	Ex nA	II C	T4	II 3 G	IP 66 / 67
479	ACS02-920-EHF-0066	E	Ndicues Surface Mounted, Fluorescent Lighting Fixture	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-0300	ACS02-C1448-920-E-DEB-0001	SAFE AREA	STAHL	6401 / 00, - 15 - 232	10001829493057	Ex nA	II C	T4	II 3 G	IP 66 / 67
480	ACS02-920-EHJ-L-1.21a	E	Kuti shperndarese Lighting JB-1.21a	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-0300	ACS02-C1448-920-E-DEB-0001	SAFE AREA	STAHL	8146/1051	1815990540440001	Ex eb	II C	T4	II 2 G	IP 66
481	ACS02-920-EHJ-L-1.21a-01	E	Kuti shperndarese Lighting JB-1.21a	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-0300	ACS02-C1448-920-E-DEB-0001	SAFE AREA	STAHL	8146/1051	1815990540440003	Ex eb	II C	T4	II 2 G	IP 66
482	ACS02-920-EHJ-L-1.21b	E	Kuti shperndarese Lighting JB-1.21a	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-0300	ACS02-C1448-920-E-DEB-0001	SAFE AREA	STAHL	8146/1051	1815990540440003	Ex eb	II C	T4	II 2 G	IP 66
483	ACS02-920-EHJ-L-1.21b-01	E	Kuti shperndarese Lighting JB-1.21a	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-0300	ACS02-C1448-920-E-DEB-0001	SAFE AREA	STAHL	8146/1051	1815990540440014	Ex eb	II C	T4	II 2 G	IP 66
484	ACS02-920-EHJ-L-1.22a	E	Kuti shperndarese Lighting JB-1.21a	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-0300	ACS02-C1448-920-E-DEB-0001	SAFE AREA	STAHL	8146/1051	1815990540440009	Ex eb	II C	T4	II 2 G	IP 66
485	ACS02-920-EHJ-L-1.22a-01	E	Kuti shperndarese Lighting JB-1.21a	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-0300	ACS02-C1448-920-E-DEB-0001	SAFE AREA	STAHL	8146/1051	1815990540440002	Ex eb	II C	T4	II 2 G	IP 66
486	ACS02-920-EHJ-L-1.22b	E	Kuti shperndarese Lighting JB-1.21a	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-0300	ACS02-C1448-920-E-DEB-0001	SAFE AREA	STAHL	8146/1051	1815990540440016	Ex eb	II C	T4	II 2 G	IP 66
487	ACS02-920-EHJ-L-1.22b-01	E	Kuti shperndarese Lighting JB-1.21a	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-0300	ACS02-C1448-920-E-DEB-0001	SAFE AREA	STAHL	8146/1051	1815990540440015	Ex eb	II C	T4	II 2 G	IP 66
488	ACS02-920-EHS-0043	E	Celesa Single Phase CEE Receptacle 16A	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-0300	ACS02-C1448-920-E-DEB-0001	ZONE 2	STAHL	8146/5083	1815754470440001	Ex de	II C	T4	II 2 G	IP 66
489	ACS02-920-EHS-0044	E	Celesa Single Phase CEE Receptacle 16A	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-0300	ACS02-C1448-920-E-DEB-0001	ZONE 2	STAHL	8146/5083	1815754470440002	Ex de	II C	T4	II 2 G	IP 66
490	ACS02-920-EHW-1.21a	E	Celes One Way Single Pole Switch 10A/250V	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-0300	ACS02-C1448-920-E-DEB-0001	SAFE AREA	STAHL	8146/5051	1815739730440003	Ex de	II C	T4	II 2 G	IP 66
491	ACS02-920-EHW-1.21b	E	Celes One Way Single Pole Switch 10A/250V	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-0300	ACS02-C1448-920-E-DEB-0001	SAFE AREA	STAHL	8146/5051	1815739730440001	Ex de	II C	T4	II 2 G	IP 66
492	ACS02-920-EHW-1.22a	E	Celes One Way Single Pole Switch 10A/250V	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-0300	ACS02-C1448-920-E-DEB-0001	SAFE AREA	STAHL	8146/5051	1815739730440002	Ex de	II C	T4	II 2 G	IP 66
493	ACS02-920-EHW-1.22b	E	Celes One Way Single Pole Switch 10A/250V	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-0300	ACS02-C1448-920-E-DEB-0001	SAFE AREA	STAHL	8146/5051	1815739730440004	Ex de	II C	T4	II 2 G	IP 66
494	ACS02-920-ERF-0041	E	Ndicues sigurie Safety Light with 18W Lamp & Electronic Ballast	STATION EMERTENCY / ESSENTIAL POWER UPS	ACS02-830	ACS02-830-0901	ACS02-C1448-920-E-DEB-0001	SAFE AREA	EATON	EXIT V-CG-S	1188	Ex e	II C	T4	II 2 G	IP 66
495	ACS02-920-ERF-0044	E	Ndicues Surface Mounted Ndicues Emergence Fixture	STATION EMERTENCY / ESSENTIAL POWER UPS	ACS02-830	ACS02-830-0901	ACS02-C1448-920-E-DEB-0001	SAFE AREA	EATON	EXIT V-CG-S	1188	Ex e	II C	T4	II 2 G	IP 66
496	ACS02-920-GD-1024	J	Detektor Hidrogjeni Hydrogen Gas Detector	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-0200	ACS02-C1448-920-T-DTA-0001	SAFE AREA	HONEYWELL	XXN AMAV NNCBI	44180399	Ex db	II C	T6 / T4	II 2 G	IP 66
497	ACS02-920-GD-2015	J	Detektor Hidrogjeni Hydrogen Gas Detector	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-0200	ACS02-C1448-920-T-DTA-0001	SAFE AREA	HONEYWELL	XXN AMAV NNCBI	44180398	Ex db	II C	T6 / T4	II 2 G	IP 66
498	ACS02-920-SCD-1022	J	Multi Sensor - Optical Smoke & Detektor Nxehtesie (Heat Detectors)	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-0200	ACS02-C1448-920-T-DTA-0001	SAFE AREA	APOLLO	ORB-OH-53027-APO	114758	Ex ia	II C	T5	II 1 G	IP 23D
499	ACS02-920-SCD-1023	J	Multi Sensor - Optical Smoke & Detektor Nxehtesie (Heat Detectors)	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-0200	ACS02-C1448-920-T-DTA-0001	SAFE AREA	APOLLO	ORB-OH-53027-APO	111158	Ex ia	II C	T5	II 1 G	IP 23D
500	ACS02-950-LP-0723 (L1-723)	E	Ndicues i jashtem (Outdoor Lighting Fixtures)	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-1301	ACS02-C1448-920-E-DEB-0001	ZONE 1	STAHL	6401/.00-15-232	10001829511057	Ex nA	II C	T4	II 3 G	IP 66
501	ACS02-950-LP-0726 (L1-726)	E	Ndicues i jashtem (Outdoor Lighting Fixtures)	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-1301	ACS02-C1448-920-E-DEB-0001	SAFE AREA	STAHL	6401/.00-15-232	10001829509057	Ex nA	II C	T4	II 3 G	IP 66
502	ACS02-950-LP-0729 (L1-729)	E	Ndicues i jashtem (Outdoor Lighting Fixtures)	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-1301	ACS02-C1448-920-E-DEB-0001	ZONE 2	STAHL	6401/.00-15-232	10001829504057	Ex nA	II C	T4	II 3 G	IP 66
503	ACS02-950-LP-0724 (L2-724)	E	Ndicues i jashtem (Outdoor Lighting Fixtures)	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-1301	ACS02-C1448-920-E-DEB-0001	SAFE AREA	STAHL	6401/.00-15-232	10001829507057	Ex nA	II C	T4	II 3 G	IP 66
504	ACS02-950-LP-0727 (L2-727)	E	Ndicues i jashtem (Outdoor Lighting Fixtures)	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-1301	ACS02-C1448-920-E-DEB-0001	SAFE AREA	STAHL	6401/.00-15-232	10001829506057	Ex nA	II C	T4	II 3 G	IP 66
505	ACS02-950-LP-0730 (L2-730)	E	Ndicues i jashtem (Outdoor Lighting Fixtures)	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-1301	ACS02-C1448-920-E-DEB-0001	ZONE 2	STAHL	6401/.00-15-232	10001829508057	Ex nA	II C	T4	II 3 G	IP 66
506	ACS02-950-LP-0725 (L3-725)	E	Ndicues i jashtem (Outdoor Lighting Fixtures)	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-1301	ACS02-C1448-920-E-DEB-0001	ZONE 2	STAHL	6401/.00-15-232	10001829510057	Ex nA	II C	T4	II 3 G	IP 66
507	ACS02-950-LP-0728 (L3-728)	E	Ndicues i jashtem (Outdoor Lighting Fixtures)	Furnizimi me Energji elektrike i Stacionit	ACS02-800	ACS02-800-1301	ACS02-C1448-920-E-DEB-0001	SAFE AREA	STAHL	6401/.00-15-232	10001829505057	Ex nA	II C	T4	II 3 G	IP 66
508	ACS02-532-JB-0100	E	Kuti Shperndarese (Junction Box)	Kablazhi (CABLING)	ACS02-858	ACS02-858-0100	ACS02-C1448-920-E-DEB-0001	SAFE AREA	TECHNOR ITALSMEA	SB-353520	I/17/222221	Ex e	II C	T6	II 2 G	IP 66
509	ACS02-330-XFX01	E	Ventilator Fan 1	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448-920-E-DEB-0001	ZONE 1	RAEL	TUBE 56B 4	102582	Ex d	II C	T5	II 2 G	IP 55
510	330-LSX01	E	Celes per ndicues (Light switch)	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448-920-E-DEB-0001	ZONE 1	CO.SI.ME	EFDC	18-14384	Ex d	II C	T5	II 2 G	IP 66
511	ACS02-330-HNX01	J	Kuti Shperndarese (Junction Box) + Siren + Beacon (JB)	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448-856-J-DJA-0001	ZONE 1	KROMA MEC	S.26	17/0391	Ex d	II C	T3 / T5 / T6	II 2 G	IP 66/67
512	ACS02-330-HNX01	J	Kuti Shperndarese (Junction Box) + Siren + Beacon (SIREN)	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448-856-J-DJA-0001	ZONE 1	KROMA MEC	ETH20 MD	18/248	Ex d	II B + H2	T6	II 2 G	IP 66
513	ACS02-330-HNX01	J	Kuti Shperndarese (Junction Box) + Siren + Beacon (BEACON)	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448-856-J-DJA-0001	ZONE 1	KROMA MEC	EVA50	18/0760	Ex d	II C	T6	II 2 G	IP 66
514	ACS02-330-XFX02	E	Fan 2	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448-920-E-DEB-0001	ZONE 1	RAEL	TUBE 56B 4	102583	Ex d	II C	T5	II 2 G	IP 55
515	ACS02-330-JB-J-0															

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
516	ACS02-330-JB-J-004	J	Kuti Shperndarese (Junction Box)	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448-856-J-DJA-0001	ZONE 1	STAHL	8118/211-401	1815548760440019	Ex ia	II C	T6	II 2 G	IP 66
517	ACS02-330-JB-J-003	J	Kuti Shperndarese (Junction Box)	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448-856-J-DJA-0001	ZONE 1	STAHL	8118/211-401	1815331110440052	Ex ia	II C	T6	II 2 G	IP 66
518	ACS02-330-JB-J-006	J	Kuti Shperndarese (Junction Box)	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448-856-J-DJA-0001	ZONE 1	STAHL	8146/1051	1916784240440005	Ex e	II C	T6	II 2 G	IP 66
519	ACS02-330-JB-E-001	E	Kuti Shperndarese (Junction Box) for Thermostat and Heater	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448-920-E-DEB-0001	ZONE 1	STAHL	8146/1051	1916784240440012	Ex e	II C	T6	II 2 G	IP 66
520	ACS02-330-AT-0001A	E	Kromatograf Chromatograph Moisture Analyser	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448-920-E-DEB-0001	ZONE 1	ELSTER	ENCAL3000	61301930	Ex d	II B	T4	II 2 G	IP 66
521	ACS02-330-JB-E-006	E	Njesi ngrohës Heat Tracing	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448.3500-820-E-DFB-0001	ZONE 1	THERMON	ZP-WP	18-1711	Ex e	II C	T4 / T6	II 2 G	IP 66
522	ACS02-330-JB-E-007	E	Njesi ngrohës Heat Tracing	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448.3500-820-E-DFB-0001	ZONE 1	THERMON	ZP-WP	18-1711	Ex e	II C	T4 / T6	II 2 G	IP 66
523	ACS02-330-AT-0001B	J	Kromatograf Chromatograph Moisture Analyser	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448-856-J-DJA-0001	ZONE 1	ELSTER	ENCAL3000	61301936	Ex d	II B	T6	II 2 G	IP 66
524	ACS02-330-JB-J-010	E	Kuti Shperndarese (Junction Box)	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448.3500-820-E-DFB-0001	ZONE 1	STAHL	8118/211-401	1815331110440118	Ex ia	II C	T6	II 2 G	IP 66
525	330-YV0002	M	Solenoid Valve	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448-856-J-DJA-0001	ZONE 1	GSR	K0592430	GP1082611	Ex e m	II C	T4	II 2 G	IP 65
526	330-YV0004	M	Solenoid Valve	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448-856-J-DJA-0001	ZONE 1	GSR	K0598010	GP1560541	Ex e m	II C	T4	II 2 G	IP 65
527	ACS02-330-JB-J-012	E	Kuti Shperndarese (Junction Box)	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448.3500-820-E-DFB-0001	ZONE 1	STAHL	8146/1051	1916784240440010	Ex e	II C	T6	II 2 G	IP 66
528	ACS02-330-JB-J-011	E	Kuti Shperndarese (Junction Box)	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448.3500-820-E-DFB-0001	ZONE 1	STAHL	8118/211-401	1815331110440063	Ex ia	II C	T6	II 2 G	IP 66
529	ACS02-330-FDX01	J	Detektor Zjarri (Flame Detector)	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448-856-J-DJA-0001	ZONE 1	HONEYWELL	FS24X-9	LB-6093-056	Ex d	II C	T4 / T6	II 2 G	IP 66
530	ACS02-330-GDX01	J	Gas Detector	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448-856-J-DJA-0001	ZONE 1	HONEYWELL	11-KB4BO-0120X	25182117	Ex d	II C	T6 / T4	II 2 G	IP 66
531	ACS02-330-JB-J-002	E	Kuti Shperndarese (Junction Box)	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448.3500-820-E-DFB-0001	ZONE 1	STAHL	8118/211-401	1815331110440062	Ex ia	II C	T6	II 2 G	IP 66
532	ACS02-330-JB-E-004	E	Kuti Shperndarese (Junction Box)	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448.3500-820-E-DFB-0001	ZONE 1	STAHL	8118/111	1512547390440000	Ex e	II C	T6	II 2 G	IP 66
533	ACS02-330-JB-J-009	E	Kuti Shperndarese (Junction Box)	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448.3500-820-E-DFB-0001	ZONE 1	STAHL	8118/211-401	1815548760440011	Ex ia	II C	T6	II 2 G	IP 66
534	ACS02-330-JB-E-005	E	Kuti Shperndarese (Junction Box)	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448.3500-820-E-DFB-0001	ZONE 1	STAHL	8118/111	1411523520440000	Ex e	II	T6	II 2 G	IP 66
535	ACS02-330-MPX01	J	Kuti alarmi zjarri Break Glass	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448-856-J-DJA-0001	ZONE 1	CO.SI.ME	EFDC	17-09438	Ex d	II C	T5	II 2 G	IP 66
536	ACS02-330-SDX01	J	Detektor Tymi Smoke detector	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448-856-J-DJA-0001	ZONE 1	HOCHIKI EUROPE	SLR-E-IS	N/A	Ex ia	II C	T5	II 1 G	IP 66/67
537	ACS02-330-GDX02	J	Detektor Gai Gas Detector	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448-856-J-DJA-0001	ZONE 1	HONEYWELL	11-KB4BO-0120X	25182116	Ex d	II C	T6 / T4	II 2 G	IP 66
538	ACS02-330-TTX01	J	Transmetues Temperature (Temperature Transmitter)	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448-856-J-DJA-0001	ZONE 1	CORTEM	SL-16.1	17/325417	Ex d	II C	T6	II 2 G	IP 66/67
539	ACS02-330-SDX02	J	Detektor Tymi Smoke detector	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448-856-J-DJA-0001	ZONE 1	HOCHIKI EUROPE	SLR-E-IS	N/A	Ex ia	II C	T5	II 1 G	IP 66/67
540	330-DSX01	J	Çeles per elektrik per deren Door Switch	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448-856-J-DJA-0001	ZONE 1	KROMA MEC	PS	19-12M	Ex d	II C	T6	II 2 G	IP 66
541	ACS02-330-LNX01	E	Rakorderi perNdricues Light Fitting	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448.3500-820-E-DFB-0001	ZONE 1	CO.SI.ME	EVFC	18-15073 / 18-15084	Ex d	II C	T6	II 2 G	IP 66
542	ACS02-330-LNX02	E	Rakorderi perNdricues Light Fitting	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448.3500-820-E-DFB-0001	ZONE 1	CO.SI.ME	EVFC	18-15075 / 18-15074	Ex d	II C	T6	II 2 G	IP 66
543	ACS02-330-JBX01	J	HVAC Kuti Shperndarese (Junction Box)	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448-856-J-DJA-0001	ZONE 1	BARTEC NASP	ESX 2222A	18/0166.1.3	Ex e	II C	T6	II 2 G	IP 66
544	ACS02-330-GDN-01	J	Gas Detector	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-0900	ACS02-C1448-920-T-DTA-0001	ZONE 2	HONEYWELL	XXN-UTAV-NNCB1	22180921	Ex d	II C	T6	II 2 G	IP 66
545	ACS02-360-HS-0040-C	J	çeles paneli lokal (Local Panel Hand Switch)	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-0900	ACS02-C1448-920-T-DTA-0001	ZONE 2	QUINTEX	CB-P6/16353	64713	Ex de	II C	T4	II 2 G	IP 66
546	330-YV0003	M	Solenoid Valve	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448-856-J-DJA-0001	ZONE 1	GSR	K0598010	GP1560541	Ex e m	II C	T4	II 2 G	IP 65
547	ACS02-330-AT-0003A	E	Sensor per matjen e pikes se veses Dew Point Transducer	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448.3500-820-E-DFB-0001	ZONE 1	VYMPEL	CONG PRIMA-2M	D17060232	Ex d	II B + H2	T5	II 2 G	IP 67
548	ACS02-330-AT-0003B	E	Sensor per matjen e pikes se veses Dew Point Transducer	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448.3500-820-E-DFB-0001	ZONE 1	VYMPEL	CONG PRIMA-2M	D17060236	Ex d	II B + H2	T5	II 2 G	IP 67
549	ACS02-330-GDX01-S	J	Sensor detektimi gazit Gas Detector Sensor	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448-856-J-DJA-0001	ZONE 1	HONEYWELL	AMCB 1	17180004	Ex d	II B + H2	T4	II 2 G	IP 66
550	ACS02-330-GDX02-S	J	Sensor detektimi gazit Gas Detector Sensor	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448-856-J-DJA-0001	ZONE 1	HONEYWELL	AMCB 1	17180007	Ex d	II B + H2	T4	II 2 G	IP 66
551	ACS02-330-JB-E-002	E	Kuti Shperndarese (Junction Box) for Thermostat and Heater	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448.3500-820-E-DFB-0001	ZONE 1	STAHL	8146/1051	1916784240440004	Ex eb	II C	T6	II 2 G	IP 66
552	ACS02-330-JB-E-008	E	Kuti Shperndarese (Junction Box)	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448.3500-820-E-DFB-0001	ZONE 1	ABTECH	BPGC01.00-029	11649433/2016	Ex e	II C	T6	II 2 G	IP 66
553	ACS02-330-JB-E-009	E	Kuti Shperndarese (Junction Box)	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448.3500-820-E-DFB-0001	ZONE 1	ABTECH	BPGC01.00-029	11649431 / 2016	Ex e	II C	T6	II 2 G	IP 66
554	ACS02-330-JB-J-007	J	Kuti Shperndarese (Junction Box)	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448-856-J-DJA-0001	ZONE 1	STAHL	8146/1051	1916784240440009	Ex eb	II C	T6	II 2 G	IP 66
555	ACS02-330-JB-J-013	J	Kuti Shperndarese (Junction Box)	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448-856-J-DJA-0001	ZONE 1	ABTECH	BPGC02.00-002	11649451/2016	Ex e	II C	T6	II 2 G	IP 66
556	ACS02-330-JB-J-014	J	Kuti Shperndarese (Junction Box)	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448-856-J-DJA-0001	ZONE 1	ABTECH	BPGC02.00-002	11649462/2016	Ex e	II C	T6	II 2 G	IP 66
557	ACS02-330-JB-E-003	E	Kuti Shperndarese (Junction Box) for Thermostat and Heater	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448.3500-820-E-DFB-0001	ZONE 1	STAHL	8146/1051	1916784240440011	Ex eb	II C	T6	II 2 G	IP 66
558	ACS02-850-HZS-1001	E	Emergency stop switch station off / ESD Abandon	PROCESS CONTROL AND SHUT DOWN	ACS02-856	ACS02-856-0200	ACS02-C1448-856-J-DJA-0001	SAFE AREA	MEDC	SM87PBLD	217583073 10 01	Ex d	II C	T5 / T6	II 2 G	IP 66/67
559	ACS02-850-HZS-1002	E	Emergency stop switch station off / ESD Abandon	PROCESS CONTROL AND SHUT DOWN	ACS02-856	ACS02-856-0200	ACS02-C1448-856-J-DJA-0001	SAFE AREA	MEDC	SM87PBLD	217583073 10 02	Ex d	II C	T5 / T6	II 2 G	IP 66/67
560	ACS02-850-HZS-1003	E	Emergency stop switch station off / ESD Abandon	PROCESS CONTROL AND SHUT DOWN	ACS02-856	ACS02-856-0200	ACS02-C1448-856-J-DJA-0001	SAFE AREA	MEDC	SM87PBLD	217583073 10 03	Ex d	II C	T5 / T6	II 2 G	IP 66/67
561	ACS02-856-EJE-J-0002	E	Kuti shperndarese Heat Tracing JB	PIG TRAP	Not in CMS	Not in CMS	ACS02-C1448.3500-820-E-DFB-0001	ZONE 2	THERMON	ZL-WP	WO18-0044	Ex e	II C	T4 / T6	II 2 G	IP 66
562	ACS02-856-EJE-J-0001	E	Kuti shperndarese Heat Tracing JB	PIG TRAP	Not in CMS	Not in CMS	ACS02-C1448.3500-820-E-DFB-0001	ZONE 2	THERMON	ZL-WP	WO18-0313	Ex e	II C	T4 / T6	II 2 G	IP 66
563	ACS02-381-YV-0001	E	Valvul Solenoid (Solenoid Valve)	CONDENSATE TANKS	ACS02-381	ACS02-381-0000	ACS02-C1448-856-J-DJA-0001	SAFE AREA	IMI BUSCHJOST	AT001518	8675703.624	Ex e m	II C	T3	II 2 G	IP 66
564	ACS02-360-HS-0010-C	J	çeles paneli lokal (Local Panel Hand Switch)	Tubacionet (PIPING)	ACS02-360	ACS02-360-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	QUINTEX	CB-P6/16353	64725	Ex de	II C	T4	II 2 G	IP 66
565	ACS02-539-LAH-0001-B	J	Alarm Pamor (Visible Alarm)	DIESEL FUEL SYSTEM	ACS02-539	ACS02-539-0100	ACS02-C1448-856-J-DJA-0001	SAFE AREA	E2S	BEXCS110-05D-P	1CS22011114	Ex d	II B	T4	II 2 G	IP 66
566	ACS02-920-SCD-2016	J	Sensor tymi dhe nxehtesie Multi Sensor - Optical Smoke & (Heat Detectors	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-0200	ACS02-C1448-920-T-DTA-0001	SAFE AREA	APOLLO	ORB-OH-53027-APO	N/A	Ex ia	II C	T5	II 1 G	N/A
567	ACS02-920-SCD-2017	J	Sensor tymi dhe nxehtesie Multi Sensor - Optical Smoke & (Heat Detectors	FIRE AND GAS MONITORING	ACS02-740	ACS02-740-0200	ACS02-C1448-920-T-DTA-0001	SAFE AREA	APOLLO	ORB-OH-53027-APO	N/A	Ex ia	II C	T5	II 1 G	N/A
568	ACS02-850-HZS-1004	E	Buton emergjence Emergency stop switch station off / ESD Abandon	PROCESS CONTROL AND SHUT DOWN	ACS02-856	ACS02-856-0200	ACS02-C1448-820-E-DEA-0002	SAFE AREA	MEDC	SM87PBLD	217583073 10 04	Ex d	II C	T5 / T6	II 2 G	IP 66/67

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
569	ASC02-920-TT-0001	J	Kuti shperndarese Anti Icing J/B on Electrical Control Building roof	Not in CMS	Not in CMS	Not in CMS	ACS02-C1448-920-T-DTA-0001	SAFE AREA	ELTHERM	ELAK-Ex-3.8 / 0X80058	1998	Ex e	II C	T6	II 2 G	IP 66
570	ASC02-550-PDS-1006	J	Transmetues temperature Temp Tansmitter on Electrical Control Building roof	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS02-551	ACS02-551-0703	ACS02-C1448-856-J-DJA-0001	SAFE AREA	SCHISCHEK	ExBin-P500	055.3020 18470069	Ex e m	II C	T6	II 2 (1) G	IP 66
571	ASC02-550-PDS-1007	J	Transmetues temperature Temp Tansmitter on Electrical Control Building roof	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS02-551	ACS02-551-0703	ACS02-C1448-856-J-DJA-0001	SAFE AREA	SCHISCHEK	ExBin-P500	055.3020 18470059	Ex e m	II C	T6	II 2 (1) G	IP 66
572	ACS02-551-V-1006	E	Ventilator Extractor fan on Electrical Control Building roof	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS02-551	ACS02-551-0701	ACS02-C1448-820-E-DEA-0002	SAFE AREA	RAEL	RL63A 4 (RL0010)	114282	Ex d	II C	T4	II 2 G	IP 55
573	ACS02-551-V-1007	E	Ventilator Extractor fan on Electrical Control Building roof	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS02-551	ACS02-551-0701	ACS02-C1448-820-E-DEA-0002	SAFE AREA	RAEL	RL63A 4 (RL0010)	114280	Ex d	II C	T4	II 2 G	IP 55
574	ACS02-551-V-1008	E	Ventilator Extractor fan on Electrical Control Building roof	Sistemi i Ftohjes dhe Ventilimit (COOLING AND VENTILATION SYSTEM)	ACS02-551	ACS02-551-0701	ACS02-C1448-820-E-DEA-0002	SAFE AREA	RAEL	RL90S 4 (RL0016)	109261	Ex d	II C	T5	II 2 G	IP 55
575	ASC02-110-PI-1022	J	Manometer presioni Pressure Gauge	SCRAPER	Not in CMS	Not in CMS	ACS02-C1448-820-E-DEA-0002	ZONE 2	WIKA	232.30.160 + Option ATEX	8970BHYH	c TX X	N/A	N/A	II 2 GD	N/A
576	ASC02-110-PDI-1001	J	Manometer presioni Pressure Gauge	SCRAPER	Not in CMS	Not in CMS	ACS02-C1448-820-E-DEA-0002	ZONE 2	WIKA	733.14.160 + Option ATEX	1109AYZN	c TX	N/A	N/A	II 2 GD	N/A
577	ASC02-110-PDI-2001	J	Manometer presioni Pressure Gauge	SCRAPER	Not in CMS	Not in CMS	ACS02-C1448-820-E-DEA-0002	ZONE 2	WIKA	733.14.160 + Option ATEX	1109AYZO	c TX	N/A	N/A	II 2 GD	N/A
578	ASC02-110-PI-1042	J	Manometer presioni Pressure Gauge	SCRAPER	Not in CMS	Not in CMS	ACS02-C1448-820-E-DEA-0002	ZONE 2	WIKA	232.30.160 + Option ATEX	8970BXT	c TX X	N/A	N/A	II 2 GD	N/A
579	ASC02-110-PI-2042	J	Manometer presioni Pressure Gauge	SCRAPER	Not in CMS	Not in CMS	ACS02-C1448-820-E-DEA-0002	ZONE 2	WIKA	232.30.160 + Option ATEX	8970BHXW	c TX X	N/A	N/A	II 2 GD	N/A
580	ACS02-110-PI-1055	J	Manometer presioni Pressure Gauge	SCRAPER	Not in CMS	Not in CMS	ACS02-C1448-820-E-DEA-0002	ZONE 2	WIKA	232.30.100	89708ZYO	c TX	N/A	N/A	II 2 GD	N/A
581	ACS02-110-PI-2055	J	Manometer presioni Pressure Gauge	SCRAPER	Not in CMS	Not in CMS	ACS02-C1448-820-E-DEA-0002	ZONE 2	WIKA	232.30.100	89708ZYH	c TX	N/A	N/A	II 2 GD	N/A
582	ACS02-330-PG-1086	J	Manometer presioni Temp DT	Matja e Gazit	ACS02-330	ACS02-330-0400	ACS02-C1448-856-J-DJA-0001	ZONE 2	ITEC	P201 ITEC / ATXT / 16	171209270003	c X	II C	N/A	2 GD	N/A
583	ACS02-310-PG-0004	J	Manometer presioni Temp DT	FILTER SEPERATOR	ACS02-310	ACS02-310-0400	ACS02-C1448-856-J-DJA-0001	ZONE 2	ITEC	P201 ITEC / ATXT / 16	171209270002	c X	II C	N/A	2 GD	N/A
584	ACS02-310-PG-0003	J	Manometer presioni Temp DT	FILTER SEPERATOR	ACS02-360	ACS02-360-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	ITEC	P201 ITEC / ATXT / 16	171209270001	c X	II C	N/A	2 GD	N/A
585	ACS02-360-PG-0029	J	Manometer presioni Temp DT	Matja e Gazit	ACS02-360	ACS02-360-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	ITEC	P201 ITEC / ATXT / 16	171209270004	c X	II C	N/A	2 GD	N/A
586	ACS02-532-PG-8105	J	Manometer presioni Temp DT	INSTRUMENT AIR	ACS02-532	ACS02-532-0901	ACS02-C1448-856-J-DJA-0001	SAFE AREA	ITEC	P201 ITEC / ATXT / 16	171209270008	c X	II	N/A	2 GD	N/A
587	ACS02-532-PG-8205	J	Manometer presioni Temp DT	INSTRUMENT AIR	ACS02-532	ACS02-532-0901	ACS02-C1448-856-J-DJA-0001	SAFE AREA	ITEC	P201 ITEC / ATXT / 16	171209270009	c X	II	N/A	2 GD	N/A
588	ACS02-110-PI-2022	J	Manometer presioni Pressure Gauge	SCRAPER	Not in CMS	Not in CMS	ACS02-C1448-820-E-DEA-0002	ZONE 2	WIKA	232.30.160 + Option ATEX	8970BHXU	c TX X	N/A	N/A	II 2 GD	N/A
589	ACS02-532-ZSC-9000	J	Celes Fundor Closed limit switch	INSTRUMENT AIR	Not in CMS	Not in CMS	ACS02-C1448-856-J-DJA-0001	SAFE AREA	HOVELHOF	Icomatic I - O 12 / G16T - 1, 5 - E - S1	D33161	EX ia	II C	T6	II 2 GD	N/A
590	ACS02-710-LSLL-0010	J	Nivel Level Switch	FIRE WATER SYSTEMS	ACS02-710	ACS02-710-1200	ASC02-C1448-856-J-DJA-0001	ZONE 2	ROSEMOUNT	2120 LEVEL SWITCH	1239943	Ex db	II C	T6	II 1/2 G	IP 66/67
591	ACS02-710-ZSC-0001	J	Celes Fundor Closed limit switch	FIRE WATER SYSTEMS	ACS02-710	ACS02-710-1200	ASC02-C1448-856-J-DJA-0001	SAFE AREA	HOVELHOF	Icomatic I - O 12 / G16T - 1, 5 - E - S1	D33161	EX ia	II C	T6	II 2 GD	N/A
592	ACS02-710-PDG-1001	J	Manometer presioni Temp DT	FIRE WATER SYSTEMS	ACS02-710	ACS02-710-1200	ASC02-C1448-856-J-DJA-0001	SAFE AREA	ITEC	P301 ITEC / ATXT / 16	79 / 18	c X	II C	N/A	2 GD	N/A
593	ACS02-710-PDG-2001	J	Manometer presioni Temp DT	FIRE WATER SYSTEMS	ACS02-710	ACS02-710-1200	ASC02-C1448-856-J-DJA-0001	SAFE AREA	ITEC	P301 ITEC / ATXT / 16	80 / 18	c X	II C	N/A	2 GD	N/A
594	ACS02-710-PDG-3001	J	Manometer presioni Temp DT	FIRE WATER SYSTEMS	ACS02-710	ACS02-710-1200	ASC02-C1448-856-J-DJA-0001	SAFE AREA	ITEC	P301 ITEC / ATXT / 16	81 / 18	c X	II C	N/A	2 GD	N/A
595	ACS02-310-PG-1001	J	Manometer presioni Temp DT	FILTER SEPERATOR	ACS02-310	ACS02-310-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	ITEC	P201 ITEC / ATXT / 16	171209270005	c X	II C	N/A	2 GD	N/A
596	ACS02-310-PG-2001	J	Manometer presioni Temp DT	FILTER SEPERATOR	ACS02-310	ACS02-310-0200	ACS02-C1448-856-J-DJA-0001	ZONE 2	ITEC	P201 ITEC / ATXT / 16	171209270006	c X	II C	N/A	2 GD	N/A
597	ACS02-310-PG-3001	J	Manometer presioni Temp DT	FILTER SEPERATOR	ACS02-310	ACS02-310-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	ITEC	P201 ITEC / ATXT / 16	171209270007	c X	II C	N/A	2 GD	N/A
598	ACS02-310-TG-1001	J	Tregues Teperature Temp Gauge	FILTER SEPERATOR	ACS02-310	ACS02-310-0100	ACS02-C1448-856-J-DJA-0001	ZONE 2	ITEC	T501 / 502 ITEC / ATXT / 16	190603490001	c X	II C	N/A	2 GD	N/A
599	ACS02-310-TG-2001	J	Tregues Teperature Temp Gauge	FILTER SEPERATOR	ACS02-310	ACS02-310-0200	ACS02-C1448-856-J-DJA-0001	ZONE 2	ITEC	T501 / 502 ITEC / ATXT / 16	190603490002	c X	II C	N/A	2 GD	N/A
600	ACS02-310-TG-3001	J	Tregues Teperature Temp Gauge	FILTER SEPERATOR	ACS02-310	ACS02-310-0300	ACS02-C1448-856-J-DJA-0001	ZONE 2	ITEC	T501 / 502 ITEC / ATXT / 16	190603490003	c X	II C	N/A	2 GD	N/A
601	ACS02-535-A-3001	J	Buton emergjence Emergency Stop / Push Button (Break Glass)	EMERGENCY GEN	ACS02-535	ACS02-535-0300	ACS02-C1448-856-J-DJA-0001	SAFE AREA	COELBO SRL	PB 1 E1 - R	2717	Ex d	II C	T6	II G	IP66
602	ACS02-535-A-2001	J	Buton emergjence Emergency Stop / Push Button (Break Glass)	EMERGENCY GEN	ACS02-535	ACS02-535-0200	ACS02-C1448-856-J-DJA-0001	SAFE AREA	COELBO SRL	PB 1 E1 - R	2717	Ex d	II C	T6	II G	IP66
603	ACS02-535-A-1001	J	Buton emergjence Emergency Stop / Push Button (Break Glass)	AUXILLIARY GEN	ACS02-535	ACS02-535-0100	ACS02-C1448-856-J-DJA-0001	SAFE AREA	COELBO SRL	PB 1 E1 - R	2717	Ex d	II C	T6	II G	IP66
604	ACS02-535-A-1001	J	Buton emergjence Emergency Stop / Push Button (Break Glass)	AUXILLIARY GEN	ACS02-535	ACS02-535-0100	ACS02-C1448-856-J-DJA-0001	SAFE AREA	COELBO SRL	PB 1 E1 - R	1617	Ex d	II C	T6	II G	IP66
605	Three Phase Induction Motor	E	Motor Three Phase Induction Motor (Diesel Tank)	DIESEL FUEL SYSTEM	Not in CMS	Not in CMS	ACS02-C1448-820-E-DEA-0002	SAFE AREA	EUROFINS	SB3 / F	33714 05 /18	Ex mb	II B	T6	II 2 G	N/A

ANEX 6

Fleta 6.3 - ABVs - ATEX Register

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
ABV24																
1	ABV24-105-JB-0001	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0024-856	BVS-0024-856-01	ABV24-C10766-105-M-DAA-0001	ZONE 2	ASP	ESX2216A	17/1587.1.13	Ex e ia	II B/II C	T5	II 2 G	IP 66
2	ABV24-105-JB-0002	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0024-856	BVS-0024-856-01	ABV24-C10766-105-M-DAA-0001	SAFE AREA	ASP	ESX2216A	17/1587.1.9	Ex e ia	II B/II C	T5	II 2 G	IP 66
3	ABV24-105-JB-0003	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0024-856	BVS-0024-856-01	ABV24-C10766-105-M-DAA-0001	ZONE 2	ASP	ESX3322B	17/1587.2.12	Ex e ia	II B/II C	T5	II 2 G	IP 66
4	ABV24-105-JB-0011	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0024-856	BVS-0024-856-01	ABV24-C10766-105-M-DAA-0001	SAFE AREA	STAHL	8150/5-0176-0116-091-2311	1714724050440000	Ex de	II C	T6	II 2 G	IP 66
5	ABV24-105-JB-0012	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0024-856	BVS-0024-856-01	ABV24-C10766-105-M-DAA-0001	SAFE AREA	STAHL	8150/5-0176-0116-091-2311	1714724060440000	Ex de	II C	T6	II 2 G	IP 66
6	ABV24-105-MOB-2410-M	E	Motor Operated Ball Valve Actuator	ELECTRICAL POWER DISTRIBUTION	BVS-0024-820	BVS-0024-820-01	ABV24-C10766-105-M-DAA-0001	ZONE 2	AUMA	SAEX 14.6-F14	3916MD99130	Ex de	II C	T4	II 2 G	IP 68
7	ABV24-105-PI-2421	J	Manometer Presioni Pressure Gauge	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0024-856	BVS-0024-856-01	ABV24-C10766-105-P-DPE-0001	ZONE 2	WIKA	233.30.100	8970BHY1	Ex c	II	T6	II 2 G	IP 65
8	ABV24-105-PI-2431	J	Manometer Presioni Pressure Gauge	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0024-856	BVS-0024-856-01	ABV24-C10766-105-P-DPE-0001	ZONE 2	WIKA	233.30.100	8970BHY2	Ex c	II	T6	II 2 G	IP 65
9	ABV24-105-PIT-2422	J	Transmetues presioni(Pressure Transmitter)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0024-856	BVS-0024-856-01	ABV24-C10766-105-M-DAA-0001	ZONE 2	YOKOGAWA	EJA530E	91T218283	Ex ia	II C	T4	II 2 G	IP 66
10	ABV24-105-PIT-2432	J	Transmetues presioni(Pressure Transmitter)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0024-856	BVS-0024-856-01	ABV24-C10766-105-M-DAA-0001	ZONE 2	YOKOGAWA	EJA530E	91T218284	Ex ia	II C	T4	II 2 G	IP 66
11	ABV24-105-ZS-2410	J	Celes Fundor Celes fundor (Position Switch Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0024-856	BVS-0024-856-01	ABV24-C10766-105-P-DPE-0001	ZONE 2	EUROTEC	EAE 2103-73-IA-DAE	N/A	Ex ia	II C	T6	II 2 G	IP 67
12	ABV24-105-ZS-2420	J	Celes Fundor Celes fundor (Position Switch Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0024-856	BVS-0024-856-01	ABV24-C10766-105-P-DPE-0001	ZONE 2	EUROTEC	EVE 2102-579-IA	N/A	Ex ia	II C	T6	II 2 G	IP 67
13	ABV24-105-ZS-2430	J	Celes Fundor Celes fundor (Position Switch Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0024-856	BVS-0024-856-01	ABV24-C10766-105-P-DPE-0001	ZONE 2	EUROTEC	EVE 2102-579-IA	N/A	Ex ia	II C	T6	II 2 G	IP 67
14	ABV24-105-ZS-2440	J	Celes Fundor Celes fundor (Position Switch Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0024-856	BVS-0024-856-01	ABV24-C10766-105-P-DPE-0001	ZONE 2	EUROTEC	EVE 2102-579-IA	N/A	Ex ia	II C	T6	II 2 G	IP 67
15	ABV24-826-EPL-0001	E	Drite emergjence Ndricues emergjence (Emergency Portable Light)	STATION ELECTRICAL INSTALLATION	BVS-0024-826	BVS-0024-826-01	ABV24-C10766-105-E-DQH-0001	ZONE 2	WOLFLITE	WOLFLITE XT-50	N/A	Ex ib	II C	T4	II 2 G	IP 67
16	ABV24-840-CZ-0001	E	Ndares shkendije Ndares shkendine (Spark Gap)	EARTHING & LIGHTING PROTECTION	BVS-0024-840	BVS-0024-840-01	ABV24-C10766-105-M-DAA-0001	ZONE 2	LEUTRON	TC 500 A	44646-006	Ex mb	II C	T4	II 2 G	IP 67
17	ABV24-856-EJE-J-0001	E	Kuti Shperndarese (Junction Box)	STATION ELECTRICAL INSTALLATION	BVS-0024-826	BVS-0024-826-01	ABV24-C10766-105-M-DAA-0001	ZONE 2	THERMON	ZL-WP	N/A	Ex e	II	T4-T6	II 2 G	IP 66
18	ABV24-856-EJE-J-0002	E	Kuti Shperndarese (Junction Box)	STATION ELECTRICAL INSTALLATION	BVS-0024-826	BVS-0024-826-01	ABV24-C10766-105-M-DAA-0001	ZONE 2	THERMON	ZL-WP	N/A	Ex e	II	T4-T6	II 2 G	IP 66
19	ABV24-856-EJE-J-0003	E	Kuti Shperndarese (Junction Box)	STATION ELECTRICAL INSTALLATION	BVS-0024-826	BVS-0024-826-01	ABV24-C10766-105-M-DAA-0001	ZONE 2	ASP	ESX2212B	17/1587.6.14	Ex e	II C	T5	II 2 G	IP 66
20	ABV24-856-EJE-J-0004	E	Kuti Shperndarese (Junction Box)	STATION ELECTRICAL INSTALLATION	BVS-0024-826	BVS-0024-826-01	ABV24-C10766-105-M-DAA-0001	ZONE 2	ASP	ESX2212B	17/1587.6.16	Ex e	II C	T5	II 2 G	IP 66
21	ABV24-856-ERQ-0001	E	Prize (Power Socket) Vent Stack Valve Actuator	ELECTRICAL POWER DISTRIBUTION	BVS-0024-820	BVS-0024-820-01	ABV24-C10766-105-M-DAA-0001	SAFE AREA	FEAM	CPSC 438-25A	16/1626/12	Ex d	II C	T5	II 2 G	IP 66/67
22	ABV24-856-HE-0001	E	Ngrohesh Ngrohesh (Standard Heating)	STATION ELECTRICAL INSTALLATION	BVS-0024-826	BVS-0024-826-01	CBV00-SPI-105-J-DJH-0001	ZONE 2	INTERTEC	DPA 200 T3 TS	82106/17	Ex d m	II C	T3	II 2 G	IP 68
23	ABV24-856-HE-0002	E	Ngrohesh Ngrohesh (Standard Heating)	STATION ELECTRICAL INSTALLATION	BVS-0024-826	BVS-0024-826-01	CBV00-SPI-105-J-DJH-0001	ZONE 2	INTERTEC	DPA 200 T3 TS	82107/17	Ex d m	II C	T3	II 2 G	IP 68
ABV25																
1	ABV25-105-JB-0001	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0025-856	BVS-0025-856-01	ABV25-C10766-105-M-DAA-0001	ZONE 2	ASP	ESX2216A	17/1587.1.11	Ex e ia	II B/II C	T5	II 2 G	IP 66
2	ABV25-105-JB-0002	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0025-856	BVS-0025-856-01	ABV25-C10766-105-M-DAA-0001		ASP	ESX2216A	17/1587.1.16	Ex e ia	II B/II C	T5	II 2 G	IP 66
3	ABV25-105-JB-0003	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0025-856	BVS-0025-856-01	ABV25-C10766-105-M-DAA-0001	ZONE 2	BARTEC NASP	ESX3322B	18/2392.1.2	Ex e ia	II B/II C	T5	II 2 G	IP 66
4	ABV25-105-JB-0011	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0025-856	BVS-0025-856-01	ABV25-C10766-105-M-DAA-0001	SAFE AREA	STAHL	8150/5-0176-0116-091-2311	1714724050440002	Ex de	II C	T6	II 2 G	IP 66
5	ABV25-105-JB-0012	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0025-856	BVS-0025-856-01	ABV25-C10766-105-M-DAA-0001	SAFE AREA	STAHL	8150/5-0176-0116-091-2311	1714724060440016	Ex de	II C	T6	II 2 G	IP 66
6	ABV25-105-MOB-2510-M	E	Aktuator Motor Operated Ball Valve Actuator	ELECTRICAL POWER DISTRIBUTION	BVS-0025-820	BVS-0025-820-01	ABV25-C10766-105-M-DAA-0001	ZONE 2	AUMA	SAEX 14.6-F14	2316MD68164	Ex de	II C	T4	II 2 G	IP 68
7	ABV25-105-PI-2521	J	Manometer presioni Pressure Gauge	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0025-856	BVS-0025-856-01	ABV25-C10766-105-P-DPE-0001	ZONE 2	WIKA	233.30.100	8970BHY3	Ex c	II	T6	II 2 G	IP 65
8	ABV25-105-PI-2531	J	manometer Presioni Pressure Gauge	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0025-856	BVS-0025-856-01	ABV25-C10766-105-P-DPE-0001	ZONE 2	WIKA	233.30.100	8970BHY4	Ex c	II	T6	II 2 G	IP 65
9	ABV25-105-PIT-2522	J	Transmetues presioni(Pressure Transmitter)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0025-856	BVS-0025-856-01	ABV25-C10766-105-M-DAA-0001	ZONE 2	YOKOGAWA	EJA530E	91T218285	Ex ia	II C	T4	II 2 G	IP 66
10	ABV25-105-PIT-2532	J	Transmetues presioni(Pressure Transmitter)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0025-856	BVS-0025-856-01	ABV25-C10766-105-M-DAA-0001	ZONE 2	YOKOGAWA	EJA530E	91T218286	Ex ia	II C	T4	II 2 G	IP 66
11	ABV25-105-ZS-2510	J	Celes fundor (Position Switch Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0025-856	BVS-0025-856-01	ABV25-C10766-105-P-DPE-0001	ZONE 2	EUROTEC	EAE 2103-73-IA-DAE	N/A	Ex ia	II C	T6	II 2 G	IP 67
12	ABV25-105-ZS-2520	J	Celes fundor (Position Switch Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0025-856	BVS-0025-856-01	ABV25-C10766-105-P-DPE-0001	ZONE 2	EUROTEC	EVE 2102-579-IA	N/A	Ex ia	II C	T6	II 2 G	IP 67
13	ABV25-105-ZS-2530	J	Celes fundor (Position Switch Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0025-856	BVS-0025-856-01	ABV25-C10766-105-P-DPE-0001	ZONE 2	EUROTEC	EVE 2102-579-IA	N/A	Ex ia	II C	T6	II 2 G	IP 67
14	ABV25-105-ZS-2540	J	Celes fundor (Position Switch Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0025-856	BVS-0025-856-01	ABV25-C10766-105-P-DPE-0001	ZONE 2	EUROTEC	EVE 2102-579-IA	N/A	Ex ia	II C	T6	II 2 G	IP 67
15	ABV25-826-EPL-0001	E	Ndricues emergjence (Emergency Portable Light)	STATION ELECTRICAL INSTALLATION	BVS-0025-826	BVS-0025-826-01	ABV25-C10766-105-E-DQH-0001	ZONE 2	WOLFLITE	WOLFLITE XT-50	N/A	Ex ib	II C	T4	II 2 G	IP 67
16	ABV25-840-CZ-0001	E	Ndares shkendije Ndares shkendine (Spark Gap)	EARTHING & LIGHTING PROTECTION	BVS-0025-840	BVS-0025-840-01	ABV25-C10766-105-M-DAA-0001	ZONE 2	LEUTRON	TC 500 A	44646-005	Ex mb	II C	T4	II 2 G	IP 67
17	ABV25-856-EJE-J-0001	E	Kuti Shperndarese (Junction Box)	STATION ELECTRICAL INSTALLATION	BVS-0025-826	BVS-0025-826-01	ABV25-C10766-105-M-DAA-0001	ZONE 2	THERMON	ZL-WP	N/A	Ex e	II	T4-T6	II 2 G	IP 66
18	ABV25-856-EJE-J-0002	E	Kuti Shperndarese (Junction Box)	STATION ELECTRICAL INSTALLATION	BVS-0025-826	BVS-0025-826-01	ABV25-C10766-105-M-DAA-0001	ZONE 2	THERMON	ZL-WP	N/A	Ex e	II	T4-T6	II 2 G	IP 66
19	ABV25-856-EJE-J-0003	E	Kuti Shperndarese (Junction Box)	STATION ELECTRICAL INSTALLATION	BVS-0025-826	BVS-0025-826-01	ABV25-C10766-105-M-DAA-0001	ZONE 2	ASP	ESX2212B	17/1587.7.13	Ex e	II C	T5	II 2 G	IP 66
20	ABV25-856-EJE-J-0004	E	Kuti Shperndarese (Junction Box)	STATION ELECTRICAL INSTALLATION	BVS-0025-826	BVS-0025-826-01	ABV25-C10766-105-M-DAA-0001	ZONE 2	ASP	ESX2212B	17/1587.7.12	Ex e	II C	T5	II 2 G	IP 66
21	ABV25-856-ERQ-0001	E	Prize (Power Socket) Vent Stack Valve Actuator	ELECTRICAL POWER DISTRIBUTION	BVS-0025-820	BVS-0025-820-01	ABV25-C10766-105-M-DAA-0001	SAFE AREA	FEAM	CPSC 438-25A	18/2332/07	Ex d	II C	T5	II 2 G	IP 66/67
22	ABV25-856-HE-0001	E	Ngrohesh (Standard Heating)	STATION ELECTRICAL INSTALLATION	BVS-0025-826	BVS-0025-826-01	CBV00-SPI-105-J-DJH-0001	ZONE 2	INTERTEC	DPA 200 T3 TS	82108/17	Ex d m	II C	T3	II 2 G	IP 68
23	ABV25-856-HE-0002	E	Ngrohesh (Standard Heating)	STATION ELECTRICAL INSTALLATION	BVS-0025-826	BVS-0025-826-01	CBV00-SPI-105-J-DJH-0001	ZONE 2	INTERTEC	DPA 200 T3 TS	82120/17	Ex d m	II C	T3	II 2 G	IP 68

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrimi	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
ABV26																
1	ABV26-105-JB-0001	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0026-856	BVS-0026-856-01	ABV26-C10766-105-M-DAA-0001	ZONE 2	ASP	ESX2216A	17/1587.3.12	Ex e ia	II B/II C	T5	II 2 G	IP 66
2	ABV26-105-JB-0002	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0026-856	BVS-0026-856-01	ABV26-C10766-105-M-DAA-0001	SAFE AREA	ASP	ESX2216A	17/1587.3.17	Ex e ia	II B/II C	T5	II 2 G	IP 66
3	ABV26-105-JB-0003	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0026-856	BVS-0026-856-01	ABV26-C10766-105-M-DAA-0001	ZONE 2	ASP	ESX3322B	17/1587.2.11	Ex e ia	II B/II C	T5	II 2 G	IP 66
4	ABV26-105-JB-0011	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0026-856	BVS-0026-856-01	ABV26-C10766-105-M-DAA-0001	SAFE AREA	STAHL	8150/5-0176-0116-091-2311	1714724050440008	Ex de	II C	T6	II 2 G	IP 66
5	ABV26-105-JB-0012	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0026-856	BVS-0026-856-01	ABV26-C10766-105-M-DAA-0001	SAFE AREA	STAHL	8150/5-0176-0116-091-2311	1714724060440010	Ex de	II C	T6	II 2 G	IP 66
6	ABV26-105-MOB-2610-M	E	Motor Operated Ball Valve Actuator	ELECTRICAL POWER DISTRIBUTION	BVS-0026-820	BVS-0026-820-01	ABV26-C10766-105-M-DAA-0001	ZONE 2	AUMA	SAEX 14.6-F14	3616MD93329	Ex de	II C	T4	II 2 G	IP 68
7	ABV26-105-PI-2621	J	Manometer presioni (Pressure Gauge)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0026-856	BVS-0026-856-01	ABV26-C10766-105-P-DPE-0001	ZONE 2	WIKA	233.30.100	8970BHY5	Ex c	II	T6	II 2 G	IP 65
8	ABV26-105-PI-2631	J	Manometer presioni (Pressure Gauge)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0026-856	BVS-0026-856-01	ABV26-C10766-105-P-DPE-0001	ZONE 2	WIKA	233.30.100	8970BHY6	Ex c	II	T6	II 2 G	IP 65
9	ABV26-105-PIT-2622	J	Transmetues presioni(Pressure Transmitter)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0026-856	BVS-0026-856-01	ABV26-C10766-105-M-DAA-0001	ZONE 2	YOKOGAWA	EJA530E	91T218287	Ex ia	II C	T4	II 2 G	IP 66/67
10	ABV26-105-PIT-2632	J	Transmetues presioni(Pressure Transmitter)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0026-856	BVS-0026-856-01	ABV26-C10766-105-M-DAA-0001	ZONE 2	YOKOGAWA	EJA530E	91T218288	Ex ia	II C	T4	II 2 G	IP 66/67
11	ABV26-105-ZS-2610	J	Celes fundor (Position Switch Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0026-856	BVS-0026-856-01	ABV26-C10766-105-P-DPE-0001	ZONE 2	EUROTEC	EAE 2103-73-IA-DAE	N/A	Ex ia	II C	T6	II 2 G	IP 67
12	ABV26-105-ZS-2620	J	Celes fundor (Position Switch Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0026-856	BVS-0026-856-01	ABV26-C10766-105-P-DPE-0001	ZONE 2	EUROTEC	EVE 2102-579-IA	N/A	Ex ia	II C	T6	II 2 G	IP 67
13	ABV26-105-ZS-2630	J	Celes fundor (Position Switch Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0026-856	BVS-0026-856-01	ABV26-C10766-105-P-DPE-0001	ZONE 2	EUROTEC	EVE 2102-579-IA	N/A	Ex ia	II C	T6	II 2 G	IP 67
14	ABV26-105-ZS-2640	J	Celes fundor (Position Switch Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0026-856	BVS-0026-856-01	ABV26-C10766-105-P-DPE-0001	ZONE 2	EUROTEC	EVE 2102-579-IA	N/A	Ex ia	II C	T6	II 2 G	IP 67
15	ABV26-826-EPL-0001	E	Ndricues emergjence (Emergency Portable Light)	STATION ELECTRICAL INSTALLATION	BVS-0026-826	BVS-0026-826-01	ABV26-C10766-105-E-DQH-0001	ZONE 2	WOLFLITE	WOLFLITE XT-50	N/A	Ex ib	II C	T4	II 2 G	IP 67
16	ABV26-840-CZ-0001	E	Ndares shkendine (Spark Gap)	EARTHING & LIGHTING PROTECTION	BVS-0026-840	BVS-0026-840-01	ABV26-C10766-105-M-DAA-0001	ZONE 2	LEUTRON	TC 500 A	44646-007	Ex mb	II C	T4	II 2 G	IP 67
17	ABV26-856-EJE-J-0001	E	Kuti Shperndarese (Junction Box)	EARTHING & LIGHTING PROTECTION	BVS-0026-826	BVS-0026-826-01	ABV26-C10766-105-M-DAA-0001	ZONE 2	THERMON	ZL-WP	N/A	Ex e	II	T4-T6	II 2 G	IP 66
18	ABV26-856-EJE-J-0002	E	Kuti Shperndarese (Junction Box)	EARTHING & LIGHTING PROTECTION	BVS-0026-826	BVS-0026-826-01	ABV26-C10766-105-M-DAA-0001	ZONE 2	THERMON	ZL-WP	N/A	Ex e	II	T4-T6	II 2 G	IP 66
19	ABV26-856-EJE-J-0003	E	Kuti Shperndarese (Junction Box)	EARTHING & LIGHTING PROTECTION	BVS-0026-826	BVS-0026-826-01	ABV26-C10766-105-M-DAA-0001	ZONE 2	ASP	ESX2212B	17/1587.6.15	Ex e	II C	T5	II 2 G	IP 66
20	ABV26-856-EJE-J-0004	E	Kuti Shperndarese (Junction Box)	EARTHING & LIGHTING PROTECTION	BVS-0026-826	BVS-0026-826-01	ABV26-C10766-105-M-DAA-0001	ZONE 2	ASP	ESX2212B	17/1587.7.14	Ex e	II C	T5	II 2 G	IP 66
21	ABV26-856-ERQ-0001	E	Prize (Power Socket) Vent Stack Valve Actuator	ELECTRICAL POWER DISTRIBUTION	BVS-0026-820	BVS-0026-820-01	ABV26-C10766-105-M-DAA-0001	SAFE AREA	FEAM	CPSC 438-25A	18/2332/07	Ex d	II C	T5	II 2 G	IP 66/67
22	ABV26-856-HE-0001	E	Ngrohes (Standard Heating)	STATION ELECTRICAL INSTALLATION	BVS-0026-826	BVS-0026-826-01	CBV00-SPI-105-J-DJH-0001	ZONE 2	INTERTEC	DPA 200 T3 TS	82104/17	Ex d m	II C	T3	II 2 G	IP 68
23	ABV26-856-HE-0002	E	Ngrohes (Standard Heating)	STATION ELECTRICAL INSTALLATION	BVS-0026-826	BVS-0026-826-01	CBV00-SPI-105-J-DJH-0001	ZONE 2	INTERTEC	DPA 200 T3 TS	82105/17	Ex d m	II C	T3	II 2 G	IP 68
ABV27																
1	ABV27-105-JB-0001	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0027-856	BVS-0027-856-01	ABV27-C10766-105-M-DAA-0001	ZONE 2	ASP	ESX2216A	17/1587.1.12	Ex e ia	II B/II C	T5	II 2 G	IP 66
2	ABV27-105-JB-0002	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0027-856	BVS-0027-856-01	ABV27-C10766-105-M-DAA-0001	SAFE AREA	ASP	ESX2216A	17/1587.3.13	Ex e ia	II B/II C	T5	II 2 G	IP 66
3	ABV27-105-JB-0003	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0027-856	BVS-0027-856-01	ABV27-C10766-105-M-DAA-0001	ZONE 2	ASP	ESX3322B	17/1587.2.9	Ex e ia	II B/II C	T5	II 2 G	IP 66
4	ABV27-105-JB-0011	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0027-856	BVS-0027-856-01	ABV27-C10766-105-M-DAA-0001	SAFE AREA	STAHL	8150/5-0176-0116-091-2311	1714724050440003	Ex de	II C	T6	II 2 G	IP 66
5	ABV27-105-JB-0012	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0027-856	BVS-0027-856-01	ABV27-C10766-105-M-DAA-0001	SAFE AREA	STAHL	8150/5-0176-0116-091-2311	1714724060440006	Ex de	II C	T6	II 2 G	IP 66
6	ABV27-105-MOB-2710-M	E	Motor Operated Ball Valve Actuator	ELECTRICAL POWER DISTRIBUTION	BVS-0027-820	BVS-0027-820-01	ABV27-C10766-105-M-DAA-0001	ZONE 2	AUMA	SAEX 14.6-F14	3616MD93330	Ex de	II C	T4	II 2 G	IP 68
7	ABV27-105-PI-2721	J	Manometer presioni (Pressure Gauge)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0027-856	BVS-0027-856-01	ABV27-C10766-105-P-DPE-0001	ZONE 2	WIKA	233.30.100	8970BHY7	Ex c	II	T6	II 2 G	IP 65
8	ABV27-105-PI-2731	J	Manometer presioni (Pressure Gauge)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0027-856	BVS-0027-856-01	ABV27-C10766-105-P-DPE-0001	ZONE 2	WIKA	233.30.100	8970BHY8	Ex c	II	T6	II 2 G	IP 65
9	ABV27-105-PIT-2722	J	Transmetues presioni(Pressure Transmitter)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0027-856	BVS-0027-856-01	ABV27-C10766-105-M-DAA-0001	ZONE 2	YOKOGAWA	EJA530E	91T218289	Ex ia	II C	T4	II 2 G	IP 66/67
10	ABV27-105-PIT-2732	J	Transmetues presioni(Pressure Transmitter)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0027-856	BVS-0027-856-01	ABV27-C10766-105-M-DAA-0001	ZONE 2	YOKOGAWA	EJA530E	91T218290	Ex ia	II C	T4	II 2 G	IP 66/67
11	ABV27-105-ZS-2710	J	Celes fundor (Position Switch Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0027-856	BVS-0027-856-01	ABV27-C10766-105-P-DPE-0001	ZONE 2	EUROTEC	EAE 2103-73-IA-DAE	N/A	Ex ia	II C	T6	II 2 G	IP 67
12	ABV27-105-ZS-2720	J	Celes fundor (Position Switch Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0027-856	BVS-0027-856-01	ABV27-C10766-105-P-DPE-0001	ZONE 2	EUROTEC	EVE 2102-579-IA	N/A	Ex ia	II C	T6	II 2 G	IP 67
13	ABV27-105-ZS-2730	J	Celes fundor (Position Switch Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0027-856	BVS-0027-856-01	ABV27-C10766-105-P-DPE-0001	ZONE 2	EUROTEC	EAE 2103-73-IA-DAE	N/A	Ex ia	II C	T6	II 2 G	IP 67
14	ABV27-105-ZS-2740	J	Celes fundor (Position Switch Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0027-856	BVS-0027-856-01	ABV27-C10766-105-P-DPE-0001	ZONE 2	EUROTEC	EVE 2102-579-IA	N/A	Ex ia	II C	T6	II 2 G	IP 67
15	ABV27-826-EPL-0001	E	Ndricues emergjence (Emergency Portable Light)	STATION ELECTRICAL INSTALLATION	BVS-0027-826	BVS-0027-826-01	ABV27-C10766-105-E-DQH-0001	ZONE 2	WOLFLITE	WOLFLITE XT-50	N/A	Ex ib	II C	T4	II 2 G	IP 67
16	ABV27-840-CZ-0001	E	Ndares shkendine (Spark Gap)	EARTHING & LIGHTING PROTECTION	BVS-0027-840	BVS-0027-840-01	ABV27-C10766-105-M-DAA-0001	ZONE 2	LEUTRON	TC 500 A	N/A	Ex mb	II C	T4	II 2 G	IP 67
17	ABV27-856-EJE-J-0001	E	Kuti Shperndarese (Junction Box)	EARTHING & LIGHTING PROTECTION	BVS-0027-826	BVS-0027-826-01	ABV27-C10766-105-M-DAA-0001	ZONE 2	THERMON	ZL-WP	N/A	Ex e	II	T4-T6	II 2 G	IP 66
18	ABV27-856-EJE-J-0002	E	Kuti Shperndarese (Junction Box)	EARTHING & LIGHTING PROTECTION	BVS-0027-826	BVS-0027-826-01	ABV27-C10766-105-M-DAA-0001	ZONE 2	THERMON	ZL-WP	N/A	Ex e	II	T4-T6	II 2 G	IP 66
19	ABV27-856-EJE-J-0003	E	Kuti Shperndarese (Junction Box)	EARTHING & LIGHTING PROTECTION	BVS-0027-826	BVS-0027-826-01	ABV27-C10766-105-M-DAA-0001	ZONE 2	ASP	ESX2212B	17/1587.6.10	Ex e	II C	T5	II 2 G	IP 66
20	ABV27-856-EJE-J-0004	E	Kuti Shperndarese (Junction Box)	EARTHING & LIGHTING PROTECTION	BVS-0027-826	BVS-0027-826-01	ABV27-C10766-105-M-DAA-0001	ZONE 2	ASP	ESX2212B	17/1587.7.9	Ex e	II C	T5	II 2 G	IP 66
21	ABV27-856-ERQ-0001	E	Prize (Power Socket) Vent Stack Valve Actuator	ELECTRICAL POWER DISTRIBUTION	BVS-0027-820	BVS-0027-820-01	ABV27-C10766-105-M-DAA-0001	SAFE AREA	FEAM	CPSC 438-25A	16/1626/12	Ex d	II C	T5	II 2 G	IP 66/67
22	ABV27-856-HE-0001	E	Ngrohes (Standard Heating)	STATION ELECTRICAL INSTALLATION	BVS-0027-826	BVS-0027-826-01	CBV00-SPI-105-J-DJH-0001	ZONE 2	INTERTEC	DPA 200 T3 TS	82113/17	Ex d m	II C	T3	II 2 G	IP 65
23	ABV27-856-HE-0002	E	Ngrohes (Standard Heating)	STATION ELECTRICAL INSTALLATION	BVS-0027-826	BVS-0027-826-01	CBV00-SPI-105-J-DJH-0001	ZONE 2	INTERTEC	DPA 200 T3 TS	82102/17	Ex d m	II C	T3	II 2 G	IP 65
ABV28																
1	ABV28-105-JB-0001	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0028-856	BVS-0028-856-01	ABV28-C10766-105-M-DAA-0001	ZONE 2	ASP	ESX2216A	17/1587.1.10	Ex e ia	II B/II C	T5	II 2 G	IP 66
2	ABV28-105-JB-0002	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0028-856	BVS-0028-856-01	ABV28-C10766-105-M-DAA-0001	SAFE AREA	ASP	ESX2216A	17/1587.3.9	Ex e ia	II B/II C	T5	II 2 G	IP 66

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrimi	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
3	ABV28-105-JB-0003	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0028-856	BVS-0028-856-01	ABV28-C10766-105-M-DAA-0001	ZONE 2	ASP	ESX3322B	17/1587.2.16	Ex e ia	II B/II C	T5	II 2 G	IP 66
4	ABV28-105-JB-0011	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0028-856	BVS-0028-856-01	ABV28-C10766-105-M-DAA-0001	SAFE AREA	STAHL	8150/5-0176-0116-091-2311	1714724050440015	Ex de	II C	T6	II 2 G	IP 66
5	ABV28-105-JB-0012	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0028-856	BVS-0028-856-01	ABV28-C10766-105-M-DAA-0001	SAFE AREA	STAHL	8150/5-0176-0116-091-2311	1714724060440008	Ex de	II C	T6	II 2 G	IP 66
6	ABV28-105-MOB-2810-M	E	Motor Operated Ball Valve Actuator	ELECTRICAL POWER DISTRIBUTION	BVS-0028-820	BVS-0028-820-01	ABV28-C10766-105-M-DAA-0001	ZONE 2	AUMA	SAEX 14.6-F14	3616MD93331	Ex de	II C	T4	II 2 G	IP 68
7	ABV28-105-PI-2821	J	Manometer presioni (Pressure Gauge)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0028-856	BVS-0028-856-01	ABV28-C10766-105-P-DPE-0001	ZONE 2	WIKA	233.30.100	8970BHY9	Ex c	II	T6	II 2 G	IP 65
8	ABV28-105-PI-2831	J	Manometer presioni (Pressure Gauge)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0028-856	BVS-0028-856-01	ABV28-C10766-105-P-DPE-0001	ZONE 2	WIKA	233.30.100	8970BHVA	Ex c	II	T6	II 2 G	IP 65
9	ABV28-105-PIT-2822	J	Transmetues presioni(Pressure Transmitter)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0028-856	BVS-0028-856-01	ABV28-C10766-105-M-DAA-0001	ZONE 2	YOKOGAWA	EJA530E	91T218291	Ex ia	II C	T4	II 2 G	IP 66/67
10	ABV28-105-PIT-2832	J	Transmetues presioni(Pressure Transmitter)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0028-856	BVS-0028-856-01	ABV28-C10766-105-M-DAA-0001	ZONE 2	YOKOGAWA	EJA530E	91T218292	Ex ia	II C	T4	II 2 G	IP 66/67
11	ABV28-105-ZS-2810	J	Celes fundor (Position Switch Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0028-856	BVS-0028-856-01	ABV28-C10766-105-P-DPE-0001	ZONE 2	EUROTEC	EAE 2103-73-IA-DAE	N/A	Ex ia	II C	T6	II 2 G	IP 67
12	ABV28-105-ZS-2820	J	Celes fundor (Position Switch Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0028-856	BVS-0028-856-01	ABV28-C10766-105-P-DPE-0001	ZONE 2	EUROTEC	EAE 2103-73-IA-DAE	N/A	Ex ia	II C	T6	II 2 G	IP 67
13	ABV28-105-ZS-2830	J	Celes fundor (Position Switch Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0028-856	BVS-0028-856-01	ABV28-C10766-105-P-DPE-0001	ZONE 2	EUROTEC	EVE 2102-579-IA	N/A	Ex ia	II C	T6	II 2 G	IP 67
14	ABV28-105-ZS-2840	J	Celes fundor (Position Switch Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0028-856	BVS-0028-856-01	ABV28-C10766-105-P-DPE-0001	ZONE 2	EUROTEC	EVE 2102-579-IA	N/A	Ex ia	II C	T6	II 2 G	IP 67
15	ABV28-826-EPL-0001	E	Ndricues emergjence (Emergency Portable Light)	STATION ELECTRICAL INSTALLATION	BVS-0028-826	BVS-0028-826-01	ABV28-C10766-105-E-DQH-0001	ZONE 2	WOLFLITE	WOLFLITE XT-50	N/A	Ex ib	II C	T4	II 2 G	IP 67
16	ABV28-840-CZ-0001	E	Ndares shkendine (Spark Gap)	EARTHING & LIGHTING PROTECTION	BVS-0028-840	BVS-0028-840-01	ABV28C10766-105-M-DAA-0001	ZONE 2	LEUTRON	TC 500 A	44576-004	Ex mb	II C	T4	II 2 G	IP 67
17	ABV28-856-EJE-J-0001	E	Kuti Shperndarese (Junction Box)	EARTHING & LIGHTING PROTECTION	BVS-0028-826	BVS-0028-826-01	ABV28C10766-105-M-DAA-0001	ZONE 2	THERMON	ZL-WP	N/A	Ex e	II	T4-T6	II 2 G	IP 66
18	ABV28-856-EJE-J-0002	E	Kuti Shperndarese (Junction Box)	EARTHING & LIGHTING PROTECTION	BVS-0028-826	BVS-0028-826-01	ABV28C10766-105-M-DAA-0001	ZONE 2	THERMON	ZL-WP	N/A	Ex e	II	T4-T6	II 2 G	IP 66
19	ABV28-856-EJE-J-0003	E	Kuti Shperndarese (Junction Box)	EARTHING & LIGHTING PROTECTION	BVS-0028-826	BVS-0028-826-01	ABV28C10766-105-M-DAA-0001	ZONE 2	ASP	ESX2212B	17/1587.6.9	Ex e	II C	T5	II 2 G	IP 66
20	ABV28-856-EJE-J-0004	E	Kuti Shperndarese (Junction Box)	EARTHING & LIGHTING PROTECTION	BVS-0028-826	BVS-0028-826-01	ABV28C10766-105-M-DAA-0001	ZONE 2	ASP	ESX2212B	17/1587.7.10	Ex e	II C	T5	II 2 G	IP 66
21	ABV28-856-ERQ-0001	E	Prize (Power Socket) Vent Stack Valve Actuator	ELECTRICAL POWER DISTRIBUTION	BVS-0028-820	BVS-0028-820-01	ABV28C10766-105-M-DAA-0001	SAFE AREA	FEAM	CPSC 438-25A	18/2332/07	Ex d	II C	T5	II 2 G	IP 66/67
22	ABV28-856-HE-0001	E	Ngrohes (Standard Heating)	STATION ELECTRICAL INSTALLATION	BVS-0028-826	BVS-0028-826-01	CBV00-SPI-105-J-DJH-0001	ZONE 2	INTERTEC	DPA 200 T3 TS	82103/17	Ex d m	II C	T3	II 2 G	IP 65
23	ABV28-856-HE-0002	E	Ngrohes (Standard Heating)	STATION ELECTRICAL INSTALLATION	BVS-0028-826	BVS-0028-826-01	CBV00-SPI-105-J-DJH-0001	ZONE 2	INTERTEC	DPA 200 T3 TS	82121/17	Ex d m	II C	T3	II 2 G	IP 65

ABV29

1	ABV29-105-JB-0001	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0029-856	BVS-0029-856-01	ABV29-C10766-105-M-DAA-0001	ZONE 2	ASP	ESX2216A	17/1587.3.16	Ex e ia	II B/II C	T5	II 2 G	IP 66
2	ABV29-105-JB-0002	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0029-856	BVS-0029-856-01	ABV29-C10766-105-M-DAA-0001	SAFE AREA	ASP	ESX2216A	17/1587.3.15	Ex e ia	II B/II C	T5	II 2 G	IP 66
3	ABV29-105-JB-0003	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0029-856	BVS-0029-856-01	ABV29-C10766-105-M-DAA-0001	ZONE 2	ASP	ESX3322B	17/1587.2.10	Ex e ia	II B/II C	T5	II 2 G	IP 66
4	ABV29-105-JB-0011	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0029-856	BVS-0029-856-01	ABV29-C10766-105-M-DAA-0001	SAFE AREA	STAHL	8150/5-0176-0116-091-2311	1714724050440012	Ex de	II C	T6	II 2 G	IP 66
5	ABV29-105-JB-0012	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0029-856	BVS-0029-856-01	ABV29-C10766-105-M-DAA-0001	SAFE AREA	STAHL	8150/5-0176-0116-091-2311	1714724060440009	Ex de	II C	T6	II 2 G	IP 66
6	ABV29-105-MOB-2910-M	E	Motor Operated Ball Valve Actuator	ELECTRICAL POWER DISTRIBUTION	BVS-0029-820	BVS-0029-820-01	ABV29-C10766-105-M-DAA-0001	ZONE 2	AUMA	SAEX 14.6-F14	3216MD87236	Ex de	II C	T4	II 2 G	IP 68
7	ABV29-105-PI-2921	J	Manometer presioni (Pressure Gauge)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0029-856	BVS-0029-856-01	ABV29-C10766-105-P-DPE-0001	ZONE 2	WIKA	233.30.100	8970BHYB	Ex c	II	T6	II 2 G	IP 65
8	ABV29-105-PI-2931	J	Manometer presioni (Pressure Gauge)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0029-856	BVS-0029-856-01	ABV29-C10766-105-P-DPE-0001	ZONE 2	WIKA	233.30.100	8970BHYC	Ex c	II	T6	II 2 G	IP 65
9	ABV29-105-PIT-2922	J	Transmetues presioni(Pressure Transmitter)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0029-856	BVS-0029-856-01	ABV29-C10766-105-M-DAA-0001	ZONE 2	YOKOGAWA	EJA530E	91T218293	Ex ia	II C	T4	II 2 G	IP 66/67
10	ABV29-105-PIT-2932	J	Transmetues presioni(Pressure Transmitter)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0029-856	BVS-0029-856-01	ABV29-C10766-105-M-DAA-0001	ZONE 2	YOKOGAWA	EJA530E	91T218294	Ex ia	II C	T4	II 2 G	IP 66/67
11	ABV29-105-ZS-2910	J	Celes fundor (Position Switch Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0029-856	BVS-0029-856-01	ABV29-C10766-105-P-DPE-0001	ZONE 2	EUROTEC	EAE 2103-73-IA-DAE	N/A	Ex ia	II C	T6	II 2 G	IP 67
12	ABV29-105-ZS-2920	J	Celes fundor (Position Switch Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0029-856	BVS-0029-856-01	ABV29-C10766-105-P-DPE-0001	ZONE 2	EUROTEC	EVE 2102-579-IA	N/A	Ex ia	II C	T6	II 2 G	IP 67
13	ABV29-105-ZS-2930	J	Celes fundor (Position Switch Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0029-856	BVS-0029-856-01	ABV29-C10766-105-P-DPE-0001	ZONE 2	EUROTEC	EVE 2102-579-IA	N/A	Ex ia	II C	T6	II 2 G	IP 67
14	ABV29-105-ZS-2940	J	Celes fundor (Position Switch Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0029-856	BVS-0029-856-01	ABV29-C10766-105-P-DPE-0001	ZONE 2	EUROTEC	EVE 2102-579-IA	N/A	Ex ia	II C	T6	II 2 G	IP 67
15	ABV29-826-EPL-0001	E	Ndricues emergjence (Emergency Portable Light)	STATION ELECTRICAL INSTALLATION	BVS-0029-826	BVS-0029-826-01	ABV29-C10766-105-E-DQH-0001	ZONE 2	WOLFLITE	WOLFLITE XT-50	N/A	Ex ib	II C	T4	II 2 G	IP 67
16	ABV29-840-CZ-0001	E	Ndares shkendine (Spark Gap)	EARTHING & LIGHTING PROTECTION	BVS-0029-840	BVS-0029-840-01	ABV29C10766-105-M-DAA-0001	ZONE 2	LEUTRON	TC 500 A	44646-004	Ex mb	II C	T4	II 2 G	IP 67
17	ABV29-856-EJE-J-0001	E	Kuti Shperndarese (Junction Box)	EARTHING & LIGHTING PROTECTION	BVS-0029-826	BVS-0029-826-01	ABV29C10766-105-M-DAA-0001	ZONE 2	THERMON	ZL-WP	N/A	Ex e	II	T4-T6	II 2 G	IP 66
18	ABV29-856-EJE-J-0002	E	Kuti Shperndarese (Junction Box)	EARTHING & LIGHTING PROTECTION	BVS-0029-826	BVS-0029-826-01	ABV29C10766-105-M-DAA-0001	ZONE 2	THERMON	ZL-WP	N/A	Ex e	II	T4-T6	II 2 G	IP 66
19	ABV29-856-EJE-J-0003	E	Kuti Shperndarese (Junction Box)	EARTHING & LIGHTING PROTECTION	BVS-0029-826	BVS-0029-826-01	ABV29C10766-105-M-DAA-0001	ZONE 2	ASP	ESX2212B	17/1587.7.17	Ex e	II C	T5	II 2 G	IP 66
20	ABV29-856-EJE-J-0004	E	Kuti Shperndarese (Junction Box)	EARTHING & LIGHTING PROTECTION	BVS-0029-826	BVS-0029-826-01	ABV29C10766-105-M-DAA-0001	ZONE 2	ASP	ESX2212B	17/1587.6.11	Ex e	II C	T5	II 2 G	IP 66
21	ABV29-856-ERQ-0001	E	Prize (Power Socket) Vent Stack Valve Actuator	ELECTRICAL POWER DISTRIBUTION	BVS-0029-820	BVS-0029-820-01	ABV29C10766-105-M-DAA-0001	SAFE AREA	FEAM	CPSC 438-25A	16/1626/12	Ex d	II C	T5	II 2 G	IP 66/67
22	ABV29-856-HE-0001	E	Ngrohes (Standard Heating)	STATION ELECTRICAL INSTALLATION	BVS-0029-826	BVS-0029-826-01	CBV00-SPI-105-J-DJH-0001	ZONE 2	INTERTEC	DPA 200 T3 TS	82090/17	Ex d m	II C	T3	II 2 G	IP 65
23	ABV29-856-HE-0002	E	Ngrohes (Standard Heating)	STATION ELECTRICAL INSTALLATION	BVS-0029-826	BVS-0029-826-01	CBV00-SPI-105-J-DJH-0001	ZONE 2	INTERTEC	DPA 200 T3 TS	82091/17	Ex d m	II C	T3	II 2 G	IP 65

ABV30

1	ABV30-105-JB-0001	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0030-856	BVS-0030-856-01	ABV30-C01766-105-E-DEA-0001	ZONE 2	ASP	ESX2216A	17/1587.7.14	Ex e ia	II B/II C	T5	II 2 G	IP 66
2	ABV30-105-JB-0002	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0030-856	BVS-0030-856-01	ABV30-C01766-105-E-DEA-0001	SAFE AREA	ASP	ESX2216A	17/1587.3.10	Ex e ia	II B/II C	T5	II 2 G	IP 66
3	ABV30-105-JB-0003	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0030-856	BVS-0030-856-01	ABV30-C01766-105-E-DEA-0001	ZONE 2	ASP	EXS3322B	18/2392.1.3	Ex e ia	II B/II C	T5	II 2 G	IP 66
4	ABV30-105-JB-0011	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0030-856	BVS-0030-856-01	ABV30-C01766-105-E-DEA-0001	SAFE AREA	STAHL	1.71472E+15	8150/5-0176-0116-091-2311	Ex e	II	T6	II 2 G	IP 66
5	ABV30-105-JB-0012	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0030-856	BVS-0030-856-01	ABV30-C01766-105-E-DEA-0001	SAFE AREA	STAHL	8150/5-0176-0116-091-2311	1714724060440000	Ex de	II C	T6	II 2 G	IP 66
6	ABV30-105-MOB-3010-M	E	Motor Operated Ball Valve Actuator	ELECTRICAL POWER DISTRIBUTION	BVS-0030-820	BVS-0030-820-01	ABV30-C01766-105-E-DEA-0001	ZONE 2	AUMA		3216MD87237	Ex de	II C	T4	II 2 G	IP 68

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrimi	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
7	ABV30-105-MOB-3060-M	E	Motor Operated Ball Valve Actuator	ELECTRICAL POWER DISTRIBUTION	BVS-0030-820	BVS-0030-820-01	ABV30-C01766-105-E-DEA-0001	ZONE 2	AUMA	SAEX 14.2-F14	3518MD52284	Ex de	II C	T4	II 2 G	IP 68
8	ABV30-105-PI-3021	J	Manometer presioni (Pressure Gauge)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0030-856	BVS-0030-856-01	ABV30-C01766-105-E-DEA-0001	ZONE 2	WIKA	233.30.600 100 bar	8970BHYD	Ex c	II	T6	II 2 G	IP 65
9	ABV30-105-PI-3031	J	Manometer presioni (Pressure Gauge)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0030-856	BVS-0030-856-01	ABV30-C01766-105-E-DEA-0001	ZONE 2	WIKA	233.30.600 100 bar	8970BHYE	Ex c	II	T6	II 2 G	IP 65
10	ABV30-105-PIT-3022	J	Transmetues presioni(Pressure Transmitter)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0030-856	BVS-0030-856-01	ABV30-C01766-105-E-DEA-0001	ZONE 2	YOKOGAWA	EJA530E-JCS8N-019EL/KU22/A/T07/M15	91T218295	Ex ia	II C	T4	II 2 G	IP 66/67
11	ABV30-105-PIT-3032	J	Transmetues presioni(Pressure Transmitter)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0030-856	BVS-0030-856-01	ABV30-C01766-105-E-DEA-0001	ZONE 2	YOKOGAWA	EJA530E-JCS8N-019EL/KU22/A/T07/M15	91T218296	Ex ia	II C	T4	II 2 G	IP 66/67
12	ABV30-105-ZS-3010	J	Celes fundor (Position Switch Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0030-856	BVS-0030-856-01	ABV30-C01766-105-E-DEA-0001	ZONE 2	EUROTEC	EAE 2103-73-IA-DAE	2016-89800	Ex ia	II C	T6	II 2 G	IP 67
13	ABV30-105-ZS-3020	J	Celes fundor (Position Switch Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0030-856	BVS-0030-856-01	ABV30-C01766-105-E-DEA-0001	ZONE 2	EUROTEC	EVE 2102-579-IA	2015-89433	Ex ia	II C	T6	II 2 G	IP 67
14	ABV30-105-ZS-3030	J	Celes fundor (Position Switch Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0030-856	BVS-0030-856-01	ABV30-C01766-105-E-DEA-0001	ZONE 2	EUROTEC	EVE 2102-579-IA	2015-89433	Ex ia	II C	T6	II 2 G	IP 67
15	ABV30-105-ZS-3040	E	Celes fundor (Position Switch Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0030-856	BVS-0030-856-01	ABV30-C01766-105-E-DEA-0001	ZONE 2	EUROTEC	EVE 2102-579-IA	2016-89500	Ex ia	II C	T6	II 2 G	IP 67
16	ABV30-105-ZS-3060	E	Celes fundor (Position Switch Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0030-856	BVS-0030-856-01	ABV30-C01766-105-E-DEA-0001	ZONE 2	EUROTEC	EVE 2102-579-IA	N/A	Ex ia	II C	T6	II 2 G	IP 67
17	ABV30-826-EPL-0001	E	Ndricues emergjence (Emergency Portable Light)	STATION ELECTRICAL INSTALLATION	BVS-0030-826	BVS-0030-826-01	ABV30-C01766-105-E-DEA-0001	ZONE 2	WOLFLITE	WOLFLITE XT-50	N/A	Ex ib	II C	T4	II 2 G	IP 67
18	ABV30-840-CZ-0001	E	Ndares shkendine (Spark Gap)	EARTHING & LIGHTING PROTECTION	BVS-0030-840	BVS-0030-840-01	ABV30-C01766-105-E-DEA-0001	ZONE 2	LEUTRON	TCRUC-DC	1700 923131	Ex mb	II C	T4	II 2 G	IP 66/67
19	ABV30-856-EJE-J-0001	E	Kuti Shperndarese (Junction Box)	EARTHING & LIGHTING PROTECTION	BVS-0030-840	BVS-0030-840-01	ABV30-C01766-105-E-DEA-0001	ZONE 2	THERMON	ZL-WP	N/A	Ex e	II	T4-T6	II 2 G	IP 66
20	ABV30-856-EJE-J-0002	E	Kuti Shperndarese (Junction Box)	EARTHING & LIGHTING PROTECTION	BVS-0030-840	BVS-0030-840-01	ABV30-C01766-105-E-DEA-0001	ZONE 2	THERMON	ZL-WP	N/A	Ex e	II	T4-T6	II 2 G	IP 66
21	ABV30-856-EJE-J-0003	E	Kuti Shperndarese (Junction Box)	EARTHING & LIGHTING PROTECTION	BVS-0030-840	BVS-0030-840-01	ABV30-C01766-105-E-DEA-0001	ZONE 2	ASP	ESX2212B	17/1587.7.11	Ex e	II C	T5	II 2 G	IP 66
22	ABV30-856-EJE-J-0004	E	Kuti Shperndarese (Junction Box)	EARTHING & LIGHTING PROTECTION	BVS-0030-840	BVS-0030-840-01	ABV30-C01766-105-E-DEA-0001	ZONE 2	ASP	ESX2212B	17/1587617	Ex e	II C	T5	II 2 G	IP 66
23	ABV30-856-ERQ-0001	E	Prize (Power Socket) Vent Stack Valve Actuator	ELECTRICAL POWER DISTRIBUTION	BVS-0030-840	BVS-0030-840-01	ABV30-C01766-105-E-DEA-0001	ZONE 2	FEAM	CPSC 438-25A	18/2332107	Ex d	II C	T6	II 2 G	IP 66/67
24	ABV30-856-HE-0001	E	Ngrohes (Standard Heating)	STATION ELECTRICAL INSTALLATION	BVS-0030-826	BVS-0030-826-01	ABV30-C01766-105-E-DEA-0001	ZONE 2	INTERTEC	DPA 200 T3 TS	82090/17	Ex d m	II C	T3	II 2 G	IP 65
25	ABV30-856-HE-0002	E	Ngrohes (Standard Heating)	STATION ELECTRICAL INSTALLATION	BVS-0030-826	BVS-0030-826-01	ABV30-C01766-105-E-DEA-0001	ZONE 2	INTERTEC	DPA 200 T3 TS	82091/17	Ex d m	II C	T3	II 2 G	IP 65

ABV31

1	ABV31-105-JB-0001	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0031-856	BVS-0031-856-01	ABV31-C01766-105-E-DEA-0001	ZONE 2	ASP	ESX2216A	17/1587.1.15	Ex e ia	II B/II C	T5	II 2 G	IP 66
2	ABV31-105-JB-0002	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0031-856	BVS-0031-856-01	ABV31-C01766-105-E-DEA-0001	SAFE AREA	ASP	ESX2216A	17/1587.3.14	Ex e ia	II B/II C	T5	II 2 G	IP 66
3	ABV31-105-JB-0003	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0031-856	BVS-0031-856-01	ABV31-C01766-105-E-DEA-0001	ZONE 2	ASP	ESX3322B	17/1587.2.15	Ex e ia	II B/II C	T5	II 2 G	IP 66
4	ABV31-105-JB-0011	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0031-856	BVS-0031-856-01	ABV31-C01766-105-E-DEA-0001	SAFE AREA	STAHL	8150/5-0176-0116-091-2311	1714724050440000	Ex de	II C	T6	II 2 G	IP 66
5	ABV31-105-JB-0012	J	Kuti Shperndarese (Junction Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0031-856	BVS-0031-856-01	ABV31-C01766-105-E-DEA-0001	SAFE AREA	STAHL	8150/5-0176-0116-091-2311	1714724060440000	Ex de	II C	T6	II 2 G	IP 66
6	ABV31-105-MOB-3110-M	E	Motor Operated Ball Valve Actuator	ELECTRICAL POWER DISTRIBUTION	BVS-0031-820	BVS-0031-820-01	ABV31-C01766-105-E-DEA-0001	ZONE 2	AUMA	SAEX 14.6-F14-Q3 Q1	3216	Ex de	II C	T4	II 2 G	IP 68
7	ABV31-105-PI-3121	J	Manometer presioni (Pressure Gauge)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0031-856	BVS-0031-856-01	ABV31-C01766-105-E-DEA-0001	ZONE 2	WIKA	233.30.160.100	8970BHYF	Ex c	II	T6	II 2 G	IP 65
8	ABV31-105-PI-3131	J	Manometer presioni (Pressure Gauge)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0031-856	BVS-0031-856-01	ABV31-C01766-105-E-DEA-0001	ZONE 2	WIKA	233.30.160.100	8970BHYG	Ex c	II	T6	II 2 G	IP 65
9	ABV31-105-PIT-3122	J	Transmetues presioni(Pressure Transmitter)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0031-856	BVS-0031-856-01	ABV31-C01766-105-E-DEA-0001	ZONE 2	YOKOGAWA	EJA530E-JCS8N-019EL/KU22/A/T07/M15	91T218297	Ex ia	II C	T4	II 2 G	IP 66/67
10	ABV31-105-PIT-3132	J	Transmetues presioni(Pressure Transmitter)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0031-856	BVS-0031-856-01	ABV31-C01766-105-E-DEA-0001	ZONE 2	YOKOGAWA	EJA530E-JCS8N-019EL/KU22/A/T07/M15	91T218298	Ex ia	II C	T4	II 2 G	IP 66/67
11	ABV31-105-ZS-3110	J	Celes fundor (Position Switch Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0031-856	BVS-0031-856-01	ABV31-C01766-105-E-DEA-0001	ZONE 2	EUROTEC	EAE 2103-73-IA-DAE	N/A	Ex ia	II C	T6	II 2 G	IP 66 / 68
12	ALV31-105-ZS-3120	J	Celes fundor (Position Switch Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0032-856	BVS-0032-856-01	ALV32-C01766-105-E-DEA-0001	ZONE 2	EUROTEC	EVE 2102-579-IA	N/A	Ex ia	II C	T6	II 2 G	IP 66 / 68
13	ALV31-105-ZS-3130	J	Celes fundor (Position Switch Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0032-856	BVS-0032-856-01	ALV32-C01766-105-E-DEA-0001	ZONE 2	EUROTEC	EVE 2102-579-IA	N/A	Ex ia	II C	T6	II 2 G	IP 66 / 68
14	ALV31-105-ZS-3140	J	Celes fundor (Position Switch Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0032-856	BVS-0032-856-01	ALV32-C01766-105-E-DEA-0001	ZONE 2	EUROTEC	EVE 2102-579-IA	N/A	Ex ia	II C	T6	II 2 G	IP 67
15	ALV31-826-EPL-0001	E	Ndricues emergjence (Emergency Portable Light)	STATION ELECTRICAL INSTALLATION	BVS-0032-826	BVS-0032-826-01	ALV32-C01766-105-E-DEA-0001	ZONE 2	WOLFLITE	WOLFLITE XT-50	N/A	Ex ib	II C	T4	II 2 G	IP 67
16	ALV31-840-CZ-0001	E	Ndares shkendine (Spark Gap)	EARTHING & LIGHTING PROTECTION	BVS-0032-840	BVS-0032-840-01	ALV32-C01766-105-E-DEA-0001	ZONE 2	LEUTRON	TC 500 A	44646-002	Ex mb	II C	T4	II 2 G	IP 67
17	ALV31-856-EJE-J-0001	E	Kuti Shperndarese (Junction Box)	STATION ELECTRICAL INSTALLATION	BVS-0032-826	BVS-0032-826-01	ALV32-C01766-105-E-DEA-0001	ZONE 2	THERMON	2L PN 27653	N/A	Ex e	II	T4-T6	II 2 G	IP 66
18	ALV31-856-EJE-J-0002	E	Kuti Shperndarese (Junction Box)	STATION ELECTRICAL INSTALLATION	BVS-0032-826	BVS-0032-826-01	ALV32-C01766-105-E-DEA-0001	ZONE 2	THERMON	2L PN 27653	N/A	Ex e	II	T4-T6	II 2 G	IP 66
19	ALV31-856-EJE-J-0003	E	Kuti Shperndarese (Junction Box)	STATION ELECTRICAL INSTALLATION	BVS-0032-826	BVS-0032-826-01	ALV32-C01766-105-E-DEA-0001	ZONE 2	ASP	ESX2212B	17/1587.6.13	Ex e	II C	T5	II 2 G	IP 66
20	ALV31-856-EJE-J-0004	E	Kuti Shperndarese (Junction Box)	STATION ELECTRICAL INSTALLATION	BVS-0032-826	BVS-0032-826-01	ALV32-C01766-105-E-DEA-0001	ZONE 2	ASP	ESX2212B	19/2632.7.15	Ex e	II C	T5	II 2 G	IP 66
21	ALV31-856-ERQ-0001	E	Prize (Power Socket) Vent Stack Valve Actuator	ELECTRICAL POWER DISTRIBUTION	BVS-0032-820	BVS-0032-820-01	ALV32-C01766-105-E-DEA-0001	ZONE 2	FEAM	CPSC-438-25A	16/1626/12	Ex d	II C	T5	II 2 G	IP 66/67
22	ALV31-856-HE-0001	E	Ngrohes (Standard Heating)	STATION ELECTRICAL INSTALLATION	BVS-0032-826	BVS-0032-826-01	ALV32-C01766-105-E-DEA-0001	ZONE 2	INTERTEC	DPA 200 T3 TS	82094/17	Ex d m	II C	T3	II 2 G	IP 65
23	ALV31-856-HE-0002	E	Ngrohes (Standard Heating)	STATION ELECTRICAL INSTALLATION	BVS-0032-826	BVS-0032-826-01	ALV32-C01766-105-E-DEA-0001	ZONE 2	INTERTEC	DPA 200 T3 TS	82095/17	Ex d m	II C	T3	II 2 G	IP 65

ALV32

1	ALV32-105-JB-0001	J	Junction Box	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0031-856	BVS-0031-856-01	ABV31-C01766-105-E-DEA-0001	ZONE 2	ASP	ESX2216A	17/1587.1.17	Ex e ia	II B/II C	T5	II 2 G	IP 66
2	ALV32-105-JB-0002	J	Junction Box	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0031-856	BVS-0031-856-01	ABV31-C01766-105-E-DEA-0002	SAFE AREA	ASP	ESX2216A	17/1587.3.11	Ex e ia	II B/II C	T5	II 2 G	IP 66
3	ALV32-105-JB-0003	J	Junction Box	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0031-856	BVS-0031-856-01	ABV31-C01766-105-E-DEA-0003	ZONE 2	ASP	ESX3322B	17/1587.2.13	Ex e ia	II B/II C	T5	II 2 G	IP 66
4	ALV32-105-PI-3221	J	Manometer presioni (Pressure Gauge)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0031-856	BVS-0031-856-01	ABV31-C01766-105-E-DEA-0001	ZONE 2	WIKA	233.30.160.100	8970BHYI	Ex c	II	T6	II 2 G	IP 65
5	ALV32-105-PI-3231	J	Manometer presioni (Pressure Gauge)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0031-856	BVS-0031-856-01	ABV31-C01766-105-E-DEA-0001	ZONE 2	WIKA	233.30.160.100	8970BHYL	Ex c	II	T6	II 2 G	IP 65
6	ALV32-105-PIT-3222	J	Transmetues presioni(Pressure Transmitter)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0031-856	BVS-0031-856-01	ABV31-C01766-105-E-DEA-0001	ZONE 2	YOKOGAWA	EJA530E-JCS8N-019EL/KU22/A/T07/M15	91VB26278	Ex ia	II C	T4	II 2 G	IP 66/67
7	ALV32-105-PIT-3232	J	Transmetues presioni(Pressure Transmitter)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0031-856	BVS-0031-856-01	ABV31-C01766-105-E-DEA-0001	ZONE 2	YOKOGAWA	EJA530E-JCS8N-019EL/KU22/A/T07/M15	91T218300	Ex ia	II C	T4	II 2 G	IP 66/67
8	ALV32-105-ZS-3220	J	Celes fundor (Position Switch Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0032-856	BVS-0032-856-01	ALV32-C01766-105-E-DEA-0001	ZONE 2	EUROTEC	EVE 2102-579-IA	2016-89543	Ex ia	II C	T6	II 2 G	IP 66 / 68

Njesite	Numri I Paisjes	Disiplina	Te dhena/Pershkrime	Pershkrimi I Sistemit	Sistemi	Nen sistemi	Numri I Vizatimit	Zona	Prodhuesi	Modeli/Lloji	Numri Serial	Lloji I Mbrojtjes	Grupi I gazit	Klasi I Temperatures	Kodi ATEX	IP
9	ALV32-105-ZS-3230	J	Celes fundor (Position Switch Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0032-856	BVS-0032-856-01	ALV32-C01766-105-E-DEA-0001	ZONE 2	EUROTEC	EVE 2102-579-IA	2016-89543	Ex ia	II C	T6	II 2 G	IP 66 / 68
10	ALV32-105-ZS-3240	J	Celes fundor (Position Switch Box)	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0032-856	BVS-0032-856-01	ALV32-C01766-105-E-DEA-0001	ZONE 2	EUROTEC	EVE 2102-579-IA	2016-89543	Ex ia	II C	T6	II 2 G	IP 67
11	ALV32-105-YOB-3210-1	J	Junction Box	PROCESS CONTROL & SHUTDOWN SYSTEM	BVS-0032-856	BVS-0032-856-01	ALV32-C01766-105-E-DEA-0001	ZONE 2	Antideflagerant Service	N/A	200802	Ex e	II C	T6	II 2 G	IP 66
12	ALV32-856-EJE-J-0001	E	Kuti Shperndarese (Junction Box)	STATION ELECTRICAL INSTALLATION	BVS-0032-826	BVS-0032-826-01	ALV32-C01766-105-E-DEA-0001	ZONE 2	THERMON	2L PN 27653	N/A	Ex e	II	T4-T6	II 2 G	IP 66
13	ALV32-856-EJE-J-0002	E	Kuti Shperndarese (Junction Box)	STATION ELECTRICAL INSTALLATION	BVS-0032-826	BVS-0032-826-01	ALV32-C01766-105-E-DEA-0001	ZONE 2	THERMON	2L PN 27653	N/A	Ex e	II	T4-T6	II 2 G	IP 66
14	ALV32-856-EJE-J-0003	E	Kuti Shperndarese (Junction Box)	STATION ELECTRICAL INSTALLATION	BVS-0032-826	BVS-0032-826-01	ALV32-C01766-105-E-DEA-0001	ZONE 2	ASP	ESX2212B	17/1587.7.16	Ex e	II C	T5	II 2 G	IP 66
15	ALV32-856-EJE-J-0004	E	Kuti Shperndarese (Junction Box)	STATION ELECTRICAL INSTALLATION	BVS-0032-826	BVS-0032-826-01	ALV32-C01766-105-E-DEA-0001	ZONE 2	ASP	ESX2212B	19/2632.14	Ex e	II C	T5	II 2 G	IP 66
16	ALV32-856-HE-0001	E	Ngrohes (Standard Heating)	STATION ELECTRICAL INSTALLATION	BVS-0032-826	BVS-0032-826-01	ALV32-C01766-105-E-DEA-0001	ZONE 2	INTERTEC	DPA 200 T3 TS	82099/17	Ex d m	II C	T3	II 2 G	IP 65
17	ALV32-856-HE-0002	E	Ngrohes (Standard Heating)	STATION ELECTRICAL INSTALLATION	BVS-0032-826	BVS-0032-826-01	ALV32-C01766-105-E-DEA-0001	ZONE 2	INTERTEC	DPA 200 T3 TS	82100/17	Ex d m	II C	T3	II 2 G	IP 65