

Projekt Zbatim

Llogaritjet Hidraulike

Për llogaritjet e tubacioneve ka përgjithësisht një numër formula hidraulike për vlerësimin e prurjeve në tubacione. Formula e Manning është formula më e përdorur për të dhënë vlerësime të mira për tubacionin dhe është miratuar për qëllimin e këtij modeli.

Analizat hidraulike u kryen me ndihmën e softuerit të miratuar SewerGEMS nga Haestad/Bentley. Sistemi i Kanalizimeve është projektuar për kërkesen për uje ne vitin 2046. Metoda e zgjedhur Brenda në program për llogaritje është sipas motorrit kalkulues SWMM.

Prurjet janë gjeneruar nga ngarkimi i pushtave fundore me ekuivalente popullsie për të katër llojet e ngarkimeve:

Popullsia – $N=200I/b$ *dite, $k_{dmax} = 1.1$, $k_{omax} = 2.2$

Institucionet – 20% e Popullsisë, $k_{omax} = 2.8$


Infiltrimet – 30% e Popullsisë

Shtesa e shirave – 30% e Popullsisë (kjo vlerë merret për systemin e K.U.N pas ndarjes së Ujërave Atmosferike nga ky rrjet)

Simulimi është kryer për të gjithë zonën e projektit zona informale e qytetit te Elbasanit. Rrjeti I ri do të bashkohet me rrjetin ekzistues të qytetit të Elbasanit.

Rezultatet e simulimit paraqitur në tabela janë për rastin më të disfavorshëm për rrjetin, I cili është ora 07:00 e mëngjesit në ditë me shi.

Shpërndarja e prurjes gjatë ditës bëhet me anën e grafikut të koeficientit të jouniformitetit:



Vlerat në model përputhen me vlerat e mëposhtme:

Konsumi I ujit Elbasan	Njesia	Zona Fr.-Me. Viti 2046	Zona Harmes Viti 2046	Zona Kraste V. Viti 2046	Lagja D.H. Viti 2046	Lagja K.R. Viti 2046
Norma e konsumit (w_d)	l/b/dite	200	200	200	200	200
Norma e shkarkimit ne kanalizime	%	100	100	100	100	100
Sasia e Shkarkimit ne kanalizime ($w_{ww,d}$)	l/b/dite	200	200	200	200	200

Ujra te perdorur nga Familjare	Njesia	Zona Fr.-Me. Viti 2046	Zona Harmes Viti 2046	Zona Kraste V. Viti 2046	Lagja D.H. Viti 2046	Lagja K.R. Viti 2046
Projeksioni I Popullsise	PE	2,978	2,260	3,892	584	620
Popullsia e Lidhur ne rrjet	%	100	100	100	100	100
PE Familjare	PE	2,978	2,260	3,892	584	620
Rrjedha mesatare ditore e ujrave te perdorur	m ³ /d	596	452	778	117	124
Sasia e Ujrave te perdorur nga Familjare Q_D	l/s	7	5	9	1	1
Koeficienti I Jouniformitetit	h/d	2.2	2.2	2.2	2.2	2.2
Sasia e Ujrave te perdorur nga Familjare orar piku	m ³ /h	54.60	41	71	11	11

Ujra te perdorur nga Industri dhe biznese	Njesia	Zona Fr.-Me. Viti 2046	Zona Harmes Viti 2046	Zona Kraste V. Viti 2046	Lagja D.H. Viti 2046	Lagja K.R. Viti 2046
Norma nga Rrjedha Familjare	%	20	20	20	20	20
Rrjedha mesatare ditore e ujrave te perdorur	m ³ /d	119	90	156	23	25
Rrjedha nga industria dhe biznese (Q_{ind})	l/s	1.4	1.0	1.8	0.3	0.3
jo uniformiteti javor $\alpha_{Q_{max}}$		12	12	12	12	12
Working days a week	d/week	5	5	5	5	5
Koeficienti I Jouniformitetit orar		2.8	2.8	2.8	2.8	2.8
Sasia e Ujrave te perdorur nga Industria orar piku	l/s	3.86	2.9	5.0	0.8	0.8
Sasia e Ujrave te perdorur nga Industria orar piku	m ³ /h	14	11	18	3	3

Infiltrime	Njesia	Zona Fr.-Me. Viti 2046	Zona Harmes Viti 2046	Zona Kraste V. Viti 2046	Lagja D.H. Viti 2046	Lagja K.R. Viti 2046
Norma e infiltrimit(lidhur me familjar dhe industri)	%	30.0	30.0	30.0	30.0	30.0
Rrjedha e ardhur nga infiltrimet	m ³ /d	214	163	280	42	45
Rrjedha e ardhur nga infiltrimet (orare) ($Q_{inf,aM}$)	m ³ /h	8.93	7	12	2	2

Infiltrime Atmosferike	Njesia	Zona Fr.-Me. Viti 2046	Zona Harmes Viti 2046	Zona Kraste V. Viti 2046	Lagja D.H. Viti 2046	Lagja K.R. Viti 2046
Hyrje nga Rreshje Atmosferike Q_{storm}	%	30.0	30.0	30.0	30.0	30.0
Rrjedha atmosferike Q_{storm}	m ³ /d	179	136	234	35	37
Rrjedha mesatare ne kohe te lagesht ($Q_{storm,aM}$)	m ³ /h	7.45	6	10	1	2

Rrjedha e Projektuar	Njesia	Zona Fr.-Me. Viti 2046	Zona Harmes Viti 2046	Zona Kraste V. Viti 2046	Lagja D.H. Viti 2046	Lagja K.R. Viti 2046
Prurja ne kohe te thate $Q_{DW,aM}$	m ³ /h	39	29	51	8	8
Prurja ne kohe te thate $Q_{DW,aM}$	l/s	11	8	14	2	2
Prurja maksimale ne kohe te thate	m ³ /h	77	59	101	15	16
Prurja maksimale ne kohe te thate	l/s	21.51	16.32	28.11	4.22	4.48
Prurja maksimale ne kohe te lagesht	l/s	23.58	17.89	30.81	4.62	4.91

Shumatore Zona e Projektit - Rrjedha e Projektuar	Njesia						
Prurja ne kohe te thate $Q_{DW,aM}$	m ³ /h						134
Prurja ne kohe te thate $Q_{DW,aM}$	l/s						37
Prurja maksimale ne kohe te thate	m ³ /h						269
Prurja maksimale ne kohe te thate	l/s						75
Prurja maksimale ne kohe te lagesht	l/s						82

Scenario Summary Report

Scenario: Property Inference Scenario - 1

Scenario Summary

ID	8470
Label	Property Inference Scenario - 1
Notes	
Active Topology	<I> Base Active Topology
User Data Extensions	<I> Base User Data Extensions
Physical	Physical Alternative - 1 - Property Inference Scenario - 1
Boundary Condition	<I> Base Boundary Condition
Initial Settings	<I> Base Initial Settings
Hydrology	<I> Base Hydrology
Output	<I> Base Output
Infiltration and Inflow	<I> Base Infiltration and Inflow
Rainfall Runoff	<I> Base Rainfall Runoff
Water Quality	<I> Base Water Quality
Sanitary Loading	Base Sanitary Loading
Headloss	<I> Base Headloss
Operational	<I> Base Operational
Design	<I> Base Design
System Flows	<I> Base System Flows
SCADA	<I> Base SCADA
Energy Cost	<I> Base Energy Cost
Solver Calculation Options	Base Calculation Options

Hydraulic Calculation Events

Use	Start Date	Start Time	End Date	End Time
Explicit Engine				
Routing Method	Dynamic Wave	Minimum Conduit Slope	0.0000m/m	
Allow Ponding at Gravity Structures	True	SWMM Pattern Mode	Use SWMM Patterns.	
Skip Steady State Periods?	False	Use Bentley Transition Equation?	False	
Apply SWMM Control Set?	False	Solver Compatibility	SWMM (BENTLEY 5.1.012)	
Explicit Results Control				
Catchments Results Type	All Results	Links Results Type	All Results	
Nodes Results Type	All Results			
Gravity Hydraulics				
Tractive Stress (Global Minimum)	0.000Pascals			
Inlets				
Inlet Transition Depth	0.00m			

Grating Parameters (United Kingdom)

Grating Type	Grating Parameter
--------------	-------------------

Scenario Summary Report
Scenario: Property Inference Scenario - 1
Grating Parameters (United Kingdom)

Grating Type	Grating Parameter
P	30.000
Q	45.000
R	60.000
S	80.000
T	110.000

Pressure Hydraulics

Pressure Friction Method	Hazen-Williams
--------------------------	----------------

Rational Method

Use Rational Method	False	Allow Runoff Coefficient to Exceed 1.0?	False
---------------------	-------	---	-------

SWMM Dynamic

Head Convergence Tolerance	0.2cm	Define Super Critical Flow	Froude And Slope
Max Trials per Time Step	8	Minimum Surface Area	0.000ha
Inertial Terms	Keep	Time Step For Conduit Lengthening	0.0sec
Use Variable Time Step?	True	Minimum Variable Time Step	0.5sec
Time Step Multiplier	75.00%	Number of Threads	1

SWMM Hydrology

Default Infiltration Method	Horton	Dry Step	1.000hours
SWMM Hydrologic Increment	0.250hours	Start Sweeping On	1/1/2000
Antecedent Dry Period	0.0days	End Sweeping On	12/31/2000

SWMM Interface Files

Rainfall File Mode	None	Save Hot Start File?	False
Runoff File Mode	None	Use Inflow File?	False
RDII File Mode	None	Save Outflow File?	False
Use Hot Start File?	False		

Water Quality

Run Hydrogen Sulfide Analysis?	False
--------------------------------	-------

HEC-22 Energy Losses

Consider Non-Piped Plunging Flow?	True
-----------------------------------	------

HEC-22 Energy Losses (Third Edition)

Flat Submerged Coefficient	-0.050	Half Bench Unsubmerged Coefficient	-0.850
Flat Unsubmerged Coefficient	-0.050	Full Bench Submerged Coefficient	-0.250
Depressed Submerged Coefficient	0.000	Full Bench Unsubmerged Coefficient	-0.930

Scenario Summary Report
Scenario: Property Inference Scenario - 1

HEC-22 Energy Losses (Third Edition)

Depressed Unsubmerged Coefficient	0.000	Improved Submerged Coefficient	-0.600
Half Bench Submerged Coefficient	-0.050	Improved Unsubmerged Coefficient	-0.980

Hydraulic Model Inventory: Modeli Hidraulik Elbasan KUN + SP.stsw

Title
 Engineer
 Company
 Date 2/23/2021
 Notes

Scenario Summary

ID	8470
Label	Property Inference Scenario - 1
Notes	
Active Topology	<I> Base Active Topology
User Data Extensions	<I> Base User Data Extensions
Physical	Physical Alternative - 1 - Property Inference Scenario - 1
Boundary Condition	<I> Base Boundary Condition
Initial Settings	<I> Base Initial Settings
Hydrology	<I> Base Hydrology
Output	<I> Base Output
Infiltration and Inflow	<I> Base Infiltration and Inflow
Rainfall Runoff	<I> Base Rainfall Runoff
Water Quality	<I> Base Water Quality
Sanitary Loading	Base Sanitary Loading
Headloss	<I> Base Headloss
Operational	<I> Base Operational
Design	<I> Base Design
System Flows	<I> Base System Flows
SCADA	<I> Base SCADA
Energy Cost	<I> Base Energy Cost
Solver Calculation Options	Base Calculation Options

Network Inventory

Conduits	1100	Low Impact Development	0
		Controls	
-Circle	1100	Ponds	0
-Box	0	Pond Outlet Structures	0
-Ellipse	0	Headwalls	0
-Virtual	0	Pumps	2
-Irregular Channel	0	-Standard 3 Point (GVF)	0
-Trapezoidal Channel	0	-Standard Extended (GVF)	0
-Triangular Channel	0	-Custom Extended (GVF)	0
-Rectangular Channel	0	-Design Point 1 Point (GVF)	2
-Pipe-Arch	0	-Multiple Point (Type 3)	0
Laterals	0	-Constant Power (GVF)	0
Channels	0	-Depth vs. Flow (Type 2)	0
Gutters	0	-Volume vs. Flow (Type 1)	0
Pressure Pipes	4	Wet Wells	2
Catch Basins	0	-Constant Area - Circular	0
Manholes	1100	-Constant Area - Non-	2
		Circular	
Property Connections	0	Pressure Junctions	0
Taps	0	SCADA Elements	0
Transitions	0	Pump Stations	0
Cross Sections	0	Variable Speed Pump	0
		Batteries	
Outfalls	6	Air Valves	0
Catchments	0		

Hydraulic Model Inventory: Modeli Hidraulik Elbasan KUN + SP.stsw

Circle Inventory			
DDN400 CHDPE SN8	68.0m	DN500 CHDPE SN8	2,897.9m
DN315 CHDPE SN8	26,159.4m	Total Length	33,918.5m
DN400 CHDPE SN8	4,793.2m		

Pressure Pipes Inventory			
176.2 (mm)	1,876.5m	All Diameters	3,547.0m
184.6 (mm)	1,670.5m		

1 Tabelat e Pusetave

Emërtimi	Kuota e Tokës (m)	Kuota e Tabanit (m)	Prurja Hyrëse (L/s)	Lartësia e Ujit në Pusetë (m)
DH-1-1	165.594	164.1	0.16	164.105
DH-1-10	139.961	138.561	1.14	138.574
DH-1-11	137.484	136.084	1.4	136.099
DH-1-12	135.309	133.909	1.4	133.925
DH-1-13	133.71	132.31	1.65	132.327
DH-1-14	131.998	130.598	1.87	130.616
DH-1-15	130.12	128.72	2.09	128.739
DH-1-15-1	130.834	129.434	0.1	129.439
DH-1-16	129.431	128.031	2.35	128.053
DH-1-16-1	131.363	129.963	0.13	129.968
DH-1-16-2	130.882	129.075	0.13	129.081
DH-1-16-3	129.765	128.365	0.13	128.372
DH-1-16-4	130.407	128.6	0.06	128.604
DH-1-16-5	129.653	128.253	0.06	128.258
DH-1-17	128.901	127.501	2.35	127.52
DH-1-18	128.33	124.926	4.56	124.98
DH-1-18-1	129.064	127.257	0.1	127.263
DH-1-18-2	127.991	126.591	0.1	126.595
DH-1-19	127.674	124.893	4.56	124.937
DH-1-2	164.907	163.1	0.16	163.105
DH-1-3	160.577	157.6	0.35	157.607
DH-1-4	154.627	153.227	0.35	153.235
DH-1-5	153.448	152.06	0.35	152.07
DH-1-6	152.894	151.483	0.35	151.491
DH-1-7	152.374	150.932	0.54	150.941
DH-1-7"	148.902	147.502	0.54	147.511
DH-1-8	146.346	144.917	0.79	144.927
DH-1-9	142.564	141.164	0.79	141.176
DH-2-1	140.107	138.3	0.13	138.304
DH-2-10	133.168	130.817	0.29	130.831
DH-2-11	133.069	130.718	0.38	130.734
DH-2-12	133.003	130.652	0.38	130.668
DH-2-13	132.887	130.536	0.38	130.552
DH-2-14	132.821	130.47	0.38	130.486
DH-2-15	132.762	130.411	0.52	130.429
DH-2-16	133.296	130.345	0.52	130.363
DH-2-18	133.658	130.147	0.52	130.165
DH-2-19	132.673	130.009	1.22	130.029

Emërtimi	Kuota e Tokës (m)	Kuota e Tabanit (m)	Prurja Hyrëse (L/s)	Lartësia e Ujit në Pusetë (m)
DH-2-19-1	141.207	139.4	0.1	139.405
DH-2-19-2	139.872	138.065	0.1	138.071
DH-2-19-3	139.385	137.578	0.16	137.586
DH-2-19-4	138.476	137.076	0.16	137.082
DH-2-19-5	136.503	135.103	0.7	135.113
DH-2-19-5-1	144.701	143.3	0.22	143.307
DH-2-19-5-2	143.917	142.11	0.22	142.116
DH-2-19-5-3	140.002	138.6	0.22	138.607
DH-2-19-5-4	137.807	136	0.38	136.012
DH-2-19-5-5	138.955	135.654	0.38	135.666
DH-2-19-5-6	139.928	135.374	0.54	135.389
DH-2-19-6	134.811	132.063	0.7	132.072
DH-2-2	137.816	136.009	0.13	136.014
DH-2-20	131.445	129.763	1.22	129.775
DH-2-21	129.363	127.963	1.69	127.978
DH-2-21-1	131.818	130.418	0.29	130.425
DH-2-21-2	131.101	129.701	0.29	129.711
DH-2-21-3	131.158	129.351	0.29	129.36
DH-2-21-4	130.222	128.815	0.29	128.824
DH-2-21-5	129.697	128.297	0.29	128.308
DH-2-22	128.114	126.307	1.7	126.325
DH-2-23	126.759	125.359	1.82	125.392
DH-2-24	126.951	125.26	1.82	125.293
DH-2-25	127.443	125.095	1.82	125.128
DH-2-26	127.591	125.029	1.83	125.062
DH-2-27	127.694	124.963	1.95	124.997
DH-2-3	136.584	134.777	0.13	134.782
DH-2-4	135.521	133.714	0.13	133.72
DH-2-5	134.687	132.88	0.29	132.888
DH-2-6	132.786	130.979	0.29	130.993
DH-2-7	133.297	130.946	0.29	130.96
DH-2-8	133.221	130.87	0.29	130.884
DH-2-9	133.195	130.844	0.29	130.858
K-1-1-1	126.76	125.35	0.6	125.365
K-1-1-10	124.891	123.45	1.13	123.466
K-1-1-10-1	125.253	123.853	0.16	123.864
K-1-1-10-2	125.2	123.718	0.16	123.727
K-1-1-11	124.841	122.969	25.24	123.07
K-1-1-11-1	137.267	135.567	0.84	135.581
K-1-1-11-10	128.004	123.587	21.38	123.698
K-1-1-11-10-1	128.497	126.69	0.52	126.709

Emërtimi	Kuota e Tokës (m)	Kuota e Tabanit (m)	Prurja Hyrëse (L/s)	Lartësia e Ujit në Pusetë (m)
K-1-1-11-11	127.529	123.499	21.55	123.611
K-1-1-11-11-1	126.779	125.379	0.16	125.39
K-1-1-11-12	127.149	123.398	21.55	123.51
K-1-1-11-13	125	123.304	22.51	123.418
K-1-1-11-13-1	126.306	124.837	0.31	124.851
K-1-1-11-13-1'	126.458	124.969	0.31	124.983
K-1-1-11-13-2	126.111	124.672	0.31	124.686
K-1-1-11-13-3	125.992	124.589	0.31	124.603
K-1-1-11-13-4	126.121	124.49	0.32	124.505
K-1-1-11-14	126.108	123.145	23.57	123.262
K-1-1-11-14-1	125.975	124.458	0.52	124.476
K-1-1-11-14-2	125.7	124.392	0.52	124.41
K-1-1-11-14-3	126.444	124.268	0.52	124.287
K-1-1-11-14-4	126.114	124.104	0.52	124.122
K-1-1-11-14-5	125.642	123.939	0.52	123.958
K-1-1-11-15	125.647	123.057	23.58	123.177
K-1-1-11-2	135.932	134.532	1.46	134.549
K-1-1-11-3	135.205	133.805	1.46	133.822
K-1-1-11-4	134.143	132.743	2.09	132.764
K-1-1-11-5	132.111	131.304	2.09	131.326
K-1-1-11-6	132.018	130.618	2.77	130.643
K-1-1-11-7	130.664	129.263	2.77	129.288
K-1-1-11-8	129.672	128.272	2.77	128.298
K-1-1-11-9	128.859	123.719	19.38	123.82
K-1-1-11-9'	129.316	123.683	20.85	123.793
K-1-1-11-9'-1	137.128	135.728	0.21	135.736
K-1-1-11-9'-2	136.261	134.861	0.47	134.871
K-1-1-11-9'-3	135.076	133.676	0.47	133.686
K-1-1-11-9'-4	133.637	132.237	0.94	132.251
K-1-1-11-9'-5	132.201	130.802	1.46	130.821
K-1-1-11-9'-6	131.265	129.865	1.46	129.884
K-1-1-11-9'-7	130.076	128.676	1.47	128.694
K-1-1-11-9-1	136.631	135.231	0.47	135.24
K-1-1-11-9-2	135.052	133.652	0.71	133.663
K-1-1-11-9-3	133.567	132.167	0.71	132.179
K-1-1-11-9-4	132.404	131.004	0.71	131.021
K-1-1-11-9-5	131.598	130.198	0.71	130.209
K-1-1-11-9-6	129.712	128.312	0.71	128.327
K-1-1-11-9-7	129.214	127.894	1.02	127.913
K-1-1-11-9-7-1	129.775	128.36	0.31	128.371
K-1-1-11-9-8	128.881	127.481	1.19	127.508

Emërtimi	Kuota e Tokës (m)	Kuota e Tabanit (m)	Prurja Hyrëse (L/s)	Lartësia e Ujit në Pusetë (m)
K-1-1-12	124.229	122.78	25.25	122.865
K-1-1-13	123.968	122.48	25.26	122.566
K-1-1-14	123.659	122.195	25.26	122.285
K-1-1-15	123.348	121.815	25.27	121.894
K-1-1-16	122.699	121.3	25.74	121.423
K-1-1-17	122.827	121.238	25.75	121.361
K-1-1-18	122.885	121.175	25.76	121.298
K-1-1-19	123.19	121.075	25.77	121.198
K-1-1-2	126.29	124.82	0.6	124.84
K-1-1-20	123.436	120.975	25.78	121.101
K-1-1-21	123.181	120.9	25.79	121.023
K-1-1-22	122.687	120.788	25.8	120.911
K-1-1-23	122.582	120.682	25.81	120.808
K-1-1-24	122.681	120.611	25.82	120.731
K-1-1-3	126.18	124.72	0.6	124.74
K-1-1-4	126.21	124.65	0.6	124.669
K-1-1-5	126.11	124.57	0.76	124.592
K-1-1-6	125.97	124.47	0.76	124.492
K-1-1-7	126.135	124.338	0.76	124.36
K-1-1-8	126.014	124.206	0.97	124.232
K-1-1-8-1	126.667	125.267	0.21	125.274
K-1-1-9	125.523	124.1	0.98	124.118
K-1-2-1	124.517	123.117	0.84	123.136
K-1-2-2	124.189	122.755	0.84	122.774
K-1-2-3	123.922	122.515	0.84	122.538
K-1-2-4	123.755	122.343	0.84	122.362
K-1-2-5	123.58	122.18	0.84	122.198
K-1-2-6	123.388	121.975	0.84	121.999
K-1-2-7	123.31	119.723	39.54	119.869
K-1-3-1	139.085	137.685	0.31	137.695
K-1-3-10	130.409	128.18	2.57	128.199
K-1-3-10-1	133.905	132.505	0.31	132.519
K-1-3-10-1-10-1	132.968	131.568	0.47	131.584
K-1-3-10-1-5-1	130.814	129.414	0.21	129.427
K-1-3-10-10	130.549	128.3	1.57	128.33
K-1-3-10-11	130.356	128.26	1.57	128.294
K-1-3-10-2	135.179	132.399	0.31	132.413
K-1-3-10-3	136.361	132.291	0.31	132.306
K-1-3-10-4	134.3	131.423	0.79	131.446
K-1-3-10-5	133.995	131.374	1.1	131.392
K-1-3-10-6	132.271	130.5	1.1	130.517

Emërtimi	Kuota e Tokës (m)	Kuota e Tabanit (m)	Prurja Hyrëse (L/s)	Lartësia e Ujit në Pusetë (m)
K-1-3-10-7	130.648	129.248	1.1	129.267
K-1-3-10-8	130.539	128.38	1.57	128.411
K-1-3-10-8-1	129.938	128.538	0.47	128.556
K-1-3-10-8-2	130.307	128.414	0.47	128.431
K-1-3-10-9	130.581	128.32	1.57	128.354
K-1-3-11	128.904	126.92	2.57	126.94
K-1-3-12	128.067	125.72	3.15	125.747
K-1-3-12-1	127.423	126.02	0.26	126.033
K-1-3-12-2	127.169	125.961	0.26	125.974
K-1-3-12-3	127.209	125.894	0.26	125.907
K-1-3-12-4	127.416	125.849	0.26	125.862
K-1-3-13	127.26	125.069	3.15	125.096
K-1-3-14	126.497	123.36	3.41	123.405
K-1-3-14-1	125.669	123.862	0.26	123.875
K-1-3-14-3	125.26	123.76	0.26	123.773
K-1-3-14-4	125.277	123.645	0.26	123.659
K-1-3-14-5	125.596	123.53	0.26	123.542
K-1-3-15	124.846	123.22	3.41	123.271
K-1-3-16	124.833	123.17	3.68	123.194
K-1-3-16-1	125.367	123.97	0.26	123.977
K-1-3-16-2	125.053	123.333	0.26	123.34
K-1-3-17	123.734	121.55	3.68	121.596
K-1-3-18	123.09	121.415	11.83	121.496
K-1-3-19	123.668	121.37	12.04	121.456
K-1-3-2	139.056	137.367	0.31	137.374
K-1-3-20	123.689	121.35	12.04	121.432
K-1-3-21	124	121.29	12.04	121.372
K-1-3-22	124.268	121.21	12.05	121.292
K-1-3-22-1	125.289	123.89	0	123.89
K-1-3-22-2	124.273	121.5	0	121.5
K-1-3-23	123.357	121.13	12.05	121.222
K-1-3-24	122.749	121.04	12.26	121.08
K-1-3-25	122.695	120.54	38.61	120.687
K-1-3-26	122.295	120.46	38.61	120.607
K-1-3-27	122.311	120.38	38.63	120.527
K-1-3-28	122.051	120.319	38.63	120.467
K-1-3-29	121.971	120.239	38.64	120.387
K-1-3-3	138.628	136.367	0.31	136.374
K-1-3-30	122.075	120.149	38.65	120.297
K-1-3-31	121.857	120.102	38.66	120.25
K-1-3-32	121.951	120.054	38.67	120.201

Emërtimi	Kuota e Tokës (m)	Kuota e Tabanit (m)	Prurja Hyrëse (L/s)	Lartësia e Ujit në Pusetë (m)
K-1-3-33	122.141	119.974	38.67	120.121
K-1-3-34	122.135	119.874	38.68	120.021
K-1-3-35	122.63	119.843	38.69	119.991
K-1-3-36	123.313	119.773	38.69	119.921
K-1-3-4	134.883	133.483	0.52	133.493
K-1-3-4-1	135.194	133.794	0.21	133.802
K-1-3-5	133.638	131.73	0.99	131.746
K-1-3-6	132.833	131.01	0.99	131.026
K-1-3-7	132.083	130.41	0.99	130.427
K-1-3-8	131.546	130.11	0.99	130.125
K-1-3-9	130.931	129.37	1	129.385
K-1-4-1	131.986	130.586	0.42	130.597
K-1-4-10	127.116	125.716	2.2	125.752
K-1-4-11	127.004	125.6	2.21	125.636
K-1-4-12	126.914	125.516	2.47	125.554
K-1-4-12-1	126.805	125.562	0.26	125.575
K-1-4-13	126.763	125.476	2.47	125.518
K-1-4-14	127.247	125.44	2.63	125.465
K-1-4-15	126.424	125.02	2.63	125.048
K-1-4-16	125.993	124.59	2.63	124.625
K-1-4-17	125.57	124.17	2.63	124.195
K-1-4-18	125.38	123.98	2.63	124.011
K-1-4-19	125.094	123.69	2.63	123.73
K-1-4-2	131.11	129.71	0.68	129.725
K-1-4-20	125.868	123.594	2.63	123.634
K-1-4-21	125.739	123.46	3	123.502
K-1-4-22	125.38	123.384	3	123.426
K-1-4-23	125	123.244	3.01	123.286
K-1-4-24	124.565	123.144	3.01	123.186
K-1-4-25	124.352	123.039	3.01	123.081
K-1-4-26	124.348	122.973	3.01	123.015
K-1-4-27	124.329	122.886	3.01	122.928
K-1-4-28	125.063	122.799	3.01	122.841
K-1-4-29	125.086	122.725	3.01	122.767
K-1-4-3	130.763	129.363	0.89	129.381
K-1-4-30	126.602	122.667	8.12	122.739
K-1-4-31	127.226	122.567	8.13	122.639
K-1-4-32	126.555	122.467	8.13	122.539
K-1-4-33	126.43	122.367	8.13	122.439
K-1-4-34	126.314	122.267	8.14	122.345
K-1-4-35	125.649	122.167	8.14	122.212

Emërtimi	Kuota e Tokës (m)	Kuota e Tabanit (m)	Prurja Hyrëse (L/s)	Lartësia e Ujit në Pusetë (m)
K-1-4-36	123.241	121.74	8.14	121.813
K-1-4-37	123.22	121.7	8.14	121.773
K-1-4-38	123.156	121.66	8.14	121.736
K-1-4-39	123.217	121.64	8.15	121.709
K-1-4-4	130.398	128.998	1.2	129.02
K-1-4-40	123.239	121.61	8.15	121.681
K-1-4-41	123.122	121.59	8.15	121.665
K-1-4-42	123.203	121.54	8.15	121.609
K-1-4-43	123.175	121.53	8.15	121.599
K-1-4-44	122.928	121.52	8.15	121.591
K-1-4-45	122.438	121.45	8.15	121.521
K-1-4-5	129.944	128.544	1.2	128.57
K-1-4-6	130.12	128.313	1.62	128.345
K-1-4-7	129.6	128.191	1.78	128.224
K-1-4-8	129.56	128.076	1.78	128.109
K-1-4-9	129.849	125.851	1.79	125.884
K-1-5-1	129.629	128.229	0.42	128.246
K-1-5-10	126.074	124.659	0.74	124.681
K-1-5-11	126.066	124.643	0.74	124.665
K-1-5-12	125.873	124.479	0.74	124.501
K-1-5-13	125.913	124.396	0.74	124.418
K-1-5-14	125.952	124.331	0.74	124.353
K-1-5-16	125.982	124.219	5.08	124.273
K-1-5-16'	125.546	124.131	5.09	124.186
K-1-5-16''	125.147	124.081	5.09	124.136
K-1-5-17	125.169	123.96	5.09	124.014
K-1-5-18	126.89	123.897	5.09	123.952
K-1-5-19	127.626	123.772	5.1	123.827
K-1-5-2	129.476	128.076	0.42	128.095
K-1-5-20	127.246	123.647	5.1	123.701
K-1-5-21	127.114	123.521	5.1	123.577
K-1-5-3	129.967	127.892	0.42	127.9
K-1-5-4	129.51	127.195	0.42	127.205
K-1-5-5	127.436	125.612	0.58	125.631
K-1-5-5-1	127.048	125.648	0.16	125.658
K-1-5-6	127.341	125.549	0.58	125.569
K-1-5-7	127.411	125.483	0.73	125.5
K-1-5-7'	126.57	125.17	0.74	125.187
K-1-5-8	126.316	124.916	0.74	124.934
K-1-5-9	126.19	124.79	0.74	124.812
K-1-6-1	132.901	131.319	0.1	131.328

Emërtimi	Kuota e Tokës (m)	Kuota e Tabanit (m)	Prurja Hyrëse (L/s)	Lartësia e Ujit në Pusetë (m)
K-1-6-1-1	132.954	131.554	0.1	131.563
K-1-6-1-2	132.918	131.458	0.1	131.467
K-1-6-10	132.603	129.784	1.26	129.801
K-1-6-11	129.753	128.353	1.26	128.373
K-1-6-12	129.159	127.759	1.26	127.781
K-1-6-15	128.702	127.302	1.27	127.33
K-1-6-16	128.68	127.153	1.27	127.181
K-1-6-17	128.477	127.054	1.27	127.082
K-1-6-18	128.406	126.972	1.27	127
K-1-6-19	128.783	126.871	1.53	126.904
K-1-6-2	132.83	131.22	0.31	131.231
K-1-6-2-2	133.277	131.47	0.21	131.481
K-1-6-20	128.213	126.788	1.53	126.81
K-1-6-21	129.168	126.29	2.33	126.327
K-1-6-21-1	131.965	128.85	0.16	128.86
K-1-6-21-10	128.984	127.58	0.79	127.602
K-1-6-21-11	128.924	127.497	0.79	127.52
K-1-6-21-12	129.518	127.349	0.79	127.37
K-1-6-21-13	128.583	127.183	0.79	127.206
K-1-6-21-14	128.771	127.02	0.79	127.039
K-1-6-21-15	128.103	126.7	0.79	126.723
K-1-6-21-16	127.976	126.517	0.79	126.54
K-1-6-21-17	128.145	126.472	0.8	126.494
K-1-6-21-18	128.498	126.406	0.8	126.428
K-1-6-21-19	128.949	126.34	0.8	126.363
K-1-6-21-2	130.99	128.68	0.16	128.691
K-1-6-21-3	130.9	128.52	0.16	128.53
K-1-6-21-4	130.417	128.35	0.16	128.361
K-1-6-21-5	130.077	128.27	0.16	128.281
K-1-6-21-6	130.047	128.24	0.16	128.251
K-1-6-21-7	129.522	128.12	0.16	128.129
K-1-6-21-8	129.389	127.898	0.79	127.917
K-1-6-21-8-1	130.456	129.08	0.63	129.096
K-1-6-21-8-2	130.005	128.686	0.63	128.702
K-1-6-21-8-3	129.93	128.292	0.63	128.308
K-1-6-21-9	129.272	127.739	0.79	127.758
K-1-6-22	128.923	126.252	2.49	126.291
K-1-6-22-1	132.825	131.425	0.16	131.435
K-1-6-22-10	128.572	127.001	0.16	127.012
K-1-6-22-2	132.701	131.301	0.16	131.309
K-1-6-22-3	132.359	130.959	0.16	130.97

Emërtimi	Kuota e Tokës (m)	Kuota e Tabanit (m)	Prurja Hyrëse (L/s)	Lartësia e Ujit në Pusetë (m)
K-1-6-22-4	132.358	130.923	0.16	130.934
K-1-6-22-5	132.47	130.041	0.16	130.046
K-1-6-22-6	128.964	127.564	0.16	127.572
K-1-6-22-7	128.572	127.172	0.16	127.182
K-1-6-22-8	129.599	127.089	0.16	127.1
K-1-6-22-9	128.485	127.045	0.16	127.055
K-1-6-23	127.952	126.132	2.49	126.171
K-1-6-24	127.806	126.07	2.49	126.109
K-1-6-25	127.897	125.995	2.7	126.035
K-1-6-25-1	128.226	126.826	0.21	126.838
K-1-6-25-2	128.123	126.678	0.21	126.691
K-1-6-26	127.816	125.895	4.31	125.937
K-1-6-26-1	144.771	142.964	0.42	142.978
K-1-6-26-10	136.882	135.41	0.94	135.423
K-1-6-26-11	136.178	133.706	0.94	133.728
K-1-6-26-12	134.778	132.51	0.94	132.522
K-1-6-26-13	131.7	130.3	1.1	130.318
K-1-6-26-14	131.184	128.75	1.36	128.767
K-1-6-26-15	131.284	128.45	1.36	128.467
K-1-6-26-16	129.202	127.7	1.6	127.718
K-1-6-26-17	128.343	126.943	1.6	126.967
K-1-6-26-18	128.323	126.846	1.6	126.877
K-1-6-26-19	128.043	126.643	1.6	126.664
K-1-6-26-2	143.001	142.601	0.42	142.609
K-1-6-26-3	142.67	141.27	0.42	141.287
K-1-6-26-4	142.642	141.217	0.42	141.234
K-1-6-26-5	143.071	141.082	0.42	141.1
K-1-6-26-6	142.681	141.016	0.42	141.028
K-1-6-26-7	142.059	140.659	0.42	140.668
K-1-6-26-8	141.818	140.31	0.42	140.318
K-1-6-26-9	139.706	137.86	0.42	137.868
K-1-6-27	127.771	125.51	4.31	125.555
K-1-6-28	127.442	125.35	4.32	125.395
K-1-6-29	127.2	125.22	4.32	125.265
K-1-6-3	132.754	130.897	0.42	130.911
K-1-6-3-1	132.859	131.052	0.1	131.061
K-1-6-30	127.115	125.14	4.32	125.192
K-1-6-31	126.609	125.02	4.32	125.068
K-1-6-32	126.396	124.99	4.33	125.041
K-1-6-33	126.56	124.87	4.33	124.92
K-1-6-34	126.091	124.73	4.33	124.784

Emërtimi	Kuota e Tokës (m)	Kuota e Tabanit (m)	Prurja Hyrëse (L/s)	Lartësia e Ujit në Pusetë (m)
K-1-6-35	126.068	124.71	4.34	124.76
K-1-6-36	126.17	124.58	4.34	124.633
K-1-6-37	126.174	124.48	4.34	124.518
K-1-6-4	132.471	130.52	0.79	130.543
K-1-6-4-1	132.519	130.737	0.37	130.753
K-1-6-5	132.462	130.385	0.84	130.408
K-1-6-5-1	132.156	130.756	0.05	130.76
K-1-6-6	132.549	130.273	1.1	130.299
K-1-6-7	132.68	130.108	1.1	130.134
K-1-6-8	132.571	129.919	1.1	129.946
K-1-6-9	132.677	129.883	1.26	129.908
K-2-1--11-1	140.26	138.86	0.26	138.87
K-2-1--11-2	139.72	137.52	0.26	137.527
K-2-1--11-3	137.875	135.946	0.37	135.953
K-2-1--11-4	136.858	134.22	0.37	134.228
K-2-1--11-5	135.149	133.62	0.37	133.628
K-2-1--11-6	133.851	132.451	0.37	132.459
K-2-1--11-7	133.165	131.765	0.37	131.78
K-2-1-1	148.543	146.736	0.26	146.744
K-2-1-10	133.436	132.036	0.84	132.067
K-2-1-11	133.018	131.618	1.63	131.633
K-2-1-12	131.579	130.179	1.63	130.196
K-2-1-13	130.063	128.663	2.26	128.684
K-2-1-13-1	135.436	133.7	0.63	133.709
K-2-1-13-2	132.1	130.7	0.63	130.711
K-2-1-13-3	131.119	129.719	0.63	129.732
K-2-1-13-4	130.332	128.932	0.63	128.953
K-2-1-13-5	130.246	128.833	0.63	128.85
K-2-1-14	129.284	127.884	2.26	127.916
K-2-1-15	129.145	127.745	3.63	127.791
K-2-1-15-1	130.501	129.101	0.57	129.113
K-2-1-15-2	129.983	128.165	0.89	128.189
K-2-1-15-2-1	130.313	128.913	0.31	128.923
K-2-1-15-2-2	130.059	128.658	0.31	128.667
K-2-1-15-2-3	129.857	128.457	0.31	128.468
K-2-1-15-2-4	129.759	128.359	0.31	128.37
K-2-1-15-2-5	129.695	128.295	0.31	128.309
K-2-1-15-3	129.586	128.05	0.89	128.075
K-2-1-15-4	129.35	127.964	0.89	127.984
K-2-1-16	129.087	127.646	3.63	127.692
K-2-1-17	129.021	127.547	4	127.6

Emërtimi	Kuota e Tokës (m)	Kuota e Tabanit (m)	Prurja Hyrëse (L/s)	Lartësia e Ujit në Pusetë (m)
K-2-1-18	129.061	127.455	4.89	127.487
K-2-1-18-1	129.836	127.96	0.37	127.975
K-2-1-18-2	129.632	127.84	0.37	127.855
K-2-1-18-3	129.39	127.72	0.37	127.735
K-2-1-18-4	129.019	127.6	0.37	127.614
K-2-1-19	129.181	126.503	5.41	126.559
K-2-1-19-1	128.253	126.853	0.52	126.871
K-2-1-19-2	128.416	126.685	0.52	126.703
K-2-1-2	147.588	146.011	0.26	146.019
K-2-1-3	146.837	145.437	0.26	145.446
K-2-1-4	146.417	145.014	0.26	145.022
K-2-1-5	146.448	144.89	0.63	144.899
K-2-1-5-1	152.698	150.58	0.37	150.587
K-2-1-5-2	149.398	147.36	0.37	147.367
K-2-1-5-3	147.748	145.85	0.37	145.857
K-2-1-6	144.686	142.61	0.63	142.619
K-2-1-7	142.719	140.95	0.63	140.959
K-2-1-8	141.581	137.49	0.63	137.499
K-2-1-9	138.918	135.84	0.63	135.849
K-2-10-1	128.761	127.361	0.31	127.372
K-2-10-2	130.17	127	0.31	127.011
K-2-10-3	127.976	126.576	0.73	126.598
K-2-2-1	127.889	126.489	0.16	126.498
K-2-3-1	128.145	126.745	0.31	126.755
K-2-4-1	127.64	126.24	0.21	126.252
K-2-4-10	127.948	125.661	0.58	125.68
K-2-4-11	127.973	125.625	0.95	125.65
K-2-4-12	127.854	125.585	1.31	125.613
K-2-4-13	127.649	125.499	1.31	125.528
K-2-4-14	127.896	125.463	1.68	125.495
K-2-4-2	127.716	126.11	0.21	126.122
K-2-4-3	127.826	126.072	0.21	126.084
K-2-4-4	127.765	126.032	0.21	126.044
K-2-4-5	127.856	125.962	0.58	125.979
K-2-4-5-1	128.44	127.04	0.37	127.053
K-2-4-5-2	128.2	126.802	0.37	126.816
K-2-4-5-3	127.96	126.56	0.37	126.572
K-2-4-6	127.831	125.839	0.58	125.861
K-2-4-7	127.77	125.8	0.58	125.823
K-2-4-8	127.904	125.754	0.58	125.773
K-2-4-9	127.937	125.71	0.58	125.729

Emërtimi	Kuota e Tokës (m)	Kuota e Tabanit (m)	Prurja Hyrëse (L/s)	Lartësia e Ujit në Pusetë (m)
K-2-5-1	128.165	126.765	0.16	126.776
K-2-6-1	127.622	126.222	0.26	126.233
K-2-6-2	127.83	125.954	0.26	125.965
K-2-6-3	127.77	125.893	0.73	125.915
K-2-6-3-1	127.852	126.452	0.47	126.467
K-2-6-3-2	128.037	126.23	0.47	126.243
K-2-6-3-3	127.452	126.052	0.47	126.069
K-2-6-4	127.74	125.778	1.41	125.807
K-2-6-4-1	127.553	125.93	0.42	125.947
K-2-6-5	127.77	125.719	1.62	125.75
K-2-6-5-1	127.6	126.2	0.21	126.207
K-2-6-6	127.82	125.58	3.62	125.626
K-2-6-6-1	131.981	130.174	0.31	130.182
K-2-6-6-10	128.3	125.991	1.62	126.017
K-2-6-6-10-1	127.805	126.405	0.16	126.414
K-2-6-6-10-2	128.059	126.141	0.16	126.15
K-2-6-6-11	128.15	125.862	1.63	125.888
K-2-6-6-12	128.02	125.665	1.63	125.691
K-2-6-6-2	130.092	128.692	0.31	128.7
K-2-6-6-3	129.676	128.275	0.31	128.284
K-2-6-6-4	129.33	127.927	0.31	127.938
K-2-6-6-5	129.22	127.82	0.58	127.835
K-2-6-6-6	128.96	127.514	0.58	127.528
K-2-6-6-7	128.68	127.224	1.05	127.242
K-2-6-6-7-1	131.86	129.79	0.47	129.798
K-2-6-6-7-2	130.093	128.403	0.47	128.412
K-2-6-6-8	128.27	126.366	1.31	126.39
K-2-6-6-8-1	127.88	126.482	0.26	126.495
K-2-6-6-9	128.35	126.258	1.47	126.283
K-2-6-7	127.61	125.382	3.83	125.43
K-2-6-7-1	127.683	126.292	0.21	126.299
K-2-6-8	127.95	125.257	4.3	125.307
K-2-6-8-1	127.687	126.287	0.31	126.294
K-2-6-8-2	127.854	126.454	0.16	126.46
K-2-6-9	127.677	125.174	4.31	125.223
K-2-7-1	127.894	126.48	0.21	126.493
K-2-8-1	127.677	126.28	0.26	126.29
K-2-8-2	127.52	125.748	0.63	125.768
K-2-8-2-1	127.38	125.95	0.16	125.96
K-2-8-2-2	127.54	125.91	0.16	125.921
K-2-8-2-3	127.497	126.1	0.21	126.108

Emërtimi	Kuota e Tokës (m)	Kuota e Tabanit (m)	Prurja Hyrëse (L/s)	Lartësia e Ujit në Pusetë (m)
K-2-8-3	127.76	125.675	0.63	125.696
K-2-9-1	127.501	126.101	0.21	126.113
K-2-9-2	127.73	126.002	0.21	126.014
K-2-9-3	127.401	125.94	0.21	125.952
K-2-9-4	127.61	125.841	0.21	125.854
K-3	108.852	106.4	14.67	106.471
K-3-0-1	135.247	133.44	1.05	133.466
K-3-0-1-1	182.195	179.19	0.19	179.195
K-3-0-1-10	147.843	146.31	0.38	146.317
K-3-0-1-11	146.206	144.31	0.38	144.317
K-3-0-1-12	143.221	141.82	0.38	141.828
K-3-0-1-13	141.952	140.53	0.38	140.54
K-3-0-1-14	141.458	140.03	0.38	140.041
K-3-0-1-15	141.04	139.35	0.38	139.361
K-3-0-1-16	139.833	138.42	0.38	138.43
K-3-0-1-17	139.102	137.66	0.38	137.672
K-3-0-1-18	138.722	137.32	0.53	137.333
K-3-0-1-19	138.094	136.68	0.53	136.692
K-3-0-1-2	175.99	174.19	0.19	174.196
K-3-0-1-20	137.757	136.06	0.53	136.071
K-3-0-1-21	137.117	135.31	0.53	135.321
K-3-0-1-22	136.444	134.56	0.53	134.573
K-3-0-1-23	135.633	134.18	0.53	134.193
K-3-0-1-24	135.09	133.66	0.53	133.673
K-3-0-1-3	171.799	170.13	0.19	170.135
K-3-0-1-4	166.852	165.13	0.19	165.135
K-3-0-1-5	164.667	162.14	0.38	162.147
K-3-0-1-5-1	166.455	165.06	0.19	165.065
K-3-0-1-5-2	166.623	164.21	0.19	164.217
K-3-0-1-5-3	165.355	163.95	0.19	163.96
K-3-0-1-5-4	165.113	163.71	0.19	163.716
K-3-0-1-6	160.691	157.26	0.38	157.267
K-3-0-1-7	153.161	151.01	0.38	151.017
K-3-0-1-8	149.736	148.35	0.38	148.358
K-3-0-1-8-1	152.667	151.27	0	151.27
K-3-0-1-8-2	151.847	150.39	0	150.39
K-3-0-1-8-3	151.178	149.55	0	149.55
K-3-0-1-8-4	150.763	149.02	0	149.02
K-3-0-1-9	148.622	147.31	0.38	147.318
K-3-0-2	134.982	133.34	1.05	133.366
K-3-0-3	134.908	133.14	1.05	133.166

Emërtimi	Kuota e Tokës (m)	Kuota e Tabanit (m)	Prurja Hyrëse (L/s)	Lartësia e Ujit në Pusetë (m)
K-3-0-4	135.226	133.04	1.05	133.066
K-3-0-5	134.656	132.913	1.05	132.939
K-3-0-6	134.483	132.877	1.24	132.903
K-3-0-6-1	141.15	139.75	0.09	139.758
K-3-0-6-2	141.287	139.645	0.09	139.653
K-3-0-6-3	141.202	139.465	0.09	139.474
K-3-0-6-4	140.758	139.399	0.09	139.403
K-3-0-6-5	137.932	136.53	0.09	136.534
K-3-0-6-6	135.74	134.26	0.09	134.265
K-3-0-7	134.059	132.659	1.24	132.677
K-3-0-8	133.287	131.863	1.48	131.885
K-3-0-8-1	133.578	132.18	0.23	132.193
K-3-0-8-2	133.433	132.03	0.23	132.043
K-3-1-1	134.317	132.51	0	132.51
K-3-1-10	131.185	129.77	0	129.77
K-3-1-11	130.997	129.19	0	129.19
K-3-1-12	130.596	129.04	0	129.04
K-3-1-14	130.809	128.92	0.86	128.944
K-3-1-15	130.199	128.74	0.86	128.759
K-3-1-16	129.821	128.42	0.86	128.443
K-3-1-17	129.88	128.3	0.86	128.323
K-3-1-18	129.904	128.18	0.86	128.204
K-3-1-19	129.894	128.1	0.86	128.123
K-3-1-20	129.964	127.96	0.86	127.983
K-3-1-21	130.339	127.85	0.86	127.877
K-3-1-22	129.634	127.82	1.1	127.832
K-3-1-22-1	131.347	129.95	0.24	129.958
K-3-1-22-2	130.697	129.3	0.24	129.313
K-3-1-22-3	130.543	129.14	0.24	129.15
K-3-1-22-4	130.136	128.74	0.24	128.751
K-3-1-22-5	129.789	128.38	0.24	128.387
K-3-1-23	127.657	126.06	1.1	126.074
K-3-1-24	126.447	124.86	1.1	124.879
K-3-1-25	126.199	124.68	1.1	124.7
K-3-1-26	126	124.44	1.29	124.465
K-3-1-27	126	124.37	1.29	124.39
K-3-1-28	125.558	124.05	1.29	124.074
K-3-1-29	125.447	123.94	1.29	123.964
K-3-1-30	125.372	123.75	1.48	123.776
K-3-1-31	125.145	123.62	1.49	123.642
K-3-1-32	124.92	123.27	1.49	123.296

Emërtimi	Kuota e Tokës (m)	Kuota e Tabanit (m)	Prurja Hyrëse (L/s)	Lartësia e Ujit në Pusetë (m)
K-3-1-33	124.655	123.14	1.68	123.163
K-3-1-34	124.438	122.94	1.68	122.964
K-3-1-35	124.143	122.62	1.68	122.654
K-3-1-36	124.048	122.575	1.68	122.596
K-3-1-37	124.006	122.47	1.68	122.503
K-3-1-38	124.019	122.43	1.68	122.463
K-3-1-39	124.557	122.39	2.97	122.436
K-3-1-39-1	174.108	172.71	0.57	172.72
K-3-1-39-10	152.555	149.84	0.57	149.849
K-3-1-39-11	149.447	148.64	0.57	148.649
K-3-1-39-12	148.536	145.84	0.57	145.849
K-3-1-39-13	144.931	141.6	0.57	141.609
K-3-1-39-14	137.998	135.63	0.57	135.64
K-3-1-39-15	136.367	133.96	0.57	133.969
K-3-1-39-16	132.672	131.07	0.57	131.079
K-3-1-39-17	132.369	129.96	0.81	129.977
K-3-1-39-17-10	136.917	133.68	0	133.68
K-3-1-39-17-11	136.912	133.65	0	133.65
K-3-1-39-17-12	137.885	133.59	0	133.59
K-3-1-39-17-13	137.829	133.56	0	133.56
K-3-1-39-17-14	137.715	133.5	0	133.5
K-3-1-39-17-15	138.271	133.35	0	133.35
K-3-1-39-17-16	138.512	133.31	0	133.31
K-3-1-39-17-17	136.072	133.14	0	133.14
K-3-1-39-17-18	135.239	133.08	0	133.08
K-3-1-39-17-19	134.516	133.06	0	133.06
K-3-1-39-17-20	133.262	131.37	0	131.37
K-3-1-39-17-21	131.671	130.27	0	130.27
K-3-1-39-17-22	132.28	130.18	0	130.18
K-3-1-39-17-23	132.723	130.1	0	130.1
K-3-1-39-17-3	136.273	134.26	0	134.26
K-3-1-39-17-4	135.538	134.14	0	134.14
K-3-1-39-17-5	136.094	133.99	0	133.99
K-3-1-39-17-6	135.851	133.89	0	133.89
K-3-1-39-17-7	136.092	133.82	0	133.82
K-3-1-39-17-8	136.403	133.79	0	133.79
K-3-1-39-17-9	136.938	133.71	0	133.71
K-3-1-39-18	131.08	129.58	0.81	129.591
K-3-1-39-19	128.16	126.71	1.05	126.725
K-3-1-39-2	173.604	171.81	0.57	171.821
K-3-1-39-20	127.37	125.9	1.05	125.921

Emërtimi	Kuota e Tokës (m)	Kuota e Tabanit (m)	Prurja Hyrëse (L/s)	Lartësia e Ujit në Pusetë (m)
K-3-1-39-21	126.929	125.5	1.05	125.516
K-3-1-39-22	126.21	124.32	1.05	124.332
K-3-1-39-22-1	131.963	130.56	0	130.56
K-3-1-39-22-2	131.316	129.92	0	129.92
K-3-1-39-22-3	129.465	127.61	0	127.61
K-3-1-39-22-4	127.535	125.01	0	125.01
K-3-1-39-22-5	125.925	124.53	0	124.53
K-3-1-39-22-6	125.803	124.47	0	124.47
K-3-1-39-22-7	126.353	124.36	0	124.36
K-3-1-39-23	128.756	127.36	0.24	127.366
K-3-1-39-3	172.41	171	0.57	171.009
K-3-1-39-4	170.007	168.5	0.57	168.509
K-3-1-39-5	168.124	166.7	0.57	166.71
K-3-1-39-6	166.821	164.31	0.57	164.32
K-3-1-39-6-1	179.448	176.851	0	176.851
K-3-1-39-6-2	175.251	173.851	0	173.851
K-3-1-39-6-3	173.146	171.688	0	171.688
K-3-1-39-6-4	171.488	168.56	0	168.56
K-3-1-39-6-5	167.66	165.27	0	165.27
K-3-1-39-7	163.456	160.15	0.57	160.159
K-3-1-39-8	161.814	158.15	0.57	158.159
K-3-1-39-9	155.047	152.65	0.57	152.659
K-3-1-40	124.498	122.38	3.45	122.41
K-3-1-40-1	125.491	124.09	0.48	124.102
K-3-1-40-2	125.223	123.79	0.48	123.809
K-3-1-40-3	125.326	123.72	0.48	123.729
K-3-1-41	123.492	121.98	3.45	122.001
K-3-1-42	122.362	120.77	3.45	120.79
K-3-1-43	119.369	116.57	3.88	116.598
K-3-1-43-1	118.598	117.2	0.43	117.212
K-3-1-43-2	118.116	116.75	0.43	116.767
K-3-1-43-3	118.671	116.65	0	116.65
K-3-1-44	117.328	115.82	3.88	115.841
K-3-1-45	115.075	113.42	4.12	113.444
K-3-1-46	113.661	112.02	4.36	112.049
K-3-1-46-1	117.406	116.01	0.24	116.016
K-3-1-46-2	115.652	114.25	0.24	114.256
K-3-1-47	112.492	110.97	4.64	111.004
K-3-1-47-1	120.355	118.42	0.29	118.426
K-3-1-47-2	117.316	114.72	0.29	114.727
K-3-1-47-3	114.243	112.84	0.29	112.847

Emërtimi	Kuota e Tokës (m)	Kuota e Tabanit (m)	Prurja Hyrëse (L/s)	Lartësia e Ujit në Pusetë (m)
K-3-1-47-4	112.801	111.34	0.29	111.35
K-3-1-47-5	112.503	111.1	0.29	111.112
K-3-1-48	112	110.52	4.65	110.555
K-3-1-49	111.163	110.28	5.12	110.346
K-3-1-49-1	113.2	111.8	0.48	111.812
K-3-1-49-2	112.652	111.24	0.48	111.254
K-3-1-49-3	112.458	111.04	0.48	111.055
K-3-1-49-4	112.293	110.89	0.48	110.904
K-3-1-49-5	112.054	110.65	0.48	110.665
K-3-1-49-6	111.931	110.53	0.48	110.545
K-3-1-5	132.544	131.144	0	131.144
K-3-1-50	111.779	110.24	5.13	110.268
K-3-1-51	111.69	108.32	7.99	108.388
K-3-1-51-1	124.875	123.47	0.95	123.482
K-3-1-51-10	112	110.45	0.95	110.462
K-3-1-51-11	111	109.3	0.95	109.316
K-3-1-51-12	110.336	108.9	1.9	108.934
K-3-1-51-13	110.251	108.8	1.9	108.834
K-3-1-51-14	110.351	108.62	1.91	108.654
K-3-1-51-15	110.479	108.54	1.91	108.574
K-3-1-51-2	123.143	121.6	0.95	121.614
K-3-1-51-3	122.128	120.6	0.95	120.624
K-3-1-51-4	122.841	120.53	0.95	120.556
K-3-1-51-5	122.367	120.4	0.95	120.418
K-3-1-51-6	121.64	119.98	0.95	119.992
K-3-1-51-7	120.518	118.7	0.95	118.711
K-3-1-51-8	119.477	118	0.95	118.011
K-3-1-51-9	117.393	113.7	0.95	113.712
K-3-1-52	111.844	108.23	8	108.299
K-3-1-53	111.73	108.17	8	108.24
K-3-1-54	111.609	108.1	8	108.168
K-3-1-55	111.509	108.01	9.87	108.089
K-3-1-55-1	111.845	110.44	0.62	110.457
K-3-1-55-10	111.741	109.53	1.19	109.545
K-3-1-55-2	111.663	110.26	0.62	110.28
K-3-1-55-3	111.653	110.18	0.62	110.2
K-3-1-55-4	111.937	110.13	0.62	110.15
K-3-1-55-5	111.599	110.08	0.62	110.1
K-3-1-55-6	111.713	110	0.62	110.02
K-3-1-55-7	111.87	109.9	1.19	109.927
K-3-1-55-8	111.872	109.75	1.19	109.777

Emërtimi	Kuota e Tokës (m)	Kuota e Tabanit (m)	Prurja Hyrëse (L/s)	Lartësia e Ujit në Pusetë (m)
K-3-1-55-9	111.801	109.6	1.19	109.63
K-3-1-56	111.115	107.96	9.87	108.032
K-3-1-57	110.711	107.87	9.88	107.945
K-3-1-58	110.577	107.81	9.88	107.883
K-3-1-59	110.447	107.7	9.89	107.776
K-3-1-60	110.394	107.66	11.04	107.739
K-3-1-61	110.335	107.6	11.04	107.679
K-3-1-62	110.294	107.57	11.04	107.647
K-3-1-63	110.246	107.53	11.05	107.61
K-3-1-64	110.144	107.49	11.05	107.574
K-3-1-65	110.056	107.4	11.29	107.451
K-3-1-66	110.043	107.05	11.63	107.13
K-3-1-66-1	111.601	110.201	0	110.201
K-3-1-66-10	110.47	108.663	0.33	108.678
K-3-1-66-11	109.877	108.496	0.33	108.511
K-3-1-66-12	109.901	108.379	0.33	108.394
K-3-1-66-2	111.302	109.902	0	109.902
K-3-1-66-3	110.553	109.153	0	109.153
K-3-1-66-4	110.702	109.013	0	109.013
K-3-1-66-5	110.66	108.973	0	108.973
K-3-1-66-6	110.554	108.923	0	108.923
K-3-1-66-7	110.115	108.715	0	108.715
K-3-1-66-8	110.115	108.7	0	108.7
K-3-1-66-9	110.1	108.68	0	108.68
K-3-1-67	109.95	106.98	12.06	107.064
K-3-1-68	109.797	106.96	12.07	107.04
K-3-1-69	109.581	106.89	12.07	106.975
K-3-1-70	109.435	106.82	12.08	106.9
K-3-1-71	109.282	106.74	12.51	106.824
K-3-1-72	109.33	106.7	12.52	106.789
K-3-1-73	109.067	106.63	12.52	106.691
K-3-2-1	130.281	128.158	0.93	128.184
K-3-2-1-1	130.246	128.846	0	128.846
K-3-2-1-2	129.823	128.423	0	128.423
K-3-2-1-3	129.778	128.325	0	128.325
K-3-2-10	125.633	124.23	1.65	124.261
K-3-2-11	125.49	124.09	1.65	124.114
K-3-2-12	125.269	123.84	1.65	123.864
K-3-2-13	125.137	123.69	1.65	123.715
K-3-2-14	124.912	123.51	1.66	123.529
K-3-2-15	124.399	122.97	2.08	122.996

Emërtimi	Kuota e Tokës (m)	Kuota e Tabanit (m)	Prurja Hyrëse (L/s)	Lartësia e Ujit në Pusetë (m)
K-3-2-16	123.993	122.59	2.08	122.62
K-3-2-17	124	122.34	2.56	122.37
K-3-2-17-1	124.007	122.607	0	122.607
K-3-2-18	123.358	121.94	2.56	121.97
K-3-2-19	122.903	121.5	3.7	121.552
K-3-2-19-1	123.761	122.36	0.71	122.375
K-3-2-19-2	123.452	121.96	0.71	121.978
K-3-2-19-3	123.162	121.76	0.71	121.777
K-3-2-19-4	123.042	121.64	0.71	121.655
K-3-2-2	129.555	128.024	0.94	128.04
K-3-2-20	122.737	121.32	4.71	121.347
K-3-2-20-1	123.409	122	0.24	122.009
K-3-2-20-2	123.215	121.74	0.24	121.754
K-3-2-20-3	123.08	121.65	0.24	121.659
K-3-2-20-4	127.351	125.41	0.52	125.418
K-3-2-20-5	124.806	123.41	0.52	123.419
K-3-2-20-6	123.355	121.91	0.52	121.922
K-3-2-21	121.517	120.07	4.71	120.107
K-3-2-22	120.833	119.35	4.71	119.396
K-3-2-23	120.574	119.17	5.28	119.228
K-3-2-24	120.521	119.09	5.28	119.139
K-3-2-25	120.335	118.94	5.29	118.987
K-3-2-25-1	119.246	117.85	0.33	117.86
K-3-2-25-2	118.449	116.95	0.33	116.965
K-3-2-25-3	118.232	116.784	0.33	116.799
K-3-2-25-4	118.325	116.619	0.33	116.634
K-3-2-26	120.206	118.8	5.29	118.841
K-3-2-27	119.928	118.52	5.29	118.565
K-3-2-28	119.622	118.22	5.29	118.259
K-3-2-29	119.362	117.88	5.67	117.92
K-3-2-29-1	118.401	117.001	0.33	117.017
K-3-2-29-2	118.225	116.825	0.33	116.834
K-3-2-29-3	116.98	115.4	0.33	115.415
K-3-2-29-4	116.881	115.229	0.33	115.243
K-3-2-3	128.741	127.28	0.94	127.299
K-3-2-30	119.324	117.76	5.67	117.818
K-3-2-31	119.516	117.66	5.67	117.718
K-3-2-32	119.986	117.56	5.68	117.617
K-3-2-33	120.284	117.47	5.68	117.53
K-3-2-34	120.418	117.44	5.68	117.497
K-3-2-35	119.995	117.32	5.68	117.378

Emërtimi	Kuota e Tokës (m)	Kuota e Tabanit (m)	Prurja Hyrëse (L/s)	Lartësia e Ujit në Pusetë (m)
K-3-2-36	119.835	117.28	5.69	117.338
K-3-2-37	119.46	117.15	5.69	117.208
K-3-2-38	119.38	117.05	5.69	117.108
K-3-2-39	119.353	116.95	5.69	117.019
K-3-2-4	128.493	127.06	0.94	127.08
K-3-2-40	119.218	116.91	5.7	116.941
K-3-2-41	118.914	116.45	6.03	116.487
K-3-2-42	117.883	115.82	6.03	115.866
K-3-2-43	117.296	115.437	6.04	115.474
K-3-2-44	117.185	115.04	6.37	115.098
K-3-2-45	117.005	115	6.38	115.063
K-3-2-46	116.895	114.943	6.38	115.003
K-3-2-47	116.804	114.87	6.38	114.936
K-3-2-48	116.522	114.83	6.38	114.867
K-3-2-49	116.013	114.31	6.91	114.371
K-3-2-49-1	115.84	114.44	0.52	114.458
K-3-2-49-2	115.959	114.35	0.52	114.371
K-3-2-5	128.221	126.82	0.94	126.839
K-3-2-50	115.896	114.28	6.91	114.347
K-3-2-51	115.813	114.25	6.91	114.296
K-3-2-52	115.518	113.99	6.91	114.034
K-3-2-53	115.351	113.85	6.92	113.912
K-3-2-54	115.352	113.81	6.92	113.873
K-3-2-55	115.257	113.72	6.92	113.782
K-3-2-56	115.185	113.68	6.92	113.747
K-3-2-57	115.098	113.64	6.92	113.681
K-3-2-58	114.88	113.37	6.93	113.411
K-3-2-59	114.739	113.25	6.93	113.295
K-3-2-6	127.838	126.42	0.94	126.435
K-3-2-60	114.568	113.07	6.93	113.125
K-3-2-61	114.507	113	6.93	113.044
K-3-2-62	114.295	112.71	6.93	112.745
K-3-2-63	113.974	112.47	6.93	112.505
K-3-2-64	113.652	112.11	6.93	112.167
K-3-2-64-1	110.364	108.557	0.33	108.564
K-3-2-65	113.537	112.03	6.93	112.073
K-3-2-66	113.093	111.61	6.94	111.654
K-3-2-67	112.849	111.4	6.94	111.443
K-3-2-68	112.755	111.25	6.94	111.297
K-3-2-68-1	125.014	123.6	0	123.6
K-3-2-68-2	124.17	122.7	0	122.7

Emërtimi	Kuota e Tokës (m)	Kuota e Tabanit (m)	Prurja Hyrëse (L/s)	Lartësia e Ujit në Pusetë (m)
K-3-2-68-3	122.675	120.84	0	120.84
K-3-2-68-4	121.493	119.73	0	119.73
K-3-2-68-5	117.227	115.73	0	115.73
K-3-2-68-6	115.355	113.82	0	113.82
K-3-2-68-7	113.989	112.59	0	112.59
K-3-2-68-8	113.117	111.72	0	111.72
K-3-2-69	112.542	111.04	7.18	111.087
K-3-2-69-1	116.182	114.02	0.24	114.026
K-3-2-69-2	112.911	111.22	0.24	111.233
K-3-2-7	127.461	126.09	0.94	126.106
K-3-2-70	112.375	110.85	7.18	110.896
K-3-2-71	112.188	110.56	7.18	110.608
K-3-2-72	111.624	110.12	7.81	110.162
K-3-2-72-1	123.238	121.84	0.24	121.85
K-3-2-72-10	111.658	110.424	0.62	110.44
K-3-2-72-2	123.037	121.62	0.24	121.63
K-3-2-72-3	123.285	121.29	0.24	121.3
K-3-2-72-4	123.379	121.1	0.24	121.11
K-3-2-72-5	122.931	121.01	0.24	121.02
K-3-2-72-6	122.592	120.9	0.24	120.91
K-3-2-72-7	122.061	117.46	0.62	117.469
K-3-2-72-8	115.856	112.6	0.62	112.609
K-3-2-72-9	112.382	110.98	0.62	110.991
K-3-2-73	111.095	109.49	7.81	109.542
K-3-2-73-1	138.606	134.17	0.24	134.176
K-3-2-73-2	132.566	129.53	0.24	129.536
K-3-2-73-3	129.433	127.3	0.24	127.306
K-3-2-73-4	127.169	124.28	0.24	124.286
K-3-2-73-5	123.909	121.47	0.24	121.476
K-3-2-73-6	120.866	119.47	0.24	119.476
K-3-2-73-7	118.904	114.88	0.24	114.886
K-3-2-73-8	112.817	110.88	0.24	110.886
K-3-2-74	110.758	109.146	7.81	109.19
K-3-2-75	110.158	108.56	8.29	108.6
K-3-2-75-1	115.221	112.78	0.48	112.788
K-3-2-75-2	110.809	108.78	0.48	108.798
K-3-2-75-3	110.169	108.66	0.48	108.677
K-3-2-76	109.942	108.41	8.29	108.45
K-3-2-77	109.699	108.28	8.29	108.32
K-3-2-78	109.499	107.9	8.63	107.971
K-3-2-78-1	110.892	109.49	0.33	109.499

Emërtimi	Kuota e Tokës (m)	Kuota e Tabanit (m)	Prurja Hyrëse (L/s)	Lartësia e Ujit në Pusetë (m)
K-3-2-78-2	110.637	109.21	0.33	109.219
K-3-2-78-3	110.528	109.06	0.33	109.069
K-3-2-78-4	109.888	108.49	0.33	108.501
K-3-2-79	109.462	107.86	8.63	107.93
K-3-2-8	126.801	125.4	0.94	125.417
K-3-2-80	109.421	107.81	8.63	107.877
K-3-2-81	109.33	107.73	8.92	107.778
K-3-2-81-1	111.277	109.88	0.29	109.887
K-3-2-82	109	107.312	8.93	107.388
K-3-2-83	108.975	107.277	9.26	107.313
K-3-2-84	108.983	106.93	9.5	107.005
K-3-2-84-1	108.532	107.1	0.24	107.113
K-3-2-85	108.764	106.89	9.51	106.963
K-3-2-86	108.629	106.85	9.51	106.923
K-3-2-87	108.718	106.8	9.51	106.873
K-3-2-88	108.747	106.75	9.52	106.826
K-3-2-89	108.672	106.73	9.52	106.804
K-3-2-9	126.015	124.58	1.41	124.6
K-3-2-90	108.639	106.67	9.52	106.741
K-3-2-91	110.659	106.62	9.91	106.697
K-3-2-92	110.795	106.53	9.91	106.603
K-3-2-93	110.767	106.47	10.16	106.544
K-3-2-94	110.844	106.41	10.16	106.485
K-3-2-95	110.572	106.35	10.16	106.425
K-3-2-96	109.794	106.29	10.17	106.365
K-3-2-97	109.145	106.24	24.85	106.328
K-3-3-1	143.404	142	0.29	142.008
K-3-3-10	129.187	127.72	0.38	127.728
K-3-3-11	126.527	125.72	0.38	125.728
K-3-3-12	126.407	125.02	0.38	125.027
K-3-3-13	125.362	123.85	0.38	123.857
K-3-3-14	123.134	121.6	0.38	121.607
K-3-3-15	120.765	118.29	0.38	118.297
K-3-3-16	118.775	116.79	0.38	116.797
K-3-3-17	116.692	114.61	0.52	114.62
K-3-3-18	114.512	112.99	1.33	113.014
K-3-3-19	114.071	112.67	1.34	112.7
K-3-3-19-1	125.35	123.95	0.24	123.958
K-3-3-19-10	114.428	113.03	0.33	113.045
K-3-3-19-2	124.842	123.24	0.24	123.246
K-3-3-19-3	121.139	118.42	0.24	118.426

Emërtimi	Kuota e Tokës (m)	Kuota e Tabanit (m)	Prurja Hyrëse (L/s)	Lartësia e Ujit në Pusetë (m)
K-3-3-19-4	117.961	116.42	0.24	116.426
K-3-3-19-5	115.818	114.42	0.24	114.427
K-3-3-19-5-1	116.374	114.97	0.1	114.974
K-3-3-19-6	114.874	113.42	0.24	113.431
K-3-3-19-7	114.703	113.3	0.33	113.315
K-3-3-19-8	114.602	113.19	0.33	113.204
K-3-3-19-9	114.506	113.1	0.33	113.115
K-3-3-2	141.986	140.59	0.29	140.596
K-3-3-20	114.045	112.61	1.34	112.632
K-3-3-21	113.752	112.31	1.34	112.332
K-3-3-22	113.331	111.93	1.73	111.955
K-3-3-23	112.956	111.56	1.73	111.591
K-3-3-24	112.807	111.41	1.73	111.43
K-3-3-24-1	112.269	111.008	0.38	111.024
K-3-3-24-2	112.328	110.841	0.38	110.857
K-3-3-25	112.589	110.691	2.11	110.724
K-3-3-26	112.454	110.602	2.12	110.636
K-3-3-27	111.918	110.52	2.12	110.557
K-3-3-28	112.714	110.46	2.12	110.495
K-3-3-29	113.335	110.33	2.12	110.366
K-3-3-3	140.065	137.97	0.29	137.976
K-3-3-30	113.002	110.21	2.12	110.246
K-3-3-31	112.869	110.08	2.13	110.116
K-3-3-32	112.361	109.96	2.13	109.996
K-3-3-33	112.097	109.83	2.13	109.866
K-3-3-34	111.629	109.71	2.13	109.746
K-3-3-35	111.611	109.58	2.14	109.615
K-3-3-36	111.343	109.46	2.14	109.499
K-3-3-37	110.912	109.33	2.14	109.356
K-3-3-38	110.243	108.84	2.14	108.857
K-3-3-39	109.263	107.85	2.14	107.872
K-3-3-4	137.628	135.97	0.29	135.976
K-3-3-40	108.84	107.43	2.14	107.46
K-3-3-41	108.772	107.27	2.14	107.297
K-3-3-42	108.569	107.07	2.14	107.087
K-3-3-5	136.52	135.01	0.38	135.017
K-3-3-5-1	137.923	136.52	0.1	136.524
K-3-3-6	135.211	133.81	0.38	133.818
K-3-3-7	132.639	131.27	0.38	131.278
K-3-3-8	131.274	129.83	0.38	129.837
K-3-3-9	130.148	128.72	0.38	128.727

Emërtimi	Kuota e Tokës (m)	Kuota e Tabanit (m)	Prurja Hyrëse (L/s)	Lartësia e Ujit në Pusetë (m)
K.2.4.15	128.051	125.363	1.68	125.395
KR-1-1	92.692	91.2	0.1	91.208
KR-1-10	90.038	88.633	1.91	88.667
KR-1-11	89.72	88.452	1.92	88.489
KR-1-12	89.772	88.317	1.92	88.338
KR-1-13	88.51	87	1.92	87.018
KR-1-14	87.692	86.1	1.92	86.136
KR-1-15	88.281	86.026	1.92	86.043
KR-1-2	92.469	91	0.1	91.005
KR-1-3	92.386	90.223	0.29	90.237
KR-1-3-2	91.968	90.442	0.1	90.45
KR-1-3-3	91.913	90.344	0.1	90.352
KR-1-4	92.301	90.059	0.29	90.073
KR-1-5	91.984	89.91	1.02	89.935
KR-1-5-1	92.998	91.598	0.1	91.606
KR-1-5-10	92.509	90.702	0.26	90.715
KR-1-5-11	92.347	90.676	0.26	90.689
KR-1-5-12	92.411	90.604	0.26	90.617
KR-1-5-13	92.377	90.57	0.51	90.588
KR-1-5-14	92.23	90.423	0.51	90.441
KR-1-5-15	92.209	90.402	0.51	90.42
KR-1-5-16	92.123	90.316	0.64	90.336
KR-1-5-17	92.123	90.153	0.73	90.174
KR-1-5-2	93.32	91.513	0.1	91.521
KR-1-5-3	93.29	91.483	0.1	91.491
KR-1-5-4	93.211	91.404	0.1	91.412
KR-1-5-5	93.119	91.312	0.1	91.32
KR-1-5-6	93.095	91.288	0.1	91.296
KR-1-5-7	93.459	91.161	0.1	91.169
KR-1-5-8	93.216	91.135	0.25	91.148
KR-1-5-9	92.587	90.78	0.25	90.793
KR-1-6	91.772	89.811	1.31	89.839
KR-1-7	91.453	89.68	1.34	89.709
KR-1-8	90.816	89.496	1.6	89.519
KR-1-9	90.197	88.797	1.6	88.828
KR-1-9-1	91.94	90.54	0.1	90.548
KR-2-1	92.065	90.6	0.22	90.613
KR-2-2	92.453	90.47	0.22	90.478
KR-3-1	92.613	91.213	0.06	91.22
KR-3-10	90.725	88.879	0.22	88.891
KR-3-11	90.588	88.781	0.22	88.793

Emërtimi	Kuota e Tokës (m)	Kuota e Tabanit (m)	Prurja Hyrëse (L/s)	Lartësia e Ujit në Pusetë (m)
KR-3-12'	91.398	88.72	0.32	88.735
KR-3-13	90.748	88.586	0.32	88.601
KR-3-14	91.032	88.429	0.32	88.444
KR-3-15	90.776	88.332	0.32	88.347
KR-3-16	90.957	88.228	0.35	88.243
KR-3-16-1	92.039	90.232	0.19	90.244
KR-3-16-10	90.28	88.615	0.51	88.634
KR-3-16-2	91.502	90.102	0.19	90.114
KR-3-16-3	91.326	89.939	0.19	89.951
KR-3-16-4	91.635	89.828	0.29	89.843
KR-3-16-5	91.59	89.783	0.29	89.792
KR-3-16-6	90.802	89.402	0.29	89.413
KR-3-16-7	90.436	89.036	0.29	89.047
KR-3-16-8	90.205	88.805	0.29	88.819
KR-3-16-9	90.103	88.703	0.29	88.717
KR-3-17	90.495	88.049	0.35	88.066
KR-3-18	89.925	87.893	0.35	87.902
KR-3-19	87.459	85.95	0.45	85.961
KR-3-2	92.436	91.116	0.06	91.124
KR-3-20	87.039	84.854	0.45	84.871
KR-3-20-1	86.498	85.098	0	85.098
KR-3-20-2	86.836	84.962	0	84.962
KR-3-21	87.342	84.689	0.74	84.711
KR-3-22	87.542	84.623	0.74	84.645
KR-3-23	87.478	84.55	1.54	84.581
KR-3-23-1	89.437	88.037	0.16	88.048
KR-3-23-2	89.381	87.877	0.16	87.888
KR-3-23-3	89.746	87.715	0.16	87.726
KR-3-23-4	89.846	87.616	0.8	87.639
KR-3-23-5	89.247	87.44	0.8	87.464
KR-3-23-6	88.789	87.343	0.8	87.36
KR-3-23-7	88.42	87.02	0.8	87.037
KR-3-23-8	87.95	86.55	0.8	86.561
KR-3-24	87.478	84.53	1.54	84.561
KR-3-25	87.478	84.414	1.54	84.445
KR-3-26	87.478	84.298	1.54	84.329
KR-3-27	86.145	84.087	1.54	84.118
KR-3-28	86.204	83.808	1.54	83.839
KR-3-29	86.45	83.556	1.73	83.589
KR-3-3	92.226	91.018	0.06	91.022
KR-3-30	86.483	83.24	1.74	83.273

Emërtimi	Kuota e Tokës (m)	Kuota e Tabanit (m)	Prurja Hyrëse (L/s)	Lartësia e Ujit në Pusetë (m)
KR-3-31	86.681	82.968	1.74	83.001
KR-3-32	86.877	82.638	3.66	82.684
KR-3-4	91.823	90.423	0.06	90.428
KR-3-5	91.328	89.928	0.06	89.933
KR-3-6	90.972	89.571	0.22	89.58
KR-3-7	90.588	89.188	0.22	89.2
KR-3-8	90.955	89.074	0.22	89.086
KR-3-9	90.922	88.976	0.22	88.988
KR-4-1	92.408	91	0.19	91.012
KR-4-10	92.659	89.901	1.05	89.927
KR-4-11	92.631	89.77	1.05	89.796
KR-4-12	92.583	89.607	1.05	89.633
KR-4-13	92.561	89.559	1.05	89.585
KR-4-14	92.615	89.51	1.05	89.536
KR-4-15	92.802	89.396	1.09	89.419
KR-4-2	92.368	90.911	0.19	90.923
KR-4-3	92.588	90.781	0.19	90.793
KR-4-4	92.673	90.65	0.48	90.668
KR-4-5	92.754	90.52	0.48	90.538
KR-4-6	92.799	90.389	0.73	90.411
KR-4-7	92.782	90.259	0.73	90.281
KR-4-8	92.758	90.162	0.73	90.184
KR-4-9	92.684	90.031	0.73	90.053
U-1-1	130.105	126.278	5.99	126.337
U-1-10	129.311	124.862	13.03	124.949
U-1-11	129.196	124.788	13.24	124.876
U-1-12	129.245	124.674	13.25	124.762
U-1-13	129.013	124.588	13.47	124.676
U-1-14	128.53	124.44	14.1	124.53
U-1-15	128.44	124.318	14.11	124.408
U-1-16	128.338	124.231	14.33	124.322
U-1-17	128.238	124.145	14.55	124.237
U-1-18	128.337	124.029	15.39	124.123
U-1-19	128.646	123.905	15.4	124
U-1-2	130.149	126.17	6.16	126.23
U-1-20	128.511	123.819	15.41	123.913
U-1-3	130.033	126.087	6.16	126.147
U-1-4	129.911	126.005	6.48	126.071
U-1-5	129.605	125.874	6.85	125.916
U-1-6	129.395	125.234	8.53	125.304
U-1-7	129.362	125.154	8.54	125.224

Emërtimi	Kuota e Tokës (m)	Kuota e Tabanit (m)	Prurja Hyrëse (L/s)	Lartësia e Ujit në Pusetë (m)
U-1-8	129.247	125.08	8.7	125.151
U-1-9	129.245	124.936	13.02	125.023
U-2-1	133.984	132.484	39.55	132.646
U-2-10	133.15	131.19	41.07	131.343
U-2-11	133.031	131.153	41.59	131.306
U-2-12	132.903	131.073	41.6	131.226
U-2-13	132.848	130.973	41.6	131.126
U-2-14	132.952	130.873	42.08	131.027
U-2-15	132.888	130.773	42.08	130.943
U-2-16	132.287	130.673	42.09	130.758
U-2-17	131.172	129.572	42.09	129.654
U-2-18	129.982	128.382	42.09	128.474
U-2-19	129.16	127.56	42.09	127.647
U-2-2	134.299	132.359	39.55	132.478
U-2-20	128.217	126.617	42.09	126.704
U-2-21	127.266	125.666	42.09	125.764
U-2-22	126.918	125.318	42.09	125.421
U-2-23	126.645	125.045	42.09	125.131
U-2-24	125.497	123.897	43.45	123.994
U-2-25	124.821	123.221	43.45	123.316
U-2-26	124.112	122.512	43.44	122.619
U-2-27	123.671	122.071	43.44	122.178
U-2-28	123.204	121.604	43.44	121.706
U-2-29	122.646	121.046	43.44	121.146
U-2-3	133.968	132.028	39.56	132.173
U-2-30	121.992	119.392	43.43	119.494
U-2-31	121.19	119.19	44.11	119.322
U-2-32	121.077	119.077	44.09	119.16
U-2-33	120.532	118.532	44.09	118.627
U-2-34	120.256	118.256	44.08	118.33
U-2-35	119.88	117.7	44.07	117.774
U-2-4	133.408	131.908	39.56	132.041
U-2-5	133.757	131.77	39.57	131.919
U-2-6	133.754	131.73	39.57	131.879
U-2-7	133.702	131.69	39.57	131.839
U-2-8	133.617	131.62	39.58	131.769
U-2-9	133.423	131.56	39.58	131.711

2 Tabela e Pompave

Emërtimi	Kuota e Tokës (m)	Kuota e Tabanit (m)	Kuota (On) (m)	Kuota (Off) (m)	Prurja (L/s)	Lartësia e Pompës (m)	Vija e Energjisë (m)	Vija e Energjisë (Shkarkim) (m)
PMP-1	123	118.7	119.15	119.65	39.54	37.481	119.05	156.531
PMP-2	109.162	105.6	106.1	105.5	24.85	17.867	105.5	123.367

3 Tabelat e Tubacioneve

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
DH-1-7'	DH-1-7"	147.502	DH-1-8	144.917	40	0.0646	284.8	DN315 CHDPE SN8	0.54	0.78	278.15	3.48
DH.1.1	DH-1-1	164.1	DH-1-2	163.1	12	0.0833	284.8	DN315 CHDPE SN8	0.16	0.66	315.91	1.71
DH.1.10	DH-1-10	138.561	DH-1-11	136.084	41.8	0.0592	284.8	DN315 CHDPE SN8	1.14	0.94	266.32	5.02
DH.1.11	DH-1-11	136.084	DH-1-12	133.909	41.2	0.0528	284.8	DN315 CHDPE SN8	1.4	1.03	251.48	5.42
DH.1.12	DH-1-12	133.909	DH-1-13	132.31	35	0.0457	284.8	DN315 CHDPE SN8	1.4	0.94	233.92	5.78
DH.1.13	DH-1-13	132.31	DH-1-14	130.598	39	0.0439	284.8	DN315 CHDPE SN8	1.65	1.02	229.28	6.16
DH.1.14	DH-1-14	130.598	DH-1-15	128.72	39.2	0.0479	284.8	DN315 CHDPE SN8	1.87	1.06	239.48	6.52
DH.1.15	DH-1-15	128.72	DH-1-16	128.031	15.8	0.0436	284.8	DN315 CHDPE SN8	2.1	1.01	228.53	7.25
DH.1.15.1	DH-1-15-1	129.434	DH-1-15	128.72	29.8	0.024	284.8	DN315 CHDPE SN8	0.1	0.1	169.47	4.3
DH.1.16	DH-1-16	128.031	DH-1-17	127.501	15	0.0353	284.8	DN315 CHDPE SN8	2.35	1.13	205.71	7.27
DH.1.16.2	DH-1-16-1	129.963	DH-1-16-2	129.075	18	0.0493	284.8	DN315 CHDPE SN8	0.13	0.44	243.07	1.94
DH.1.16.3	DH-1-16-2	129.075	DH-1-16-3	128.365	30	0.0237	284.8	DN315 CHDPE SN8	0.13	0.33	168.35	2.34
DH.1.16.4	DH-1-16-3	128.365	DH-1-16	128.031	33	0.0101	284.8	DN315 CHDPE SN8	0.13	0.1	110.17	5.15
DH.1.16.4"	DH-1-16-4	128.6	DH-1-16-5	128.253	14.6	0.0237	284.8	DN315 CHDPE SN8	0.06	0.28	168.43	1.64
DH.1.16.5	DH-1-16-5	128.253	DH-1-16	128.031	18.3	0.0121	284.8	DN315 CHDPE SN8	0.06	0.06	120.39	4.76
DH.1.17	DH-1-17	127.501	DH-1-18	124.926	48.3	0.0533	284.8	DN315 CHDPE SN8	2.35	0.49	252.76	12.86
DH.1.18	DH-1-18	124.926	DH-1-19	124.893	10	0.0033	284.8	DN315 CHDPE SN8	4.56	0.63	62.87	17.12
DH.1.18.1	DH-1-18-1	127.257	DH-1-18-2	126.591	30	0.0222	284.8	DN315 CHDPE SN8	0.1	0.41	163.05	1.67
DH.1.18.2	DH-1-18-2	126.591	DH-1-18	124.926	20.7	0.0806	284.8	DN315 CHDPE SN8	0.1	0.03	310.61	10.13
DH.1.19	DH-1-19	124.893	Lidhja me Rrjetin Ekz.	124.8	13.8	0.0067	284.8	DN315 CHDPE SN8	4.56	0.74	89.81	15.31
DH.1.2	DH-1-2	163.1	DH-1-3	158.77	45	0.0962	284.8	DN315 CHDPE SN8	0.16	0.67	339.46	1.68
DH.1.3	DH-1-3	157.6	DH-1-4	153.227	40	0.1093	284.8	DN315 CHDPE SN8	0.35	0.8	361.84	2.55

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
DH.1.4	DH-1-4	153.227	DH-1-5	152.06	20	0.0584	284.8	DN315 CHDPE SN8	0.35	0.59	264.35	3.12
DH.1.5	DH-1-5	152.06	DH-1-6	151.483	25	0.0231	284.8	DN315 CHDPE SN8	0.35	0.56	166.25	3.22
DH.1.6	DH-1-6	151.483	DH-1-7	150.932	13	0.0424	284.8	DN315 CHDPE SN8	0.35	0.63	225.3	3
DH.1.7	DH-1-7	150.932	DH-1-7"	147.502	40	0.0857	284.8	DN315 CHDPE SN8	0.54	0.89	320.46	3.16
DH.1.8	DH-1-8	144.917	DH-1-9	141.164	45	0.0834	284.8	DN315 CHDPE SN8	0.79	0.96	316.04	3.9
DH.1.9	DH-1-9	141.164	DH-1-10	138.561	50	0.0521	284.8	DN315 CHDPE SN8	0.79	0.79	249.69	4.41
DH.2.1	DH-2-1	138.3	DH-2-2	136.009	25	0.0916	284.8	DN315 CHDPE SN8	0.13	0.58	331.28	1.59
DH.2.10	DH-2-10	130.817	DH-2-11	130.718	30	0.0033	284.8	DN315 CHDPE SN8	0.29	0.22	62.87	5.21
DH.2.11	DH-2-11	130.718	DH-2-12	130.652	20	0.0033	284.8	DN315 CHDPE SN8	0.38	0.27	62.87	5.57
DH.2.12	DH-2-12	130.652	DH-2-13	130.536	35	0.0033	284.8	DN315 CHDPE SN8	0.38	0.27	63	5.57
DH.2.13	DH-2-13	130.536	DH-2-14	130.47	20	0.0033	284.8	DN315 CHDPE SN8	0.38	0.27	62.87	5.58
DH.2.14	DH-2-14	130.47	DH-2-15	130.411	18	0.0033	284.8	DN315 CHDPE SN8	0.38	0.25	62.65	6.01
DH.2.15	DH-2-15	130.411	DH-2-16	130.345	20	0.0033	284.8	DN315 CHDPE SN8	0.52	0.3	62.87	6.43
DH.2.16	DH-2-16	130.345	DH-2-18	130.147	60	0.0033	284.8	DN315 CHDPE SN8	0.52	0.3	62.88	6.43
DH.2.18	DH-2-18	130.147	DH-2-19	130.009	41.7	0.0033	284.8	DN315 CHDPE SN8	0.52	0.28	62.95	6.69
DH.2.19	DH-2-19	130.009	DH-2-20	129.763	12	0.0205	284.8	DN315 CHDPE SN8	1.22	0.86	156.69	5.62
DH.2.19.1	DH-2-19-1	139.4	DH-2-19-2	138.065	50.2	0.0266	284.8	DN315 CHDPE SN8	0.1	0.31	178.54	2.03
DH.2.19.2	DH-2-19-2	138.065	DH-2-19-3	137.578	50	0.0097	284.8	DN315 CHDPE SN8	0.1	0.22	108	2.51
DH.2.19.3	DH-2-19-3	137.578	DH-2-19-4	137.076	35.6	0.0141	284.8	DN315 CHDPE SN8	0.16	0.39	130.04	2.44
DH.2.19.4	DH-2-19-4	137.076	DH-2-19-5	135.103	54.8	0.036	284.8	DN315 CHDPE SN8	0.16	0.32	207.6	2.76
DH.2.19.5	DH-2-19-5	135.103	DH-2-19-6	132.829	24.6	0.0924	284.8	DN315 CHDPE SN8	0.7	1.04	332.66	3.4
DH.2.19.5.1	DH-2-19-5-1	143.3	DH-2-19-5-2	142.11	22	0.0541	284.8	DN315 CHDPE SN8	0.22	0.65	254.52	2.17
DH.2.19.5.2	DH-2-19-5-2	142.11	DH-2-19-5-3	138.6	40	0.0877	284.8	DN315 CHDPE SN8	0.22	0.65	324.18	2.18
DH.2.19.5.3	DH-2-19-5-3	138.6	DH-2-19-5-4	136	55.2	0.0471	284.8	DN315 CHDPE SN8	0.22	0.34	237.54	3.32
DH.2.19.5.4	DH-2-19-5-4	136	DH-2-19-5-5	135.654	35	0.0099	284.8	DN315 CHDPE SN8	0.38	0.4	108.81	4.26
DH.2.19.5.5	DH-2-19-5-5	135.654	DH-2-19-5-6	135.374	26	0.0108	284.8	DN315 CHDPE SN8	0.38	0.35	113.57	4.71

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
DH.2.19.5.6	DH-2-19-5-6	135.374	DH-2-19-5	135.103	22.4	0.0121	284.8	DN315 CHDPE SN8	0.54	0.56	120.41	4.3
DH.2.19.6	DH-2-19-6	132.063	DH-2-19	130.009	15.1	0.136	284.8	DN315 CHDPE SN8	0.7	0.58	403.59	5.02
DH.2.2	DH-2-2	136.009	DH-2-3	134.777	20	0.0616	284.8	DN315 CHDPE SN8	0.13	0.49	271.61	1.8
DH.2.20	DH-2-20	129.763	DH-2-21	127.963	18	0.1	284.8	DN315 CHDPE SN8	1.22	1.08	346.06	4.77
DH.2.21	DH-2-21	127.963	DH-2-22	126.307	20	0.0828	284.8	DN315 CHDPE SN8	1.7	1.17	314.9	5.7
DH.2.21.1	DH-2-21-1	130.418	DH-2-21-2	129.701	15	0.0478	284.8	DN315 CHDPE SN8	0.29	0.5	239.17	3.03
DH.2.21.2	DH-2-21-2	129.701	DH-2-21-3	129.351	22	0.0159	284.8	DN315 CHDPE SN8	0.29	0.45	138.03	3.25
DH.2.21.3	DH-2-21-3	129.351	DH-2-21-4	128.815	22	0.0244	284.8	DN315 CHDPE SN8	0.29	0.47	170.82	3.18
DH.2.21.4	DH-2-21-4	128.815	DH-2-21-5	128.297	30	0.0173	284.8	DN315 CHDPE SN8	0.29	0.4	143.8	3.52
DH.2.21.5	DH-2-21-5	128.297	DH-2-21	127.963	32.3	0.0103	284.8	DN315 CHDPE SN8	0.29	0.28	111.25	4.49
DH.2.22	DH-2-22	126.307	DH-2-23	125.359	22	0.0431	284.8	DN315 CHDPE SN8	1.7	0.6	227.17	8.92
DH.2.23	DH-2-23	125.359	DH-2-24	125.26	30	0.0033	284.8	DN315 CHDPE SN8	1.82	0.44	62.87	11.69
DH.2.24	DH-2-24	125.26	DH-2-25	125.095	50	0.0033	284.8	DN315 CHDPE SN8	1.82	0.44	62.87	11.7
DH.2.25	DH-2-25	125.095	DH-2-26	125.029	20	0.0033	284.8	DN315 CHDPE SN8	1.83	0.44	62.87	11.7
DH.2.26	DH-2-26	125.029	DH-2-27	124.963	20	0.0033	284.8	DN315 CHDPE SN8	1.83	0.43	62.87	11.87
DH.2.27	DH-2-27	124.963	DH-1-18	124.926	11	0.0034	284.8	DN315 CHDPE SN8	1.95	0.31	63.51	15.48
DH.2.3	DH-2-3	134.777	DH-2-4	133.714	30	0.0354	284.8	DN315 CHDPE SN8	0.13	0.44	206	1.94
DH.2.4	DH-2-4	133.714	DH-2-5	132.88	25	0.0334	284.8	DN315 CHDPE SN8	0.13	0.33	199.88	2.35
DH.2.5	DH-2-5	132.88	DH-2-6	130.979	50	0.038	284.8	DN315 CHDPE SN8	0.29	0.36	213.38	3.8
DH.2.6	DH-2-6	130.979	DH-2-7	130.946	10	0.0033	284.8	DN315 CHDPE SN8	0.29	0.25	62.87	4.85
DH.2.7	DH-2-7	130.946	DH-2-8	130.87	23	0.0033	284.8	DN315 CHDPE SN8	0.29	0.25	62.91	4.86
DH.2.8	DH-2-8	130.87	DH-2-9	130.844	8	0.0033	284.8	DN315 CHDPE SN8	0.29	0.25	62.39	4.85
DH.2.9	DH-2-9	130.844	DH-2-10	130.817	8	0.0034	284.8	DN315 CHDPE SN8	0.29	0.25	63.58	4.84
K-3-1-43-1	K-3-1-43-1	117.2	K-3-1-43-2	116.75	30	0.015	284.8	DN315 CHDPE SN8	0.43	0.35	134.03	5.01
K-3-1-43-2	K-3-1-43-2	116.75	K-3-1-43	116.57	55	0.0033	284.8	DN315 CHDPE SN8	0.43	0.18	62.61	7.91
K-3-1-43-3	K-3-1-43-3	116.65	K-3-1-43	116.57	25	0.0032	284.8	DN400 CHDPE SN8	0	0	61.9	4.96

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
K-SP	K-1-2-7	119.723	W-1	119.7	10.7	0.0021	452.4	DN500 CHDPE SN8	39.54	0.93	174.2	31.07
K.1.1.1	K-1-1-1	125.35	K-1-1-2	124.82	50	0.0106	284.8	DN315 CHDPE SN8	0.6	0.38	112.67	6.07
K.1.1.10	K-1-1-10	123.45	K-1-1-11	122.969	19	0.0253	284.8	DN315 CHDPE SN8	1.13	0.12	174.12	20.57
K.1.1.10.1	K-1-1-10-1	123.853	K-1-1-10-2	123.718	40	0.0034	284.8	DN315 CHDPE SN8	0.16	0.22	63.58	3.54
K.1.1.10.2	K-1-1-10-2	123.718	K-1-1-10	123.45	50	0.0054	284.8	DN315 CHDPE SN8	0.16	0.15	80.12	4.52
K.1.1.11	K-1-1-11	122.969	K-1-1-12	122.78	30	0.0063	361.8	DN400 CHDPE SN8	25.25	1.21	164.43	25.72
K.1.1.11.1	K-1-1-11-1	135.567	K-1-1-11-2	134.532	35	0.0296	284.8	DN315 CHDPE SN8	0.84	0.62	188.19	5.38
K.1.1.11.10	K-1-1-11-10	123.587	K-1-1-11-11	123.499	35	0.0025	361.8	DN315 CHDPE SN8	21.39	0.79	103.87	30.83
K.1.1.11.11	K-1-1-11-11	123.499	K-1-1-11-12	123.398	40	0.0025	361.8	DN315 CHDPE SN8	21.55	0.8	104.14	30.86
K.1.1.11.11.1	K-1-1-11-11-1	125.379	K-1-1-11-11	125.247	40	0.0033	284.8	DN315 CHDPE SN8	0.16	0.24	62.87	3.3
K.1.1.11.12	K-1-1-11-12	123.398	K-1-1-11-13	123.304	37	0.0025	361.8	DN315 CHDPE SN8	21.56	0.79	104.41	31.22
K.1.1.11.13	K-1-1-11-13	123.304	K-1-1-11-14	123.145	63	0.0025	361.8	DN315 CHDPE SN8	22.52	0.79	104.04	31.99
K.1.1.11.13.1	K-1-1-11-13-1	124.837	K-1-1-11-13-2	124.672	50	0.0033	284.8	DN315 CHDPE SN8	0.31	0.26	62.93	5.07
K.1.1.11.13.1'	K-1-1-11-13-1'	124.969	K-1-1-11-13-1	124.837	40	0.0033	284.8	DN315 CHDPE SN8	0.31	0.26	62.87	5.06
K.1.1.11.13.2	K-1-1-11-13-2	124.672	K-1-1-11-13-3	124.589	25	0.0033	284.8	DN315 CHDPE SN8	0.31	0.26	62.93	5.07
K.1.1.11.13.3	K-1-1-11-13-3	124.589	K-1-1-11-13-4	124.49	30	0.0033	284.8	DN315 CHDPE SN8	0.32	0.25	62.93	5.17
K.1.1.11.13.4	K-1-1-11-13-4	124.49	K-1-1-11-13	124.374	35	0.0033	284.8	DN315 CHDPE SN8	0.32	0.27	62.93	4.87
K.1.1.11.14	K-1-1-11-14	123.145	K-1-1-11-15	123.057	35	0.0025	361.8	DN315 CHDPE SN8	23.58	0.8	103.9	32.79
K.1.1.11.14.1	K-1-1-11-14-1	124.458	K-1-1-11-14-2	124.392	20	0.0033	284.8	DN315 CHDPE SN8	0.52	0.3	62.84	6.46
K.1.1.11.14.2	K-1-1-11-14-2	124.392	K-1-1-11-14-3	124.268	37.5	0.0033	284.8	DN315 CHDPE SN8	0.52	0.3	62.84	6.47
K.1.1.11.14.3	K-1-1-11-14-3	124.268	K-1-1-11-14-4	124.104	50	0.0033	284.8	DN315 CHDPE SN8	0.52	0.3	62.84	6.47
K.1.1.11.14.4	K-1-1-11-14-4	124.104	K-1-1-11-14-5	123.939	50	0.0033	284.8	DN315 CHDPE SN8	0.52	0.29	62.84	6.58
K.1.1.11.14.5	K-1-1-11-14-5	123.939	K-1-1-11-14	123.807	40	0.0033	284.8	DN315 CHDPE SN8	0.53	0.32	62.76	6.19
K.1.1.11.15	K-1-1-11-15	123.057	K-1-1-11	122.969	35	0.0025	361.8	DN315 CHDPE SN8	23.59	0.89	103.9	30.52
K.1.1.11.2	K-1-1-11-2	134.532	K-1-1-11-3	133.805	20	0.0364	284.8	DN315 CHDPE SN8	1.46	0.94	208.65	5.99
K.1.1.11.3	K-1-1-11-3	133.805	K-1-1-11-4	132.743	30	0.0354	284.8	DN315 CHDPE SN8	1.46	0.79	205.9	6.74

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
K.1.1.11.4	K-1-1-11-4	132.743	K-1-1-11-5	131.304	50	0.0288	284.8	DN315 CHDPE SN8	2.09	0.93	185.65	7.67
K.1.1.11.5	K-1-1-11-5	131.304	K-1-1-11-6	130.618	30	0.0229	284.8	DN315 CHDPE SN8	2.09	0.82	165.48	8.36
K.1.1.11.6	K-1-1-11-6	130.618	K-1-1-11-7	129.263	55	0.0246	284.8	DN315 CHDPE SN8	2.77	1	171.8	8.83
K.1.1.11.7	K-1-1-11-7	129.263	K-1-1-11-8	128.272	40	0.0248	284.8	DN315 CHDPE SN8	2.77	0.97	172.25	9.05
K.1.1.11.8	K-1-1-11-8	128.272	K-1-1-11-9	127.459	40	0.0203	284.8	DN315 CHDPE SN8	2.78	0.94	156.02	9.23
K.1.1.11.9	K-1-1-11-9	123.719	K-1-1-11-9'	123.683	12	0.003	361.8	DN315 CHDPE SN8	19.38	0.78	113.54	29.16
K.1.1.11.9'.1	K-1-1-11-9'-1	135.728	K-1-1-11-9'-2	134.861	36	0.0241	284.8	DN315 CHDPE SN8	0.21	0.35	169.83	3.12
K.1.1.11.9'.2	K-1-1-11-9'-2	134.861	K-1-1-11-9'-3	133.676	36	0.0329	284.8	DN315 CHDPE SN8	0.47	0.65	198.55	3.58
K.1.1.11.9'.3	K-1-1-11-9'-3	133.676	K-1-1-11-9'-4	132.237	42	0.0343	284.8	DN315 CHDPE SN8	0.47	0.5	202.59	4.27
K.1.1.11.9'.4	K-1-1-11-9'-4	132.237	K-1-1-11-9'-5	130.802	45	0.0319	284.8	DN315 CHDPE SN8	0.94	0.63	195.42	5.82
K.1.1.11.9'.5	K-1-1-11-9'-5	130.802	K-1-1-11-9'-6	129.865	41	0.0229	284.8	DN315 CHDPE SN8	1.46	0.8	165.45	6.64
K.1.1.11.9'.6	K-1-1-11-9'-6	129.865	K-1-1-11-9'-7	128.676	50	0.0238	284.8	DN315 CHDPE SN8	1.47	0.83	168.75	6.52
K.1.1.11.9'.7	K-1-1-11-9'-7	128.676	K-1-1-11-9'	127.335	50	0.0268	284.8	DN315 CHDPE SN8	1.47	0.85	179.22	6.42
K.1.1.11.9.1	K-1-1-11-9-1	135.231	K-1-1-11-9-2	133.652	25	0.0632	284.8	DN315 CHDPE SN8	0.47	0.69	275.03	3.43
K.1.1.11.9.2	K-1-1-11-9-2	133.652	K-1-1-11-9-3	132.167	25	0.0594	284.8	DN315 CHDPE SN8	0.71	0.83	266.72	3.98
K.1.1.11.9.3	K-1-1-11-9-3	132.167	K-1-1-11-9-4	131.004	30	0.0388	284.8	DN315 CHDPE SN8	0.71	0.59	215.47	5.01
K.1.1.11.9.4	K-1-1-11-9-4	131.004	K-1-1-11-9-5	130.725	30	0.0093	284.8	DN315 CHDPE SN8	0.71	0.47	105.52	5.85
K.1.1.11.9.5	K-1-1-11-9-5	130.198	K-1-1-11-9-6	128.312	40	0.0472	284.8	DN315 CHDPE SN8	0.71	0.66	237.63	4.61
K.1.1.11.9.6	K-1-1-11-9-6	128.312	K-1-1-11-9-7	127.894	28	0.0149	284.8	DN315 CHDPE SN8	0.71	0.46	133.69	5.95
K.1.1.11.9.7	K-1-1-11-9-7	127.894	K-1-1-11-9-8	127.481	38	0.0109	284.8	DN315 CHDPE SN8	1.02	0.42	114.09	8.16
K.1.1.11.9.7.1	K-1-1-11-9-7-1	128.36	K-1-1-11-9-7	127.894	42	0.0111	284.8	DN315 CHDPE SN8	0.31	0.24	115.27	5.26
K.1.1.11.9.8(1)	K-1-1-11-9-8	127.481	K-1-1-11-9	127.435	13.8	0.0033	284.8	DN315 CHDPE SN8	1.19	0.4	63.24	9.27
K.1.1.12	K-1-1-12	122.78	K-1-1-13	122.48	30	0.01	361.8	DN400 CHDPE SN8	25.26	1.35	207.16	23.73
K.1.1.13	K-1-1-13	122.48	K-1-1-14	122.195	30	0.0095	361.8	DN400 CHDPE SN8	25.26	1.31	201.91	24.32
K.1.1.14	K-1-1-14	122.195	K-1-1-15	121.815	40	0.0095	361.8	DN400 CHDPE SN8	25.27	1.39	201.88	23.31

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
K.1.1.15	K-1-1-15	121.815	K-1-1-16	121.3	38	0.0136	361.8	DN400 CHDPE SN8	25.27	1.07	241.16	27.97
K.1.1.2	K-1-1-2	124.82	K-1-1-3	124.72	30	0.0033	284.8	DN315 CHDPE SN8	0.6	0.31	63.14	6.96
K.1.1.20	K-1-1-20	120.975	K-1-1-21	120.9	32.5	0.0023	361.8	DN400 CHDPE SN8	25.79	0.82	99.52	34.46
K.1.1.21	K-1-1-21	120.9	K-1-1-22	120.788	45	0.0025	361.8	DN400 CHDPE SN8	25.8	0.84	103.35	34
K.1.1.22	K-1-1-22	120.788	K-1-1-23	120.682	42	0.0025	361.8	DN400 CHDPE SN8	25.81	0.83	104.07	34.34
K.1.1.23	K-1-1-23	120.682	K-1-1-24	120.611	30	0.0024	361.8	DN400 CHDPE SN8	25.82	0.84	100.78	33.97
K.1.1.24	K-1-1-24	120.611	K-1-3-25	120.54	25.8	0.0028	361.8	DN400 CHDPE SN8	25.83	0.75	108.66	36.97
K.1.1.3	K-1-1-3	124.72	K-1-1-4	124.65	22	0.0032	284.8	DN315 CHDPE SN8	0.6	0.31	61.78	6.93
K.1.1.4	K-1-1-4	124.65	K-1-1-5	124.57	23.1	0.0035	284.8	DN315 CHDPE SN8	0.61	0.29	64.4	7.28
K.1.1.5	K-1-1-5	124.57	K-1-1-6	124.47	30	0.0033	284.8	DN315 CHDPE SN8	0.76	0.34	63.18	7.72
K.1.1.6	K-1-1-6	124.47	K-1-1-7	124.338	40	0.0033	284.8	DN315 CHDPE SN8	0.76	0.34	62.96	7.73
K.1.1.6.8.1	K-1-1-11-10-1	126.69	K-1-1-11-10	126.56	40	0.0033	284.8	DN315 CHDPE SN8	0.52	0.32	62.39	6.19
K.1.1.7	K-1-1-7	124.338	K-1-1-8	124.206	40	0.0033	284.8	DN315 CHDPE SN8	0.76	0.29	62.86	8.47
K.1.1.8	K-1-1-8	124.206	K-1-1-9	124.1	32	0.0033	284.8	DN315 CHDPE SN8	0.98	0.43	62.87	7.77
K.1.1.8.1	K-1-1-8-1	125.267	K-1-1-8	124.206	43	0.0247	284.8	DN315 CHDPE SN8	0.21	0.14	171.93	5.92
K.1.1.9	K-1-1-9	124.1	K-1-1-10	123.45	48	0.0135	284.8	DN315 CHDPE SN8	0.98	0.62	127.32	6.05
K.1.2.1	K-1-2-1	123.117	K-1-2-2	122.755	45	0.008	284.8	DN315 CHDPE SN8	0.84	0.47	98.15	6.54
K.1.2.2	K-1-2-2	122.755	K-1-2-3	122.515	30	0.008	284.8	DN315 CHDPE SN8	0.84	0.4	97.88	7.26
K.1.2.3	K-1-2-3	122.515	K-1-2-4	122.343	43	0.004	284.8	DN315 CHDPE SN8	0.84	0.4	69.22	7.27
K.1.2.4	K-1-2-4	122.343	K-1-2-5	122.18	20	0.0082	284.8	DN315 CHDPE SN8	0.84	0.48	98.8	6.45
K.1.2.5	K-1-2-5	122.18	K-1-2-6	121.975	22	0.0093	284.8	DN315 CHDPE SN8	0.84	0.4	105.64	7.33
K.1.2.6	K-1-2-6	121.975	K-1-2-7	121.839	42.5	0.0032	284.8	DN315 CHDPE SN8	0.84	0.36	61.91	7.92
K.1.3.1	K-1-3-1	137.685	K-1-3-2	137.367	11.8	0.0269	284.8	DN315 CHDPE SN8	0.31	0.62	179.5	2.82
K.1.3.10	K-1-3-10	128.18	K-1-3-11	126.92	20	0.063	284.8	DN315 CHDPE SN8	2.57	1.34	274.68	6.86
K.1.3.10.1	K-1-3-10-1	132.505	K-1-3-10-2	132.399	32	0.0033	284.8	DN315 CHDPE SN8	0.31	0.26	63	5.07

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
K.1.3.10.1.10.1	K-1-3-10-1-10-1	131.568	K-1-3-10-4	131.423	28	0.0052	284.8	DN315 CHDPE SN8	0.47	0.25	78.78	6.8
K.1.3.10.1.5.1	K-1-3-10-1-5-1	129.414	K-1-4-3	129.363	25	0.002	284.8	DN315 CHDPE SN8	0.21	0.15	49.43	5.51
K.1.3.10.10	K-1-3-10-10	128.3	K-1-3-10-11	128.26	10	0.004	284.8	DN315 CHDPE SN8	1.57	0.4	69.21	11.19
K.1.3.10.11	K-1-3-10-11	128.26	K-1-3-10	128.18	25	0.0032	284.8	DN315 CHDPE SN8	1.57	0.52	61.91	9.4
K.1.3.10.2	K-1-3-10-2	132.399	K-1-3-10-3	132.291	33	0.0033	284.8	DN315 CHDPE SN8	0.31	0.25	62.61	5.17
K.1.3.10.3	K-1-3-10-3	132.291	K-1-3-10-4	132.209	25	0.0033	284.8	DN315 CHDPE SN8	0.31	0.27	62.67	4.87
K.1.3.10.4	K-1-3-10-4	131.423	K-1-3-10-5	131.374	14.6	0.0034	284.8	DN315 CHDPE SN8	0.79	0.38	63.39	7.28
K.1.3.10.5	K-1-3-10-5	131.374	K-1-3-10-6	130.871	35	0.0144	284.8	DN315 CHDPE SN8	1.1	0.63	131.19	6.49
K.1.3.10.6	K-1-3-10-6	130.5	K-1-3-10-7	129.475	49	0.0209	284.8	DN315 CHDPE SN8	1.1	0.72	158.28	5.95
K.1.3.10.7	K-1-3-10-7	129.248	K-1-3-10-8	129.09	13	0.0122	284.8	DN315 CHDPE SN8	1.1	0.59	120.65	6.75
K.1.3.10.8	K-1-3-10-8	128.38	K-1-3-10-9	128.32	18	0.0033	284.8	DN315 CHDPE SN8	1.57	0.39	63.18	11.36
K.1.3.10.8.1	K-1-3-10-8-1	128.538	K-1-3-10-8-2	128.414	38	0.0033	284.8	DN315 CHDPE SN8	0.47	0.29	62.51	6.15
K.1.3.10.8.2	K-1-3-10-8-2	128.414	K-1-3-10-8	128.38	10	0.0034	284.8	DN315 CHDPE SN8	0.47	0.18	63.81	8.49
K.1.3.10.9	K-1-3-10-9	128.32	K-1-3-10-10	128.3	8	0.0025	284.8	DN315 CHDPE SN8	1.57	0.4	54.72	11.13
K.1.3.11	K-1-3-11	126.92	K-1-3-12	125.72	20.1	0.0599	284.8	DN315 CHDPE SN8	2.57	1.02	267.76	8.29
K.1.3.12	K-1-3-12	125.72	K-1-3-13	125.069	30	0.0217	284.8	DN315 CHDPE SN8	3.15	0.99	161.21	9.69
K.1.3.12.1	K-1-3-12-1	126.02	K-1-3-12-2	125.961	18	0.0033	284.8	DN315 CHDPE SN8	0.26	0.24	62.87	4.65
K.1.3.12.2	K-1-3-12-2	125.961	K-1-3-12-3	125.894	20.2	0.0033	284.8	DN315 CHDPE SN8	0.26	0.24	62.87	4.65
K.1.3.12.3	K-1-3-12-3	125.894	K-1-3-12-4	125.849	13.8	0.0033	284.8	DN315 CHDPE SN8	0.26	0.24	62.87	4.65
K.1.3.12.4	K-1-3-12-4	125.849	K-1-3-12	125.72	39	0.0033	284.8	DN315 CHDPE SN8	0.26	0.13	62.87	7.17
K.1.3.13	K-1-3-13	125.069	K-1-3-14	124.372	32.1	0.0217	284.8	DN315 CHDPE SN8	3.15	1	161.25	9.65
K.1.3.14	K-1-3-14	123.36	K-1-3-15	123.22	42.5	0.0033	284.8	DN315 CHDPE SN8	3.41	0.48	62.81	16.82
K.1.3.14.1	K-1-3-14-1	123.862	K-1-3-14-3	123.76	31.1	0.0033	284.8	DN315 CHDPE SN8	0.26	0.24	62.64	4.66
K.1.3.14.3	K-1-3-14-3	123.76	K-1-3-14-4	123.645	35.1	0.0033	284.8	DN315 CHDPE SN8	0.26	0.24	62.65	4.73
K.1.3.14.4	K-1-3-14-4	123.645	K-1-3-14-5	123.53	35	0.0033	284.8	DN315 CHDPE SN8	0.26	0.25	62.73	4.53

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
K.1.3.14.5	K-1-3-14-5	123.53	K-1-3-14	123.36	35	0.0049	284.8	DN315 CHDPE SN8	0.26	0.08	76.27	10.05
K.1.3.15	K-1-3-15	123.22	K-1-3-16	123.17	14	0.0036	284.8	DN315 CHDPE SN8	3.42	0.69	65.4	13.12
K.1.3.16	K-1-3-16	123.17	K-1-3-17	121.55	40	0.0405	361.8	DN400 CHDPE SN8	3.68	0.72	416.9	9.72
K.1.3.16.1	K-1-3-16-1	123.97	K-1-3-16-2	123.333	16	0.0398	284.8	DN315 CHDPE SN8	0.26	0.58	218.36	2.61
K.1.3.16.2	K-1-3-16-2	123.333	K-1-3-16	123.17	4	0.0407	284.8	DN315 CHDPE SN8	0.26	0.19	220.91	5.52
K.1.3.17	K-1-3-17	121.55	K-1-3-18	121.415	52.5	0.0026	361.8	DN400 CHDPE SN8	3.68	0.3	105.05	17.57
K.1.3.18	K-1-3-18	121.415	K-1-3-19	121.37	22	0.002	452.4	DN500 CHDPE SN8	11.83	0.58	170.02	18.4
K.1.3.19	K-1-3-19	121.37	K-1-3-20	121.35	12.2	0.0016	452.4	DN500 CHDPE SN8	12.04	0.59	152.41	18.53
K.1.3.2	K-1-3-2	137.367	K-1-3-3	136.367	10	0.1	284.8	DN315 CHDPE SN8	0.31	0.81	346.06	2.36
K.1.3.20	K-1-3-20	121.35	K-1-3-21	121.29	30	0.002	452.4	DN500 CHDPE SN8	12.04	0.61	168.12	18.12
K.1.3.21	K-1-3-21	121.29	K-1-3-22	121.21	40	0.002	452.4	DN500 CHDPE SN8	12.05	0.61	168.12	18.12
K.1.3.22	K-1-3-22	121.21	K-1-3-23	121.13	40	0.002	452.4	DN500 CHDPE SN8	12.05	0.56	168.12	19.2
K.1.3.22.1	K-1-3-22-1	123.89	K-1-3-22-2	122.87	58	0.0176	284.8	DN315 CHDPE SN8	0	0	145.13	0.01
K.1.3.22.2	K-1-3-22-2	121.5	K-1-3-22	121.21	7	0.0414	284.8	DN315 CHDPE SN8	0	0	222.74	14.4
K.1.3.23	K-1-3-23	121.13	K-1-3-24	121.04	45	0.002	452.4	DN500 CHDPE SN8	12.05	0.83	168.12	14.53
K.1.3.24	K-1-3-24	121.04	K-1-3-25	120.54	12	0.0417	452.4	DN500 CHDPE SN8	12.26	0.51	767.37	20.69
K.1.3.25	K-1-3-25	120.54	K-1-3-26	120.46	40.1	0.002	452.4	DN315 CHDPE SN8	38.61	0.85	168.12	32.6
K.1.3.26	K-1-3-26	120.46	K-1-3-27	120.38	40	0.002	452.4	DN315 CHDPE SN8	38.63	0.85	168.12	32.6
K.1.3.27	K-1-3-27	120.38	K-1-3-28	120.319	30.3	0.002	452.4	DN315 CHDPE SN8	38.63	0.85	168.12	32.6
K.1.3.28	K-1-3-28	120.319	K-1-3-29	120.239	40	0.002	452.4	DN315 CHDPE SN8	38.64	0.85	168.12	32.61
K.1.3.29	K-1-3-29	120.239	K-1-3-30	120.149	45	0.002	452.4	DN315 CHDPE SN8	38.65	0.85	168.12	32.61
K.1.3.3	K-1-3-3	136.367	K-1-3-4	133.483	36	0.0801	284.8	DN315 CHDPE SN8	0.31	0.59	309.68	2.92
K.1.3.30	K-1-3-30	120.149	K-1-3-31	120.102	23.4	0.002	452.4	DN315 CHDPE SN8	38.66	0.85	168.12	32.62
K.1.3.31	K-1-3-31	120.102	K-1-3-32	120.054	24.4	0.002	452.4	DN315 CHDPE SN8	38.67	0.85	168.12	32.62
K.1.3.32	K-1-3-32	120.054	K-1-3-33	119.974	40	0.002	452.4	DN315 CHDPE SN8	38.67	0.85	168.12	32.62
K.1.3.33	K-1-3-33	119.974	K-1-3-34	119.874	50	0.002	452.4	DN315 CHDPE SN8	38.68	0.85	168.12	32.63

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
K.1.3.34	K-1-3-34	119.874	K-1-3-35	119.843	15.3	0.002	452.4	DN315 CHDPE SN8	38.69	0.85	168.12	32.63
K.1.3.35	K-1-3-35	119.843	K-1-3-36	119.773	35	0.002	452.4	DN315 CHDPE SN8	38.69	0.85	168.12	32.64
K.1.3.36	K-1-3-36	119.773	K-1-2-7	119.723	25	0.002	452.4	DN315 CHDPE SN8	38.7	0.86	168.12	32.46
K.1.3.4	K-1-3-4	133.483	K-1-3-5	131.73	35	0.0501	284.8	DN315 CHDPE SN8	0.52	0.52	244.91	4.45
K.1.3.4.1	K-1-3-4-1	133.794	K-1-3-4	133.483	16	0.0194	284.8	DN315 CHDPE SN8	0.21	0.36	152.57	3.1
K.1.3.5	K-1-3-5	131.73	K-1-3-6	131.01	30	0.024	284.8	DN315 CHDPE SN8	0.99	0.7	169.56	5.6
K.1.3.6	K-1-3-6	131.01	K-1-3-7	130.41	30	0.02	284.8	DN315 CHDPE SN8	0.99	0.67	154.76	5.79
K.1.3.7	K-1-3-7	130.41	K-1-3-8	130.11	15	0.02	284.8	DN315 CHDPE SN8	0.99	0.71	154.76	5.54
K.1.3.8	K-1-3-8	130.11	K-1-3-9	129.37	24.9	0.0297	284.8	DN315 CHDPE SN8	1	0.78	188.55	5.19
K.1.3.9	K-1-3-9	129.37	K-1-3-10	128.92	15	0.03	284.8	DN315 CHDPE SN8	1	0.78	189.55	5.2
K.1.4.1	K-1-4-1	130.586	K-1-4-2	129.71	43	0.0204	284.8	DN315 CHDPE SN8	0.42	0.39	156.17	4.62
K.1.4.10	K-1-4-10	125.716	K-1-4-11	125.6	35	0.0033	284.8	DN315 CHDPE SN8	2.21	0.46	63	12.78
K.1.4.11	K-1-4-11	125.6	K-1-4-12	125.516	25	0.0034	284.8	DN315 CHDPE SN8	2.21	0.45	63.44	13.13
K.1.4.12	K-1-4-12	125.516	K-1-4-13	125.476	12	0.0033	284.8	DN315 CHDPE SN8	2.47	0.45	63.18	14.15
K.1.4.12.1	K-1-4-12-1	125.562	K-1-4-12	125.516	13	0.0035	284.8	DN315 CHDPE SN8	0.26	0.09	65.1	9.04
K.1.4.13	K-1-4-13	125.476	K-1-4-14	125.44	11.1	0.0032	284.8	DN315 CHDPE SN8	2.47	0.58	62.31	11.87
K.1.4.14	K-1-4-14	125.44	K-1-4-15	125.02	20	0.021	284.8	DN315 CHDPE SN8	2.63	0.86	158.59	9.46
K.1.4.15	K-1-4-15	125.02	K-1-4-16	124.59	32.1	0.0134	284.8	DN315 CHDPE SN8	2.63	0.67	126.68	11.18
K.1.4.16	K-1-4-16	124.59	K-1-4-17	124.17	60	0.007	284.8	DN315 CHDPE SN8	2.63	0.73	91.56	10.55
K.1.4.17	K-1-4-17	124.17	K-1-4-18	123.98	8	0.0237	284.8	DN315 CHDPE SN8	2.63	0.82	168.49	9.74
K.1.4.18	K-1-4-18	123.98	K-1-4-19	123.69	30	0.0097	284.8	DN315 CHDPE SN8	2.63	0.58	107.6	12.44
K.1.4.19	K-1-4-19	123.69	K-1-4-20	123.594	30	0.0032	284.8	DN315 CHDPE SN8	2.63	0.49	61.89	14.01
K.1.4.2	K-1-4-2	129.71	K-1-4-3	129.363	30	0.0116	284.8	DN315 CHDPE SN8	0.68	0.45	117.7	5.88
K.1.4.20	K-1-4-20	123.594	K-1-4-21	123.46	40	0.0034	284.8	DN315 CHDPE SN8	2.64	0.47	63.34	14.39
K.1.4.21	K-1-4-21	123.46	K-1-4-22	123.384	23	0.0033	284.8	DN315 CHDPE SN8	3	0.51	62.91	14.85
K.1.4.22	K-1-4-22	123.384	K-1-4-23	123.244	42	0.0033	284.8	DN315 CHDPE SN8	3.01	0.51	63.18	14.84

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
K.1.4.23	K-1-4-23	123.244	K-1-4-24	123.144	30	0.0033	284.8	DN315 CHDPE SN8	3.01	0.51	63.18	14.84
K.1.4.24	K-1-4-24	123.144	K-1-4-25	123.039	31.5	0.0033	284.8	DN315 CHDPE SN8	3.01	0.51	63.18	14.87
K.1.4.25	K-1-4-25	123.039	K-1-4-26	122.973	20	0.0033	284.8	DN315 CHDPE SN8	3.01	0.51	62.87	14.87
K.1.4.26	K-1-4-26	122.973	K-1-4-27	122.886	26	0.0033	284.8	DN315 CHDPE SN8	3.01	0.51	63.3	14.84
K.1.4.27	K-1-4-27	122.886	K-1-4-28	122.799	26	0.0033	284.8	DN315 CHDPE SN8	3.01	0.51	63.24	14.85
K.1.4.28	K-1-4-28	122.799	K-1-4-29	122.725	22.2	0.0033	284.8	DN315 CHDPE SN8	3.01	0.51	63.22	14.87
K.1.4.29	K-1-4-29	122.725	K-1-4-30	122.667	17.5	0.0033	284.8	DN315 CHDPE SN8	3.02	0.33	63	20.16
K.1.4.3	K-1-4-3	129.363	K-1-4-4	128.998	35	0.0104	284.8	DN315 CHDPE SN8	0.89	0.45	111.76	7.01
K.1.4.30	K-1-4-30	122.667	K-1-4-31	122.567	50	0.002	361.8	DN500 CHDPE SN8	8.13	0.55	92.64	20.02
K.1.4.31	K-1-4-31	122.567	K-1-4-32	122.467	50	0.002	361.8	DN500 CHDPE SN8	8.13	0.55	92.64	20.03
K.1.4.32	K-1-4-32	122.467	K-1-4-33	122.367	50	0.002	361.8	DN500 CHDPE SN8	8.13	0.55	92.64	20.03
K.1.4.33	K-1-4-33	122.367	K-1-4-34	122.267	50	0.002	361.8	DN500 CHDPE SN8	8.14	0.53	92.64	20.77
K.1.4.34	K-1-4-34	122.267	K-1-4-35	122.167	50	0.002	361.8	DN500 CHDPE SN8	8.14	0.7	92.64	16.98
K.1.4.35	K-1-4-35	122.167	K-1-4-36	121.74	30.2	0.0141	361.8	DN500 CHDPE SN8	8.14	0.75	246.41	16.24
K.1.4.36	K-1-4-36	121.74	K-1-4-37	121.7	20	0.002	361.8	DN500 CHDPE SN8	8.14	0.55	92.64	20.06
K.1.4.37	K-1-4-37	121.7	K-1-4-38	121.66	20.1	0.002	361.8	DN500 CHDPE SN8	8.14	0.54	92.37	20.49
K.1.4.38	K-1-4-38	121.66	K-1-4-39	121.64	12	0.0017	361.8	DN500 CHDPE SN8	8.15	0.56	84.57	19.94
K.1.4.39	K-1-4-39	121.64	K-1-4-40	121.61	12	0.0025	361.8	DN500 CHDPE SN8	8.15	0.59	103.58	19.26
K.1.4.4	K-1-4-4	128.998	K-1-4-5	128.544	54	0.0084	284.8	DN315 CHDPE SN8	1.2	0.47	100.34	8.37
K.1.4.40	K-1-4-40	121.61	K-1-4-41	121.59	9	0.0022	361.8	DN500 CHDPE SN8	8.15	0.55	97.65	20.14
K.1.4.41	K-1-4-41	121.59	K-1-4-42	121.54	27	0.0019	361.8	DN500 CHDPE SN8	8.15	0.56	89.15	19.86
K.1.4.42	K-1-4-42	121.54	K-1-4-43	121.53	4	0.0025	361.8	DN500 CHDPE SN8	8.15	0.6	103.58	19.06
K.1.4.43	K-1-4-43	121.53	K-1-4-44	121.52	4	0.0025	361.8	DN500 CHDPE SN8	8.15	0.58	103.58	19.43
K.1.4.44	K-1-4-44	121.52	K-1-4-45	121.45	32.8	0.0021	361.8	DN500 CHDPE SN8	8.15	0.57	95.72	19.7
K.1.4.45	K-1-4-45	121.45	K-1-3-18	121.415	21.3	0.0016	452.4	DN500 CHDPE SN8	8.15	0.46	152.25	16.79
K.1.4.5	K-1-4-5	128.544	K-1-4-6	128.313	55	0.0042	284.8	DN315 CHDPE SN8	1.21	0.36	70.92	10.09

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
K.1.4.6	K-1-4-6	128.313	K-1-4-7	128.191	38	0.0032	284.8	DN315 CHDPE SN8	1.63	0.41	62.01	11.36
K.1.4.7	K-1-4-7	128.191	K-1-4-8	128.076	35	0.0033	284.8	DN315 CHDPE SN8	1.78	0.43	62.73	11.65
K.1.4.8	K-1-4-8	128.076	K-1-4-9	127.954	37	0.0033	284.8	DN315 CHDPE SN8	1.79	0.45	62.84	11.35
K.1.4.9	K-1-4-9	125.851	K-1-4-10	125.716	41.2	0.0033	284.8	DN315 CHDPE SN8	1.79	0.4	62.67	12.2
K.1.5.1	K-1-5-1	128.229	K-1-5-2	128.076	50	0.0031	284.8	DN315 CHDPE SN8	0.42	0.25	60.54	6.27
K.1.5.10	K-1-5-10	124.659	K-1-5-11	124.643	5	0.0032	284.8	DN315 CHDPE SN8	0.74	0.33	61.91	7.63
K.1.5.11	K-1-5-11	124.643	K-1-5-12	124.479	48.9	0.0034	284.8	DN315 CHDPE SN8	0.74	0.33	63.36	7.68
K.1.5.12	K-1-5-12	124.479	K-1-5-13	124.396	27.1	0.0031	284.8	DN315 CHDPE SN8	0.74	0.33	60.61	7.71
K.1.5.13	K-1-5-13	124.396	K-1-5-14	124.331	20	0.0033	284.8	DN315 CHDPE SN8	0.74	0.33	62.39	7.63
K.1.5.14	K-1-5-14	124.331	K-1-5-16	124.219	34	0.0033	284.8	DN315 CHDPE SN8	0.74	0.15	62.81	13.37
K.1.5.16	K-1-5-16	124.219	K-1-5-16'	124.131	35	0.0025	361.8	DN400 CHDPE SN8	5.09	0.52	103.87	15.06
K.1.5.16'	K-1-5-16'	124.131	K-1-5-16''	124.081	20	0.0025	361.8	DN400 CHDPE SN8	5.09	0.52	103.58	15.07
K.1.5.16''	K-1-5-16''	124.081	K-1-5-17	123.96	48.2	0.0025	361.8	DN400 CHDPE SN8	5.09	0.52	103.74	15.06
K.1.5.17	K-1-5-17	123.96	K-1-5-18	123.897	25.1	0.0025	361.8	DN400 CHDPE SN8	5.09	0.52	103.86	15.07
K.1.5.18	K-1-5-18	123.897	K-1-5-19	123.772	50	0.0025	361.8	DN400 CHDPE SN8	5.1	0.52	103.58	15.09
K.1.5.19	K-1-5-19	123.772	K-1-5-20	123.647	50	0.0025	361.8	DN400 CHDPE SN8	5.1	0.52	103.58	15.08
K.1.5.2	K-1-5-2	128.076	K-1-5-3	127.892	60	0.0031	284.8	DN315 CHDPE SN8	0.42	0.37	60.6	4.79
K.1.5.20	K-1-5-20	123.647	K-1-5-21	123.521	50	0.0025	361.8	DN400 CHDPE SN8	5.1	0.52	103.99	15.23
K.1.5.21	K-1-5-21	123.521	K-1-4-30	123.408	45	0.0025	361.8	DN400 CHDPE SN8	5.11	0.55	103.8	14.63
K.1.5.3	K-1-5-3	127.892	K-1-5-4	127.195	12	0.0581	284.8	DN315 CHDPE SN8	0.42	0.66	263.74	3.28
K.1.5.4	K-1-5-4	127.195	K-1-5-5	125.612	60	0.0264	284.8	DN315 CHDPE SN8	0.42	0.33	177.75	5.18
K.1.5.5	K-1-5-5	125.612	K-1-5-6	125.549	19.1	0.0033	284.8	DN315 CHDPE SN8	0.58	0.3	62.79	6.87
K.1.5.5.1	K-1-5-5-1	125.648	K-1-5-5	125.612	11	0.0033	284.8	DN315 CHDPE SN8	0.16	0.12	62.61	5.23
K.1.5.6	K-1-5-6	125.549	K-1-5-7	125.483	20	0.0033	284.8	DN315 CHDPE SN8	0.58	0.33	62.87	6.49
K.1.5.7	K-1-5-7	125.483	K-1-5-7'	125.17	35	0.0089	284.8	DN315 CHDPE SN8	0.74	0.47	103.49	6.05
K.1.5.7'	K-1-5-7'	125.17	K-1-5-8	124.916	29.9	0.0085	284.8	DN315 CHDPE SN8	0.74	0.45	100.94	6.18

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
K.1.5.8	K-1-5-8	124.916	K-1-5-9	124.79	17	0.0074	284.8	DN315 CHDPE SN8	0.74	0.38	94.21	6.94
K.1.5.9	K-1-5-9	124.79	K-1-5-10	124.659	39.6	0.0033	284.8	DN315 CHDPE SN8	0.74	0.33	62.93	7.64
K.1.6.1	K-1-6-1	131.319	K-1-6-2	131.22	30	0.0033	284.8	DN315 CHDPE SN8	0.11	0.16	62.87	3.38
K.1.6.1.1	K-1-6-1-1	131.554	K-1-6-1-2	131.458	29	0.0033	284.8	DN315 CHDPE SN8	0.1	0.18	62.91	3.04
K.1.6.1.2	K-1-6-1-2	131.458	K-1-6-1	131.319	42	0.0033	284.8	DN315 CHDPE SN8	0.1	0.18	62.96	3.05
K.1.6.10	K-1-6-10	129.784	K-1-6-11	128.353	50	0.0286	284.8	DN315 CHDPE SN8	1.26	0.73	185.14	6.42
K.1.6.11	K-1-6-11	128.353	K-1-6-12	127.759	42	0.0141	284.8	DN315 CHDPE SN8	1.26	0.6	130.14	7.33
K.1.6.12	K-1-6-12	127.759	K-1-6-15	127.302	50	0.0091	284.8	DN315 CHDPE SN8	1.27	0.46	104.62	8.77
K.1.6.15	K-1-6-15	127.302	K-1-6-16	127.153	45	0.0033	284.8	DN315 CHDPE SN8	1.27	0.39	62.97	9.82
K.1.6.16	K-1-6-16	127.153	K-1-6-17	127.054	30	0.0033	284.8	DN315 CHDPE SN8	1.27	0.39	62.87	9.84
K.1.6.17	K-1-6-17	127.054	K-1-6-18	126.972	25	0.0033	284.8	DN315 CHDPE SN8	1.27	0.39	62.67	9.84
K.1.6.18	K-1-6-18	126.972	K-1-6-19	126.871	30.6	0.0033	284.8	DN315 CHDPE SN8	1.27	0.35	62.89	10.63
K.1.6.19	K-1-6-19	126.871	K-1-6-20	126.788	25	0.0033	284.8	DN315 CHDPE SN8	1.53	0.49	63.06	9.58
K.1.6.2	K-1-6-2	131.22	K-1-6-3	130.897	25	0.0129	284.8	DN315 CHDPE SN8	0.31	0.32	124.39	4.35
K.1.6.2.2	K-1-6-2-2	131.47	K-1-6-2	131.22	49	0.0051	284.8	DN315 CHDPE SN8	0.21	0.27	78.17	3.76
K.1.6.20	K-1-6-20	126.788	K-1-6-21	126.29	37.4	0.0133	284.8	DN315 CHDPE SN8	1.53	0.43	126.2	10.42
K.1.6.21	K-1-6-21	126.29	K-1-6-22	126.252	15	0.0025	361.8	DN400 CHDPE SN8	2.33	0.4	104.27	10.51
K.1.6.21.1	K-1-6-21-1	128.85	K-1-6-21-2	128.68	50	0.0034	284.8	DN315 CHDPE SN8	0.16	0.21	63.81	3.69
K.1.6.21.10	K-1-6-21-10	127.58	K-1-6-21-11	127.497	25.1	0.0033	284.8	DN315 CHDPE SN8	0.79	0.34	62.89	7.89
K.1.6.21.11	K-1-6-21-11	127.497	K-1-6-21-12	127.349	45	0.0033	284.8	DN315 CHDPE SN8	0.79	0.34	62.89	7.79
K.1.6.21.12	K-1-6-21-12	127.349	K-1-6-21-13	127.183	45	0.0037	284.8	DN315 CHDPE SN8	0.79	0.34	66.39	7.91
K.1.6.21.13	K-1-6-21-13	127.183	K-1-6-21-14	127.02	50	0.0033	284.8	DN315 CHDPE SN8	0.79	0.37	62.48	7.44
K.1.6.21.14	K-1-6-21-14	127.02	K-1-6-21-15	126.7	50	0.0064	284.8	DN315 CHDPE SN8	0.79	0.37	87.55	7.36
K.1.6.21.15	K-1-6-21-15	126.7	K-1-6-21-16	126.517	58	0.0032	284.8	DN315 CHDPE SN8	0.79	0.34	61.47	7.95
K.1.6.21.16	K-1-6-21-16	126.517	K-1-6-21-17	126.472	13.7	0.0033	284.8	DN315 CHDPE SN8	0.8	0.34	62.68	7.9
K.1.6.21.17	K-1-6-21-17	126.472	K-1-6-21-18	126.406	20	0.0033	284.8	DN315 CHDPE SN8	0.8	0.34	62.87	7.89

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
K.1.6.21.18	K-1-6-21-18	126.406	K-1-6-21-19	126.34	20	0.0033	284.8	DN315 CHDPE SN8	0.8	0.34	62.87	7.9
K.1.6.21.19	K-1-6-21-19	126.34	K-1-6-21	126.29	15.2	0.0033	284.8	DN315 CHDPE SN8	0.8	0.22	62.7	10.51
K.1.6.21.2	K-1-6-21-2	128.68	K-1-6-21-3	128.52	50	0.0032	284.8	DN315 CHDPE SN8	0.16	0.21	61.91	3.7
K.1.6.21.3	K-1-6-21-3	128.52	K-1-6-21-4	128.35	50	0.0034	284.8	DN315 CHDPE SN8	0.16	0.21	63.81	3.69
K.1.6.21.4	K-1-6-21-4	128.35	K-1-6-21-5	128.27	25	0.0032	284.8	DN315 CHDPE SN8	0.16	0.2	61.91	3.75
K.1.6.21.5	K-1-6-21-5	128.27	K-1-6-21-6	128.24	10	0.003	284.8	DN315 CHDPE SN8	0.16	0.2	59.94	3.8
K.1.6.21.6	K-1-6-21-6	128.24	K-1-6-21-7	128.12	35	0.0034	284.8	DN315 CHDPE SN8	0.16	0.23	64.08	3.5
K.1.6.21.7	K-1-6-21-7	128.12	K-1-6-21-8	127.898	35	0.0064	284.8	DN315 CHDPE SN8	0.16	0.13	87.23	4.94
K.1.6.21.8	K-1-6-21-8	127.898	K-1-6-21-9	127.739	25	0.0064	284.8	DN315 CHDPE SN8	0.79	0.43	87.23	6.72
K.1.6.21.8.1	K-1-6-21-8-1	129.08	K-1-6-21-8-2	128.686	50	0.0079	284.8	DN315 CHDPE SN8	0.63	0.43	97.16	5.74
K.1.6.21.8.2	K-1-6-21-8-2	128.686	K-1-6-21-8-3	128.292	50	0.0079	284.8	DN315 CHDPE SN8	0.63	0.43	97.16	5.74
K.1.6.21.8.3	K-1-6-21-8-3	128.292	K-1-6-21-8	127.898	50	0.0079	284.8	DN315 CHDPE SN8	0.63	0.38	97.16	6.23
K.1.6.21.9	K-1-6-21-9	127.739	K-1-6-21-10	127.58	25	0.0064	284.8	DN315 CHDPE SN8	0.79	0.38	87.23	7.29
K.1.6.22	K-1-6-22	126.252	K-1-6-23	126.132	48	0.0025	361.8	DN400 CHDPE SN8	2.49	0.42	103.58	10.68
K.1.6.22.1	K-1-6-22-1	131.425	K-1-6-22-2	131.301	30	0.0041	284.8	DN315 CHDPE SN8	0.16	0.25	70.36	3.28
K.1.6.22.10	K-1-6-22-10	127.001	K-1-6-22	126.902	30	0.0033	284.8	DN315 CHDPE SN8	0.16	0.24	62.87	3.32
K.1.6.22.2	K-1-6-22-2	131.301	K-1-6-22-3	130.959	40	0.0085	284.8	DN315 CHDPE SN8	0.16	0.24	101.19	3.32
K.1.6.22.3	K-1-6-22-3	130.959	K-1-6-22-4	130.923	11	0.0033	284.8	DN315 CHDPE SN8	0.16	0.2	62.6	3.8
K.1.6.22.4	K-1-6-22-4	130.923	K-1-6-22-5	130.857	20	0.0033	284.8	DN315 CHDPE SN8	0.16	0.24	62.87	3.3
K.1.6.22.5	K-1-6-22-5	130.041	K-1-6-22-6	127.564	22	0.1126	284.8	DN315 CHDPE SN8	0.16	0.44	367.2	2.23
K.1.6.22.6	K-1-6-22-6	127.564	K-1-6-22-7	127.172	40	0.0098	284.8	DN315 CHDPE SN8	0.16	0.25	108.34	3.27
K.1.6.22.7	K-1-6-22-7	127.172	K-1-6-22-8	127.089	25	0.0033	284.8	DN315 CHDPE SN8	0.16	0.21	63.06	3.7
K.1.6.22.8	K-1-6-22-8	127.089	K-1-6-22-9	127.045	13.5	0.0033	284.8	DN315 CHDPE SN8	0.16	0.21	62.51	3.7
K.1.6.22.9	K-1-6-22-9	127.045	K-1-6-22-10	127.001	13.1	0.0034	284.8	DN315 CHDPE SN8	0.16	0.2	63.37	3.81
K.1.6.23	K-1-6-23	126.132	K-1-6-24	126.07	24.6	0.0025	361.8	DN400 CHDPE SN8	2.49	0.42	103.9	10.68
K.1.6.24	K-1-6-24	126.07	K-1-6-25	125.995	30	0.0025	361.8	DN400 CHDPE SN8	2.49	0.41	103.58	10.9

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
K.1.6.25	K-1-6-25	125.995	K-1-6-26	125.895	40	0.0025	361.8	DN400 CHDPE SN8	2.71	0.42	103.58	11.41
K.1.6.25.1	K-1-6-25-1	126.826	K-1-6-25-2	126.678	45	0.0033	284.8	DN315 CHDPE SN8	0.21	0.22	62.76	4.3
K.1.6.25.2	K-1-6-25-2	126.678	K-1-6-25	126.562	35	0.0033	284.8	DN315 CHDPE SN8	0.21	0.25	63	3.99
K.1.6.26	K-1-6-26	125.895	K-1-6-27	125.51	75	0.0051	361.8	DN400 CHDPE SN8	4.31	0.61	148.42	12.07
K.1.6.26.1	K-1-6-26-1	142.964	K-1-6-26-2	142.601	36	0.0101	284.8	DN315 CHDPE SN8	0.42	0.51	109.89	3.9
K.1.6.26.10	K-1-6-26-10	135.41	K-1-6-26-11	134.51	20	0.045	284.8	DN315 CHDPE SN8	0.94	0.88	232.15	4.61
K.1.6.26.11	K-1-6-26-11	133.706	K-1-6-26-12	133.586	22.1	0.0054	284.8	DN315 CHDPE SN8	0.94	0.43	80.57	7.6
K.1.6.26.12	K-1-6-26-12	132.51	K-1-6-26-13	130.3	38	0.0582	284.8	DN315 CHDPE SN8	0.94	0.71	263.91	5.33
K.1.6.26.13	K-1-6-26-13	130.3	K-1-6-26-14	129.784	32	0.0161	284.8	DN315 CHDPE SN8	1.1	0.65	138.97	6.32
K.1.6.26.14	K-1-6-26-14	128.75	K-1-6-26-15	128.45	10	0.03	284.8	DN315 CHDPE SN8	1.36	0.86	189.55	6.04
K.1.6.26.15	K-1-6-26-15	128.45	K-1-6-26-16	127.7	25	0.03	284.8	DN315 CHDPE SN8	1.36	0.85	189.55	6.11
K.1.6.26.16	K-1-6-26-16	127.7	K-1-6-26-17	126.943	20	0.0378	284.8	DN315 CHDPE SN8	1.6	0.76	212.91	7.35
K.1.6.26.17	K-1-6-26-17	126.943	K-1-6-26-18	126.846	10.2	0.0095	284.8	DN315 CHDPE SN8	1.6	0.5	106.83	9.7
K.1.6.26.18	K-1-6-26-18	126.846	K-1-6-26-19	126.643	45	0.0045	284.8	DN315 CHDPE SN8	1.6	0.55	73.5	9.17
K.1.6.26.19	K-1-6-26-19	126.643	K-1-6-26	125.895	45	0.0166	284.8	DN315 CHDPE SN8	1.6	0.41	141.09	11.18
K.1.6.26.2	K-1-6-26-2	142.601	K-1-6-26-3	141.27	22	0.0605	284.8	DN315 CHDPE SN8	0.42	0.42	269.17	4.39
K.1.6.26.3	K-1-6-26-3	141.27	K-1-6-26-4	141.217	16.1	0.0033	284.8	DN315 CHDPE SN8	0.42	0.28	62.83	5.83
K.1.6.26.4	K-1-6-26-4	141.217	K-1-6-26-5	141.082	41	0.0033	284.8	DN315 CHDPE SN8	0.42	0.27	62.8	6.01
K.1.6.26.5	K-1-6-26-5	141.082	K-1-6-26-6	141.016	20	0.0033	284.8	DN315 CHDPE SN8	0.42	0.33	62.87	5.14
K.1.6.26.6	K-1-6-26-6	141.016	K-1-6-26-7	140.659	20	0.0178	284.8	DN315 CHDPE SN8	0.42	0.55	146.21	3.69
K.1.6.26.7	K-1-6-26-7	140.659	K-1-6-26-8	140.31	8	0.0436	284.8	DN315 CHDPE SN8	0.42	0.73	228.57	3.07
K.1.6.26.8	K-1-6-26-8	140.31	K-1-6-26-9	137.86	35	0.07	284.8	DN315 CHDPE SN8	0.42	0.81	289.54	2.86
K.1.6.26.9	K-1-6-26-9	137.86	K-1-6-26-10	135.41	35	0.07	284.8	DN315 CHDPE SN8	0.42	0.55	289.54	3.72
K.1.6.27	K-1-6-27	125.51	K-1-6-28	125.35	40	0.004	361.8	DN400 CHDPE SN8	4.32	0.59	131.02	12.42
K.1.6.28	K-1-6-28	125.35	K-1-6-29	125.22	32	0.0041	361.8	DN400 CHDPE SN8	4.32	0.59	132.04	12.41
K.1.6.29	K-1-6-29	125.22	K-1-6-30	125.14	20	0.004	361.8	DN400 CHDPE SN8	4.32	0.53	131.02	13.37

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
K.1.6.3	K-1-6-3	130.897	K-1-6-4	130.52	60	0.0063	284.8	DN315 CHDPE SN8	0.42	0.24	86.71	6.42
K.1.6.3.1	K-1-6-3-1	131.052	K-1-6-3	130.897	47	0.0033	284.8	DN315 CHDPE SN8	0.1	0.12	62.85	4.02
K.1.6.30	K-1-6-30	125.14	K-1-6-31	125.02	50	0.0024	361.8	DN400 CHDPE SN8	4.32	0.5	101.49	13.82
K.1.6.31	K-1-6-31	125.02	K-1-6-32	124.99	10	0.003	361.8	DN400 CHDPE SN8	4.33	0.51	113.46	13.75
K.1.6.32	K-1-6-32	124.99	K-1-6-33	124.87	50	0.0024	361.8	DN400 CHDPE SN8	4.33	0.49	101.49	14.01
K.1.6.33	K-1-6-33	124.87	K-1-6-34	124.73	54.6	0.0026	361.8	DN400 CHDPE SN8	4.33	0.48	104.85	14.33
K.1.6.34	K-1-6-34	124.73	K-1-6-35	124.71	10	0.002	361.8	DN400 CHDPE SN8	4.34	0.48	92.64	14.31
K.1.6.35	K-1-6-35	124.71	K-1-6-36	124.58	50	0.0026	361.8	DN400 CHDPE SN8	4.34	0.48	105.63	14.24
K.1.6.36	K-1-6-36	124.58	K-1-6-37	124.48	40	0.0025	361.8	DN400 CHDPE SN8	4.34	0.58	103.58	12.58
K.1.6.37	K-1-6-37	124.48	K-1-5-16	124.219	32	0.0082	361.8	DN400 CHDPE SN8	4.34	0.57	187.09	12.78
K.1.6.4	K-1-6-4	130.52	K-1-6-5	130.385	41	0.0033	284.8	DN315 CHDPE SN8	0.79	0.33	62.88	7.98
K.1.6.4.1	K-1-6-4-1	130.737	K-1-6-4	130.52	66	0.0033	284.8	DN315 CHDPE SN8	0.37	0.2	62.7	6.66
K.1.6.5	K-1-6-5	130.385	K-1-6-6	130.273	34	0.0033	284.8	DN315 CHDPE SN8	0.84	0.31	62.88	8.65
K.1.6.5.1	K-1-6-5-1	130.756	K-1-6-5	130.385	14	0.0265	284.8	DN315 CHDPE SN8	0.05	0.05	178.16	4.71
K.1.6.6	K-1-6-6	130.273	K-1-6-7	130.108	50	0.0033	284.8	DN315 CHDPE SN8	1.1	0.38	62.88	9.2
K.1.6.7	K-1-6-7	130.108	K-1-6-8	129.919	57	0.0033	284.8	DN315 CHDPE SN8	1.1	0.37	62.88	9.26
K.1.6.8	K-1-6-8	129.919	K-1-6-9	129.883	11	0.0033	284.8	DN315 CHDPE SN8	1.11	0.39	62.88	9.02
K.1.6.9	K-1-6-9	129.883	K-1-6-10	129.784	13	0.0076	284.8	DN315 CHDPE SN8	1.26	0.6	95.52	7.31
K.2.1.1	K-2-1-1	146.736	K-2-1-2	146.011	20	0.0363	284.8	DN400 CHDPE SN8	0.26	0.56	208.36	2.67
K.2.1.10	K-2-1-10	132.036	K-2-1-11	132.03	7	0.0009	284.8	DN315 CHDPE SN8	0.84	0.29	32.15	9.14
K.2.1.11	K-2-1-11	131.618	K-2-1-12	130.179	19.8	0.0728	284.8	DN315 CHDPE SN8	1.63	1.16	295.36	5.56
K.2.1.11.1	K-2-1--11-1	138.86	K-2-1--11-2	138.32	48	0.0112	284.8	DN315 CHDPE SN8	0.26	0.37	116.07	3.51
K.2.1.11.2	K-2-1--11-2	137.52	K-2-1--11-3	136.475	15	0.0697	284.8	DN315 CHDPE SN8	0.26	0.7	288.85	2.3
K.2.1.11.3	K-2-1--11-3	135.946	K-2-1--11-4	135.185	8	0.0951	284.8	DN315 CHDPE SN8	0.37	0.86	337.52	2.5
K.2.1.11.4	K-2-1--11-4	134.22	K-2-1--11-5	133.62	12	0.05	284.8	DN315 CHDPE SN8	0.37	0.71	244.7	2.83
K.2.1.11.5	K-2-1--11-5	133.62	K-2-1--11-6	132.451	18	0.0649	284.8	DN315 CHDPE SN8	0.37	0.72	278.89	2.82

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
K.2.1.11.6	K-2-1--11-6	132.451	K-2-1--11-7	131.765	14	0.049	284.8	DN315 CHDPE SN8	0.37	0.41	242.24	4.12
K.2.1.11.7	K-2-1--11-7	131.765	K-2-1-11	131.618	40	0.0037	284.8	DN315 CHDPE SN8	0.37	0.28	66.34	5.32
K.2.1.12	K-2-1-12	130.179	K-2-1-13	128.663	29.9	0.0506	284.8	DN315 CHDPE SN8	1.63	0.89	246.23	6.67
K.2.1.13	K-2-1-13	128.663	K-2-1-14	127.884	24	0.0325	284.8	DN315 CHDPE SN8	2.26	0.74	197.16	9.43
K.2.1.13.1	K-2-1-13-1	133.7	K-2-1-13-2	130.7	30	0.1	284.8	DN315 CHDPE SN8	0.63	0.87	346.06	3.55
K.2.1.13.2	K-2-1-13-2	130.7	K-2-1-13-3	129.719	25	0.0392	284.8	DN315 CHDPE SN8	0.63	0.66	216.78	4.28
K.2.1.13.3	K-2-1-13-3	129.719	K-2-1-13-4	128.932	40	0.0197	284.8	DN315 CHDPE SN8	0.63	0.41	153.57	5.95
K.2.1.13.4	K-2-1-13-4	128.932	K-2-1-13-5	128.833	30	0.0033	284.8	DN315 CHDPE SN8	0.63	0.35	62.87	6.63
K.2.1.13.5	K-2-1-13-5	128.833	K-2-1-13	128.663	25	0.0068	284.8	DN315 CHDPE SN8	0.63	0.34	90.24	6.74
K.2.1.14	K-2-1-14	127.884	K-2-1-15	127.745	24.1	0.0058	284.8	DN315 CHDPE SN8	2.26	0.43	83.19	13.82
K.2.1.15	K-2-1-15	127.745	K-2-1-16	127.646	30	0.0033	284.8	DN315 CHDPE SN8	3.63	0.54	62.87	16.3
K.2.1.15.1	K-2-1-15-1	129.101	K-2-1-15-2	128.165	35	0.0267	284.8	DN315 CHDPE SN8	0.57	0.35	178.96	6.23
K.2.1.15.2	K-2-1-15-2	128.165	K-2-1-15-3	128.05	35	0.0033	284.8	DN315 CHDPE SN8	0.89	0.34	62.73	8.47
K.2.1.15.2.1	K-2-1-15-2-1	128.913	K-2-1-15-2-2	128.658	16	0.0159	284.8	DN315 CHDPE SN8	0.31	0.46	138.16	3.45
K.2.1.15.2.2	K-2-1-15-2-2	128.658	K-2-1-15-2-3	128.457	10	0.0201	284.8	DN315 CHDPE SN8	0.31	0.42	155.15	3.64
K.2.1.15.2.3	K-2-1-15-2-3	128.457	K-2-1-15-2-4	128.359	10	0.0098	284.8	DN315 CHDPE SN8	0.31	0.37	108.34	3.98
K.2.1.15.2.4	K-2-1-15-2-4	128.359	K-2-1-15-2-5	128.295	7	0.0091	284.8	DN315 CHDPE SN8	0.31	0.3	104.64	4.54
K.2.1.15.2.5	K-2-1-15-2-5	128.295	K-2-1-15-2	128.165	39.2	0.0033	284.8	DN315 CHDPE SN8	0.31	0.17	63.02	6.69
K.2.1.15.3	K-2-1-15-3	128.05	K-2-1-15-4	127.964	26	0.0033	284.8	DN315 CHDPE SN8	0.89	0.39	62.94	7.75
K.2.1.15.4	K-2-1-15-4	127.964	K-2-1-15	127.745	30	0.0073	284.8	DN315 CHDPE SN8	0.89	0.22	93.5	11.59
K.2.1.16	K-2-1-16	127.646	K-2-1-17	127.547	30	0.0033	284.8	DN315 CHDPE SN8	3.63	0.48	62.87	17.5
K.2.1.17	K-2-1-17	127.547	K-2-1-18	127.455	28	0.0033	284.8	DN315 CHDPE SN8	4	0.67	62.72	14.88
K.2.1.18	K-2-1-18	127.455	K-2-1-19	126.503	32	0.0297	284.8	DN315 CHDPE SN8	4.89	0.78	188.76	15.45
K.2.1.18.1	K-2-1-18-1	127.96	K-2-1-18-2	127.84	30	0.004	284.8	DN315 CHDPE SN8	0.37	0.29	69.21	5.21
K.2.1.18.2	K-2-1-18-2	127.84	K-2-1-18-3	127.72	30	0.004	284.8	DN315 CHDPE SN8	0.37	0.28	69.21	5.24
K.2.1.18.3	K-2-1-18-3	127.72	K-2-1-18-4	127.6	30	0.004	284.8	DN315 CHDPE SN8	0.37	0.29	69.21	5.13

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
K.2.1.18.4	K-2-1-18-4	127.6	K-2-1-18	127.455	30	0.0048	284.8	DN315 CHDPE SN8	0.37	0.15	76.08	8.03
K.2.1.19	K-2-1-19	126.503	U-1-1	126.278	68	0.0033	284.8	DN315 CHDPE SN8	5.42	0.59	62.95	20.28
K.2.1.19.1	K-2-1-19-1	126.853	K-2-1-19-2	126.685	50	0.0034	284.8	DN315 CHDPE SN8	0.52	0.3	63.43	6.45
K.2.1.19.2	K-2-1-19-2	126.685	K-2-1-19	126.503	55	0.0033	284.8	DN315 CHDPE SN8	0.52	0.11	62.95	13.15
K.2.1.2	K-2-1-2	146.011	K-2-1-3	145.437	16	0.0359	284.8	DN400 CHDPE SN8	0.26	0.48	207.25	2.95
K.2.1.3	K-2-1-3	145.437	K-2-1-4	145.014	24	0.0176	284.8	DN315 CHDPE SN8	0.26	0.45	145.29	3.07
K.2.1.4	K-2-1-4	145.014	K-2-1-5	144.89	5	0.0248	284.8	DN315 CHDPE SN8	0.26	0.46	172.34	3.04
K.2.1.5	K-2-1-5	144.89	K-2-1-6	143.286	16	0.1002	284.8	DN315 CHDPE SN8	0.63	1.04	346.5	3.17
K.2.1.5.1	K-2-1-5-1	150.58	K-2-1-5-2	148	27	0.0956	284.8	DN315 CHDPE SN8	0.37	0.87	338.29	2.49
K.2.1.5.2	K-2-1-5-2	147.36	K-2-1-5-3	146.64	9	0.0801	284.8	DN315 CHDPE SN8	0.37	0.81	309.72	2.6
K.2.1.5.3	K-2-1-5-3	145.85	K-2-1-5	144.89	8	0.12	284.8	DN315 CHDPE SN8	0.37	0.74	379.09	2.77
K.2.1.6	K-2-1-6	142.61	K-2-1-7	141.31	12.8	0.1018	284.8	DN315 CHDPE SN8	0.63	1.04	349.12	3.16
K.2.1.7	K-2-1-7	140.95	K-2-1-8	140.181	7.9	0.0972	284.8	DN315 CHDPE SN8	0.63	1.03	341.25	3.19
K.2.1.8	K-2-1-8	137.49	K-2-1-9	135.84	16.5	0.0997	284.8	DN315 CHDPE SN8	0.63	1.04	345.57	3.17
K.2.1.9	K-2-1-9	135.84	K-2-1-10	132.036	38.1	0.0998	284.8	DN315 CHDPE SN8	0.63	0.32	345.68	6.98
K.2.10	U-2-10	131.19	U-2-11	131.153	18.8	0.002	452.4	DN315 CHDPE SN8	41.07	0.86	166.9	33.85
K.2.10.1	K-2-10-1	127.361	K-2-10-2	127	35	0.0103	284.8	DN315 CHDPE SN8	0.31	0.38	111.14	3.9
K.2.10.2	K-2-10-2	127	K-2-10-3	126.576	41	0.0103	284.8	DN315 CHDPE SN8	0.31	0.21	111.29	5.84
K.2.10.3	K-2-10-3	126.576	U-1-18	126.378	60	0.0033	284.8	DN315 CHDPE SN8	0.73	0.35	62.87	7.33
K.2.12	U-2-12	131.073	U-2-13	130.973	50	0.002	452.4	DN500 CHDPE SN8	41.6	0.87	168.12	33.89
K.2.13	U-2-13	130.973	U-2-14	130.873	50	0.002	452.4	DN500 CHDPE SN8	41.61	0.86	168.12	34
K.2.14	U-2-14	130.873	U-2-15	130.773	50	0.002	452.4	DN500 CHDPE SN8	42.08	0.81	168.12	35.82
K.2.15	U-2-15	130.773	U-2-16	130.673	50	0.002	452.4	DN500 CHDPE SN8	42.09	1.13	168.12	28.14
K.2.16	U-2-16	130.673	U-2-17	129.572	50	0.022	452.4	DN500 CHDPE SN8	42.09	2.06	557.85	18.48
K.2.17	U-2-17	129.572	U-2-18	128.382	50	0.0238	452.4	DN500 CHDPE SN8	42.09	1.94	579.96	19.24
K.2.18	U-2-18	128.382	U-2-19	127.56	50	0.0164	452.4	DN500 CHDPE SN8	42.09	1.87	482.02	19.79

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
K.2.19	U-2-19	127.56	U-2-20	126.617	50	0.0189	452.4	DN500 CHDPE SN8	42.09	1.94	516.28	19.29
K.2.2.1	K-2-2-1	126.489	U-1-2	126.17	52	0.0061	284.8	DN315 CHDPE SN8	0.16	0.04	85.71	12.08
K.2.20	U-2-20	126.617	U-2-21	125.666	50	0.019	452.4	DN500 CHDPE SN8	42.09	1.78	518.46	20.43
K.2.21	U-2-21	125.666	U-2-22	125.318	29	0.012	452.4	DN500 CHDPE SN8	42.09	1.58	411.85	22.23
K.2.22	U-2-22	125.318	U-2-23	125.045	20.4	0.0134	452.4	DN500 CHDPE SN8	42.09	1.72	434.36	20.95
K.2.23	U-2-23	125.045	U-2-24	123.897	57.3	0.02	452.4	DN500 CHDPE SN8	42.09	1.81	532.23	20.21
K.2.24	U-2-24	123.897	U-2-25	123.221	50	0.0135	452.4	DN500 CHDPE SN8	43.45	1.74	437.12	21.22
K.2.25	U-2-25	123.221	U-2-26	122.512	50	0.0142	452.4	DN500 CHDPE SN8	43.44	1.62	447.66	22.36
K.2.26	U-2-26	122.512	U-2-27	122.071	50	0.0088	452.4	DN500 CHDPE SN8	43.44	1.49	353.06	23.7
K.2.27	U-2-27	122.071	U-2-28	121.604	50	0.0093	452.4	DN500 CHDPE SN8	43.44	1.55	363.32	23.1
K.2.28	U-2-28	121.604	U-2-29	121.046	50	0.0112	452.4	DN500 CHDPE SN8	43.44	1.63	397.14	22.24
K.2.29	U-2-29	121.046	U-2-30	120.392	55.1	0.0119	452.4	DN500 CHDPE SN8	43.43	1.66	409.48	21.99
K.2.3.1	K-2-3-1	126.745	U-1-4	126.005	46	0.0161	284.8	DN315 CHDPE SN8	0.31	0.06	138.8	13.27
K.2.30	U-2-30	119.392	U-2-31	119.19	44.9	0.0045	905.4	DN500 CHDPE SN8	43.43	0.89	1604.16	12.92
K.2.31	U-2-31	119.19	U-2-32	119.077	50	0.0023	905.4	DN500 CHDPE SN8	44.09	1.02	1136.79	11.88
K.2.32	U-2-32	119.077	U-2-33	118.532	50	0.0109	905.4	DN500 CHDPE SN8	44.09	1.35	2496.54	9.83
K.2.33	U-2-33	118.532	U-2-34	118.256	30	0.0092	905.4	DN500 CHDPE SN8	44.08	1.46	2293.6	9.3
K.2.34	U-2-34	118.256	U-2-35	117.7	30	0.0185	905.4	DN500 CHDPE SN8	44.07	1.77	3255.38	8.18
K.2.35	U-2-35	117.7	O-2	117.52	10	0.018	905.4	DN500 CHDPE SN8	44.07	1.76	3208.2	8.2
K.2.4.1	K-2-4-1	126.24	K-2-4-2	126.11	38	0.0034	284.8	DN315 CHDPE SN8	0.21	0.23	64.01	4.21
K.2.4.10	K-2-4-10	125.661	K-2-4-11	125.625	11	0.0033	284.8	DN315 CHDPE SN8	0.58	0.26	62.43	7.66
K.2.4.11	K-2-4-11	125.625	K-2-4-12	125.585	12	0.0034	284.8	DN315 CHDPE SN8	0.95	0.32	63.46	9.25
K.2.4.12	K-2-4-12	125.585	K-2-4-13	125.499	26	0.0033	284.8	DN315 CHDPE SN8	1.31	0.4	62.94	10
K.2.4.13	K-2-4-13	125.499	K-2-4-14	125.463	11	0.0033	284.8	DN315 CHDPE SN8	1.31	0.36	62.62	10.62
K.2.4.14	K-2-4-14	125.463	K.2.4.15	125.363	30	0.0033	284.8	DN315 CHDPE SN8	1.68	0.43	63.16	11.19
K.2.4.15	K.2.4.15	125.363	U-1-6	125.234	38	0.0034	284.8	DN315 CHDPE SN8	1.68	0.22	63.78	17.91

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
K.2.4.2	K-2-4-2	126.11	K-2-4-3	126.072	12	0.0032	284.8	DN315 CHDPE SN8	0.21	0.22	61.58	4.23
K.2.4.3	K-2-4-3	126.072	K-2-4-4	126.032	12	0.0033	284.8	DN315 CHDPE SN8	0.21	0.23	63.18	4.2
K.2.4.4	K-2-4-4	126.032	K-2-4-5	125.962	21	0.0033	284.8	DN315 CHDPE SN8	0.21	0.17	63.18	5.06
K.2.4.5	K-2-4-5	125.962	K-2-4-6	125.839	21	0.0059	284.8	DN315 CHDPE SN8	0.58	0.31	83.75	6.75
K.2.4.5.1	K-2-4-5-1	127.04	K-2-4-5-2	126.802	35	0.0068	284.8	DN315 CHDPE SN8	0.37	0.33	90.24	4.73
K.2.4.5.2	K-2-4-5-2	126.802	K-2-4-5-3	126.56	40	0.0061	284.8	DN315 CHDPE SN8	0.37	0.36	85.16	4.46
K.2.4.5.3	K-2-4-5-3	126.56	K-2-4-5	125.962	50.1	0.0119	284.8	DN315 CHDPE SN8	0.37	0.31	119.61	4.99
K.2.4.6	K-2-4-6	125.839	K-2-4-7	125.8	19	0.0021	284.8	DN315 CHDPE SN8	0.58	0.25	49.55	7.79
K.2.4.7	K-2-4-7	125.8	K-2-4-8	125.754	23	0.002	284.8	DN315 CHDPE SN8	0.58	0.27	48.94	7.37
K.2.4.8	K-2-4-8	125.754	K-2-4-9	125.71	13	0.0034	284.8	DN315 CHDPE SN8	0.58	0.31	63.67	6.75
K.2.4.9	K-2-4-9	125.71	K-2-4-10	125.661	14.7	0.0033	284.8	DN315 CHDPE SN8	0.58	0.31	63.14	6.78
K.2.5.1	K-2-5-1	126.765	U-1-8	126.616	45	0.0033	284.8	DN315 CHDPE SN8	0.16	0.24	62.97	3.3
K.2.6.1	K-2-6-1	126.222	K-2-6-2	125.954	40	0.0067	284.8	DN315 CHDPE SN8	0.26	0.32	89.58	3.92
K.2.6.2	K-2-6-2	125.954	K-2-6-3	125.893	8	0.0076	284.8	DN315 CHDPE SN8	0.26	0.18	95.43	5.72
K.2.6.3	K-2-6-3	125.893	K-2-6-4	125.778	35	0.0033	284.8	DN315 CHDPE SN8	0.73	0.26	62.87	8.98
K.2.6.3.1	K-2-6-3-1	126.452	K-2-6-3-2	126.23	29.3	0.0076	284.8	DN315 CHDPE SN8	0.47	0.4	95.32	4.9
K.2.6.3.2	K-2-6-3-2	126.23	K-2-6-3-3	126.052	17	0.0105	284.8	DN315 CHDPE SN8	0.47	0.35	111.98	5.38
K.2.6.3.3	K-2-6-3-3	126.052	K-2-6-3	125.893	46	0.0035	284.8	DN315 CHDPE SN8	0.47	0.25	64.34	6.84
K.2.6.4	K-2-6-4	125.778	K-2-6-5	125.719	18	0.0033	284.8	DN315 CHDPE SN8	1.42	0.38	62.6	10.72
K.2.6.4.1	K-2-6-4-1	125.93	K-2-6-4	125.778	46	0.0033	284.8	DN315 CHDPE SN8	0.42	0.17	63.01	8.1
K.2.6.5	K-2-6-5	125.719	K-2-6-6	125.58	42	0.0033	284.8	DN315 CHDPE SN8	1.63	0.31	62.87	13.67
K.2.6.5.1	K-2-6-5-1	126.2	K-2-6-5	125.719	15	0.0321	284.8	DN315 CHDPE SN8	0.21	0.11	196.05	6.77
K.2.6.6	K-2-6-6	125.58	K-2-6-7	125.382	60	0.0033	284.8	DN315 CHDPE SN8	3.62	0.53	62.87	16.51
K.2.6.6.1	K-2-6-6-1	130.174	K-2-6-6-2	128.692	29	0.0511	284.8	DN315 CHDPE SN8	0.31	0.64	247.39	2.75
K.2.6.6.10	K-2-6-6-10	125.991	K-2-6-6-11	125.862	18.3	0.007	284.8	DN315 CHDPE SN8	1.63	0.55	91.87	9.23
K.2.6.6.10.1	K-2-6-6-10-1	126.405	K-2-6-6-10-2	126.141	45	0.0059	284.8	DN315 CHDPE SN8	0.16	0.25	83.82	3.22

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
K.2.6.6.10.2	K-2-6-6-10-2	126.141	K-2-6-6-10	125.991	25.6	0.0059	284.8	DN315 CHDPE SN8	0.16	0.1	83.8	6.22
K.2.6.6.11	K-2-6-6-11	125.862	K-2-6-6-12	125.665	28	0.007	284.8	DN315 CHDPE SN8	1.63	0.55	91.79	9.23
K.2.6.6.12	K-2-6-6-12	125.665	K-2-6-6	125.58	12	0.0071	284.8	DN315 CHDPE SN8	1.63	0.34	92.1	12.75
K.2.6.6.2	K-2-6-6-2	128.692	K-2-6-6-3	128.275	10	0.0417	284.8	DN315 CHDPE SN8	0.31	0.57	223.47	2.97
K.2.6.6.3	K-2-6-6-3	128.275	K-2-6-6-4	127.927	13	0.0268	284.8	DN315 CHDPE SN8	0.31	0.45	179.05	3.5
K.2.6.6.4	K-2-6-6-4	127.927	K-2-6-6-5	127.82	10	0.0107	284.8	DN315 CHDPE SN8	0.31	0.3	112.95	4.52
K.2.6.6.5	K-2-6-6-5	127.82	K-2-6-6-6	127.514	30	0.0102	284.8	DN315 CHDPE SN8	0.58	0.46	110.6	5.16
K.2.6.6.6	K-2-6-6-6	127.514	K-2-6-6-7	127.224	28	0.0103	284.8	DN315 CHDPE SN8	0.58	0.41	111.2	5.59
K.2.6.6.7	K-2-6-6-7	127.224	K-2-6-6-8	126.366	48	0.0179	284.8	DN315 CHDPE SN8	1.05	0.51	146.35	7.17
K.2.6.6.7.1	K-2-6-6-7-1	129.79	K-2-6-6-7-2	128.693	11	0.1001	284.8	DN315 CHDPE SN8	0.47	0.95	346.24	2.77
K.2.6.6.7.2	K-2-6-6-7-2	128.403	K-2-6-6-7	127.224	18	0.0655	284.8	DN315 CHDPE SN8	0.47	0.45	280.03	4.54
K.2.6.6.8	K-2-6-6-8	126.366	K-2-6-6-9	126.258	15	0.0072	284.8	DN315 CHDPE SN8	1.31	0.5	92.86	8.55
K.2.6.6.8.1	K-2-6-6-8-1	126.482	K-2-6-6-8	126.366	35	0.0033	284.8	DN315 CHDPE SN8	0.26	0.15	63	6.47
K.2.6.6.9	K-2-6-6-9	126.258	K-2-6-6-10	125.991	38	0.007	284.8	DN315 CHDPE SN8	1.47	0.51	91.78	9.01
K.2.6.7	K-2-6-7	125.382	K-2-6-8	125.257	38	0.0033	284.8	DN315 CHDPE SN8	3.83	0.52	62.87	17.28
K.2.6.7.1	K-2-6-7-1	126.292	K-2-6-7	125.382	26	0.035	284.8	DN315 CHDPE SN8	0.21	0.07	204.73	9.58
K.2.6.8	K-2-6-8	125.257	K-2-6-9	125.174	25	0.0033	284.8	DN315 CHDPE SN8	4.31	0.57	62.87	17.55
K.2.6.8.1	K-2-6-8-1	126.287	K-2-6-8	125.257	18	0.0572	284.8	DN315 CHDPE SN8	0.31	0.09	261.83	10.22
K.2.6.8.2	K-2-6-8-2	126.454	K-2-6-8	125.257	25	0.0479	284.8	DN315 CHDPE SN8	0.16	0.05	239.5	9.91
K.2.6.9	K-2-6-9	125.174	U-1-9	124.936	65	0.0037	284.8	DN315 CHDPE SN8	4.31	0.37	66.23	23.91
K.2.7.1	K-2-7-1	126.48	U-1-11	126.282	60	0.0033	284.8	DN315 CHDPE SN8	0.21	0.25	62.87	3.99
K.2.8.1	K-2-8-1	126.28	K-2-8-2	125.748	42	0.0127	284.8	DN315 CHDPE SN8	0.26	0.2	123.17	5.23
K.2.8.2	K-2-8-2	125.748	K-2-8-3	125.675	22	0.0033	284.8	DN315 CHDPE SN8	0.63	0.31	62.87	7.14
K.2.8.2.1	K-2-8-2-1	125.95	K-2-8-2-2	125.91	12	0.0033	284.8	DN315 CHDPE SN8	0.16	0.21	62.97	3.68
K.2.8.2.2	K-2-8-2-2	125.91	K-2-8-2	125.748	49	0.0033	284.8	DN315 CHDPE SN8	0.16	0.12	62.97	5.36
K.2.8.2.3	K-2-8-2-3	126.1	K-2-8-2	125.748	18	0.0196	284.8	DN315 CHDPE SN8	0.21	0.18	153.09	4.91

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
K.2.8.3	K-2-8-3	125.675	U-1-14	125.609	20.1	0.0033	284.8	DN315 CHDPE SN8	0.63	0.34	62.87	6.76
K.2.9.1	K-2-9-1	126.101	K-2-9-2	126.002	30	0.0033	284.8	DN315 CHDPE SN8	0.21	0.23	62.87	4.21
K.2.9.2	K-2-9-2	126.002	K-2-9-3	125.94	19	0.0033	284.8	DN315 CHDPE SN8	0.21	0.23	62.51	4.21
K.2.9.3	K-2-9-3	125.94	K-2-9-4	125.841	30	0.0033	284.8	DN315 CHDPE SN8	0.21	0.22	62.87	4.3
K.2.9.4	K-2-9-4	125.841	U-1-17	125.745	29	0.0033	284.8	DN315 CHDPE SN8	0.21	0.25	62.98	3.99
K.3.0.1	K-3-0-1	133.44	K-3-0-2	133.34	30	0.0033	284.8	DN315 CHDPE SN8	1.05	0.37	63.18	8.97
K.3.0.1.1	K-3-0-1-1	179.19	K-3-0-1-2	174.19	50	0.1	284.8	DN315 CHDPE SN8	0.19	0.68	346.06	1.91
K.3.0.1.10	K-3-0-1-10	146.31	K-3-0-1-11	144.31	20	0.1	284.8	DN315 CHDPE SN8	0.38	0.89	346.06	2.52
K.3.0.1.11	K-3-0-1-11	144.31	K-3-0-1-12	141.82	24.9	0.1	284.8	DN315 CHDPE SN8	0.38	0.85	346.05	2.6
K.3.0.1.12	K-3-0-1-12	141.82	K-3-0-1-13	140.53	17.2	0.075	284.8	DN315 CHDPE SN8	0.38	0.66	299.67	3.08
K.3.0.1.13	K-3-0-1-13	140.53	K-3-0-1-14	140.03	20	0.025	284.8	DN315 CHDPE SN8	0.38	0.51	173.03	3.64
K.3.0.1.14	K-3-0-1-14	140.03	K-3-0-1-15	139.35	40	0.017	284.8	DN315 CHDPE SN8	0.38	0.47	142.69	3.85
K.3.0.1.15	K-3-0-1-15	139.35	K-3-0-1-16	138.42	55	0.0169	284.8	DN315 CHDPE SN8	0.38	0.51	142.3	3.68
K.3.0.1.16	K-3-0-1-16	138.42	K-3-0-1-17	137.66	30	0.0253	284.8	DN315 CHDPE SN8	0.38	0.47	174.18	3.9
K.3.0.1.17	K-3-0-1-17	137.66	K-3-0-1-18	137.32	35	0.0097	284.8	DN315 CHDPE SN8	0.38	0.39	107.86	4.36
K.3.0.1.18	K-3-0-1-18	137.32	K-3-0-1-19	136.68	35	0.0183	284.8	DN315 CHDPE SN8	0.53	0.57	147.98	4.22
K.3.0.1.19	K-3-0-1-19	136.68	K-3-0-1-20	136.06	25	0.0248	284.8	DN315 CHDPE SN8	0.53	0.61	172.34	4.04
K.3.0.1.2	K-3-0-1-2	174.19	K-3-0-1-3	170.13	55	0.0738	284.8	DN315 CHDPE SN8	0.19	0.68	297.33	1.91
K.3.0.1.20	K-3-0-1-20	136.06	K-3-0-1-21	135.31	30	0.025	284.8	DN315 CHDPE SN8	0.53	0.61	173.03	4.04
K.3.0.1.21	K-3-0-1-21	135.31	K-3-0-1-22	134.56	30	0.025	284.8	DN315 CHDPE SN8	0.53	0.55	173.03	4.28
K.3.0.1.22	K-3-0-1-22	134.56	K-3-0-1-23	134.18	25	0.0152	284.8	DN315 CHDPE SN8	0.53	0.51	134.92	4.53
K.3.0.1.23	K-3-0-1-23	134.18	K-3-0-1-24	133.66	35	0.0149	284.8	DN315 CHDPE SN8	0.53	0.5	133.39	4.55
K.3.0.1.24	K-3-0-1-24	133.66	K-3-0-1	133.44	15	0.0147	284.8	DN315 CHDPE SN8	0.53	0.28	132.53	6.76
K.3.0.1.3	K-3-0-1-3	170.13	K-3-0-1-4	165.13	50	0.1	284.8	DN315 CHDPE SN8	0.19	0.72	346.06	1.82
K.3.0.1.4	K-3-0-1-4	165.13	K-3-0-1-5	163.27	18.6	0.1001	284.8	DN315 CHDPE SN8	0.19	0.72	346.23	1.82
K.3.0.1.5	K-3-0-1-5	162.14	K-3-0-1-6	159.29	28.5	0.1001	284.8	DN315 CHDPE SN8	0.38	0.89	346.17	2.51

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
K.3.0.1.5.1	K-3-0-1-5-1	165.06	K-3-0-1-5-2	164.21	10	0.085	284.8	DN315 CHDPE SN8	0.19	0.57	319.06	2.13
K.3.0.1.5.2	K-3-0-1-5-2	164.21	K-3-0-1-5-3	163.95	8	0.0325	284.8	DN315 CHDPE SN8	0.19	0.35	197.29	2.95
K.3.0.1.5.3	K-3-0-1-5-3	163.95	K-3-0-1-5-4	163.71	30	0.008	284.8	DN315 CHDPE SN8	0.19	0.36	97.88	2.87
K.3.0.1.5.4	K-3-0-1-5-4	163.71	K-3-0-1-5	163.27	10	0.044	284.8	DN315 CHDPE SN8	0.19	0.54	229.55	2.21
K.3.0.1.6	K-3-0-1-6	157.26	K-3-0-1-7	151.76	50	0.11	284.8	DN315 CHDPE SN8	0.38	0.92	362.96	2.46
K.3.0.1.7	K-3-0-1-7	151.01	K-3-0-1-8	148.35	26.6	0.1002	284.8	DN315 CHDPE SN8	0.38	0.86	346.35	2.58
K.3.0.1.8	K-3-0-1-8	148.35	K-3-0-1-9	147.31	13	0.08	284.8	DN315 CHDPE SN8	0.38	0.81	309.53	2.68
K.3.0.1.8.1	K-3-0-1-8-1	151.27	K-3-0-1-8-2	150.39	30	0.0293	284.8	DN315 CHDPE SN8	0	0	187.43	0.01
K.3.0.1.8.2	K-3-0-1-8-2	150.39	K-3-0-1-8-3	149.55	29	0.029	284.8	DN315 CHDPE SN8	0	0	186.25	0.01
K.3.0.1.8.3	K-3-0-1-8-3	149.55	K-3-0-1-8-4	149.02	18	0.0294	284.8	DN315 CHDPE SN8	0	0	187.78	0.01
K.3.0.1.8.4	K-3-0-1-8-4	149.02	K-3-0-1-8	148.35	23.2	0.0289	284.8	DN315 CHDPE SN8	0	0	186.08	1.33
K.3.0.1.9	K-3-0-1-9	147.31	K-3-0-1-10	146.6	10	0.071	284.8	DN315 CHDPE SN8	0.38	0.79	291.6	2.72
K.3.0.2	K-3-0-2	133.34	K-3-0-3	133.14	60	0.0033	284.8	DN315 CHDPE SN8	1.05	0.37	63.18	8.97
K.3.0.3	K-3-0-3	133.14	K-3-0-4	133.04	30	0.0033	284.8	DN315 CHDPE SN8	1.05	0.37	63.18	8.97
K.3.0.4	K-3-0-4	133.04	K-3-0-5	132.913	38	0.0033	284.8	DN315 CHDPE SN8	1.05	0.37	63.27	8.99
K.3.0.5	K-3-0-5	132.913	K-3-0-6	132.877	11	0.0033	284.8	DN315 CHDPE SN8	1.05	0.36	62.61	9.1
K.3.0.6	K-3-0-6	132.877	K-3-0-7	132.659	40	0.0054	284.8	DN315 CHDPE SN8	1.24	0.54	80.79	7.83
K.3.0.6.1	K-3-0-6-1	139.75	K-3-0-6-2	139.645	32	0.0033	284.8	DN315 CHDPE SN8	0.09	0.18	62.69	2.9
K.3.0.6.2	K-3-0-6-2	139.645	K-3-0-6-3	139.465	55	0.0033	284.8	DN315 CHDPE SN8	0.09	0.16	62.61	3.08
K.3.0.6.3	K-3-0-6-3	139.465	K-3-0-6-4	139.399	20	0.0033	284.8	DN315 CHDPE SN8	0.09	0.25	62.87	2.32
K.3.0.6.4	K-3-0-6-4	139.399	K-3-0-6-5	136.53	40	0.0717	284.8	DN315 CHDPE SN8	0.09	0.52	293.08	1.4
K.3.0.6.5	K-3-0-6-5	136.53	K-3-0-6-6	134.26	35	0.0648	284.8	DN315 CHDPE SN8	0.09	0.46	278.66	1.51
K.3.0.6.6	K-3-0-6-6	134.26	K-3-0-6	133.06	30	0.0401	284.8	DN315 CHDPE SN8	0.09	0.43	219.02	1.61
K.3.0.7	K-3-0-7	132.659	K-3-0-8	131.863	43	0.0185	284.8	DN315 CHDPE SN8	1.24	0.62	148.89	7.12
K.3.0.8	K-3-0-8	131.863	U-2-10	131.49	30.5	0.0122	284.8	DN315 CHDPE SN8	1.48	0.65	120.92	7.76
K.3.0.8.1	K-3-0-8-1	132.18	K-3-0-8-2	132.03	45	0.0033	284.8	DN315 CHDPE SN8	0.23	0.23	63.21	4.41

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
K.3.0.8.2	K-3-0-8-2	132.03	K-3-0-8	131.863	50	0.0033	284.8	DN315 CHDPE SN8	0.23	0.15	63.22	6.09
K.3.1.1	K-3-1-1	132.51	K-3-1-5	131.144	40	0.0341	284.8	DN315 CHDPE SN8	0	0	202.23	0.01
K.3.1.10	K-3-1-10	129.77	K-3-1-11	129.19	50.5	0.0115	284.8	DN315 CHDPE SN8	0	0	117.25	0.01
K.3.1.11	K-3-1-11	129.19	K-3-1-12	129.04	45	0.0033	284.8	DN315 CHDPE SN8	0	0	63.18	0.01
K.3.1.12	K-3-1-12	129.04	K-3-1-14	128.92	35	0.0034	284.8	DN315 CHDPE SN8	0	0	64.08	4.26
K.3.1.14	K-3-1-14	128.92	K-3-1-15	128.74	55	0.0033	284.8	DN315 CHDPE SN8	0.86	0.39	62.61	7.56
K.3.1.15	K-3-1-15	128.74	K-3-1-16	128.42	40	0.008	284.8	DN315 CHDPE SN8	0.86	0.4	97.88	7.36
K.3.1.16	K-3-1-16	128.42	K-3-1-17	128.3	35	0.0034	284.8	DN315 CHDPE SN8	0.86	0.35	64.07	8.11
K.3.1.17	K-3-1-17	128.3	K-3-1-18	128.18	35	0.0034	284.8	DN315 CHDPE SN8	0.86	0.35	64.08	8.18
K.3.1.18	K-3-1-18	128.18	K-3-1-19	128.1	25	0.0032	284.8	DN315 CHDPE SN8	0.86	0.35	61.91	8.22
K.3.1.19	K-3-1-19	128.1	K-3-1-20	127.96	42	0.0033	284.8	DN315 CHDPE SN8	0.86	0.35	63.18	8.15
K.3.1.20	K-3-1-20	127.96	K-3-1-21	127.85	32	0.0034	284.8	DN315 CHDPE SN8	0.86	0.31	64.16	8.86
K.3.1.21	K-3-1-21	127.85	K-3-1-22	127.82	16.5	0.0018	361.8	DN400 CHDPE SN8	0.86	0.39	88.24	5.44
K.3.1.22	K-3-1-22	127.82	K-3-1-23	126.06	25	0.0704	361.8	DN400 CHDPE SN8	1.1	0.95	549.65	3.55
K.3.1.22.1	K-3-1-22-1	129.95	K-3-1-22-2	129.3	25	0.026	284.8	DN315 CHDPE SN8	0.24	0.32	176.46	3.67
K.3.1.22.2	K-3-1-22-2	129.3	K-3-1-22-3	129.14	45	0.0036	284.8	DN315 CHDPE SN8	0.24	0.28	65.25	4.02
K.3.1.22.3	K-3-1-22-3	129.14	K-3-1-22-4	128.74	40	0.01	284.8	DN315 CHDPE SN8	0.24	0.32	109.44	3.64
K.3.1.22.4	K-3-1-22-4	128.74	K-3-1-22-5	128.38	40	0.009	284.8	DN315 CHDPE SN8	0.24	0.41	103.82	3.09
K.3.1.22.5	K-3-1-22-5	128.38	K-3-1-22	127.82	10.8	0.0518	284.8	DN315 CHDPE SN8	0.24	0.37	248.96	3.29
K.3.1.23	K-3-1-23	126.06	K-3-1-24	124.86	30	0.04	361.8	DN400 CHDPE SN8	1.1	0.65	414.31	4.57
K.3.1.24	K-3-1-24	124.86	K-3-1-25	124.68	20	0.009	361.8	DN400 CHDPE SN8	1.1	0.5	196.53	5.43
K.3.1.25	K-3-1-25	124.68	K-3-1-26	124.44	30	0.008	361.8	DN400 CHDPE SN8	1.1	0.41	185.29	6.27
K.3.1.26	K-3-1-26	124.44	K-3-1-27	124.37	15	0.0047	361.8	DN400 CHDPE SN8	1.29	0.47	141.52	6.34
K.3.1.27	K-3-1-27	124.37	K-3-1-28	124.05	32	0.01	361.8	DN400 CHDPE SN8	1.29	0.51	207.16	6.07
K.3.1.28	K-3-1-28	124.05	K-3-1-29	123.94	20	0.0055	361.8	DN400 CHDPE SN8	1.29	0.45	153.52	6.57
K.3.1.29	K-3-1-29	123.94	K-3-1-30	123.75	38	0.005	361.8	DN400 CHDPE SN8	1.29	0.41	146.53	6.96

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
K.3.1.30	K-3-1-30	123.75	K-3-1-31	123.62	25	0.0052	361.8	DN400 CHDPE SN8	1.49	0.5	149.38	6.66
K.3.1.31	K-3-1-31	123.62	K-3-1-32	123.27	35	0.01	361.8	DN400 CHDPE SN8	1.49	0.51	207.15	6.61
K.3.1.32	K-3-1-32	123.27	K-3-1-33	123.14	25	0.0052	361.8	DN400 CHDPE SN8	1.49	0.49	149.35	6.78
K.3.1.33	K-3-1-33	123.14	K-3-1-34	122.94	20	0.01	361.8	DN400 CHDPE SN8	1.68	0.58	207.16	6.55
K.3.1.34	K-3-1-34	122.94	K-3-1-35	122.62	40	0.008	361.8	DN400 CHDPE SN8	1.68	0.43	185.29	8.1
K.3.1.35	K-3-1-35	122.62	K-3-1-36	122.575	18	0.0025	361.8	DN400 CHDPE SN8	1.68	0.47	103.58	7.63
K.3.1.36	K-3-1-36	122.575	K-3-1-37	122.47	6.9	0.0152	361.8	DN400 CHDPE SN8	1.68	0.48	255.48	7.45
K.3.1.37	K-3-1-37	122.47	K-3-1-38	122.43	18	0.0022	361.8	DN400 CHDPE SN8	1.68	0.36	97.65	9.17
K.3.1.38	K-3-1-38	122.43	K-3-1-39	122.39	19	0.0021	361.8	DN400 CHDPE SN8	1.68	0.27	95.05	11
K.3.1.39	K-3-1-39	122.39	K-3-1-40	122.38	6	0.0017	361.8	DN400 CHDPE SN8	2.97	0.52	84.68	10.49
K.3.1.39.1	K-3-1-39-1	172.71	K-3-1-39-2	171.81	20	0.045	284.8	DN315 CHDPE SN8	0.57	0.74	232.15	3.73
K.3.1.39.10	K-3-1-39-10	149.84	K-3-1-39-11	149	12	0.07	284.8	DN315 CHDPE SN8	0.57	0.89	289.54	3.3
K.3.1.39.11	K-3-1-39-11	148.64	K-3-1-39-12	147.14	15	0.1	284.8	DN315 CHDPE SN8	0.57	1.01	346.06	3.04
K.3.1.39.12	K-3-1-39-12	145.84	K-3-1-39-13	143.53	28	0.0825	284.8	DN315 CHDPE SN8	0.57	0.94	314.33	3.18
K.3.1.39.13	K-3-1-39-13	141.6	K-3-1-39-14	136.6	50	0.1	284.8	DN315 CHDPE SN8	0.57	1.01	346.06	3.04
K.3.1.39.14	K-3-1-39-14	135.63	K-3-1-39-15	134.6	16.7	0.0617	284.8	DN315 CHDPE SN8	0.57	0.85	271.84	3.4
K.3.1.39.15	K-3-1-39-15	133.96	K-3-1-39-16	131.07	28.9	0.0999	284.8	DN315 CHDPE SN8	0.57	1.01	345.85	3.03
K.3.1.39.16	K-3-1-39-16	131.07	K-3-1-39-17	130.6	4.6	0.1021	284.8	DN315 CHDPE SN8	0.57	1.02	349.61	3.02
K.3.1.39.17	K-3-1-39-17	129.96	K-3-1-39-18	129.58	25	0.0152	284.8	DN315 CHDPE SN8	0.81	0.69	134.92	4.94
K.3.1.39.17.10	K-3-1-39-17-10	133.68	K-3-1-39-17-11	133.65	8	0.0038	284.8	DN315 CHDPE SN8	0	0	67.02	0.01
K.3.1.39.17.11	K-3-1-39-17-11	133.65	K-3-1-39-17-12	133.59	20	0.003	284.8	DN315 CHDPE SN8	0	0	59.94	0.01
K.3.1.39.17.12	K-3-1-39-17-12	133.59	K-3-1-39-17-13	133.56	7	0.0043	284.8	DN315 CHDPE SN8	0	0	71.64	0.01
K.3.1.39.17.13	K-3-1-39-17-13	133.56	K-3-1-39-17-14	133.5	20	0.003	284.8	DN315 CHDPE SN8	0	0	59.94	0.01
K.3.1.39.17.14	K-3-1-39-17-14	133.5	K-3-1-39-17-15	133.35	45	0.0033	284.8	DN315 CHDPE SN8	0	0	63.18	0.01
K.3.1.39.17.15	K-3-1-39-17-15	133.35	K-3-1-39-17-16	133.31	12.1	0.0033	284.8	DN315 CHDPE SN8	0	0	63.03	0.01
K.3.1.39.17.16	K-3-1-39-17-16	133.31	K-3-1-39-17-17	133.14	50	0.0034	284.8	DN315 CHDPE SN8	0	0	63.81	0.01

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
K.3.1.39.17.17	K-3-1-39-17-17	133.14	K-3-1-39-17-18	133.08	19.9	0.003	284.8	DN315 CHDPE SN8	0	0	60.16	0.01
K.3.1.39.17.18	K-3-1-39-17-18	133.08	K-3-1-39-17-19	133.06	6	0.0033	284.8	DN315 CHDPE SN8	0	0	63.18	0.01
K.3.1.39.17.19	K-3-1-39-17-19	133.06	K-3-1-39-17-20	131.37	12	0.1408	284.8	DN315 CHDPE SN8	0	0	410.69	0.01
K.3.1.39.17.20	K-3-1-39-17-20	131.37	K-3-1-39-17-21	130.27	22	0.05	284.8	DN315 CHDPE SN8	0	0	244.7	0.01
K.3.1.39.17.21	K-3-1-39-17-21	130.27	K-3-1-39-17-22	130.18	27.8	0.0032	284.8	DN315 CHDPE SN8	0	0	62.24	0.01
K.3.1.39.17.22	K-3-1-39-17-22	130.18	K-3-1-39-17-23	130.1	25	0.0032	284.8	DN315 CHDPE SN8	0	0	61.91	0.01
K.3.1.39.17.23	K-3-1-39-17-23	130.1	K-3-1-39-17	129.96	42	0.0033	284.8	DN315 CHDPE SN8	0	0	63.18	3
K.3.1.39.17.3	K-3-1-39-17-3	134.26	K-3-1-39-17-4	134.14	33.2	0.0036	284.8	DN315 CHDPE SN8	0	0	65.78	0.01
K.3.1.39.17.4	K-3-1-39-17-4	134.14	K-3-1-39-17-5	133.99	45	0.0033	284.8	DN315 CHDPE SN8	0	0	63.18	0.01
K.3.1.39.17.5	K-3-1-39-17-5	133.99	K-3-1-39-17-6	133.89	30	0.0033	284.8	DN315 CHDPE SN8	0	0	63.18	0.01
K.3.1.39.17.6	K-3-1-39-17-6	133.89	K-3-1-39-17-7	133.82	21.4	0.0033	284.8	DN315 CHDPE SN8	0	0	62.62	0.01
K.3.1.39.17.7	K-3-1-39-17-7	133.82	K-3-1-39-17-8	133.79	8	0.0038	284.8	DN315 CHDPE SN8	0	0	67.02	0.01
K.3.1.39.17.8	K-3-1-39-17-8	133.79	K-3-1-39-17-9	133.71	25	0.0032	284.8	DN315 CHDPE SN8	0	0	61.91	0.01
K.3.1.39.17.9	K-3-1-39-17-9	133.71	K-3-1-39-17-10	133.68	10	0.003	284.8	DN315 CHDPE SN8	0	0	59.94	0.01
K.3.1.39.18	K-3-1-39-18	129.58	K-3-1-39-19	126.71	41	0.07	284.8	DN315 CHDPE SN8	0.81	0.79	289.54	4.5
K.3.1.39.19	K-3-1-39-19	126.71	K-3-1-39-20	125.9	23	0.0353	284.8	DN315 CHDPE SN8	1.05	0.65	205.53	6.17
K.3.1.39.2	K-3-1-39-2	171.81	K-3-1-39-3	171	18	0.045	284.8	DN315 CHDPE SN8	0.57	0.84	232.15	3.42
K.3.1.39.20	K-3-1-39-20	125.9	K-3-1-39-21	125.5	40	0.01	284.8	DN315 CHDPE SN8	1.05	0.6	109.44	6.44
K.3.1.39.21	K-3-1-39-21	125.5	K-3-1-39-22	124.6	39	0.0231	284.8	DN315 CHDPE SN8	1.05	0.73	166.24	5.68
K.3.1.39.22	K-3-1-39-22	124.32	K-3-1-39	122.39	22	0.0877	284.8	DN315 CHDPE SN8	1.05	0.31	324.13	10.19
K.3.1.39.22.1	K-3-1-39-22-1	130.56	K-3-1-39-22-2	129.92	35	0.0183	284.8	DN315 CHDPE SN8	0	0	147.98	0.01
K.3.1.39.22.2	K-3-1-39-22-2	129.92	K-3-1-39-22-3	127.61	33	0.0699	284.8	DN315 CHDPE SN8	0	0	289.39	0.01
K.3.1.39.22.3	K-3-1-39-22-3	127.61	K-3-1-39-22-4	126.07	22	0.07	284.8	DN315 CHDPE SN8	0	0	289.54	0.01
K.3.1.39.22.4	K-3-1-39-22-4	125.01	K-3-1-39-22-5	124.53	48	0.01	284.8	DN315 CHDPE SN8	0	0	109.44	0.01
K.3.1.39.22.5	K-3-1-39-22-5	124.53	K-3-1-39-22-6	124.47	18	0.0033	284.8	DN315 CHDPE SN8	0	0	63.18	0.01
K.3.1.39.22.6	K-3-1-39-22-6	124.47	K-3-1-39-22-7	124.36	32	0.0034	284.8	DN315 CHDPE SN8	0	0	64.16	0.01

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
K.3.1.39.22.7	K-3-1-39-22-7	124.36	K-3-1-39-22	124.32	12	0.0033	284.8	DN315 CHDPE SN8	0	0	63.18	2.08
K.3.1.39.23	K-3-1-39-23	127.36	K-3-1-39	122.86	45	0.1	284.8	DN315 CHDPE SN8	0.24	0.78	346.06	2.03
K.3.1.39.3	K-3-1-39-3	171	K-3-1-39-4	168.5	25	0.1	284.8	DN315 CHDPE SN8	0.57	1.01	346.06	3.03
K.3.1.39.4	K-3-1-39-4	168.5	K-3-1-39-5	166.7	18	0.1	284.8	DN315 CHDPE SN8	0.57	0.89	346.06	3.3
K.3.1.39.5	K-3-1-39-5	166.7	K-3-1-39-6	165.2	30	0.05	284.8	DN315 CHDPE SN8	0.57	0.79	244.7	3.57
K.3.1.39.6	K-3-1-39-6	164.31	K-3-1-39-7	162.06	45	0.05	284.8	DN315 CHDPE SN8	0.57	0.79	244.7	3.57
K.3.1.39.6.1	K-3-1-39-6-1	176.851	K-3-1-39-6-2	173.851	30	0.1	284.8	DN315 CHDPE SN8	0	0	346.06	0.01
K.3.1.39.6.2	K-3-1-39-6-2	173.851	K-3-1-39-6-3	171.688	25	0.0865	284.8	DN315 CHDPE SN8	0	0	321.9	0.01
K.3.1.39.6.3	K-3-1-39-6-3	171.688	K-3-1-39-6-4	170.088	16	0.1	284.8	DN315 CHDPE SN8	0	0	346.06	0.01
K.3.1.39.6.4	K-3-1-39-6-4	168.56	K-3-1-39-6-5	166.26	23	0.1	284.8	DN315 CHDPE SN8	0	0	346.04	0.01
K.3.1.39.6.5	K-3-1-39-6-5	165.27	K-3-1-39-6	164.31	9.6	0.0999	284.8	DN315 CHDPE SN8	0	0	345.86	1.79
K.3.1.39.7	K-3-1-39-7	160.15	K-3-1-39-8	158.15	20	0.1	284.8	DN315 CHDPE SN8	0.57	1.01	346.06	3.03
K.3.1.39.8	K-3-1-39-8	158.15	K-3-1-39-9	153.65	45	0.1	284.8	DN315 CHDPE SN8	0.57	1.01	346.06	3.03
K.3.1.39.9	K-3-1-39-9	152.65	K-3-1-39-10	151.15	15	0.1	284.8	DN315 CHDPE SN8	0.57	1.01	346.06	3.03
K.3.1.40	K-3-1-40	122.38	K-3-1-41	121.98	20	0.02	361.8	DN400 CHDPE SN8	3.45	1.07	292.96	7.07
K.3.1.40.1	K-3-1-40-1	124.09	K-3-1-40-2	123.79	20	0.015	284.8	DN315 CHDPE SN8	0.48	0.34	134.03	5.57
K.3.1.40.2	K-3-1-40-2	123.79	K-3-1-40-3	123.72	20	0.0035	284.8	DN315 CHDPE SN8	0.48	0.4	64.74	4.94
K.3.1.40.3	K-3-1-40-3	123.72	K-3-1-40	122.38	20	0.067	284.8	DN315 CHDPE SN8	0.48	0.26	283.27	6.74
K.3.1.41	K-3-1-41	121.98	K-3-1-42	120.77	20.1	0.0603	361.8	DN400 CHDPE SN8	3.45	1.44	508.52	5.8
K.3.1.42	K-3-1-42	120.77	K-3-1-43	117.76	43	0.07	361.8	DDN400 CHDPE SN8	3.45	1.48	548.03	5.67
K.3.1.43	K-3-1-43	116.57	K-3-1-44	115.82	25	0.03	361.8	DN400 CHDPE SN8	3.88	1.27	358.81	6.8
K.3.1.44	K-3-1-44	115.82	K-3-1-45	113.42	30	0.08	361.8	DN400 CHDPE SN8	3.88	1.45	585.93	6.23
K.3.1.45	K-3-1-45	113.42	K-3-1-46	112.02	28	0.05	361.8	DN400 CHDPE SN8	4.12	1.2	463.19	7.37
K.3.1.46	K-3-1-46	112.02	K-3-1-47	110.97	42	0.025	361.8	DN400 CHDPE SN8	4.36	0.99	327.54	8.73
K.3.1.46.1	K-3-1-46-1	116.01	K-3-1-46-2	114.25	22	0.08	284.8	DN315 CHDPE SN8	0.24	0.71	309.53	2.14

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
K.3.1.46.2	K-3-1-46-2	114.25	K-3-1-46	112.02	28	0.0795	284.8	DN315 CHDPE SN8	0.24	0.14	308.64	6.2
K.3.1.47	K-3-1-47	110.97	K-3-1-48	110.52	30	0.015	361.8	DN400 CHDPE SN8	4.65	0.93	253.71	9.52
K.3.1.47.1	K-3-1-47-1	118.42	K-3-1-47-2	115.6	25	0.1128	284.8	DN315 CHDPE SN8	0.29	0.85	367.55	2.14
K.3.1.47.2	K-3-1-47-2	114.72	K-3-1-47-3	112.84	25	0.0752	284.8	DN315 CHDPE SN8	0.29	0.71	300.1	2.41
K.3.1.47.3	K-3-1-47-3	112.84	K-3-1-47-4	111.34	25	0.06	284.8	DN315 CHDPE SN8	0.29	0.5	268.06	3.04
K.3.1.47.4	K-3-1-47-4	111.34	K-3-1-47-5	111.1	20	0.012	284.8	DN315 CHDPE SN8	0.29	0.34	119.88	3.98
K.3.1.47.5	K-3-1-47-5	111.1	K-3-1-47	110.97	25	0.0052	284.8	DN315 CHDPE SN8	0.29	0.12	78.87	8.14
K.3.1.48	K-3-1-48	110.52	K-3-1-49	110.28	18	0.0133	361.8	DN400 CHDPE SN8	4.65	0.53	239.2	13.95
K.3.1.49	K-3-1-49	110.28	K-3-1-50	110.24	25	0.0016	361.8	DN400 CHDPE SN8	5.13	0.65	82.86	13.03
K.3.1.49.1	K-3-1-49-1	111.8	K-3-1-49-2	111.24	35	0.016	284.8	DN315 CHDPE SN8	0.48	0.46	138.43	4.5
K.3.1.49.2	K-3-1-49-2	111.24	K-3-1-49-3	111.04	20	0.01	284.8	DN315 CHDPE SN8	0.48	0.38	109.44	5.09
K.3.1.49.3	K-3-1-49-3	111.04	K-3-1-49-4	110.89	25	0.006	284.8	DN315 CHDPE SN8	0.48	0.37	84.76	5.22
K.3.1.49.4	K-3-1-49-4	110.89	K-3-1-49-5	110.65	30	0.008	284.8	DN315 CHDPE SN8	0.48	0.37	97.88	5.19
K.3.1.49.5	K-3-1-49-5	110.65	K-3-1-49-6	110.53	20	0.006	284.8	DN315 CHDPE SN8	0.48	0.36	84.71	5.35
K.3.1.49.6	K-3-1-49-6	110.53	K-3-1-49	110.28	40.3	0.0062	284.8	DN315 CHDPE SN8	0.48	0.09	86.19	14.25
K.3.1.5	K-3-1-5	131.144	K-3-1-10	129.77	50	0.0275	284.8	DN315 CHDPE SN8	0	0	181.41	0.01
K.3.1.50	K-3-1-50	110.24	K-3-1-51	108.32	48	0.04	361.8	DN400 CHDPE SN8	5.13	0.64	414.31	13.24
K.3.1.51	K-3-1-51	108.32	K-3-1-52	108.23	35	0.0026	361.8	DN400 CHDPE SN8	8	0.6	105.05	18.83
K.3.1.51.1	K-3-1-51-1	123.47	K-3-1-51-2	121.6	25	0.0748	284.8	DN315 CHDPE SN8	0.95	0.95	299.3	4.43
K.3.1.51.10	K-3-1-51-10	110.45	K-3-1-51-11	109.3	15	0.0767	284.8	DN315 CHDPE SN8	0.95	0.83	303.01	4.85
K.3.1.51.11	K-3-1-51-11	109.3	K-3-1-51-12	108.9	20	0.02	284.8	DN315 CHDPE SN8	0.95	0.35	154.76	8.71
K.3.1.51.12	K-3-1-51-12	108.9	K-3-1-51-13	108.8	29	0.0034	284.8	DN315 CHDPE SN8	1.9	0.44	64.26	11.9
K.3.1.51.13	K-3-1-51-13	108.8	K-3-1-51-14	108.62	55.1	0.0033	284.8	DN315 CHDPE SN8	1.91	0.44	62.57	11.96
K.3.1.51.14	K-3-1-51-14	108.62	K-3-1-51-15	108.54	24	0.0033	284.8	DN315 CHDPE SN8	1.91	0.44	63.18	11.93
K.3.1.51.15	K-3-1-51-15	108.54	K-3-1-51	108.32	66	0.0033	284.8	DN315 CHDPE SN8	1.91	0.25	63.17	17.82
K.3.1.51.2	K-3-1-51-2	121.6	K-3-1-51-3	120.6	25	0.04	284.8	DN315 CHDPE SN8	0.95	0.53	218.87	6.6

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
K.3.1.51.3	K-3-1-51-3	120.6	K-3-1-51-4	120.53	20	0.0035	284.8	DN315 CHDPE SN8	0.95	0.35	64.74	8.79
K.3.1.51.4	K-3-1-51-4	120.53	K-3-1-51-5	120.4	40	0.0033	284.8	DN315 CHDPE SN8	0.95	0.42	62.39	7.71
K.3.1.51.5	K-3-1-51-5	120.4	K-3-1-51-6	119.98	25	0.0168	284.8	DN315 CHDPE SN8	0.95	0.74	141.84	5.21
K.3.1.51.6	K-3-1-51-6	119.98	K-3-1-51-7	118.7	16	0.08	284.8	DN315 CHDPE SN8	0.95	1.12	309.53	3.98
K.3.1.51.7	K-3-1-51-7	118.7	K-3-1-51-8	118	7	0.1	284.8	DN315 CHDPE SN8	0.95	1.18	346.06	3.85
K.3.1.51.8	K-3-1-51-8	118	K-3-1-51-9	115.99	20.1	0.1001	284.8	DN315 CHDPE SN8	0.95	1.18	346.28	3.85
K.3.1.51.9	K-3-1-51-9	113.7	K-3-1-51-10	111.704	32	0.0624	284.8	DN315 CHDPE SN8	0.95	1	273.31	4.29
K.3.1.52	K-3-1-52	108.23	K-3-1-53	108.17	25	0.0024	361.8	DN400 CHDPE SN8	8	0.58	101.49	19.11
K.3.1.53	K-3-1-53	108.17	K-3-1-54	108.1	30	0.0023	361.8	DN400 CHDPE SN8	8	0.59	100.07	18.96
K.3.1.54	K-3-1-54	108.1	K-3-1-55	108.01	35	0.0026	361.8	DN400 CHDPE SN8	8.01	0.54	105.05	20.31
K.3.1.55	K-3-1-55	108.01	K-3-1-56	107.96	30.6	0.0016	452.4	DN500 CHDPE SN8	9.87	0.56	151.92	16.73
K.3.1.55.1	K-3-1-55-1	110.44	K-3-1-55-2	110.26	30	0.006	284.8	DN315 CHDPE SN8	0.62	0.34	84.77	6.57
K.3.1.55.10	K-3-1-55-10	109.53	K-3-1-55	108.01	36.6	0.0415	284.8	DN315 CHDPE SN8	1.19	0.17	223.03	16.55
K.3.1.55.2	K-3-1-55-2	110.26	K-3-1-55-3	110.18	25	0.0032	284.8	DN315 CHDPE SN8	0.62	0.31	61.91	7.02
K.3.1.55.3	K-3-1-55-3	110.18	K-3-1-55-4	110.13	15	0.0033	284.8	DN315 CHDPE SN8	0.62	0.32	63.18	6.97
K.3.1.55.4	K-3-1-55-4	110.13	K-3-1-55-5	110.08	15	0.0033	284.8	DN315 CHDPE SN8	0.62	0.31	63.18	7.02
K.3.1.55.5	K-3-1-55-5	110.08	K-3-1-55-6	110	25	0.0032	284.8	DN315 CHDPE SN8	0.62	0.31	61.85	7.03
K.3.1.55.6	K-3-1-55-6	110	K-3-1-55-7	109.9	30	0.0033	284.8	DN315 CHDPE SN8	0.62	0.25	63.23	8.25
K.3.1.55.7	K-3-1-55-7	109.9	K-3-1-55-8	109.75	45	0.0033	284.8	DN315 CHDPE SN8	1.19	0.39	63.18	9.52
K.3.1.55.8	K-3-1-55-8	109.75	K-3-1-55-9	109.6	45	0.0033	284.8	DN315 CHDPE SN8	1.19	0.36	63.18	10.01
K.3.1.55.9	K-3-1-55-9	109.6	K-3-1-55-10	109.53	20	0.0035	284.8	DN315 CHDPE SN8	1.19	0.51	64.74	7.87
K.3.1.56	K-3-1-56	107.96	K-3-1-57	107.87	39.4	0.0023	452.4	DN500 CHDPE SN8	9.88	0.58	179.71	16.23
K.3.1.57	K-3-1-57	107.87	K-3-1-58	107.81	30	0.002	452.4	DN500 CHDPE SN8	9.88	0.58	168.12	16.3
K.3.1.58	K-3-1-58	107.81	K-3-1-59	107.7	50	0.0022	452.4	DN500 CHDPE SN8	9.89	0.57	176.33	16.46
K.3.1.59	K-3-1-59	107.7	K-3-1-60	107.66	22	0.0018	452.4	DN500 CHDPE SN8	9.9	0.54	160.3	17.1
K.3.1.60	K-3-1-60	107.66	K-3-1-61	107.6	30	0.002	452.4	DN500 CHDPE SN8	11.04	0.59	168.12	17.38

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
K.3.1.61	K-3-1-61	107.6	K-3-1-62	107.57	15	0.002	452.4	DN500 CHDPE SN8	11.04	0.6	168.12	17.16
K.3.1.62	K-3-1-62	107.57	K-3-1-63	107.53	18	0.0022	452.4	DN500 CHDPE SN8	11.05	0.59	177.14	17.35
K.3.1.63	K-3-1-63	107.53	K-3-1-64	107.49	22	0.0018	452.4	DN500 CHDPE SN8	11.05	0.55	160.3	18.16
K.3.1.64	K-3-1-64	107.49	K-3-1-65	107.4	45	0.002	452.4	DN500 CHDPE SN8	11.06	0.74	168.07	14.91
K.3.1.65	K-3-1-65	107.4	K-3-1-66	107.05	28	0.0125	452.4	DN500 CHDPE SN8	11.3	0.79	420.31	14.45
K.3.1.66	K-3-1-66	107.05	K-3-1-67	106.98	33.5	0.0021	452.4	DN500 CHDPE SN8	11.64	0.59	171.85	18.07
K.3.1.66.1	K-3-1-66-1	110.201	K-3-1-66-2	109.902	25	0.012	284.8	DN315 CHDPE SN8	0	0	119.68	0.01
K.3.1.66.10	K-3-1-66-10	108.663	K-3-1-66-11	108.496	50	0.0033	284.8	DN315 CHDPE SN8	0.33	0.26	63.25	5.2
K.3.1.66.11	K-3-1-66-11	108.496	K-3-1-66-12	108.379	35.1	0.0033	284.8	DN315 CHDPE SN8	0.33	0.25	63.21	5.29
K.3.1.66.12	K-3-1-66-12	108.379	K-3-1-66	108.282	29	0.0033	284.8	DN315 CHDPE SN8	0.33	0.28	63.29	4.98
K.3.1.66.2	K-3-1-66-2	109.902	K-3-1-66-3	109.153	36	0.0208	284.8	DN315 CHDPE SN8	0	0	157.85	0.01
K.3.1.66.3	K-3-1-66-3	109.153	K-3-1-66-4	109.013	42	0.0033	284.8	DN315 CHDPE SN8	0	0	63.18	0.01
K.3.1.66.4	K-3-1-66-4	109.013	K-3-1-66-5	108.973	12	0.0033	284.8	DN315 CHDPE SN8	0	0	63.18	0.01
K.3.1.66.5	K-3-1-66-5	108.973	K-3-1-66-6	108.923	15	0.0033	284.8	DN315 CHDPE SN8	0	0	63.18	0.01
K.3.1.66.6	K-3-1-66-6	108.923	K-3-1-66-7	108.715	48.9	0.0042	284.8	DN315 CHDPE SN8	0	0	71.34	0.01
K.3.1.66.7	K-3-1-66-7	108.715	K-3-1-66-8	108.7	22	0.0007	284.8	DN315 CHDPE SN8	0	0	28.58	0.01
K.3.1.66.8	K-3-1-66-8	108.7	K-3-1-66-9	108.68	21	0.001	284.8	DN315 CHDPE SN8	0	0	33.77	0.01
K.3.1.66.9	K-3-1-66-9	108.68	K-3-1-66-10	108.663	22.2	0.0008	284.8	DN315 CHDPE SN8	0	0	30.28	2.6
K.3.1.67	K-3-1-67	106.98	K-3-1-68	106.96	11	0.0018	452.4	DN500 CHDPE SN8	12.07	0.61	160.3	18.14
K.3.1.68	K-3-1-68	106.96	K-3-1-69	106.89	32	0.0022	452.4	DN500 CHDPE SN8	12.07	0.6	175.83	18.23
K.3.1.69	K-3-1-69	106.89	K-3-1-70	106.82	38	0.0018	452.4	DN500 CHDPE SN8	12.08	0.6	161.35	18.2
K.3.1.70	K-3-1-70	106.82	K-3-1-71	106.74	36	0.0022	452.4	DN500 CHDPE SN8	12.08	0.61	177.22	18.07
K.3.1.71	K-3-1-71	106.74	K-3-1-72	106.7	20	0.002	452.4	DN500 CHDPE SN8	12.52	0.59	168.09	19.04
K.3.1.72	K-3-1-72	106.7	K-3-1-73	106.63	38	0.0018	452.4	DN500 CHDPE SN8	12.52	0.72	161.35	16.57
K.3.1.73	K-3-1-73	106.63	K-3	106.4	32	0.0072	452.4	DN500 CHDPE SN8	12.53	0.86	318.71	14.62
K.3.2.1	K-3-2-1	128.158	K-3-2-2	128.024	40	0.0034	284.8	DN315 CHDPE SN8	0.94	0.45	63.37	7.32

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
K.3.2.1.1	K-3-2-1-1	128.846	K-3-2-1-2	128.423	35	0.0121	284.8	DN315 CHDPE SN8	0	0	120.31	0.01
K.3.2.1.2	K-3-2-1-2	128.423	K-3-2-1-3	128.325	30	0.0033	284.8	DN315 CHDPE SN8	0	0	62.55	0.01
K.3.2.1.3	K-3-2-1-3	128.325	K-3-2-1	128.158	49.9	0.0033	284.8	DN315 CHDPE SN8	0	0	63.3	4.59
K.3.2.10	K-3-2-10	124.23	K-3-2-11	124.09	32	0.0044	284.8	DN315 CHDPE SN8	1.65	0.52	72.38	9.72
K.3.2.11	K-3-2-11	124.09	K-3-2-12	123.84	25	0.01	284.8	DN315 CHDPE SN8	1.65	0.62	109.44	8.57
K.3.2.12	K-3-2-12	123.84	K-3-2-13	123.69	15	0.01	284.8	DN315 CHDPE SN8	1.65	0.62	109.44	8.66
K.3.2.13	K-3-2-13	123.69	K-3-2-14	123.51	15	0.012	284.8	DN315 CHDPE SN8	1.66	0.74	119.88	7.67
K.3.2.14	K-3-2-14	123.51	K-3-2-15	122.97	18	0.03	284.8	DN315 CHDPE SN8	1.66	0.71	189.55	7.89
K.3.2.15	K-3-2-15	122.97	K-3-2-16	122.59	32	0.0119	284.8	DN315 CHDPE SN8	2.08	0.65	119.25	9.8
K.3.2.152	K-3-2-97	106.24	W-2	106.2	6.1	0.0066	452.4	DN500 CHDPE SN8	24.85	1.14	304.4	19.34
K.3.2.16	K-3-2-16	122.59	K-3-2-17	122.34	36	0.0069	284.8	DN315 CHDPE SN8	2.08	0.59	91.2	10.45
K.3.2.17	K-3-2-17	122.34	K-3-2-18	121.94	38.8	0.0103	284.8	DN315 CHDPE SN8	2.56	0.72	111.12	10.51
K.3.2.17.1	K-3-2-17-1	122.607	K-3-2-17	122.34	42	0.0064	284.8	DN315 CHDPE SN8	0	0	87.25	5.24
K.3.2.18	K-3-2-18	121.94	K-3-2-19	121.5	44	0.01	284.8	DN315 CHDPE SN8	2.56	0.45	109.44	14.46
K.3.2.19	K-3-2-19	121.5	K-3-2-20	121.32	56	0.0032	284.8	DN315 CHDPE SN8	3.71	0.69	62.04	13.99
K.3.2.19.1	K-3-2-19-1	122.36	K-3-2-19-2	121.96	27	0.0148	284.8	DN315 CHDPE SN8	0.71	0.48	133.2	5.78
K.3.2.19.2	K-3-2-19-2	121.96	K-3-2-19-3	121.76	28	0.0071	284.8	DN315 CHDPE SN8	0.71	0.45	92.49	6.1
K.3.2.19.3	K-3-2-19-3	121.76	K-3-2-19-4	121.64	12	0.01	284.8	DN315 CHDPE SN8	0.71	0.5	109.43	5.6
K.3.2.19.4	K-3-2-19-4	121.64	K-3-2-19	121.5	10	0.014	284.8	DN315 CHDPE SN8	0.71	0.17	129.49	11.84
K.3.2.2	K-3-2-2	128.024	K-3-2-3	127.28	35	0.0213	284.8	DN315 CHDPE SN8	0.94	0.6	159.65	6.01
K.3.2.20	K-3-2-20	121.32	K-3-2-21	120.07	25	0.05	284.8	DN315 CHDPE SN8	4.71	1.2	244.7	11.21
K.3.2.20.1	K-3-2-20-1	122	K-3-2-20-2	121.74	17	0.0153	284.8	DN315 CHDPE SN8	0.24	0.28	135.34	4
K.3.2.20.2	K-3-2-20-2	121.74	K-3-2-20-3	121.65	30	0.003	284.8	DN315 CHDPE SN8	0.24	0.28	59.94	3.98
K.3.2.20.3	K-3-2-20-3	121.65	K-3-2-20	121.32	20.1	0.0164	284.8	DN315 CHDPE SN8	0.24	0.14	140.27	6.34
K.3.2.20.4	K-3-2-20-4	125.41	K-3-2-20-5	123.41	20	0.1	284.8	DN315 CHDPE SN8	0.52	0.93	346.06	3.01
K.3.2.20.5	K-3-2-20-5	123.41	K-3-2-20-6	121.91	20	0.075	284.8	DN315 CHDPE SN8	0.52	0.72	299.7	3.57

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
K.3.2.20.6	K-3-2-20-6	121.91	K-3-2-20	121.32	24	0.0246	284.8	DN315 CHDPE SN8	0.52	0.28	171.59	6.82
K.3.2.21	K-3-2-21	120.07	K-3-2-22	119.35	48	0.015	284.8	DN315 CHDPE SN8	4.71	0.83	134.03	14.41
K.3.2.22	K-3-2-22	119.35	K-3-2-23	119.17	30	0.006	284.8	DN315 CHDPE SN8	4.71	0.6	84.77	18.17
K.3.2.23	K-3-2-23	119.17	K-3-2-24	119.09	25	0.0032	284.8	DN315 CHDPE SN8	5.28	0.64	61.91	18.71
K.3.2.24	K-3-2-24	119.09	K-3-2-25	118.94	25	0.006	284.8	DN315 CHDPE SN8	5.29	0.75	84.77	16.74
K.3.2.25	K-3-2-25	118.94	K-3-2-26	118.8	18	0.0078	284.8	DN315 CHDPE SN8	5.29	0.84	96.51	15.47
K.3.2.25.1	K-3-2-25-1	117.85	K-3-2-25-2	116.95	60	0.015	284.8	DN315 CHDPE SN8	0.33	0.33	134.03	4.44
K.3.2.25.2	K-3-2-25-2	116.95	K-3-2-25-3	116.784	50	0.0033	284.8	DN315 CHDPE SN8	0.33	0.26	62.96	5.21
K.3.2.25.3	K-3-2-25-3	116.784	K-3-2-25-4	116.619	50	0.0033	284.8	DN315 CHDPE SN8	0.33	0.26	62.95	5.22
K.3.2.25.4	K-3-2-25-4	116.619	K-3-2-41	116.45	51.1	0.0033	284.8	DN315 CHDPE SN8	0.33	0.12	62.95	9.08
K.3.2.26	K-3-2-26	118.8	K-3-2-27	118.52	25	0.0112	284.8	DN315 CHDPE SN8	5.29	0.87	115.82	15.12
K.3.2.27	K-3-2-27	118.52	K-3-2-28	118.22	32	0.0094	284.8	DN315 CHDPE SN8	5.29	0.91	105.96	14.64
K.3.2.28	K-3-2-28	118.22	K-3-2-29	117.88	22.9	0.0149	284.8	DN315 CHDPE SN8	5.29	0.99	133.43	13.82
K.3.2.29	K-3-2-29	117.88	K-3-2-30	117.76	8	0.015	284.8	DN315 CHDPE SN8	5.67	0.78	133.84	17.15
K.3.2.29.1	K-3-2-29-1	117.001	K-3-2-29-2	116.825	48	0.0037	284.8	DN315 CHDPE SN8	0.33	0.34	66.27	4.34
K.3.2.29.2	K-3-2-29-2	116.825	K-3-2-29-3	115.4	48	0.0297	284.8	DN315 CHDPE SN8	0.33	0.37	188.56	4.15
K.3.2.29.3	K-3-2-29-3	115.4	K-3-2-29-4	115.229	50	0.0034	284.8	DN315 CHDPE SN8	0.33	0.26	64.08	5.17
K.3.2.29.4	K-3-2-29-4	115.229	K-3-2-44	115.04	55	0.0034	284.8	DN315 CHDPE SN8	0.33	0.07	64.08	12.85
K.3.2.3	K-3-2-3	127.28	K-3-2-4	127.06	22	0.01	284.8	DN315 CHDPE SN8	0.94	0.5	109.36	6.73
K.3.2.30	K-3-2-30	117.76	K-3-2-31	117.66	30	0.0033	284.8	DN315 CHDPE SN8	5.67	0.61	63.18	20.28
K.3.2.31	K-3-2-31	117.66	K-3-2-32	117.56	30	0.0033	284.8	DN315 CHDPE SN8	5.68	0.62	63.18	20.19
K.3.2.32	K-3-2-32	117.56	K-3-2-33	117.47	26	0.0035	284.8	DN315 CHDPE SN8	5.68	0.6	64.39	20.5
K.3.2.33	K-3-2-33	117.47	K-3-2-34	117.44	10	0.003	284.8	DN315 CHDPE SN8	5.68	0.6	59.94	20.53
K.3.2.34	K-3-2-34	117.44	K-3-2-35	117.32	35	0.0034	284.8	DN315 CHDPE SN8	5.68	0.62	64.08	20.2
K.3.2.35	K-3-2-35	117.32	K-3-2-36	117.28	12	0.0033	284.8	DN315 CHDPE SN8	5.69	0.61	63.18	20.35
K.3.2.36	K-3-2-36	117.28	K-3-2-37	117.15	40	0.0032	284.8	DN315 CHDPE SN8	5.69	0.61	62.39	20.36

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
K.3.2.37	K-3-2-37	117.15	K-3-2-38	117.05	30	0.0033	284.8	DN315 CHDPE SN8	5.69	0.62	63.18	20.28
K.3.2.38	K-3-2-38	117.05	K-3-2-39	116.95	30	0.0033	284.8	DN315 CHDPE SN8	5.69	0.54	63.18	22.2
K.3.2.39	K-3-2-39	116.95	K-3-2-40	116.91	14	0.0029	284.8	DN315 CHDPE SN8	5.7	0.77	58.5	17.42
K.3.2.4	K-3-2-4	127.06	K-3-2-5	126.82	30	0.008	284.8	DN315 CHDPE SN8	0.94	0.49	97.88	6.87
K.3.2.40	K-3-2-40	116.91	K-3-2-41	116.45	10	0.046	284.8	DN315 CHDPE SN8	5.7	1.34	234.71	11.83
K.3.2.41	K-3-2-41	116.45	K-3-2-42	115.82	35	0.018	361.8	DN400 CHDPE SN8	6.03	0.92	277.93	11.51
K.3.2.42	K-3-2-42	115.82	K-3-2-43	115.437	46.4	0.0083	361.8	DN400 CHDPE SN8	6.04	0.91	188.35	11.56
K.3.2.43	K-3-2-43	115.437	K-3-2-44	115.04	23	0.0172	361.8	DN400 CHDPE SN8	6.04	0.75	272.03	13.22
K.3.2.44	K-3-2-44	115.04	K-3-2-45	115	13.6	0.0029	361.8	DN400 CHDPE SN8	6.38	0.56	112.51	16.72
K.3.2.45	K-3-2-45	115	K-3-2-46	114.943	25	0.0023	361.8	DN400 CHDPE SN8	6.38	0.55	99.28	16.98
K.3.2.46	K-3-2-46	114.943	K-3-2-47	114.87	28	0.0026	361.8	DN400 CHDPE SN8	6.38	0.53	105.47	17.44
K.3.2.47	K-3-2-47	114.87	K-3-2-48	114.83	15	0.0027	361.8	DN400 CHDPE SN8	6.38	0.72	107	14.16
K.3.2.48	K-3-2-48	114.83	K-3-2-49	114.31	25	0.0208	361.8	DN400 CHDPE SN8	6.38	0.77	298.77	13.49
K.3.2.49	K-3-2-49	114.31	K-3-2-50	114.28	10.3	0.0029	361.8	DN400 CHDPE SN8	6.91	0.57	111.53	17.64
K.3.2.49.1	K-3-2-49-1	114.44	K-3-2-49-2	114.35	26	0.0035	284.8	DN315 CHDPE SN8	0.52	0.27	64.39	6.96
K.3.2.49.2	K-3-2-49-2	114.35	K-3-2-49	114.31	14.3	0.0028	284.8	DN315 CHDPE SN8	0.52	0.09	57.83	14.48
K.3.2.5	K-3-2-5	126.82	K-3-2-6	126.42	40	0.01	284.8	DN315 CHDPE SN8	0.94	0.58	109.43	6.13
K.3.2.50	K-3-2-50	114.28	K-3-2-51	114.25	12	0.0025	361.8	DN400 CHDPE SN8	6.91	0.68	103.58	15.53
K.3.2.51	K-3-2-51	114.25	K-3-2-52	113.99	26	0.01	361.8	DN400 CHDPE SN8	6.91	0.95	207.16	12.36
K.3.2.52	K-3-2-52	113.99	K-3-2-53	113.85	12	0.0117	361.8	DN400 CHDPE SN8	6.92	0.74	223.76	14.64
K.3.2.53	K-3-2-53	113.85	K-3-2-54	113.81	15	0.0027	361.8	DN400 CHDPE SN8	6.92	0.58	106.98	17.33
K.3.2.54	K-3-2-54	113.81	K-3-2-55	113.72	35	0.0026	361.8	DN400 CHDPE SN8	6.92	0.58	105.05	17.33
K.3.2.55	K-3-2-55	113.72	K-3-2-56	113.68	15	0.0027	361.8	DN400 CHDPE SN8	6.92	0.55	106.98	17.94
K.3.2.56	K-3-2-56	113.68	K-3-2-57	113.64	15	0.0027	361.8	DN400 CHDPE SN8	6.92	0.72	106.98	15
K.3.2.57	K-3-2-57	113.64	K-3-2-58	113.37	18	0.015	361.8	DN400 CHDPE SN8	6.93	1.07	253.71	11.35
K.3.2.58	K-3-2-58	113.37	K-3-2-59	113.25	8	0.015	361.8	DN400 CHDPE SN8	6.93	1	253.71	11.92

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
K.3.2.59	K-3-2-59	113.25	K-3-2-60	113.07	17.8	0.0101	361.8	DN400 CHDPE SN8	6.93	0.8	208.24	13.85
K.3.2.6	K-3-2-6	126.42	K-3-2-7	126.09	15	0.022	284.8	DN315 CHDPE SN8	0.94	0.66	162.32	5.61
K.3.2.60	K-3-2-60	113.07	K-3-2-61	113	12	0.0058	361.8	DN400 CHDPE SN8	6.93	0.82	158.22	13.71
K.3.2.61	K-3-2-61	113	K-3-2-62	112.71	20	0.0145	361.8	DN400 CHDPE SN8	6.93	1.13	249.45	10.92
K.3.2.62	K-3-2-62	112.71	K-3-2-63	112.47	8	0.03	361.8	DN400 CHDPE SN8	6.93	1.37	358.81	9.63
K.3.2.63	K-3-2-63	112.47	K-3-2-64	112.11	12	0.03	361.8	DN400 CHDPE SN8	6.93	0.92	358.81	12.62
K.3.2.64	K-3-2-64	112.11	K-3-2-65	112.03	15	0.0053	361.8	DN400 CHDPE SN8	6.93	0.81	151.29	13.81
K.3.2.64.1	K-3-2-64-1	108.557	K-3-2-83	107.277	16	0.08	284.8	DN315 CHDPE SN8	0.33	0.15	309.54	7.64
K.3.2.65	K-3-2-65	112.03	K-3-2-66	111.61	35	0.012	361.8	DN400 CHDPE SN8	6.94	0.98	226.93	12.08
K.3.2.66	K-3-2-66	111.61	K-3-2-67	111.4	18	0.0117	361.8	DN400 CHDPE SN8	6.94	0.99	223.76	12.02
K.3.2.67	K-3-2-67	111.4	K-3-2-68	111.25	12	0.0125	361.8	DN400 CHDPE SN8	6.94	0.93	231.61	12.5
K.3.2.68	K-3-2-68	111.25	K-3-2-69	111.04	25	0.0084	361.8	DN400 CHDPE SN8	6.94	0.88	189.86	13.02
K.3.2.68.1	K-3-2-68-1	123.6	K-3-2-68-2	122.7	20	0.0451	284.8	DN315 CHDPE SN8	0	0	232.41	0.01
K.3.2.68.2	K-3-2-68-2	122.7	K-3-2-68-3	120.84	20.1	0.0927	284.8	DN315 CHDPE SN8	0	0	333.18	0.01
K.3.2.68.3	K-3-2-68-3	120.84	K-3-2-68-4	119.73	12	0.0925	284.8	DN315 CHDPE SN8	0	0	332.83	0.01
K.3.2.68.4	K-3-2-68-4	119.73	K-3-2-68-5	115.73	40	0.1	284.8	DN315 CHDPE SN8	0	0	346.06	0.01
K.3.2.68.5	K-3-2-68-5	115.73	K-3-2-68-6	113.82	25	0.0764	284.8	DN315 CHDPE SN8	0	0	302.48	0.01
K.3.2.68.6	K-3-2-68-6	113.82	K-3-2-68-7	112.59	16	0.0767	284.8	DN315 CHDPE SN8	0	0	303.03	0.01
K.3.2.68.7	K-3-2-68-7	112.59	K-3-2-68-8	111.72	30	0.029	284.8	DN315 CHDPE SN8	0	0	186.36	0.01
K.3.2.68.8	K-3-2-68-8	111.72	K-3-2-68	111.25	40	0.0117	284.8	DN315 CHDPE SN8	0	0	118.62	8.34
K.3.2.69	K-3-2-69	111.04	K-3-2-70	110.85	20	0.0095	361.8	DN400 CHDPE SN8	7.18	0.93	201.91	12.88
K.3.2.69.1	K-3-2-69-1	114.02	K-3-2-69-2	111.22	35	0.08	284.8	DN315 CHDPE SN8	0.24	0.37	309.53	3.3
K.3.2.69.2	K-3-2-69-2	111.22	K-3-2-69	111.04	55	0.0033	284.8	DN315 CHDPE SN8	0.24	0.07	62.6	10.43
K.3.2.7	K-3-2-7	126.09	K-3-2-8	125.4	40.8	0.0169	284.8	DN315 CHDPE SN8	0.94	0.63	142.3	5.82
K.3.2.70	K-3-2-70	110.85	K-3-2-71	110.56	30	0.0097	361.8	DN400 CHDPE SN8	7.18	0.91	203.68	13.01
K.3.2.71	K-3-2-71	110.56	K-3-2-72	110.12	44.9	0.0098	361.8	DN400 CHDPE SN8	7.19	0.98	205.13	12.35

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
K.3.2.72	K-3-2-72	110.12	K-3-2-73	109.49	35	0.018	361.8	DN400 CHDPE SN8	7.81	1.01	277.9	12.87
K.3.2.72.1	K-3-2-72-1	121.84	K-3-2-72-2	121.62	20	0.011	284.8	DN315 CHDPE SN8	0.24	0.36	114.78	3.37
K.3.2.72.10	K-3-2-72-10	110.424	K-3-2-72	110.12	35.2	0.0086	284.8	DN315 CHDPE SN8	0.62	0.18	101.65	10.1
K.3.2.72.2	K-3-2-72-2	121.62	K-3-2-72-3	121.29	30	0.011	284.8	DN315 CHDPE SN8	0.24	0.35	114.78	3.4
K.3.2.72.3	K-3-2-72-3	121.29	K-3-2-72-4	121.1	18	0.0106	284.8	DN315 CHDPE SN8	0.24	0.36	112.43	3.39
K.3.2.72.4	K-3-2-72-4	121.1	K-3-2-72-5	121.01	8	0.0112	284.8	DN315 CHDPE SN8	0.24	0.36	116.07	3.37
K.3.2.72.5	K-3-2-72-5	121.01	K-3-2-72-6	120.9	10	0.011	284.8	DN315 CHDPE SN8	0.24	0.36	114.78	3.38
K.3.2.72.6	K-3-2-72-6	120.9	K-3-2-72-7	120.66	22	0.0109	284.8	DN315 CHDPE SN8	0.24	0.36	114.3	3.38
K.3.2.72.7	K-3-2-72-7	117.46	K-3-2-72-8	114.46	25	0.12	284.8	DN315 CHDPE SN8	0.62	1.1	379.09	3.02
K.3.2.72.8	K-3-2-72-8	112.6	K-3-2-72-9	110.98	20	0.081	284.8	DN315 CHDPE SN8	0.62	0.84	311.46	3.63
K.3.2.72.9	K-3-2-72-9	110.98	K-3-2-72-10	110.424	14.8	0.0377	284.8	DN315 CHDPE SN8	0.62	0.55	212.36	4.77
K.3.2.73	K-3-2-73	109.49	K-3-2-74	109.146	40	0.0086	361.8	DN400 CHDPE SN8	7.81	0.97	192.14	13.23
K.3.2.73.1	K-3-2-73-1	134.17	K-3-2-73-2	131.17	25	0.12	284.8	DN315 CHDPE SN8	0.24	0.83	379.09	1.94
K.3.2.73.2	K-3-2-73-2	129.53	K-3-2-73-3	128.03	15	0.1	284.8	DN315 CHDPE SN8	0.24	0.78	346.06	2.03
K.3.2.73.3	K-3-2-73-3	127.3	K-3-2-73-4	125.91	14	0.0993	284.8	DN315 CHDPE SN8	0.24	0.77	344.83	2.03
K.3.2.73.4	K-3-2-73-4	124.28	K-3-2-73-5	122.51	17.7	0.0998	284.8	DN315 CHDPE SN8	0.24	0.78	345.66	2.03
K.3.2.73.5	K-3-2-73-5	121.47	K-3-2-73-6	119.47	20	0.1	284.8	DN315 CHDPE SN8	0.24	0.77	346.06	2.03
K.3.2.73.6	K-3-2-73-6	119.47	K-3-2-73-7	117.46	20.1	0.1001	284.8	DN315 CHDPE SN8	0.24	0.78	346.27	2.03
K.3.2.73.7	K-3-2-73-7	114.88	K-3-2-73-8	110.88	40	0.1	284.8	DN315 CHDPE SN8	0.24	0.77	346.06	2.03
K.3.2.73.8	K-3-2-73-8	110.88	K-3-2-93	109.37	15.1	0.1003	284.8	DN315 CHDPE SN8	0.24	0.78	346.6	2.03
K.3.2.74	K-3-2-74	109.146	K-3-2-75	108.56	38	0.0154	361.8	DN400 CHDPE SN8	7.81	1.17	257.25	11.65
K.3.2.75	K-3-2-75	108.56	K-3-2-76	108.41	8	0.0188	452.4	DN500 CHDPE SN8	8.29	1.19	514.77	8.83
K.3.2.75.1	K-3-2-75-1	112.78	K-3-2-75-2	108.78	40	0.1	284.8	DN315 CHDPE SN8	0.48	0.46	346.06	4.54
K.3.2.75.2	K-3-2-75-2	108.78	K-3-2-75-3	108.66	38	0.0032	284.8	DN315 CHDPE SN8	0.48	0.29	61.5	6.21
K.3.2.75.3	K-3-2-75-3	108.66	K-3-2-75	108.56	29	0.0034	284.8	DN315 CHDPE SN8	0.48	0.14	64.25	10.08
K.3.2.76	K-3-2-76	108.41	K-3-2-77	108.28	6.9	0.0189	452.4	DN500 CHDPE SN8	8.29	1.19	517.24	8.81

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
K.3.2.77	K-3-2-77	108.28	K-3-2-78	107.9	20	0.019	452.4	DN500 CHDPE SN8	8.29	0.73	518.19	12.3
K.3.2.78	K-3-2-78	107.9	K-3-2-79	107.86	22	0.0018	452.4	DN500 CHDPE SN8	8.63	0.54	160.3	15.67
K.3.2.78.1	K-3-2-78-1	109.49	K-3-2-78-2	109.21	10	0.028	284.8	DN315 CHDPE SN8	0.33	0.55	183.12	3.15
K.3.2.78.2	K-3-2-78-2	109.21	K-3-2-78-3	109.06	5	0.03	284.8	DN315 CHDPE SN8	0.33	0.56	189.55	3.14
K.3.2.78.3	K-3-2-78-3	109.06	K-3-2-78-4	108.49	20	0.0285	284.8	DN315 CHDPE SN8	0.33	0.48	184.75	3.46
K.3.2.78.4	K-3-2-78-4	108.49	K-3-2-78	107.9	43	0.0137	284.8	DN315 CHDPE SN8	0.33	0.06	128.2	14.42
K.3.2.79	K-3-2-79	107.86	K-3-2-80	107.81	25	0.002	452.4	DN500 CHDPE SN8	8.63	0.56	168.12	15.13
K.3.2.8	K-3-2-8	125.4	K-3-2-9	124.58	50	0.0164	284.8	DN315 CHDPE SN8	0.94	0.53	140.15	6.48
K.3.2.80	K-3-2-80	107.81	K-3-2-81	107.73	26	0.0031	452.4	DN500 CHDPE SN8	8.64	0.73	208.68	12.67
K.3.2.81	K-3-2-81	107.73	K-3-2-82	107.312	42	0.01	452.4	DN500 CHDPE SN8	8.93	0.67	375.24	13.82
K.3.2.81.1	K-3-2-81-1	109.88	K-3-2-81	107.73	38	0.0566	284.8	DN315 CHDPE SN8	0.29	0.09	260.31	9.7
K.3.2.82	K-3-2-82	107.312	K-3-2-83	107.277	16	0.0022	452.4	DN500 CHDPE SN8	8.93	0.77	174.96	12.53
K.3.2.83	K-3-2-83	107.277	K-3-2-84	106.93	10	0.0347	452.4	DN500 CHDPE SN8	9.27	0.82	700.18	12.32
K.3.2.84	K-3-2-84	106.93	K-3-2-85	106.89	22	0.0018	452.4	DN500 CHDPE SN8	9.51	0.55	160.3	16.36
K.3.2.84.1	K-3-2-84-1	107.1	K-3-2-84	106.93	50	0.0034	284.8	DN315 CHDPE SN8	0.24	0.04	63.81	15.38
K.3.2.85	K-3-2-85	106.89	K-3-2-86	106.85	20	0.002	452.4	DN500 CHDPE SN8	9.51	0.57	168.12	16.14
K.3.2.86	K-3-2-86	106.85	K-3-2-87	106.8	25	0.002	452.4	DN500 CHDPE SN8	9.51	0.57	168.2	16.14
K.3.2.87	K-3-2-87	106.8	K-3-2-88	106.75	25	0.002	452.4	DN500 CHDPE SN8	9.52	0.55	168.12	16.48
K.3.2.88	K-3-2-88	106.75	K-3-2-89	106.73	11.9	0.0017	452.4	DN500 CHDPE SN8	9.52	0.55	154.26	16.54
K.3.2.89	K-3-2-89	106.73	K-3-2-90	106.67	30	0.002	452.4	DN500 CHDPE SN8	9.52	0.58	168.12	15.96
K.3.2.9	K-3-2-9	124.58	K-3-2-10	124.23	22	0.0159	284.8	DN315 CHDPE SN8	1.41	0.5	138.03	9
K.3.2.90	K-3-2-90	106.67	K-3-2-91	106.62	22	0.0023	452.4	DN500 CHDPE SN8	9.53	0.56	179.22	16.29
K.3.2.91	K-3-2-91	106.62	K-3-2-92	106.53	48	0.0019	452.4	DN500 CHDPE SN8	9.91	0.57	162.78	16.49
K.3.2.92	K-3-2-92	106.53	K-3-2-93	106.47	27	0.0022	452.4	DN500 CHDPE SN8	9.92	0.58	177.22	16.25
K.3.2.93	K-3-2-93	106.47	K-3-2-94	106.41	28.4	0.0021	452.4	DN500 CHDPE SN8	10.16	0.58	172.73	16.56
K.3.2.94	K-3-2-94	106.41	K-3-2-95	106.35	30	0.002	452.4	DN500 CHDPE SN8	10.16	0.58	168.12	16.67

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
K.3.2.95	K-3-2-95	106.35	K-3-2-96	106.29	30	0.002	452.4	DN500 CHDPE SN8	10.17	0.58	168.12	16.67
K.3.2.96	K-3-2-96	106.29	K-3-2-97	106.24	25	0.002	452.4	DN500 CHDPE SN8	10.17	0.52	168.12	18.03
K.3.2.97	K-3	106.4	K-3-2-97	106.24	30.1	0.0053	452.4	DN500 CHDPE SN8	14.68	0.77	274.23	17.54
K.3.3.1	K-3-3-1	142	K-3-3-2	140.59	30	0.047	284.8	DN315 CHDPE SN8	0.29	0.69	237.25	2.47
K.3.3.10	K-3-3-10	127.72	K-3-3-11	125.72	25	0.08	284.8	DN315 CHDPE SN8	0.38	0.8	309.53	2.71
K.3.3.11	K-3-3-11	125.72	K-3-3-12	125.02	10	0.07	284.8	DN315 CHDPE SN8	0.38	0.81	289.54	2.67
K.3.3.12	K-3-3-12	125.02	K-3-3-13	123.85	13	0.09	284.8	DN315 CHDPE SN8	0.38	0.86	328.31	2.58
K.3.3.13	K-3-3-13	123.85	K-3-3-14	121.6	25	0.09	284.8	DN315 CHDPE SN8	0.38	0.86	328.31	2.58
K.3.3.14	K-3-3-14	121.6	K-3-3-15	119.35	25	0.09	284.8	DN315 CHDPE SN8	0.38	0.86	328.31	2.58
K.3.3.15	K-3-3-15	118.29	K-3-3-16	116.79	15	0.1	284.8	DN315 CHDPE SN8	0.38	0.89	346.06	2.52
K.3.3.16	K-3-3-16	116.79	K-3-3-17	115.29	15	0.1	284.8	DN315 CHDPE SN8	0.38	0.89	346.06	2.52
K.3.3.17	K-3-3-17	114.61	K-3-3-18	112.99	30	0.054	284.8	DN315 CHDPE SN8	0.52	0.35	254.3	5.88
K.3.3.18	K-3-3-18	112.99	K-3-3-19	112.67	45	0.0071	284.8	DN315 CHDPE SN8	1.34	0.43	92.28	9.48
K.3.3.19	K-3-3-19	112.67	K-3-3-20	112.61	18	0.0033	284.8	DN315 CHDPE SN8	1.34	0.46	63.18	9.15
K.3.3.19.1	K-3-3-19-1	123.95	K-3-3-19-2	123.24	20	0.0355	284.8	DN315 CHDPE SN8	0.24	0.61	206.19	2.37
K.3.3.19.10	K-3-3-19-10	113.03	K-3-3-18	112.99	11	0.0036	284.8	DN315 CHDPE SN8	0.33	0.18	66.07	6.75
K.3.3.19.2	K-3-3-19-2	123.24	K-3-3-19-3	119.74	35	0.0999	284.8	DN315 CHDPE SN8	0.24	0.78	345.83	2.03
K.3.3.19.3	K-3-3-19-3	118.42	K-3-3-19-4	116.42	20	0.1	284.8	DN315 CHDPE SN8	0.24	0.74	346.06	2.08
K.3.3.19.4	K-3-3-19-4	116.42	K-3-3-19-5	114.42	25	0.08	284.8	DN315 CHDPE SN8	0.24	0.63	309.53	2.32
K.3.3.19.5	K-3-3-19-5	114.42	K-3-3-19-6	113.42	25	0.04	284.8	DN315 CHDPE SN8	0.24	0.4	218.74	3.16
K.3.3.19.5.1	K-3-3-19-5-1	114.97	K-3-3-19-7	113.3	35	0.0477	284.8	DN315 CHDPE SN8	0.1	0.14	239	3.47
K.3.3.19.6	K-3-3-19-6	113.42	K-3-3-19-7	113.3	18.3	0.0066	284.8	DN315 CHDPE SN8	0.24	0.22	88.63	4.6
K.3.3.19.7	K-3-3-19-7	113.3	K-3-3-19-8	113.19	35	0.0031	284.8	DN315 CHDPE SN8	0.33	0.26	61.35	5.18
K.3.3.19.8	K-3-3-19-8	113.19	K-3-3-19-9	113.1	22	0.0041	284.8	DN315 CHDPE SN8	0.33	0.27	69.99	5.1
K.3.3.19.9	K-3-3-19-9	113.1	K-3-3-19-10	113.03	21	0.0033	284.8	DN315 CHDPE SN8	0.33	0.26	63.18	5.17
K.3.3.2	K-3-3-2	140.59	K-3-3-3	138.67	20	0.096	284.8	DN315 CHDPE SN8	0.29	0.81	339.07	2.22

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
K.3.3.20	K-3-3-20	112.61	K-3-3-21	112.31	29.9	0.01	284.8	DN315 CHDPE SN8	1.34	0.58	109.55	7.81
K.3.3.21	K-3-3-21	112.31	K-3-3-22	111.93	40.1	0.0095	284.8	DN315 CHDPE SN8	1.34	0.53	106.58	8.34
K.3.3.22	K-3-3-22	111.93	K-3-3-23	111.56	50	0.0074	361.8	DN400 CHDPE SN8	1.73	0.47	178.2	7.73
K.3.3.23	K-3-3-23	111.56	K-3-3-24	111.41	35	0.0043	361.8	DN400 CHDPE SN8	1.73	0.55	135.62	6.99
K.3.3.24	K-3-3-24	111.41	K-3-3-25	110.691	35	0.0205	361.8	DN400 CHDPE SN8	1.73	0.51	296.93	7.35
K.3.3.24.1	K-3-3-24-1	111.008	K-3-3-24-2	110.841	50	0.0033	284.8	DN315 CHDPE SN8	0.38	0.27	63.25	5.54
K.3.3.24.2	K-3-3-24-2	110.841	K-3-3-25	110.691	45	0.0033	284.8	DN315 CHDPE SN8	0.38	0.14	63.18	8.65
K.3.3.25	K-3-3-25	110.691	K-3-3-26	110.602	27	0.0033	361.8	DN400 CHDPE SN8	2.12	0.44	118.94	9.26
K.3.3.26	K-3-3-26	110.602	K-3-3-27	110.52	25	0.0033	361.8	DN400 CHDPE SN8	2.12	0.41	118.64	9.72
K.3.3.27	K-3-3-27	110.52	K-3-3-28	110.46	26	0.0023	361.8	DN400 CHDPE SN8	2.12	0.4	99.51	9.99
K.3.3.28	K-3-3-28	110.46	K-3-3-29	110.33	50	0.0026	361.8	DN400 CHDPE SN8	2.12	0.4	105.64	9.94
K.3.3.29	K-3-3-29	110.33	K-3-3-30	110.21	50.1	0.0024	361.8	DN400 CHDPE SN8	2.12	0.4	101.4	9.95
K.3.3.3	K-3-3-3	137.97	K-3-3-4	135.97	20	0.1	284.8	DN315 CHDPE SN8	0.29	0.82	346.06	2.2
K.3.3.30	K-3-3-30	110.21	K-3-3-31	110.08	49.9	0.0026	361.8	DN400 CHDPE SN8	2.13	0.4	105.74	9.95
K.3.3.31	K-3-3-31	110.08	K-3-3-32	109.96	50	0.0024	361.8	DN400 CHDPE SN8	2.13	0.4	101.49	9.96
K.3.3.32	K-3-3-32	109.96	K-3-3-33	109.83	50	0.0026	361.8	DN400 CHDPE SN8	2.13	0.4	105.63	9.95
K.3.3.33	K-3-3-33	109.83	K-3-3-34	109.71	50.1	0.0024	361.8	DN400 CHDPE SN8	2.13	0.4	101.37	10
K.3.3.34	K-3-3-34	109.71	K-3-3-35	109.58	50	0.0026	361.8	DN400 CHDPE SN8	2.14	0.41	105.63	9.77
K.3.3.35	K-3-3-35	109.58	K-3-3-36	109.46	42.2	0.0028	361.8	DN400 CHDPE SN8	2.14	0.39	110.52	10.22
K.3.3.36	K-3-3-36	109.46	K-3-3-37	109.33	57.8	0.0022	361.8	DN400 CHDPE SN8	2.14	0.47	98.23	8.98
K.3.3.37	K-3-3-37	109.33	K-3-3-38	108.84	35	0.014	361.8	DN400 CHDPE SN8	2.14	0.86	245.11	5.96
K.3.3.38	K-3-3-38	108.84	K-3-3-39	107.85	18	0.055	361.8	DN400 CHDPE SN8	2.14	0.98	485.83	5.44
K.3.3.39	K-3-3-39	107.85	K-3-3-40	107.43	21.2	0.0198	361.8	DN400 CHDPE SN8	2.14	0.65	291.41	7.19
K.3.3.4	K-3-3-4	135.97	K-3-3-5	135.01	9.6	0.0999	284.8	DN315 CHDPE SN8	0.29	0.74	345.85	2.36
K.3.3.40	K-3-3-40	107.43	K-3-3-41	107.27	27	0.0059	361.8	DN400 CHDPE SN8	2.14	0.57	159.47	7.88
K.3.3.41	K-3-3-41	107.27	K-3-3-42	107.07	15	0.0133	361.8	DN400 CHDPE SN8	2.14	0.85	239.2	6.03

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
K.3.3.42	K-3-3-42	107.07	K-3	106.4	10.1	0.0665	361.8	DN400 CHDPE SN8	2.15	0.3	534.16	12.11
K.3.3.5	K-3-3-5	135.01	K-3-3-6	133.81	12	0.1	284.8	DN315 CHDPE SN8	0.38	0.85	346.06	2.59
K.3.3.5.1	K-3-3-5-1	136.52	K-3-3-5	135.4	16	0.07	284.8	DN315 CHDPE SN8	0.1	0.51	289.54	1.41
K.3.3.6	K-3-3-6	133.81	K-3-3-7	131.27	32.8	0.0774	284.8	DN315 CHDPE SN8	0.38	0.81	304.55	2.67
K.3.3.7	K-3-3-7	131.27	K-3-3-8	129.83	18	0.08	284.8	DN315 CHDPE SN8	0.38	0.85	309.53	2.6
K.3.3.8	K-3-3-8	129.83	K-3-3-9	128.72	11.1	0.1004	284.8	DN315 CHDPE SN8	0.38	0.89	346.78	2.51
K.3.3.9	K-3-3-9	128.72	K-3-3-10	127.72	10	0.1	284.8	DN315 CHDPE SN8	0.38	0.86	346.06	2.58
KR.1.1	KR-1-1	91.2	KR-1-2	91	46.9	0.0043	284.8	DN315 CHDPE SN8	0.1	0.24	71.46	2.42
KR.1.1.16	K-1-1-16	121.3	K-1-1-17	121.238	25	0.0025	361.8	DN400 CHDPE SN8	25.75	0.84	103.16	33.99
KR.1.1.17	K-1-1-17	121.238	K-1-1-18	121.175	25	0.0025	361.8	DN400 CHDPE SN8	25.76	0.84	103.99	33.95
KR.1.1.18	K-1-1-18	121.175	K-1-1-19	121.075	40	0.0025	361.8	DN400 CHDPE SN8	25.77	0.84	103.58	33.99
KR.1.1.19	K-1-1-19	121.075	K-1-1-20	120.975	40	0.0025	361.8	DN400 CHDPE SN8	25.78	0.82	103.55	34.42
KR.1.10	KR-1-10	88.633	KR-1-11	88.452	55	0.0033	284.8	DN315 CHDPE SN8	1.92	0.42	62.78	12.52
KR.1.11	KR-1-11	88.452	KR-1-12	88.317	40.8	0.0033	284.8	DN315 CHDPE SN8	1.92	0.55	62.93	10.29
KR.1.12	KR-1-12	88.317	KR-1-13	87	50	0.0263	284.8	DN315 CHDPE SN8	1.92	0.98	177.61	6.98
KR.1.13	KR-1-13	87	KR-1-14	86.1	20	0.045	284.8	DN315 CHDPE SN8	1.92	0.62	232.15	9.52
KR.1.1387	K-1-1-11-9'	123.683	K-1-1-11-10	123.587	38	0.0025	361.8	DN315 CHDPE SN8	20.86	0.78	104.1	30.57
KR.1.14	KR-1-14	86.1	KR-1-15	86.026	22.3	0.0033	361.8	DN315 CHDPE SN8	1.92	0.57	119.41	7.31
KR.1.15	KR-1-15	86.026	KR-3-32	82.638	54.5	0.0621	284.8	DN315 CHDPE SN8	1.92	0.5	272.78	11.09
KR.1.16.1	KR-3-16-1	90.232	KR-3-16-2	90.102	40	0.0032	284.8	DN315 CHDPE SN8	0.19	0.22	62.39	4.04
KR.1.16.10	KR-3-16-10	88.615	KR-3-23-4	88.366	76.4	0.0033	284.8	DN315 CHDPE SN8	0.51	0.32	62.47	6.12
KR.1.16.2	KR-3-16-2	90.102	KR-3-16-3	89.939	50	0.0033	284.8	DN315 CHDPE SN8	0.19	0.22	62.48	4.04
KR.1.16.3	KR-3-16-3	89.939	KR-3-16-4	89.828	34	0.0033	284.8	DN315 CHDPE SN8	0.19	0.18	62.53	4.67
KR.1.16.4	KR-3-16-4	89.828	KR-3-16-5	89.783	14	0.0032	284.8	DN315 CHDPE SN8	0.29	0.31	62.04	4.16
KR.1.16.5	KR-3-16-5	89.783	KR-3-16-6	89.402	15	0.0254	284.8	DN315 CHDPE SN8	0.29	0.43	174.41	3.38
KR.1.16.6	KR-3-16-6	89.402	KR-3-16-7	89.036	35	0.0105	284.8	DN315 CHDPE SN8	0.29	0.35	111.91	3.87

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
KR.1.16.7	KR-3-16-7	89.036	KR-3-16-8	88.805	30	0.0077	284.8	DN315 CHDPE SN8	0.29	0.29	96.03	4.41
KR.1.16.8	KR-3-16-8	88.805	KR-3-16-9	88.703	30	0.0034	284.8	DN315 CHDPE SN8	0.29	0.25	63.81	4.85
KR.1.16.9	KR-3-16-9	88.703	KR-3-16-10	88.615	27.1	0.0033	284.8	DN315 CHDPE SN8	0.29	0.2	62.41	5.76
KR.1.18"	KR-3-18	87.893	KR-3-19	85.95	57.1	0.0341	284.8	DN315 CHDPE SN8	0.35	0.51	201.96	3.49
KR.1.19"	KR-3-19	85.95	KR-3-20	84.854	50	0.0219	284.8	DN315 CHDPE SN8	0.45	0.38	162.02	4.95
KR.1.2	KR-1-2	91	KR-1-3	90.223	36	0.0216	284.8	DN315 CHDPE SN8	0.1	0.14	160.77	3.38
KR.1.3	KR-1-3	90.223	KR-1-4	90.059	50	0.0033	284.8	DN315 CHDPE SN8	0.29	0.25	62.67	4.85
KR.1.3.1	KR-1-9-1	90.54	KR-1-3-2	90.442	30	0.0033	284.8	DN315 CHDPE SN8	0.1	0.18	62.55	2.92
KR.1.3.2	KR-1-3-2	90.442	KR-1-3-3	90.344	30	0.0033	284.8	DN315 CHDPE SN8	0.1	0.18	62.55	2.92
KR.1.3.3	KR-1-3-3	90.344	KR-1-3	90.223	37.2	0.0033	284.8	DN315 CHDPE SN8	0.1	0.12	62.44	3.89
KR.1.4	KR-1-4	90.059	KR-1-5	89.91	45	0.0033	284.8	DN315 CHDPE SN8	0.29	0.15	62.97	6.86
KR.1.5	KR-1-5	89.91	KR-1-6	89.811	30	0.0033	284.8	DN315 CHDPE SN8	1.02	0.33	62.87	9.44
KR.1.5.1	KR-1-5-1	91.598	KR-1-5-2	91.513	26	0.0033	284.8	DN315 CHDPE SN8	0.1	0.18	62.58	2.93
KR.1.5.10	KR-1-5-10	90.702	KR-1-5-11	90.676	7.9	0.0033	284.8	DN315 CHDPE SN8	0.26	0.24	62.66	4.61
KR.1.5.11	KR-1-5-11	90.676	KR-1-5-12	90.604	22	0.0033	284.8	DN315 CHDPE SN8	0.26	0.24	62.6	4.61
KR.1.5.12	KR-1-5-12	90.604	KR-1-5-13	90.57	10.4	0.0033	284.8	DN315 CHDPE SN8	0.26	0.19	62.66	5.5
KR.1.5.13	KR-1-5-13	90.57	KR-1-5-14	90.423	44.9	0.0033	284.8	DN315 CHDPE SN8	0.51	0.29	62.64	6.42
KR.1.5.14	KR-1-5-14	90.423	KR-1-5-15	90.402	6.6	0.0032	284.8	DN315 CHDPE SN8	0.51	0.29	61.81	6.43
KR.1.5.15	KR-1-5-15	90.402	KR-1-5-16	90.316	26.3	0.0033	284.8	DN315 CHDPE SN8	0.51	0.27	62.58	6.76
KR.1.5.16	KR-1-5-16	90.316	KR-1-5-17	90.153	50	0.0033	284.8	DN315 CHDPE SN8	0.64	0.31	62.48	7.22
KR.1.5.17	KR-1-5-17	90.153	KR-1-5	89.91	63.6	0.0038	284.8	DN315 CHDPE SN8	0.73	0.3	67.63	8.1
KR.1.5.2	KR-1-5-2	91.513	KR-1-5-3	91.483	9.3	0.0032	284.8	DN315 CHDPE SN8	0.1	0.18	62.02	2.93
KR.1.5.3	KR-1-5-3	91.483	KR-1-5-4	91.404	24.2	0.0033	284.8	DN315 CHDPE SN8	0.1	0.18	62.59	2.92
KR.1.5.4	KR-1-5-4	91.404	KR-1-5-5	91.312	28	0.0033	284.8	DN315 CHDPE SN8	0.1	0.18	62.69	2.92
KR.1.5.5	KR-1-5-5	91.312	KR-1-5-6	91.288	7.3	0.0033	284.8	DN315 CHDPE SN8	0.1	0.18	62.88	2.93
KR.1.5.6	KR-1-5-6	91.288	KR-1-5-7	91.161	39	0.0033	284.8	DN315 CHDPE SN8	0.1	0.18	62.45	2.93

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
KR.1.5.7	KR-1-5-7	91.161	KR-1-5-8	91.135	8	0.0033	284.8	DN315 CHDPE SN8	0.1	0.12	62.58	3.77
KR.1.5.8	KR-1-5-8	91.135	KR-1-5-9	90.78	108.8	0.0033	284.8	DN315 CHDPE SN8	0.25	0.24	62.5	4.6
KR.1.5.9	KR-1-5-9	90.78	KR-1-5-10	90.702	23.7	0.0033	284.8	DN315 CHDPE SN8	0.26	0.24	62.76	4.6
KR.1.6	KR-1-6	89.811	KR-1-7	89.68	40	0.0033	284.8	DN315 CHDPE SN8	1.31	0.39	62.63	10.13
KR.1.7	KR-1-7	89.68	KR-1-8	89.496	50	0.0037	284.8	DN315 CHDPE SN8	1.34	0.46	66.39	9.11
KR.1.8	KR-1-8	89.496	KR-1-9	88.797	55	0.0127	284.8	DN315 CHDPE SN8	1.6	0.52	123.37	9.48
KR.1.9	KR-1-9	88.797	KR-1-10	88.633	50	0.0033	284.8	DN315 CHDPE SN8	1.6	0.39	62.67	11.49
KR.2.1	KR-2-1	90.6	KR-2-2	90.47	40	0.0032	284.8	DN315 CHDPE SN8	0.22	0.29	62.39	3.7
KR.2.2	KR-2-2	90.47	O-4	89.4	43.6	0.0245	284.8	DN315 CHDPE SN8	0.22	0.46	171.39	2.71
KR.3.1	KR-3-1	91.213	KR-3-2	91.116	30	0.0032	284.8	DN315 CHDPE SN8	0.06	0.15	62.23	2.53
KR.3.10	KR-3-10	88.879	KR-3-11	88.781	30	0.0033	284.8	DN315 CHDPE SN8	0.22	0.23	62.55	4.34
KR.3.11	KR-3-11	88.781	KR-3-12'	88.72	18.8	0.0032	284.8	DN315 CHDPE SN8	0.22	0.2	62.31	4.74
KR.3.12	KR-3-12'	88.72	KR-3-13	88.586	41.4	0.0032	284.8	DN315 CHDPE SN8	0.32	0.26	62.26	5.13
KR.3.13	KR-3-13	88.586	KR-3-14	88.429	48	0.0033	284.8	DN315 CHDPE SN8	0.32	0.26	62.59	5.13
KR.3.14	KR-3-14	88.429	KR-3-15	88.332	30	0.0032	284.8	DN315 CHDPE SN8	0.32	0.26	62.23	5.14
KR.3.15	KR-3-15	88.332	KR-3-16	88.228	32	0.0032	284.8	DN315 CHDPE SN8	0.32	0.25	62.39	5.25
KR.3.16	KR-3-16	88.228	KR-3-17	88.049	55	0.0033	284.8	DN315 CHDPE SN8	0.35	0.25	62.43	5.64
KR.3.17	KR-3-17	88.049	KR-3-18	87.893	48	0.0033	284.8	DN315 CHDPE SN8	0.35	0.34	62.39	4.52
KR.3.2	KR-3-2	91.116	KR-3-3	91.018	30	0.0033	284.8	DN315 CHDPE SN8	0.06	0.2	62.55	2.07
KR.3.20	KR-3-20	84.854	KR-3-21	84.689	50	0.0033	284.8	DN315 CHDPE SN8	0.45	0.24	62.87	6.82
KR.3.20.1	KR-3-20-1	85.098	KR-3-20-2	84.962	41.2	0.0033	284.8	DN315 CHDPE SN8	0	0	62.86	0.01
KR.3.20.2	KR-3-20-2	84.962	KR-3-20	84.854	32.6	0.0033	284.8	DN315 CHDPE SN8	0	0	63.01	3.02
KR.3.21	KR-3-21	84.689	KR-3-22	84.623	20	0.0033	284.8	DN315 CHDPE SN8	0.74	0.33	62.87	7.59
KR.3.22	KR-3-22	84.623	KR-3-23	84.55	22	0.0033	284.8	DN315 CHDPE SN8	0.74	0.25	63.04	9.17
KR.3.23	KR-3-23	84.55	KR-3-24	84.53	6	0.0033	284.8	DN315 CHDPE SN8	1.54	0.42	63.18	10.75
KR.3.23.1	KR-3-23-1	88.037	KR-3-23-2	87.877	49	0.0033	284.8	DN315 CHDPE SN8	0.16	0.21	62.54	3.72

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
KR.3.23.2	KR-3-23-2	87.877	KR-3-23-3	87.715	50	0.0032	284.8	DN315 CHDPE SN8	0.16	0.21	62.29	3.72
KR.3.23.3	KR-3-23-3	87.715	KR-3-23-4	87.616	30.2	0.0033	284.8	DN315 CHDPE SN8	0.16	0.11	62.66	5.82
KR.3.23.4	KR-3-23-4	87.616	KR-3-23-5	87.44	54	0.0033	284.8	DN315 CHDPE SN8	0.8	0.33	62.48	8.14
KR.3.23.5	KR-3-23-5	87.44	KR-3-23-6	87.343	30	0.0032	284.8	DN315 CHDPE SN8	0.8	0.39	62.23	7.17
KR.3.23.6	KR-3-23-6	87.343	KR-3-23-7	87.02	30	0.0108	284.8	DN315 CHDPE SN8	0.8	0.51	113.55	6.05
KR.3.23.7	KR-3-23-7	87.02	KR-3-23-8	86.55	35	0.0134	284.8	DN315 CHDPE SN8	0.8	0.66	126.82	5.01
KR.3.23.8	KR-3-23-8	86.55	KR-3-23	84.55	30	0.0667	284.8	DN315 CHDPE SN8	0.8	0.38	282.56	7.32
KR.3.24	KR-3-24	84.53	KR-3-25	84.414	35	0.0033	284.8	DN315 CHDPE SN8	1.54	0.42	63	10.76
KR.3.25	KR-3-25	84.414	KR-3-26	84.298	35	0.0033	284.8	DN315 CHDPE SN8	1.54	0.41	63	10.77
KR.3.26	KR-3-26	84.298	KR-3-27	84.087	63.9	0.0033	284.8	DN315 CHDPE SN8	1.54	0.41	62.87	10.78
KR.3.27	KR-3-27	84.087	KR-3-28	83.808	84.3	0.0033	284.8	DN315 CHDPE SN8	1.54	0.42	62.97	10.78
KR.3.28	KR-3-28	83.808	KR-3-29	83.556	76.3	0.0033	284.8	DN315 CHDPE SN8	1.54	0.4	62.89	11.1
KR.3.29	KR-3-29	83.556	KR-3-30	83.24	95.5	0.0033	284.8	DN315 CHDPE SN8	1.74	0.43	62.95	11.42
KR.3.3	KR-3-3	91.018	KR-3-4	90.423	25	0.0238	284.8	DN315 CHDPE SN8	0.06	0.3	168.83	1.58
KR.3.30	KR-3-30	83.24	KR-3-31	82.968	82.3	0.0033	284.8	DN315 CHDPE SN8	1.74	0.43	62.91	11.43
KR.3.31	KR-3-31	82.968	KR-3-32	82.638	99.7	0.0033	284.8	DN315 CHDPE SN8	1.74	0.33	62.97	13.81
KR.3.4	KR-3-4	90.423	KR-3-5	89.928	30	0.0165	284.8	DN315 CHDPE SN8	0.06	0.26	140.57	1.72
KR.3.5	KR-3-5	89.928	KR-3-6	89.571	30	0.0119	284.8	DN315 CHDPE SN8	0.06	0.16	119.38	2.41
KR.3.6	KR-3-6	89.571	KR-3-7	89.188	25	0.0153	284.8	DN315 CHDPE SN8	0.22	0.29	135.45	3.68
KR.3.7	KR-3-7	89.188	KR-3-8	89.074	35	0.0033	284.8	DN315 CHDPE SN8	0.22	0.23	62.46	4.33
KR.3.8	KR-3-8	89.074	KR-3-9	88.976	30	0.0033	284.8	DN315 CHDPE SN8	0.22	0.23	62.55	4.34
KR.3.9	KR-3-9	88.976	KR-3-10	88.879	30	0.0032	284.8	DN315 CHDPE SN8	0.22	0.23	62.23	4.34
KR.4.1	KR-4-1	91	KR-4-2	90.911	30	0.003	284.8	DN315 CHDPE SN8	0.19	0.21	59.61	4.1
KR.4.10	KR-4-10	89.901	KR-4-11	89.77	40	0.0033	284.8	DN315 CHDPE SN8	1.05	0.37	62.63	9.01
KR.4.11	KR-4-11	89.77	KR-4-12	89.607	50	0.0033	284.8	DN315 CHDPE SN8	1.05	0.37	62.48	9.04
KR.4.12	KR-4-12	89.607	KR-4-13	89.559	15	0.0032	284.8	DN315 CHDPE SN8	1.05	0.37	61.91	9.05

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
KR.4.13	KR-4-13	89.559	KR-4-14	89.51	15	0.0033	284.8	DN315 CHDPE SN8	1.05	0.36	62.55	9.15
KR.4.14	KR-4-14	89.51	KR-4-15	89.396	35	0.0033	284.8	DN315 CHDPE SN8	1.05	0.39	62.46	8.63
KR.4.15	KR-4-15	89.396	O-3	89.2	33.2	0.0059	284.8	DN315 CHDPE SN8	1.09	0.46	84.06	7.97
KR.4.2	KR-4-2	90.911	KR-4-3	90.781	40	0.0032	284.8	DN315 CHDPE SN8	0.19	0.22	62.39	4.04
KR.4.3	KR-4-3	90.781	KR-4-4	90.65	40	0.0033	284.8	DN315 CHDPE SN8	0.19	0.15	62.63	5.13
KR.4.4	KR-4-4	90.65	KR-4-5	90.52	40	0.0032	284.8	DN315 CHDPE SN8	0.48	0.29	62.39	6.21
KR.4.5	KR-4-5	90.52	KR-4-6	90.389	40	0.0033	284.8	DN315 CHDPE SN8	0.48	0.25	62.63	6.9
KR.4.6	KR-4-6	90.389	KR-4-7	90.259	40	0.0033	284.8	DN315 CHDPE SN8	0.73	0.33	62.39	7.61
KR.4.7	KR-4-7	90.259	KR-4-8	90.162	30	0.0032	284.8	DN315 CHDPE SN8	0.73	0.33	62.23	7.61
KR.4.8	KR-4-8	90.162	KR-4-9	90.031	40	0.0033	284.8	DN315 CHDPE SN8	0.73	0.33	62.63	7.6
KR.4.9	KR-4-9	90.031	KR-4-10	89.901	40	0.0032	284.8	DN315 CHDPE SN8	0.73	0.29	62.39	8.31
Tub shkarkimi provizor	KR-3-32	82.638	Shkarkim provizor ne kanal	82	182.8	0.0035	284.8	DN315 CHDPE SN8	3.67	0.55	64.65	16.11
U.1.1	U-1-1	126.278	U-1-2	126.17	43	0.0025	361.8	DN400 CHDPE SN8	6	0.54	103.82	16.41
U.1.10	U-1-10	124.862	U-1-11	124.788	30	0.0025	361.8	DN400 CHDPE SN8	13.03	0.68	102.88	24.12
U.1.11	U-1-11	124.788	U-1-12	124.674	46	0.0025	361.8	DN400 CHDPE SN8	13.25	0.69	103.15	24.23
U.1.12	U-1-12	124.674	U-1-13	124.588	35	0.0025	361.8	DN400 CHDPE SN8	13.26	0.68	102.69	24.35
U.1.13	U-1-13	124.588	U-1-14	124.44	60	0.0025	361.8	DN400 CHDPE SN8	13.47	0.68	102.89	24.71
U.1.14	U-1-14	124.44	U-1-15	124.318	49.3	0.0025	361.8	DN400 CHDPE SN8	14.11	0.7	103.1	24.98
U.1.15	U-1-15	124.318	U-1-16	124.231	35	0.0025	361.8	DN400 CHDPE SN8	14.12	0.7	103.29	25.1
U.1.16	U-1-16	124.231	U-1-17	124.145	35	0.0025	361.8	DN400 CHDPE SN8	14.34	0.7	102.69	25.32
U.1.17	U-1-17	124.145	U-1-18	124.029	47	0.0025	361.8	DN400 CHDPE SN8	14.55	0.69	102.92	25.75
U.1.18	U-1-18	124.029	U-1-19	123.905	50	0.0025	361.8	DN315 CHDPE SN8	15.4	0.72	103.16	26.15
U.1.19	U-1-19	123.905	U-1-20	123.819	35	0.0025	361.8	DN315 CHDPE SN8	15.41	0.72	102.69	26.15
U.1.2	U-1-2	126.17	U-1-3	126.087	33	0.0025	361.8	DN400 CHDPE SN8	6.16	0.55	103.89	16.54
U.1.20	U-1-20	123.819	K-1-1-11-9	123.719	40.3	0.0025	361.8	DN315 CHDPE SN8	15.41	0.69	103.22	27.04

Emërtimi	Puseta e Fillimit	Kuota në Fillim (m)	Puseta e Fundit	Kuota në Fund (m)	Gjatësia (m)	Pjerrësia (m/m)	Diametri I Brend. (mm)	Lloji I Tubacionit	Prurja (l/s)	Shpejtësia (m/s)	Kapac. Max. (L/s)	Mbushje (%)
U.1.3	U-1-3	126.087	U-1-4	126.005	33	0.0025	361.8	DN400 CHDPE SN8	6.16	0.52	103.26	17.35
U.1.4	U-1-4	126.005	U-1-5	125.874	52	0.0025	361.8	DN400 CHDPE SN8	6.49	0.68	103.98	14.84
U.1.5	U-1-5	125.874	U-1-6	125.234	47	0.0136	361.8	DN400 CHDPE SN8	6.85	0.68	241.74	15.49
U.1.6	U-1-6	125.234	U-1-7	125.154	32	0.0025	361.8	DN400 CHDPE SN8	8.54	0.61	103.65	19.45
U.1.7	U-1-7	125.154	U-1-8	125.08	30	0.0025	361.8	DN400 CHDPE SN8	8.54	0.6	102.89	19.56
U.1.8	U-1-8	125.08	U-1-9	124.936	58	0.0025	361.8	DN400 CHDPE SN8	8.71	0.52	103.22	21.83
U.1.9	U-1-9	124.936	U-1-10	124.862	30	0.0025	361.8	DN400 CHDPE SN8	13.03	0.69	102.89	24.03
U.2.1	U-2-1	132.484	U-2-2	132.359	50	0.0025	361.8	DN400 CHDPE SN8	39.55	1.07	103.58	38.89
U.2.11	U-2-11	131.153	U-2-12	131.073	40	0.002	452.4	DN500 CHDPE SN8	41.6	0.87	168.12	33.89
U.2.2	U-2-2	132.359	U-2-3	132.028	50	0.0066	361.8	DN400 CHDPE SN8	39.56	1.17	168.55	36.47
U.2.3	U-2-3	132.028	U-2-4	131.908	35	0.0034	361.8	DN400 CHDPE SN8	39.56	1.09	121.3	38.41
U.2.4	U-2-4	131.908	U-2-5	131.77	31.7	0.0044	361.8	DN400 CHDPE SN8	39.57	1.06	136.67	39.06
U.2.5	U-2-5	131.77	U-2-6	131.73	20	0.002	452.4	DN315 CHDPE SN8	39.57	0.85	168.12	33.01
U.2.6	U-2-6	131.73	U-2-7	131.69	20	0.002	452.4	DN315 CHDPE SN8	39.57	0.85	168.12	33.02
U.2.7	U-2-7	131.69	U-2-8	131.62	35	0.002	452.4	DN315 CHDPE SN8	39.58	0.85	168.12	33.02
U.2.8	U-2-8	131.62	U-2-9	131.56	30	0.002	452.4	DN315 CHDPE SN8	39.58	0.85	168.12	33.23
U.2.9	U-2-9	131.56	U-2-10	131.49	35	0.002	452.4	DN315 CHDPE SN8	39.59	0.91	168.12	31.66

