



GRAFIKU I PUNIMEVE

OBJEKTI:

"RIKONSTRUKSION I KOPSHITIT TE FEMIJEVE, FUSHE ARREZ"

- MARS 2022 -



| | | | | | | | | | | | | | | | | | | |
|--------------|---------|---|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|
| 4 | Analize | F.V Tub PEX/Al/PEX, DN 12 (Ø32 X 3.0) mm, i termoizoluar $\delta = 6\text{mm}$ | | | | | | | | | | | | | | | | |
| 5 | Analize | F.V Tub PEX/Al/PEX, DN 12 (Ø40 X 4.0) mm, i termoizoluar $\delta = 6\text{mm}$ | | | | | | | | | | | | | | | | |
| 6 | Analize | Rakorderi mberthimi (Ti, brya.etj) | | | | | | | | | | | | | | | | |
| 7 | Analiza | Kapset tubosh ne dyshteme dhe ne murre | | | | | | | | | | | | | | | | |
| 8 | Analiza | Rakorderi mberthimi (Ti, brya.etj) | | | | | | | | | | | | | | | | |
| 9 | Analize | F.Valvol nderperrese radiator me sferë $\frac{1}{2}"$ | | | | | | | | | | | | | | | | |
| 10 | Analize | F. Valvola termostatike $\frac{1}{2}"$ te drejta | | | | | | | | | | | | | | | | |
| 11 | Analize | F. Detonator $\frac{1}{2}"$ | | | | | | | | | | | | | | | | |
| 12 | Analize | F. Valvola ajemxyerrrese $\frac{1}{2}"$ | | | | | | | | | | | | | | | | |
| 13 | Analize | F. Elemente fiksues ne mur | | | | | | | | | | | | | | | | |
| D-4-2 | | Pajisjet - Sistemi i Ngrohjes | | | | | | | | | | | | | | | | |
| D-4-2.3 | Analize | F.V Kolektor shperndares per radiatoret 1" (5+5)x1/2" I kompletuar me minivalvula dergim kthim, valvula nderperrese, ne hyrje-dalje, valvul balancuese, valvul zonale dy kalimshe, ajernxyerrrese, valvula shkarkim, dhe element te F.V Kolektor shperndares per radiatoret 1" (6+6)x1/2" I kompletuar me minivalvula dergim kthim, valvula nderperrese, ne hyrje-dalje, valvul balancuese, valvul zonale dy kalimshe, ajernxyerrrese, valvula shkarkim, dhe element te F.V Kolektor shperndares per radiatoret 1" (7+7)x1/2" I kompletuar me minivalvula dergim kthim, valvula nderperrese, ne hyrje-dalje, valvul balancuese, valvul zonale dy kalimshe, ajernxyerrrese, valvula shkarkim, dhe element te F.V Kasete kolektori | | | | | | | | | | | | | | | | |
| D-4-2.4 | Analize | F.V Element radiatori alumini per klaset , Presioni max. 600 kPa, interaksi 600 mm, $\Delta T_{ek} = 50^{\circ}\text{C}$, | | | | | | | | | | | | | | | | |
| D-4-2.7 | Analize | F.V Kasete kolektori | | | | | | | | | | | | | | | | |
| D-4-3 | | Instalimet e ambientit teknik | | | | | | | | | | | | | | | | |
| D-4-3.1 | 2.493 | Fv.Tubo çeliku pategel (Mannesmann) Ø 2" | | | | | | | | | | | | | | | | |
| D-4-3.2 | 2.493 | Fv.Tubo çeliku pategel (Mannesmann) Ø 1½" | | | | | | | | | | | | | | | | |
| D-4-3.5 | 2.535/g | Fv.Armafleks per tubo çeliku pategel Ø2"x13mm | | | | | | | | | | | | | | | | |
| D-4-3.6 | 3.493/d | Fv.Armafleks per tubo çeliku pategel | | | | | | | | | | | | | | | | |
| D-4-4 | | Makineri - Ambientin teknik | | | | | | | | | | | | | | | | |
| D-4-4.1 | Analize | Furnizim dhe instalim kaldfaje per ngrrohje me uje me lende diegese pellet komplet me instrumentat mates dhe te kontrollit te parametrave te ujit te ngrrohte, Q-nominale 150 000 kilokalori/ore , perfshire montimin e te gjithë tubacioneve dhe te dalisveve dhe aksesoreve deri ne dalje nga dhoma | | | | | | | | | | | | | | | | |

PREVENTIVO:

"TRIANGLE" sh.p.k

Drejtues Teknik & Ligjor

Ing. Zenulla MEHMETTI

