


NYJET E RRJETIT THANASAJ

SH: 1:20

Nyja 1	Rakorderite
	1 - PE EFW Tee OD 140 1cope 2 - PE EFW Fasheta OD 140 1cope 2' - PE EFW Fasheta OD 125 1cope 3 - PE EFW Filanxhe adaptor OD 125 2cope 4 - Saracineske me shpindel DN 110 perfsh. shpindel,kapak. 1cope 5 - PE EFW Reduktor OD140/50 1cope 6 - PE EFW Reduktor OD140/125 1cope
Nyja 2	Rakorderite
	1 - PE EFW Red. Tee OD 125/OD110m 1cope 2 - PE EFW Fashete OD 125 1cope 3 - PE EFW Red. OD 110/75 1cope 4 - PE EFW Filanxhe adaptor OD 75 2cope 5 - DI Resilient Seated Gate Valves DN 65 perfsh.spindel,kapak. 1cope
Nyja 3	Rakorderite
	1 - PE EFW T OD 110/50 1cope 2 - PE EFW Fashete OD 110 1cope
Nyja 4	Rakorderite
	1 - PE EFW T red. OD 110/50 1cope 2 - PE EFW Fashete OD 50 1cope

Nyja 5	Rakorderite
	1 - PE EFW T red. OD 110/50 1cope 2 - PE EFW Fashete OD 50 1cope 3 - PE EFW Red OD 110/90 1cope
Nyja 6	Rakorderite
	1 - PE EFW T red. OD 90/75 1cope 2 - PE EFW Fashete OD 75 1cope 3 - PE EFW Filanxhe adaptor OD75 2cope 4 - DI Resilient Seated Gate Valves DN 65 perfsh.spindel,kapak. 1cope

Rip.		Qelimi / dorëtimi		Kontrolluar nga		Aprovuar nga		Shënim/Perzhkrim	
Përgatiti:		Pozicioni	Emri	Nr. Licensës		Firma			
		Ing. Ndërtimi	Minush NURÇIA						
		Ing. Hidroteknik	Fahri MAHO						
		Ing. Hidroteknik	Silvia GJONAJ						
		Ing. Mekanik	Vladimir JOVANI						
		Ing. Gjeodet	Julian GJOKA						
		Ing. Elektrik	Besmir DERVISHI						
		Arkitekt	Besmir SERRANI						
Miratohet:		Drejues Projekti	Fahri MAHO						
Botimi		Shkalla		Permasa e fletes					
1		1:25		A1(841x594mm)					
NUMRI I VIZATIMIT		FU-LU-DU-DET_NY.TH-01							
TITULLI I VIZATIMIT		NYJET E RRJETIT THANASAJ							
TITULLI I PROJEKTIT		RRJETI I UJESJELLESIT TE FSHATRAVE ZHAM, KONJAT, KONJAT, THANASAJ, DUSHK, NJESIA ADMINISTRATIVE DUSHK, BASHKIA LUSHNJE							
NENTITULL:		DETAJET E PROJEKTIT							
		<p style="text-align: center;">UJESJELLES KANALIZIME LUSHNJE</p> 							
KONSULENTI INXHINIERIK:		<p style="text-align: center;">"EBS" shpk</p> 